

**Detroit  
Edison**

Wayne H. Jens  
Vice President  
Nuclear Operations

2000 Second Avenue  
Detroit, Michigan 48226  
(313) 586-4150

March 5, 1984  
EF2 - 67,231

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Youngblood:


- Reference: (1) Fermi-2  
NRC Docket No. 50-341
- (2) Letter, Detroit Edison to NRC,  
Containment Leakage Testing, Type A",  
EF2-64579, August 18, 1983
- (3) Letter, NRC to Detroit Edison, "Use of  
BN-TOP-1 for the Fermi 2 Facility  
Containment Leakage Testing per Appendix  
J", December 13, 1983

Subject: Use of BN-TOP-1 for the Fermi-2 Facility  
Containment Leakage Testing per Appendix J

In accordance with your letter of December 12, 1983  
(Reference 3) responding to our Reference (2) letter,  
Detroit Edison will adopt all applicable provisions of  
BN-TOP-1, "Testing Criteria for Integrated Leakage  
Rate Testing of Primary Containment Structures for  
Nuclear Plants", Rev. 1, associated with performing an  
eight hour Type A test. As requested, these provisions  
will be incorporated into the Fermi-2 Technical Specifi-  
cations.

Should you have any further questions, please contact  
Mr. O. Keener Earle, (313) 586-4211.

Sincerely,



cc: Mr. P. M. Byron  
Mr. M. D. Lynch

8403090247 840305  
PDR ADDCK 05000341  
A PDR

Bool  
1/0