

50-333

INTEGRATED LEAK RATE TEST COMPUTER PROGRAM
FOR THE PRIMARY CONTAINMENT, FRITZPATRICK

1/hr 5/20/74

#5134

THE ATTACHED FILES ARE OFFICIAL RECORDS
OF THE OFFICE OF REGULATION. THEY HAVE
BEEN CHARGED TO YOU FOR A LIMITED TIME
PERIOD AND MUST BE RETURNED TO THE
CENTRAL RECORDS STATION 008. ANY PAGE(S)
REMOVED FOR REPRODUCTION MUST BE RETURNED
TO ITS/THEIR ORIGINAL ORDER.

NOTICE

DEADLINE RETURN DATE

NOTICE

W. L. DONALDSON, CHIEF
CENTRAL RECORDS STATION

Received with Report 5-20-74

Section 7.6

CONTENTS

	<u>PAGE</u>
I. Purpose and Scope	217
II. Absolute Method	217
III. Reference Vessel Method	218
IV. Correlation of Results	219
V. Equipment	
a. Temperatures - RTD's	220
b. Pressures and Differential Pressures	222
c. Moisture Analyzer	222
VI. Computer Program	
a. Required Computations and Nomenclature	224
b. Organization and Execution - Flow Chart	227
Appendix A: Derivation of differential leak rate	234
B: Program variable definitions	235
C: Operator Guide	240
D: Sample Output	242
E: Error Analysis	251
F: G.E. Program Listing	258

I. PURPOSE AND SCOPE

The American Nuclear Society (ANS) Standard (Ref. 1) specifies uniform methods for determining the ability of a reactor containment structure to retain, within the limits of permissible leakage rates, any hazardous air and water vapor. The purpose of this document is to describe the absolute and reference volume methods to be implemented at PASNY - Fitzpatrick, and the on-line computer programs installed to condition the data, perform the calculations, and control the output.

Leakage rates are reported as the percentage by weight of the original content of air at the leakage rate test pressure that escapes to the outside atmosphere during a 24-hour test period. A 4-hour initial waiting period will be allowed before the commencement of the test to allow temperature and pressure to come to equilibrium.

A manually operated nitrogen bleed system provides a means for insuring a positive pressure at all times within the containment.

II. ABSOLUTE METHOD

The absolute method of leakage-rate testing consists of the determination and calculation of air losses by containment structure leakage over 24 hours by means of direct pressure, temperature, and moisture content observations during the period of test, with the temperature detectors properly located to provide an average air temperature. It is assumed that temperature variations during the test will be insignificant. The absolute test consists of subtracting the final mass in the containment from the initial mass, computing the masses by the ideal gas law.

The containment mass is computed as follows via the perfect gas law:

$$\frac{M}{RT} = \frac{(P-P_v)}{29.92} V = 14.696 (144) \frac{(P-P_v)V}{RT}$$

where the rightmost identity has the units:

M = lb gas

P (total pressure) - inches Hg

P_v (vapor pressure - inches Hg)

R = 53.35 ft lbf / lbm°F (for air)

T = containment temp °R

The leakage rate is then determined by plotting the mass as a function of time, using a least squares fit to determine the slope, dM/dt. The leak rate is expressed as fraction of contained mass lost per 24 hours or symbolically:

$$(1) \text{ Leak rate} = \frac{dM/dt}{M_0} * -24. * 100.$$

when t is elapsed time expressed in hours and M_0 is the containment mass at time zero. The sign convention is such that an outward leak is positive. The mass of air must be corrected for the nitrogen added by the manually operated bleed system which insures a positive containment pressure. The nitrogen meter is a flow totalizer; thus, the weight of nitrogen added may be computed and subtracted from the containment mass as calculated above. Note: Comments concerning N_2 bleed refer only to continuous monitoring of leak rate when plant is fully operational.

III. REFERENCE VESSEL METHOD

The reference vessel method consists of the calculation of air losses by observations of the pressure differentials between the containment structure and a gas-tight reference system located so as to represent the average temperature of the aggregate containment air. That is, the reference vessels are so placed and are of such a geometry that they will assume the temperatures of the contained atmosphere within a time lag compatible to the frequency of data taking.

The reference volume-measurement test differs from the absolute test primarily in that the mass at a given instant is computed by a differential leak rate rather than by use of the ideal gas law. That is,

$$(2) M = M_0 - \frac{L' t}{24}$$

where L' is the differential leak rate (fraction of contained mass lost/hr.)

Again, mass is plotted as a function of time, the slope is determined by a least squares fit and the 24 hour leak rate is determined by equation (1) above. In equation (2), the initial mass M_0 is computed by the ideal gas law.

Derived in Appendix A, the differential leak rate is:

$$L' = \frac{24}{t} \cdot \frac{1}{(P_o - P_{ro})} \left\{ \Delta P_i \frac{T_0}{T_i} - \Delta P_{ro} - (P_{ro} - P_{ri}) \frac{T_0}{T_i} \right\}$$

where the subscripts indicate:

R = reference

O = initial

and

P = pressure differential in H_2O

t = elapsed time, hrs

The reference volume method (Equation (2)) is used to achieve more accuracy in determining M. The containments are very large (order of 100,000 ft³) which casts doubt on temperature and pressure measurements. This doubt is considerably lessened by the inclusion of a reference volume or container within the main containment. Rather than use absolute pressure, the differential pressure between reference volume and containment is measured instead. The error in temperature measurement by the temperature detectors is of much less effect because the reference system temperature follows that of the containment.

IV. CORRELATION OF RESULTS

In the Fitzpatrick plant, two containments exist: torus (or suppression chamber) and dry well (or bulb). The masses for each containment are computed separately, added together, and the result correlated as a function of time by means of a least squares curve fit of form:

$$y = mx + b$$

The slope, $d(\text{mass})/d(\text{hours})$ is then used in equation (1) to determine the leak rate. Thus, the least squares fit is executed only for the total mass in both containments, i.e. the masses of air in the torus and dry well are summed and the result fitted against time. If desired, the computer program may be easily modified to fit each containment singly and separately. Two separate fits are required: one for each of two basic methods, absolute and reference volume.

The least square fits, as described above, use all available data up to and including, but not preceding, the prior 24 hours, where results are computed hourly. Thus, the number of points fitted will never exceed 25 (without operator intervention). As a result, the 24 hr leak rate should become more accurate as time progresses up to 24 hr.

A 95 percent "Student T" confidence level is associated with each hourly leak rate computation. The leak rate (in percent mass loss per 24 hr) may be described as 95 percent accurate to within the value of the printed confidence level.

The leak rate testing package is divided into two separately executable parts, the first being the computations themselves, as outlined above. This program is executed once each hour as determined by the real time clock of the GEPAC process control computer. The other part of the package consists of real time programs executed at intervals of 1 minute, 10 minutes, and 1 hour which scan the analog inputs and perform the signal conditioning necessary to store the necessary engineering reading into the computer memory. These readings must be used by the main leak rate program, and therefore should be as up-to-date as possible when the ILRT program is executed. In particular, analog readings from the

Beckman MAZ-870 moisture analyzer require a 5 minute cycle to assemble the necessary readings. An analyzer routine must therefore be executed 5.5 to 5.0 minutes prior to the execution of the ILRT program.

V. EQUIPMENT

a. Temperature Sensors:

A total of 18 RTD's are provided as follows:

16-1-RTD 113 and 16-1-RTD 114 are located in the torus and the remaining 16 in the dry bulb. All RTD'S are arranged in pairs to provide an average temperature for each arbitrarily assigned zone of containment volume. Zones 0-7 are located in the dry bulb and Zone 8 in the torus. Each RTD pair is averaged: the resulting averages are multiplied by a volume weighting factor assigned as the fraction of total volume represented by each zone. The two containments, dry well and torus, are handled separately in the program, that is, the mass of air in each of the containments is computed individually.

<u>16-1-RTD</u>	<u>Zone</u>	<u>Weight factor</u>
Suppression chamber (torus)		
113	8 (Torus)	1.0
114		
Dry well (Bulb)		
101	0 (Vent Header)	0.1133
120		
102	1 (Dry Well)	0.1652
119		
103	2 (Dry Well)	0.3560
104		
105	3 (Dry Well)	0.1313
106		
107	4 (Dry Well)	0.0470
108		
109	5 (Dry Well)	0.0534
117		
110	6 (Dry Well)	0.0715
111		
112	7 (Dry Well)	0.0621
118		

ILRT ANALOG INPUTS

<u>INSTRUMENT</u>	<u>LOCATION</u>	<u>COMPUTER POINTS</u>	<u>MEASURING UNITS</u>
16-1-PI-103	TORUS REF VESSEL	M098	PSIA
16-1-PI-101	DRYWELL REF VESSEL	M096	PSIA
16-1-RTD-113	TOR AREA 8	M095	DEGF
16-1-RTD-114	TOR AREA 8	M102	DEGF
16-1-RTD-101	DWLL AREA 0	M103	DEGF
16-1-RTD-120	DWLL AREA 0	M116	DEGF
16-1-RTD-102	DWLL AREA 1	M084	DEGF
16-1-RTD-119	DWLL AREA 1	M115	DEGE
16-1-RTD-103	DWLL AREA 2	M085	DEGF
16-1-RTD-104	DWLL AREA 2	M086	DEGF
16-1-RTD-105	DWLL AREA 3	M087	DEGF
16-1-RTD-106	DWLL AREA 3	M088	DEGF
16-1-RTD-107	DWLL AREA 4	M089	DEGF
16-1-RTD-108	DWLL AREA 4	M090	DEGF
16-1-RTD-109	DWLL AREA 5	M091	DEGF
16-1-RTD-117	DWLL AREA 5	M0113	DEGF
16-1-RTD-110	DWLL AREA 6	M092	DEGF
16-1-RTD-111	DWLL AREA 6	M093	DEGF
16-1-RTD-112	DWLL AREA 7	M094	DEGF
16-1-RTD-118	DWLL AREA 8	M114	DEGF
LRT MOIST AZ	PNL OP MODE	M111	PPM
LRT MOIST AZ	PNL STRM ID	M112	PPM
16-1-MAZ-101	TORUS ILRT HUMIDITY	M106	PPM
16-1-MAZ-102	DRYWELL ILRT HUMIDITY	M069	PPM
BAROMETRIC	PRESS	F125	IN HG
16-1-dPIT-102	REF VES TO TORUS	M101	PSID
16-1-dPIT-101	REF VES TO DRYWELL	M100	PSID
16-1-PI-104	TORUS PRESSURE	M099	PSIA
16-1-PI-102	DRYWELL PRESSURE	M097	PSIA

If the two zone temperature readings differ by more than \pm 2.0 degrees F, it is assumed that at least one RTD reading is faulty. Faulty readings are corrected by the operator by removing the point from scan and inserting an arbitrary value of zero. Refer to Appendix C, Operator Guide, for details. To allow the operator to accomplish this, the program is put into a wait state and the required action is printed on the programmer's typer. This action will consist of suppressing the standard action keys on the operator's console. In addition, the operator may wish to de-energize the RTD in error. After the operator has acted, the program is continued by inserting a 0 into a computer point called IFLAG. (See Section VI(a) - Program).

b. Pressure and Pressure Differential Sensors:

Total pressures (psia) in the containments and reference vessels are converted from analog readings as follows: (These conversions were originally coded into the ILRT program. On-site at PASNY, conversions will be handled by GEOPAC system subroutines)

$$P = \text{Reading} (70./100.)$$

i.e. 0 - 100. Mv corresponds to 0. - 70. psia

Differential pressures (psia) are converted as follows:

$$P = \text{Reading} (5.0/100.)$$

i.e. 0 - 100. Mv corresponds to 0. - 5.0 psia

Barometric pressure conversion:

$$\text{Barom (inches Hg)} = (\text{Reading} - 16.)/64. (30.0)$$

i.e. 16 - 80. Mv corresponds to 0. - 30. in. Hg

c. Moisture Analyzers (Beckman Model 870)

The Beckman moisture analyzers provide a reading of parts per million (volume) of water in the containment volumes. The analyzer is set up to measure 5 sample streams which represent 5 definite volumes within the total containment (torus and dry bulb). The instrument has an internal timer which switches streams at 1 minute intervals. Stream No. 1 represents the volume contained in the torus; whereas streams 2-5 represent certain portions of the volume of the dry bulb. Two analyzers are present: 16-MAZ-101 and 16-MAZ-102 are both capable of measuring streams Nos. 1-5 selected continuously. In

addition, analyzer 101 may be set up to measure only stream No. 1 with analyzer 102 measuring streams 2-5 selected continuously. Thus, three modes of operation are possible:

1. Both analyzers in operation: 16-MAZ-101 measuring stream No. 1, 16-MAZ-102 measuring streams 2-5 continuously (normal mode)
2. Only 16-MAZ-101 in operation, measuring all 5 streams selected continuously
3. Only 16-MAZ-102 in operation, measuring all 5 streams selected continuously

These modes are identified by an operator selected mode switch which produces a 20, 30, 40 ma signal for modes 1-3, respectively. To determine which stream is under analysis (in the case of continuously selected streams), a 14, 18, 22, 26, and 30 ma signal is provided. The respective signals are in the order of streams 1-5. All signals are in the 10-50 ma range which translate to 16-80 mv using a 1.6 ohm resistor. The partial pressures of the water vapor in the two containments (torus and dry bulb) are computed from the stream values of ppm by volume as measured and a volume weighting factor. The weighting factors are assigned to account for the fractional containment volume represented by each stream, as follows:

<u>Zone</u>	<u>Stream</u>	<u>Weight factor</u>
8 (Torus)	1	1.0
0 (Vent Header)	3	0.1133
1 (Dry Well)	5	0.5833
2 (Dry Well)	5	
7 (Dry Well)	5	
3 (Dry Well)	2	0.1783
4 (Dry Well)	2	-
5 (Dry Well)	4	0.1249
6 (Dry Well)	4	

Since the 24 hr leak rate test program is to be executed once per hour, a routine to secure the proper moisture values must be executed at least 5 minutes prior to the execution of the main program. That is, a minimum of 1 minute per stream is required to adequately handle the transient data. Maximum accuracy is achieved by executing the moisture content routine at 5 minute intervals and arranging the interval to begin 2.5 to 3.0 minutes prior to execution of the ILRT program.

The ILRT program is set up to accept the signals for modes, stream, and ppmv readings and convert these readings to the desired partial pressure of water vapor in the containment. An error of ± 4.0 ma is accepted for the mode readings, while an error of ± 1.0 ma is accepted for the stream identifications. If these errors are exceeded, the stream or mode with least total error is selected. However, an on-line warning is printed on the programmer's typer when this occurs.

The conversion of the moisture analyzer reading in mv to parts per million by volume is:

$$\text{ppmv} = (\text{Reading} - 16.) / 64. \quad (15,000.)$$

i.e., 16. - 80 mv corresponds to 0. - 15,000. ppmv

Parts per million by volume is converted to partial pressure (psia) by:

$$P(H_2O) = (\text{ppmv}/(1.E6 + \text{ppmv}) * (P \text{ total}))$$

VI. COMPUTER PROGRAM

a. Required computations (in sequential order)

1. Initial mass: Suppression chamber and dry well

$$M_{SO} = \frac{144.}{R T_{SO}} (P_{SO} - P_{SVO}) V_S$$

$$M_{DO} = \frac{144.}{R T_{DO}} (P_{DO} - P_{DVO}) V_D$$

(pressures in psia)

2. Differential leak rate: suppression chamber and dry well

$$L'_{sr} = \frac{24.}{t} \left(\frac{1}{(P_{SO} - P_{SVO})} \right) \left[\Delta P_{sr} \frac{T_{SO}}{T_s} - \Delta P_{sro} - (P_{SV} - P_{SV} \frac{T_{SO}}{T_s}) \right]$$

$$L'_{dr} = \frac{24.}{t} \left(\frac{1}{(P_{DO} - P_{DRO})} \right) \left[\Delta P_{dr} \frac{T_{DO}}{T_d} - \Delta P_{dro} - (P_{DVO} - P_{DV} \frac{T_{DO}}{T_d}) \right]$$

3. Mass as computed by reference volume method (current):

$$M_{sr} = M_{so} (1 - L'sr * t/24.)$$

$$M_{dr} = M_{do} (1 - L'dr * t/24.)$$

4. Mass (by absolute method) at current time:

$$M_{sa} = \frac{144. (P_s - P_{sv}) V_s}{RT_s}$$

$$M_{da} = \frac{144. (P_d - P_{dv}) V_d}{RT_d}$$

5. Totals:

$$M_{tr} = M_{sr} + M_{dr}$$

$$M_{ta} = M_{sa} + M_{da}$$

6. Least squares fit of M_{tr} vs t
and M_{ta} vs t :

let y = mass , m = slope
 x = time , b = intercept
 n = no. of data points

$$m = \left\{ \frac{dM_{tr}}{dt}, \quad \frac{dM_{ta}}{dt} \right\} = \frac{n \sum xy - \sum x \sum y}{n \sum x^2 - (\sum x)^2}$$

$$b = \frac{\sum y \sum x^2 - \sum x \sum x y}{n \sum x^2 - (\sum x)^2}$$

$$\text{Std. deviation} = \sigma_m = \sigma / (\sum x^2 - (\sum x)^2 / n)^{1/2}$$

$$\text{where } \sigma = (\text{Variance})^{1/2} = \left[\frac{\sum (y - \bar{y})^2}{n-2} \right]^{1/2}$$

The "Student T" 95 percent confidence level is a function of the standard deviation and the total number of samples i.e.

$$95 \text{ percent confidence} = \sigma_m \frac{(+2400)}{M_0} f(n)$$

(expressed as percent by weight leakage rate)

where $f(n)$ is fitted using data from statistical tables:

$$f(n) = 1.95996 + 2.37226/n + 2.8225/n^2$$

Note: 95 percent confidence level = 2.06

(Student T for 25 data points)

Note: Fits will begin at N=3; data will be a maximum of 24 points (1 day); the most recent 25 points will be considered i.e., when data for 24 hours is collected, the earliest point will be discarded.

7. Fraction of total containment mass lost/day: /

$$L_{tr} = \frac{dM_{tr}/dt}{M_{to}} *24.$$

$$L_{td} = \frac{dM_{td}/dt}{M_{to}} *24.$$

NOMENCLATURE

Subscripts:

S - suppression chamber (or torus)
D - dry well (or bulb)
0 - initial values
R - reference volume method
A - absolute method
T - total

Variables:

M - mass air in containment, lb
t - time, hr
p - total pressure in containment, psia
pv - vapor pressure in containment, psia
p - differential pressure between reference vessel
and containment psia
T - temperature, °R
L' - differential leak rate computed for reference
volume method (fraction of contained mass lost/hour)
V - containment volume, ft³
R - gas constant, air 53.35 ft lbf/lbm °R
L - 24 hour leak rate, computed from least squares fit of
M vs t, fraction of containment mass lost/day.

b. Organization and Flow Chart

A list of subroutines and a flow chart are attached. Appendix B contains definitions of program variables. Program control through the operator's console is accomplished by manipulation of the variable IFLAG.

The computer point designated IFLAG will at any given time contain an integer which determines the mode of ILRT program operation. This integer is set by the operator and allows him to control program execution as follows:

<u>Value of IFLAG</u>	<u>Result</u>
0	Normal Operation
1	Reinitialize program
3	Reinitialize, setting t=0
4	Minimum output (1 line)
5	Provide short printout (current hour)
6	Provide long printout (latest 24 hr)
8	RTD error
9	Abort program

When the program is started or reinitiated, the variable IEDIT is set to 1 and the PRINT subroutine subsequently outputs an abbreviated data set consisting of leak rate, confidence level, and the moisture readings for the 5 streams corresponding to the 5 containment volumes (4 in dry well + torus). Thus, normal output will always be of this abbreviated form.

To obtain output as depicted in Appendix C, that is, complete data and calculations, it is necessary for the operator to set IFLAG to 5 or 6. If IFLAG = 5, the variable IEDIT is set to 2 and only the data and calculations for the current hour are printed (short form). If IFLAG = 6, IEDIT is set to 3 and data plus calculations are printed for 24 hours (or all output available up to 24 hours).


Refer to Appendix B-VI for more detail.

The program sets the computer point IFLAG equal to 8 whenever an RTD reading is determined false. After operator action (as outlined above), resetting IFLAG to 0 will cause the program to resume.

Reinitialization consists of resetting the values for initial mass, pressure, vapor pressure, and temperature in the containments, and initial pressure difference between containment and reference volume. The computed leakages (See calculations - Appendix A) require these initial observations. In addition, since only the most recent 24-hour period of test is printed, the program arrays which contain the hourly readings must be compressed so as to reflect the more recent hourly observations.

Usually, the test is started at arbitrary hour 0. and all subsequent readings are tabulated in increments from time 0. hours. If the program is reinitialized using ITYPE = 1, however, the initial time is

set to the current time and all subsequent readings are tabulated in increments from this new initial time (not equal to 0.). The only difference between ITYPE = 1 above, and ITYPE = 3 is that the latter resets the initial time to 0. and resets the subsequent times of observation relative to 0.



START
COMPUTE

CALL MASS

[Compute mass by reference
vol. and by absolute method]

iFLAG .eq. 1
.or. 3 ?

yes

COMPUTATION -
ILRT Program

no

N ≥ 35?

yes

Set and store initial
values of variables at
t start. [If iFLAG=3,
tstart is reset to 0.]

no

N < 3?

yes

Compress data
Reset initial values
of variables
 $N = N - 1$

no

Containment p < 2.0 psia?
[If low pressure, skip fit]

no

CALL CURFIT
[Least squares fit of
total mass vs t]

Compute leakage rates
[Rate = $\frac{24}{M_0} \frac{dm}{dt}$]

END
COMPUTE

Simplified Flow
Diagram of Comput-
ation Logic for
ILRT program

SUBROUTINES:

1. Main program - All flow chart logic, including the compression of data when arrays are full, or during reinitialization.
2. MASS - Computes mass of air in torus and in the dry well and the total mass in both containments. This is done through the perfect gas law (absolute method) and through the differential leak rate computation (reference volume method).
3. CURFIT - Computes slope and intercept of total mass in containment vs time by means of a least squares curve fit of the form $y = mx + b$.
4. TSL - Computes saturation temperature in deg F given the saturation pressure on the water - water vapor saturation line. It is used to compute the dew points within the torus and dry bulb containments as functions of total pressure.
5. SETUP - Performs signal modifications to engineering units for all process variables. Also, accuracy checks are performed on all RTD readings.
6. ANALYZER - Performs signal modifications for process variables connected with moisture analyzer. Accuracy checks on analog mv readings are performed.
7. PRINT - Outputs data and results in EPA approved format.

GEPAC System - Subroutines and Reserved Variables

INHIBIT, PERMIT - GEPAC routines which inhibit and permit interrupts, respectively. These routines in the ILRT program are needed to avoid interrupting the GEPAC timer when delay times are being computed.

BEGQUE, ENDQUE - GEPAC routines which start and end the placement of output messages into a queue. These routines are used in the ILRT program to avoid computation delays.

PANFUN - panel function number (on console)

NPRIO - program priority number

IUNITD - console activity flag

 1 (console in use)
 0 (console not in use)

NOPTC (identical to IFLAG program variable)

This operator function takes its input from the console. In GEPAC programs, to check NOPTC, IUNITD must be set to 1; after checking NOPTC in the ILRT program, IUNITD is set to 0 so that other programs may be executed from the console.

NTA - Output device logical unit designation for alarm typer

TIME - GEPAC time counter; time is measured in terms of digital counts, 0.5 second/count (mod 7,200 seconds/hr)

APPENDIX A

DERIVATION OF DIFFERENTIAL LEAK RATE BY REFERENCE VOLUME METHOD

The fractional leakage rate:

$$L' = \frac{1}{P_o - P_{ro}} \left[(\Delta P_o - \Delta P_i \frac{T_o}{T_i}) - (P_{ro} - P_{ri} \frac{T_o}{T_i}) \right] \quad (1)$$

is developed below based on the pressure differential between containment vessel and reference volume as defined: $\Delta P_o = P_o - P_{ro}$

$$\Delta P_i = P_i - P_{ri} \quad (2)$$

Note that care must be taken to insure that the containment pressure is higher than the reference volume pressure at the start of the test. If this is not true, equation (1) must be modified by reversing the signs of ΔP_o and ΔP_i . For example, a leak in the containment volume might cause this situation. The derivation of (1) is found in reference (1) below. The steps in the derivation are:

- a. Express values of P in equation (2) by ideal gas law and rearrange to solve for M_o and M_i .
- b. Form the ratio, $\frac{M_o - M_i}{M_o}$ and replace M_r and M_o by $M_r = \frac{P_{ro}V_r}{RT_{ro}}$ and $M_o = \frac{P_oV_o}{RT_o}$
- c. If the temperatures in the reference vessel and the containment are allowed to equalize, then $T_o = T_{ro}$ and $T_i = T_{ri}$. The result is:

$$\frac{M_o - M_i}{M_o} = \frac{T_o}{P_o} \left(\frac{\Delta P_o - \Delta P_i}{T_o - T_i} \right)$$

- d. Correcting for vapor pressure, P is replaced by $(P - P_v)$ and equation (1) results.

Ref (1): Proposed Standard for Leakage-Rate Testing for Containment Structures for Nuclear Reactors - Amer. Nat. Std N45.4

(Amer. Nuclear Soc. Standards Committee, September 15, 1971)

APPENDIX B

FORTRAN VARIABLES

I. Initial values (at t = 0.)

PSØ - P_{so}, initial total pressure, suppression chamber

PDØ - P_{do}, initial total pressure, dry bulb

PSVØ - P_{svo}, initial vapor pressure, suppression chamber

PDVØ - P_{dvo}, initial vapor pressure, dry well

TSØ - T_{so}, initial temperature, suppression chamber

DPSRØ - P_{sro}, initial differential pressure between ref. volume and suppression chamber

DPDRØ - P_{dro}, initial differential pressure between ref. volume and dry well

YMØS - M_{so}, initial mass air in torus

YMØD - M_{do}, initial mass air in dry well

WTNØØ - W_{n2} Weight of nitrogen added to system at time 0. (from totalizing meter)

II. Current values

Time - t, hours elapsed since test started

PS,PD - P_s, P_d, total pressure, torus and dry well

PSV,PDV - P_{sv},P_{dv}, vapor pressures, torus and dry well

TS,TD - T_s,T_d, temperatures, torus and dry well

DPSR, DFDR - P_{sr}, P_{dr}, differential pressures between ref. volume and containment, torus and dry well

BAROM - barometric pressure, inches Hg

DEWPTD - Dew Point, dry well

DEWPTS - Dew point, torus

PSR,PDR - P_{sr}, P_{dr}, pressure, reference volumes, torus and dry well.

RLEAKS L'sr, Differential leak rate from torus, fractional loss of mass per hour.

PLEAKD L'dr, Differential leak rate from dry well, fractional loss of mass per hour

TAVER(i), i=1,9 - Tav, average of the 2 RTDS located within each of the 9 zones of the containment volume

IMODE Mode of moisture analyzer operation

1. Both
2. 16-MAZ-101 only
3. 16-MAZ-102 only

(See moisture analyzer section for details)

ISTRM Number designation of stream (1-5)

- | | |
|-----|----------|
| 1 | Torus |
| 2-5 | Dry Well |

N Counter for index of number time steps in current leak rate evaluation

III. Stored Results (dimensioned for maximum of 26 time steps or 26 hours)

Rate (1,j), j=1, 26	dMta/dt, rate absolute method
Rate (2,j), j=1, 26	dMtr/dt, rate reference volume method
VAR (1,j), j=1, 26	Variance of least squares fit, Mta vs t, absolute method
VAR (2,j) j=1, 26	Variance of least squares fit, Mts vs t, reference volume method
STDM (1,j), j=1, 26	Standard deviation of fit, Mtr vs t, absolute method. Units: lb/hr
STDM (2,j) j=1, 26	Standard deviation of fit, Mtr vs t, reference volume method. Units: lb/hr
CON(2,j), j=1,?6	95 percent confidence level based on number of observations.
PBAR (j), j=1, 26	Barometric pressure
RTD (18,j) j=1, 26	RTD temperature readings
XTIME (j), j=1, 26	Time, hours
PPMV (i,j), j=1, 26	Parts per million by volume of moisture in stream i, where i = 1,5

YMASS (1, j), j=1, 26	Msa, Mass air in torus, absolute
YMASS (2, j), j=1, 26	Mda, Mass air in dry well, absolute
YMASS (3, j), J=1, 26	Msa + Mda, total mass, absolute
YMASS (4, j), j=1, 26	Ms _r , mass air in torus, ref. volume
YMASS (5, j), j=1, 26	Md _r , mass air in dry well, ref. volume
YMASS (6, j), j=1, 26	Ms _r + Md _r , total mass, ref. volume
OUT (1, j), j=1, 26	P _s , total pressure, torus
OUT (2, j), j=1, 26	P _d , total pressure, dry well
OUT (3, j), j = 1,26	P _{sv} , vapor pressure, torus
OUT (4,j), j = 1,26	P _{dv} , vapor pressure, dry well
OUT (5,j), j = 1,26	T _s , temperature, torus
OUT (6,j), j = 1,26	T _d , temperature, dry well
OUT (7,j), j = 1,26	P _{sr} , pressure, differential reference volume and torus
OUT (8,j), j = 1,26	P _{dr} , pressure, differential reference volume and dry well
OUT (9,j), j = 1,26	P _{sr} , pressure, reference volume, torus
OUT (10,j), j = 1,26	P _{dr} , pressure, reference volume, dry well
OUT (11,j), j = 1,26	Dew point, torus
OUT (12,j), j = 1,26	Dew point, dry well
OUT (13,j), j = 1,26	Nitrogen bleed, lbs (total added)
YM \emptyset (1)	B _a , intercept of L. S. fit of M _{ta} vs t, absolute method
YM \emptyset (2)	B _r , intercept of L.S. fit of M _{tr} vs t, ref. volume method
DMDT (1)	M _a , slope, dM _{ta} /dt
DMDT (2)	M _r , slope, dM _{tr} /dt
WTN ₂	Nitrogen bleed, lb. (total added)
WTCOR(j), j = 1,26	Cumulative weight N ₂ bleed added to containment from time base (N=1) i.e. from time XTIME(1)

IV. Fixed values:

VS, VD	VS,VD, volumes of torus and dry well
TWT (i), i = 1,9	Volume weighting factors for temperature measurements in 9 zones of volume
WATWT (i), i = 1,5	Volume weighting factors for moisture measurements in 5 moisture analyzer streams
R	Gas constant for air, 53.35 ft lbf/lbm R

V. Within the setup subroutine, which accepts the real time analog readings into Fortran variables by means of equivalence statements, the following define unprocessed signals:

TREAD (i), i=1,18	Current scan of 18 RTD'S (degrees F)
PSREF	Current scan of reference vessel pressure in torus (mv)
CFN2	Nitrogen bleed, cu ft (total added)
PDREF	Current scan of reference vessel pressure in dry well (mv)
XMODE	Current scan of mode switch of moisture analyzer (mv)
XSTRM	Current scan of stream ID of moisture analyzer (mv)
XRDG1	Current scan of moisture reading (16-MAZ-101), mv
XRDG2	Current scan of moisture reading (16-MAZ-102), mv
BARRD	Current scan of barometric pressure, mv
CTIME	Current time, hours
PSVPR	Current scan of total pressure in torus, mv
PBULB	Current scan of total pressure in dry well, mv
DPSREF	Current scan of differential pressure between torus and reference vessel, mv
DPDREF	Current scan of differential pressure between dry well and reference vessel, mv
IDUMMY	Current scan of operator set program control variable. This value will be set as an integer (0-9) (See IFLAG below)

VI. Manually set variables:

IEDIT	{ 1 - Abbreviated output 2 - One hr output (3 - 24 hr (or max. output) below) As set by IFLAG
IFLAG	0 Normal operation of IRLT program	
	1 Reinitialize	IEDIT = 1
	3 Reinitialize, setting t = 0.	
	4 Provide abbreviated output (1 line containing rate, cont. level, moistures)	- IEDIT = 1
	5 Current output (1 hr)	- IEDIT = 2
	6 Long output (24 hr)	- IEDIT = 3
	9 Abort program	

Note: In addition, IFLAG may be set to 8 within the scan program, if an RTD measurement error exists. After manual correction of the RTD error, the IRLT program is restarted by manually setting IFLAG = 0. If program is running normally or being reinitialized (i.e. ITYPE = 0, 1, or 3) IEDIT is set to 1 and the output will be of the abbreviated form. (See Section VI-a for details).

APPENDIX C

Operator Guide

The procedure for starting the ILRT program is as follows:

on the GEPAC 4030 console,

- 1) Dial into location labeled "FUNCTION" the value 29
(Function switch 29)
- 2) Dial into location labeled "NUMBER," the value 0
(This is the program value for ITYPE).
- 3) Press the "ACTION" button

After starting the ILRT program, the program may be reinitialized by the same procedure as above except that ITYPE ("NUMBER" dial) is set to 1 to reinitialize with the time variable automatically reset to 0. Follow the above procedure with ITYPE = 3.

When the program is started or reinitialized, an abbreviated, shortened set of results is printed (leak rate, confidence level, and moisture analyzer readings only). If complete output is desired, i.e. all measurements and calculations, perform the start program procedure as above with "NUMBER" dial set to 0; then repeat the procedure with "NUMBER" dial set to 5 or 6. Note: ITYPE = 5 produces output for current hour, ITYPE = 6 produces a log of the output for the preceding 24 hours (or less than 24 hours, depending upon the maximum time the program has been executing).

In the case the ILRT program detects an RTD measurement error, it enters into a "wait" state of 30 seconds duration pending operator action, and internally sets IFLAG = 8. As long as the value of IFLAG remains 8, the program will continue in the wait state. That is, in order to continue the program, the operator must dial another value on the "NUMBER" dial (usually 0) and press the "ACTION" button.

While in the wait state the operator must correct the RTD observation by either of the following two methods:

- 1) a) Dial in the computer point number corresponding to the bad RTD on the GEPAC console.
b) Manually dial in a corrected observation (in deg F) using "INPUT" dial
c) Remove the computer point from scan (by depressing "REMOVE SCAN" button on console) and insert new value (by depressing "INSERT" button). This new value will remain constant in the computer until it is changed manually or the RTD computer point is returned to SCAN (a console push-button is also provided for this purpose).

- 2) Same as above except dial in a value of 0. instead of a corrected observation. With this procedure, the scanned reading will be ignored. For example, each of the 9 containment volumes contains 2 RTD's which are averaged. If one of these 2 RTD's reads 0., it will be ignored and the "average" will consist only of one good reading.

Caution: After the operator breaks the computer out of the WAIT state, no further corrections will be possible. Therefore, all corrections must be made before proceeding.

To abort or end the ILRT program, dial the value 9 into "NUMBER" and press "ACTION".

For further details, see Section VI and Appendix B-VI of documentation.

APPENDIX D

SAMPLE OUTPUT
IBM 370 PROGRAM

***** JAFNPP-1 14 PSTA K TE TEST AFTER 8.00 HRS *****

TOTAL RATE (PCT/DAY)	95PCT CONF (PCT/DAY)	MOISTURE READING STREAMS - PPMV VOLUME				
		A	B	C	D	E
5.8189	0.4559	9375.00	9375.00	9375.00	9375.00	9375.00
5.8189	0.4559					

16-1-RTD INDEX 113 OR 114 IS BAD
OPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0.
AFTER FIXUP, SET IFLAG=0 TO RESUME PROGRAM
DEENTRGIZE BAD RTD
OR SET IFLAG=9 TO ABORT PROGRAM

16-1-RTD RUG

113	100.00
114	98.00
101	93.00
120	94.00
102	95.00
119	96.00
103	97.00
104	98.00
105	99.00
106	100.00
107	101.00
108	102.00
109	103.00
117	104.00
110	105.00
111	106.00
112	107.00
118	108.00

EXAMPLE:

ABBREVIATED OUTPUT
(IFLAG = 1, IEDIT = 1)

***** JAFNPP-1 14 PSIA LEV TEST AFTER 9.00 HRS *****
 RFF.DNG 11025-FM- AND FM-1PA

EXAMPLE: LONG OUTPUT

HRS	TEMPERATURE (DEG F) 14-1-STD-VAREA																	
	113/R	114/R	101/I	120/I	102/I	119/I	103/I	104/I	105/I	106/I	107/I	108/I	109/I	117/I	110/I	111/I	112/I	113/I
0	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
1	100.00	95.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
2	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
3	100.00	99.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
4	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
5	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
6	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
7	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
8	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
9	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00

HRS	AVE TEMP		PRESSURES (PSIA)						BAROMETRIC	
	TORUS	DRYWELL	TORUS	REF VOL	DP	TOTAL	REF VOL	DRYWELL	PRESSURE	INCHES HG
		(P1-104)	(P1-103)	(DP1-102)	(P1-102)	(P1-101)	(DP1-101)			
0	99.00	98.55	14.00	14.00	0.0	14.00	14.00	0.0	28.50	
1	99.00	93.55	14.00	14.00	0.0	14.00	14.00	0.0	28.50	
2	99.00	98.55	13.86	14.00	0.1400	13.99	14.00	0.0140	28.50	
3	99.00	98.55	13.86	14.00	0.1400	13.99	14.00	0.0140	28.50	
4	99.00	98.55	13.72	14.00	0.2300	13.97	14.00	0.0230	28.50	
5	99.00	98.55	13.72	14.00	0.2800	13.97	14.00	0.0280	28.50	
6	99.00	98.55	13.58	14.00	0.4200	13.96	14.00	0.0420	28.50	
7	99.00	94.55	13.58	14.00	0.4200	13.96	14.00	0.0420	28.50	
8	99.00	93.55	13.44	14.00	0.5600	13.94	14.00	0.0560	28.50	
9	99.00	93.55	13.44	14.00	0.5600	13.94	14.00	0.0560	28.50	

HRS	MOISTURE READINGS					TORUS		DRYWELL	
	PPM VOLUME FOR STREAMS A-E					VAPOR PRES (PSIA)	DEW POINT (DEG F)	VAPOR PRES (PSIA)	DEW POINT, (DEG F)
A	B'	C	D	E					
0	9375.00	9375.00	9375.00	9375.00	9375.00	0.1300	41.76	0.1300	41.75
1	9375.00	9375.00	9375.00	9375.00	9375.00	0.1300	41.76	0.1300	41.75
2	9375.00	9375.00	9375.00	9375.00	9375.00	0.1267	41.50	0.1299	41.73
3	9375.00	9375.00	9375.00	9375.00	9375.00	0.1267	41.50	0.1299	41.73
4	9375.00	9375.00	9375.00	9375.00	9375.00	0.1274	41.24	0.1297	41.70
5	9375.00	9375.00	9375.00	9375.00	9375.00	0.1274	41.24	0.1297	41.70
6	9375.00	9375.00	9375.00	9375.00	9375.00	0.1261	40.99	0.1296	41.67
7	9375.00	9375.00	9375.00	9375.00	9375.00	0.1261	40.98	0.1296	41.67
8	9375.00	9375.00	9375.00	9375.00	9375.00	0.1248	40.71	0.1295	41.65
9	9375.00	9375.00	9375.00	9375.00	9375.00	0.1248	40.71	0.1295	41.65

HRS	MASS AIR IN CONTAINMENTS - LBS			REF VESSEL METHOD		
	IDEAL GAS LAW			TORUS	DRYWELL	SUM
	TORUS	DRYWELL	SUM	TORUS	DRYWELL	SUM
0	7755.33	10353.84	18109.17	7755.33	10353.84	18109.17
1	7755.33	10353.84	18109.17	7755.33	10353.84	18109.17
2	7677.76	10343.49	18021.27	7677.76	10343.49	18021.27
3	7677.75	10343.49	18021.27	7677.75	10343.49	18021.27
4	7600.23	10333.13	17933.36	7600.23	10333.13	17933.36
5	7600.23	10333.13	17933.36	7600.23	10333.13	17933.36
6	7522.67	10322.78	17845.45	7522.67	10322.78	17845.45
7	7522.67	10322.78	17845.45	7522.67	10322.78	17845.45
8	7445.12	10312.43	17757.54	7445.12	10312.43	17757.54
9	7445.12	10312.43	17757.54	7445.12	10312.43	17757.54

C OUTPUT (CONT.)

LONG

INTEGRATED X RATE

HRS	ABSOLUTE METHOD				REF VESSEL METHOD			
	CALC 24HR LEAK RATE(PCT)	STD DEV OF SLOPE	95PCT CONF LIMIT(PCT)	LEAK RATE(PCT) OF SLOPE	STD DEV	95PCT CONF LIMIT(PCT)		
0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	5.8204	25.3766	10.2975	5.8204	25.3766	10.2974		
3	4.6579	12.4319	4.4948	4.6579	12.4319	4.4948		
4	5.8195	6.7907	2.9648	5.8195	8.7907	2.9648		
5	5.3222	6.1522	1.9830	5.3222	6.1522	1.9830		
6	5.8191	4.8638	1.5174	5.8191	4.8638	1.5174		
7	5.5433	3.8213	1.1642	5.9189	3.1972	0.9559		
8	5.8189	3.1972	0.9559	5.6436	2.6639	0.7850		
9	5.6436	2.6639	0.7850					

16-1-RTD INDEX 113, OR 114 IS BAD
 OPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0.
 AFTER FIXUP, SET IFLAG=0 TO RESUME PROGRAM
 DEENERGIZE BAD RTD
 OR SET IFLAG=9 TO ABORT PROGRAM

16-1-RTD RDG

113	100.00
114	98.00
101	93.00
120	94.00
102	95.00
119	96.00
103	97.00
104	98.00
105	99.00
106	100.00
107	101.00
108	102.00
109	103.00
117	104.00
110	105.00
111	106.00
112	107.00
118	108.00

***** JAENPP-1 14 PSIA LF ATE TEST AFTER 10.00 HRS *****
REF.DWG 11B25-FM AND FM-18A

EXAMPLE: SHORT OUTPUT

TEMPERATURE (DEG F) 16-1-RTD-/ARFA
 HRS 113/8 114/8 101/1 120/1 102/1 119/1 103/2 104/2 105/3 106/3 107/4 108/4 109/5 117/5 110/6 111/6 112/7 113/7
 10 100.00 98.00 93.00 94.00 95.00 96.00 97.00 98.00 99.00 100.00 101.00 102.00 103.00 104.00 105.00 106.00 107.00 108.00

HRS	AVE TEMP TORUS	DRYWELL	PRESSURES (PSIA)						BAROMETRIC PRESSURE INCHES HG
			TOTAL (P1-104)	TORUS REF VOL (P1-103)	DP (DP1-102)	TOTAL (P1-102)	REF VOL (P1-101)	DP (DP1-101)	
10	99.00	98.55	13.30	14.00	0.7000	13.93	14.00	0.0700	28.50

HRS	MOISTURE READINGS					TORUS VAPOR PRES (PSIA)	DEW POINT (DEG F)	DRYWELL VAPOR PRES (PSIA)	DEW POINT (DEG F)
	A	B	C	D	E				
10	9375.00	9375.00	9375.00	9375.00	9375.00	0.1235	40.45	0.1294	41.62

HRS	MASS AIR IN CONTAINMENTS - LBS			REF VESSEL METHOD		
	TORUS	DRYWELL	SUM		TORUS - DRYWELL	SUM
10	7367.57	10302.07	17669.64	7367.57	10302.07	17669.64

INTEGRATED LEAK RATE

HRS	ABSOLUTE METHOD			REF VESSEL METHOD			
	CALC 24HR	STD DEV	95PCT CONF	CALC 24HR	STD DEV	95PCT CONF	
10	LEAK RATE(PCT) OF SLOPE	LIMIT(PCT)	LEAK RATE(PCT) OF SLOPE	LIMIT(PCT)	5.8187	2.3070	0.6716

16-1-RTD INDEX 113 OR 114 IS BAD
 OPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0.
 AFTER FIXUP, SET IFLAG=0 TO RESUME PROGRAM
 DEENFRGIZE BAD RTD
 OR SET IFLAG=9 TO ABORT PROGRAM

16-1-RTD RDG

113	100.00
114	98.00
101	93.00
120	94.00
102	95.00
119	96.00
103	97.00
104	98.00
105	99.00
106	100.00
107	101.00
108	102.00
109	103.00
117	104.00
110	105.00
111	106.00
112	107.00
119	108.00

EXCERPTS: SHORT OUTPUT

*6669 JAFNPP-1 14 PSIA LEAK TEST AFTER 11.00 HRS ~~sec**~~
REF.DWG 11925-FM-4 AND FM-1PA

HRS 113/9 114/8 101/1 120/1 102/1 119/1 103/2 104/2 105/3 106/3 107/4 108/4 109/5 117/5 110/6 111/6 112/7 113/7
11 100.00 98.00 93.00 94.00 95.00 96.00 97.00 98.00 99.00 100.00 101.00 102.00 103.00 104.00 105.00 106.00 107.00 108.00

HRS	AVE TEMP		PRESSURES (PSIA)						BAROMETRIC		
	TORUS	DRYWELL	TORUS	REF VOL	DP	TOTAL	REF VOL	DP	DRYWELL	PRESSURE	INCHES HG
		TOTAL	(P1-104)	(P1-103)	(DP1-102)	(P1-102)	(P1-101)	(DP1-101)			
11	99.00	98.55	13.30	14.00	0.7000	13.93	14.00	0.0700	28.50		

HRS	MOISTURE READINGS				TORUS			DRYWELL			
	A	B	C	D	VAPOR PRES	DEW POINT	(PSIA)	VAPOR PRES	DEW POINT	(PSIA)	(DEG F)
11	9375.00	9375.00	9375.00	9375.00	9375.00	0.1235	40.45	0.1294	41.62		

HRS	MASS AIR IN CONTAINMENTS - LBS			REF VESSEL METHOD		
	TORUS	DRYWELL	SUM	TORUS	DRYWELL	SUM
11	7367.57	10302.07	17669.64	7367.57	10302.07	17669.64

INTEGRATED LEAK RATE

HRS	ABSOLUTE METHOD			REF VESSEL METHOD		
	CALC 24HR	STD DEV	95PCT CONF	CALC 24HR	STD DEV	95PCT CONF
	LEAK RATE(PCT) OF SLOPE	LIMIT(PCT)	LEAK RATE(PCT) OF SLOPE	LIMIT(PCT)		
11	5.6976	1.9920	0.5742	5.6976	1.9920	0.5742

16-1-RTD INDEX 113 OR 114 IS BAD
OPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0.
AFTER FIXUP, SET IFLAG=0 TO RESUME PROGRAM
DEEMERGIZE BAD RTD
OR SET IFLAG=9 TO ABORT PROGRAM

16-1-RTD RDG

113	100.00
114	98.00
101	93.00
120	94.00
102	95.00
119	96.00
103	97.00
104	98.00
105	99.00
106	100.00
107	101.00
108	102.00
109	103.00
117	104.00
110	105.00
111	106.00
112	107.00
118	108.00

(cont.) OBT RECENT 24 HOUR ***** JAFNPP-1 14 PSIA LEP TEST AFTER 26.00 HRS * * * * *

REF. DNG 11825-FH-10A AND FM-10A

PRES ID'S EXAMINER: Long Output

HRS	113/8	114/P	101/1	120/1	102/1	119/1	103/2	104/2	105/3	106/3	107/4	108/4	109/5	110/5	111/6	112/6	113/7	114/7
2	103.00	99.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
3	103.00	99.00	93.30	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
4	106.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
5	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
6	109.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
7	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
8	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
9	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
10	107.30	98.00	92.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
11	107.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
12	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
13	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
14	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
15	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
16	100.00	96.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
17	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
18	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
19	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
20	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
21	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
22	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
23	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
24	100.00	99.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
25	100.00	98.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00
26	100.00	93.00	93.00	94.00	95.00	96.00	97.00	98.00	99.00	100.00	101.00	102.00	103.00	104.00	105.00	106.00	107.00	108.00

HRS

AVE TEMP DRYWELL

TORUS

REF VOL

TOTAL

(P1-104)

OP VOL

(CP1-102)

TOTAL

(P1-102)

REF VOL

(P1-101)

DP

(CP1-101)

PRESURES (PSIA)

DRYWELL

REF VOL

TOTAL

(P1-104)

OP VOL

(CP1-102)

TOTAL

(P1-102)

REF VOL

(P1-101)

DP

(CP1-101)

BAROMETRIC

PRESSURE

INCHES HG

LINE NO.	MILESTONE REALIZATION PPM VOLUME FOR STREAMS A-E					TORUS (PSIA)	DEW POINT (DEG F)	VAPOR PRES (PSIA)	DEW POINT (DEG F)
	A	B	C	D	E				
2	9375.00	9375.00	9375.00	9375.00	9375.00	0.1287	41.50	0.1299	41.73
3	9375.00	9375.00	9375.00	9375.00	9375.00	0.1287	41.50	0.1299	41.73
4	9375.00	9375.00	9375.00	9375.00	9375.00	0.1274	41.24	0.1297	41.70
5	9375.00	9375.00	9375.00	9375.00	9375.00	0.1274	41.24	0.1297	41.70
6	9375.00	9375.00	9375.00	9375.00	9375.00	0.1261	40.98	0.1296	41.67
7	9375.00	9375.00	9375.00	9375.00	9375.00	0.1261	40.98	0.1296	41.67
8	9375.00	9375.00	9375.00	9375.00	9375.00	0.1248	40.71	0.1295	41.65
9	9375.00	9375.00	9375.00	9375.00	9375.00	0.1248	40.71	0.1295	41.65
10	9375.00	9375.00	9375.00	9375.00	9375.00	0.1235	40.45	0.1294	41.62
11	9375.00	9375.00	9375.00	9375.00	9375.00	0.1235	40.45	0.1294	41.62
12	9375.00	9375.00	9375.00	9375.00	9375.00	0.1222	40.18	0.1292	41.60
13	9375.00	9375.00	9375.00	9375.00	9375.00	0.1222	40.18	0.1292	41.60
14	9375.00	9375.00	9375.00	9375.00	9375.00	0.1209	39.91	0.1291	41.57
15	9375.00	9375.00	9375.00	9375.00	9375.00	0.1209	39.91	0.1291	41.57
16	9375.00	9375.00	9375.00	9375.00	9375.00	0.1196	39.63	0.1290	41.55
17	9375.00	9375.00	9375.00	9375.00	9375.00	0.1196	39.63	0.1290	41.55
18	9375.00	9375.00	9375.00	9375.00	9375.00	0.1183	39.36	0.1289	41.52
19	9375.00	9375.00	9375.00	9375.00	9375.00	0.1193	39.36	0.1289	41.52
20	9375.00	9375.00	9375.00	9375.00	9375.00	0.1170	39.08	0.1287	41.49
21	9375.00	9375.00	9375.00	9375.00	9375.00	0.1170	39.08	0.1287	41.49
22	9375.00	9375.00	9375.00	9375.00	9375.00	0.1157	38.79	0.1286	41.47
23	9375.00	9375.00	9375.00	9375.00	9375.00	0.1157	38.79	0.1286	41.47
24	9375.00	9375.00	9375.00	9375.00	9375.00	0.1144	38.51	0.1284	41.44
25	9375.00	9375.00	9375.00	9375.00	9375.00	0.1144	38.51	0.1284	41.44
26	9375.00	9375.00	9375.00	9375.00	9375.00	0.1131	38.22	0.1283	41.42

249

HRS	TORUS	IDEAL GAS LAW			REF VESSEL METHOD		
		DRYWELL	SUM	TORUS	DRYWELL	SUM	
2	7677.78	10343.49	18021.27	7677.78	10343.49	18021.27	
3	7677.78	10343.49	18021.27	7677.78	10343.49	18021.27	
4	7600.23	10333.13	17933.36	7600.23	10333.13	17933.36	
5	7600.23	10333.13	17933.36	7600.23	10333.13	17933.36	
6	7522.67	10322.78	17845.45	7522.67	10322.78	17845.45	
7	7522.67	10322.78	17845.45	7522.67	10322.78	17845.45	
8	7445.12	10312.43	17757.54	7445.12	10312.43	17757.54	
9	7445.12	10312.43	17757.54	7445.12	10312.43	17757.54	
10	7367.57	10302.07	17669.64	7367.57	10302.07	17669.64	
11	7367.57	10302.07	17669.64	7367.57	10302.07	17669.64	
12	7290.01	10291.72	17581.73	7290.01	10291.72	17581.73	
13	7290.01	10291.72	17581.73	7290.01	10291.72	17581.73	
14	7212.46	10281.36	17493.82	7212.46	10281.36	17493.82	
15	7212.46	10281.36	17493.82	7212.46	10281.36	17493.82	
16	7134.91	10271.01	17405.92	7134.91	10271.01	17405.92	
17	7134.91	10271.01	17405.92	7134.91	10271.01	17405.92	
18	7057.35	10260.66	17318.01	7057.35	10260.66	17318.01	
19	7057.35	10260.66	17318.01	7057.35	10260.66	17318.01	
20	6979.30	10250.30	17230.10	6979.30	10250.30	17230.10	
21	6979.30	10250.30	17230.10	6979.30	10250.30	17230.10	
22	6902.25	10229.95	17142.19	6902.25	10229.95	17142.19	
23	6902.25	10229.95	17142.19	6902.25	10229.95	17142.19	
24	6824.69	10229.60	17054.29	6824.69	10229.60	17054.29	
25	6824.69	10229.60	17054.29	6824.69	10229.60	17054.29	
26	6747.14	10219.24	16966.38	6747.14	10219.24	16966.38	

INTEGRATED LEAK RATE

ABSOLUTE METHOD

REF VESSEL METHOD

39 QIP

CONT.

HRS	CALC 24HR LEAK RATE(PCT)	STD DEV OF SLOPE	95PCT CONF LIMIT(PCT)	CALC 24HR LEAK RATE(PCT)	STD DEV OF SLOPE	95PCT CONF LIMIT(PCT)
2	5.8204	25.3766	10.2975	5.8204	25.3766	10.2974
3	4.6579	12.4319	4.4949	4.6579	12.4319	4.4948
4	5.8195	8.7907	2.9648	5.8195	8.7907	2.9648
5	5.3222	6.1522	1.9830	5.3222	6.1522	1.9830
6	5.8191	4.8638	1.5174	5.8191	4.8638	1.5174
7	5.5433	3.8213	1.1642	5.5433	3.8213	1.1642
8	5.8189	3.1972	0.9559	5.8189	3.1972	0.9559
9	5.6436	2.6639	0.7850	5.6436	2.6639	0.7850
10	5.8187	2.3070	0.6716	5.8187	2.3070	0.6716
11	5.6976	1.9920	0.5742	5.6976	1.9920	0.5742
12	5.8186	1.7657	0.5047	5.8186	1.7657	0.5047
13	5.7300	1.5616	0.4433	5.7300	1.5615	0.4433
14	5.8186	1.4076	0.3970	5.8186	1.4076	0.3970
15	5.7509	1.2666	0.3554	5.7509	1.2666	0.3554
16	5.8185	1.1563	0.3229	5.8185	1.1563	0.3229
17	5.7652	1.0541	0.2931	5.7652	1.0541	0.2931
18	5.8185	0.9716	0.2692	5.8185	0.9718	0.2692
19	5.2753	0.6949	0.2471	5.7753	0.8949	0.2471
20	5.8184	0.6317	0.2289	5.8184	0.8317	0.2289
21	5.7829	0.7722	0.2120	5.7329	0.7722	0.2120
22	5.8184	0.7223	0.1978	5.8184	0.7223	0.1978
23	5.7586	0.6751	0.1844	5.7466	0.6751	0.1844
24	5.8184	0.6350	0.1731	5.8184	0.6350	0.1731
25	5.5319	0.6350	0.1735	5.4319	0.6350	0.1735
26	5.8467	0.6350	0.1739	5.8467	0.6350	0.1739

16-1-RTD INDEX 113 OR 114 IS BAD
OPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0.
AFTER FIXUP, SET IFLAG=0 TO RESUME PROGRAM
DEENERGIZE BAD RTD
OR SET IFLAG=9 TO ABORT PROGRAM

16-1-RTD RDG

113	100.00
114	98.00
101	93.00
120	94.00
102	95.00
119	96.00
103	97.00
104	98.00
105	99.00
106	100.00
107	101.00
108	102.00
109	103.00
117	104.00
110	105.00
111	106.00
112	107.00
118	108.00

APPENDIX E

ERROR ANALYSIS

The error analysis which has been performed determines the relative error of the previously defined functions which have been used to calculate the leak rate by both the absolute and reference vessel methods. Relative error is defined as the absolute error divided by the true value of the quantity. The absolute error is expressed in terms of the unit used and is the numerical difference between the true value of a quantity and the given value as given or obtained by measurement or calculation. The percentage error is defined as the relative error times one hundred (100). It can be said that the true index of accuracy of measurement is relative error.

A development of the general formula for errors follows:

$$\text{let } N = f(u_1, u_2, u_3, \dots, u_n) \quad (a)$$

denote any function of several independent variables $u_1, u_2, u_3, \dots, u_n$ which are subjected to the errors $\Delta u_1, \Delta u_2, \Delta u_3, \dots, \Delta u_n$, respectively. These errors will cause an error ΔN in the function N , according to the relationship

$$N + \Delta N = f(u_1 + \Delta u_1, u_2 + \Delta u_2, u_3 + \Delta u_3, \dots, u_n + \Delta u_n) \quad (b)$$

To find an expression for ΔN expand the right-hand member by Taylors' Theorem for a function of several variables. Then

$$\begin{aligned} f(u_1 + \Delta u_1, u_2 + \Delta u_2, u_3 + \Delta u_3, \dots, u_n + \Delta u_n) &= \\ f(u_1, u_2, \dots, u_n) + \Delta u_1 \frac{\partial f}{\partial u_1} + \frac{\Delta u_2 \partial f}{\partial u_2} + \dots + \Delta u_n \frac{\partial f}{\partial u_n} + \\ 1/2 [(\Delta u_1)^2 \frac{\partial^2 f}{\partial u_1^2} + \dots + \frac{(\Delta u_n)^2 \partial^2 f}{\partial u_n^2} + 2 \Delta u_1 \Delta u_2 \frac{\partial^2 f}{\partial u_1 \partial u_2} + \dots \\ \vdots \\ \cdot + \dots] \end{aligned} \quad (c)$$

Since the errors $\Delta u_1, \Delta u_2, \dots, \Delta u_n$ are always relatively small*, their squares, products, and higher powers may be neglected. Then

$$N + \Delta N = f(u_1, u_2, u_3, \dots, u_n) + \Delta u_1 \frac{\partial f}{\partial u_1} + \Delta u_2 \frac{\partial f}{\partial u_2} + \dots + \Delta u_n \frac{\partial f}{\partial u_n} \quad (d)$$

Subtracting (a) from (d)

$$\Delta N = \frac{\partial f}{\partial u_1} \Delta u_1 + \frac{\partial f}{\partial u_2} \Delta u_2 + \dots + \frac{\partial f}{\partial u_n} \Delta u_n, \quad (e) \text{ or}$$

$$\Delta N = \frac{\partial N}{\partial u_1} \Delta u_1 + \frac{\partial N}{\partial u_2} \Delta u_2 + \dots + \frac{\partial N}{\partial u_n} \Delta u_n \quad (f)$$

which is a general formula for computing the error of a function. The right hand member of (f) is merely the total differential of N. For the relative error of the function N

$$E_r = \frac{\Delta N}{N} = \frac{\partial N}{\partial u_1} \frac{\Delta u_1}{N} + \frac{\partial N}{\partial u_2} \frac{\Delta u_2}{N} + \dots + \frac{\partial N}{\partial u_n} \frac{\Delta u_n}{N} \quad (g)$$

The equations used to determine the leak rate and the relative error calculated from them will now be treated for the absolute method and the reference vessel method.

ABSOLUTE METHOD

$$M_{ta} = M_{sa} + M_{da}$$

$$= \frac{144(P_s - P_{sv})V_s}{RT_s} + \frac{144(P_d - P_{dv})V_d}{RT_d}$$

$$= \frac{144}{RT_s T_d} [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]$$

* A quantity Q is relatively small in comparison with a second quantity Q_2 if the ratio is small in comparison with unity. The squares and products of such small ratios are negligible in most calculations.

$$\begin{aligned}
 E_r &= \frac{\Delta M_{ta}}{M_{ta}} = \frac{144}{R} \left[\frac{(V_s \Delta P_s)}{T_s M_{ta}} - \frac{V_s \Delta P_{sv}}{T_s M_{ta}} + \frac{V_d \Delta P_d}{T_d M_{ta}} \right. \\
 &\quad - \frac{V_d \Delta P_{dv}}{T_d M_{ta}} + \frac{(P_s - P_{sv}) \Delta V_s}{T_s M_{ta}} + \frac{(P_d - P_{dv}) \Delta V_d}{T_d M_{ta}} \\
 &\quad - \frac{(P_s - P_{sv}) V_s \Delta T_s}{T_s^2} \left. - \frac{(P_d - P_{dv}) V_d \Delta T_d}{T_d^2} \right] \\
 &= \frac{V_s T_d \Delta P_s}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} - \frac{V_s T_d \Delta P_{sv}}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \\
 &\quad + \frac{V_d T_s \Delta P_d}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} - \frac{V_d T_s \Delta P_{dv}}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \\
 &\quad + \frac{(P_d - P_{dv}) \Delta V_d}{T_s [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} + \frac{(P_s - P_{sv}) \Delta V_s}{T_d [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} \\
 &\quad + \frac{-(P_s - P_{sv}) V_s \Delta T_s}{T_s [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} + \frac{-(P_d - P_{dv}) V_d \Delta T_d}{T_d [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]}
 \end{aligned}$$

Since the errors of ΔP_s , ΔP_{sv} , ΔP_d , ΔP_{dv} , ΔV_d , ΔV_s , ΔT_s , and ΔT_d are just as likely to be negative as positive, the terms must be taken with the positive sign in order to be sure of the maximum error in the leak rate. Therefore

$$\begin{aligned}
 E_r \leq & \left| \frac{V_s T_d \Delta P_s}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \right| + \left| \frac{V_s T_d \Delta P_{sv}}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \right| \\
 & + \left| \frac{V_d T_s \Delta P_d}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \right| + \left| \frac{V_d T_s \Delta P_{dv}}{(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d} \right| \\
 & + \left| \frac{(P_d - P_{dv}) \Delta V_d}{T_s [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} \right| + \left| \frac{(P_s - P_{sv}) \Delta V_s}{T_d [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} \right| \\
 & + \left| \frac{(P_s - P_{sv}) V_s \Delta T_s}{T_s [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} \right| + \left| \frac{(P_d - P_{dv}) V_d \Delta T_d}{T_d [(P_s - P_{sv}) V_s + (P_d - P_{dv}) V_d]} \right|
 \end{aligned}$$

REFERENCE VESSEL METHOD

$$\begin{aligned}
 M_{tr} &= M_{sr} + M_{dr} \\
 &= M_{so} (1-L'sr * t/24) + M_{do} (1-L'dr * t/24) \\
 &= \frac{144 (P_{so}-P_{svo})V_s}{R T_{so}} (1-L'sr * t/24) \\
 &\quad + \frac{144 (P_{do}-P_{dvo})V_d}{R T_{do}} (1-L'dr * t/24) \\
 &= \frac{144 V_s}{R T_{so}} (P_{so} + \Delta P_{sro}) - \frac{144 V_s}{R T_s} (\Delta P_{sr} + P_{sv}) \\
 &\quad + \frac{144 V_d}{R T_{do}} (P_{do} + \Delta P_{dro}) - \frac{144 V_d}{R T_d} (\Delta P_{dr} + P_{dv})
 \end{aligned}$$

$$\begin{aligned}
 E_r - \frac{\Delta M_{tr}}{M_{tr}} &\leq \left| \frac{(P_{so} + \Delta P_{sro}) \Delta V_s}{D} \frac{T_s}{T_d} \frac{T_d}{T_{do}} \right| \\
 &\quad + \left| \frac{(\Delta P_{sr} + P_{sv}) \Delta V_s}{D} \frac{T_{so}}{T_d} \frac{T_d}{T_{do}} \right| + \left| \frac{(P_{do} + \Delta P_{dro}) \Delta V_d}{D} \frac{T_s}{T_{so}} \frac{T_{so}}{T_d} \right| \\
 &\quad + \left| \frac{(\Delta P_{dr} + P_{dv}) \Delta V_d}{D} \frac{T_s}{T_{so}} \frac{T_{so}}{T_d} \right| + \left| \frac{(P_{so} + \Delta P_{sro}) V_s}{D} \frac{\Delta T_{so}}{T_d} \frac{T_d}{T_{so}} \frac{T_{so}}{T_{do}} \right| \\
 &\quad + \left| \frac{(\Delta P_{sr} + P_{sv}) \Delta T_s}{D} \frac{V_s}{T_{so}} \frac{T_{so}}{T_d} \frac{T_d}{T_{do}} \right| + \left| \frac{(P_{do} + \Delta P_{dro}) V_d}{D} \frac{\Delta T_{do}}{T_{do}} \frac{T_{do}}{T_s} \frac{T_s}{T_{so}} \right| \\
 &\quad + \left| \frac{(\Delta P_{dr} + P_{dv}) \Delta T_d}{D} \frac{V_d}{T_{so}} \frac{T_{so}}{T_s} \frac{T_s}{T_{do}} \right| + \left| \frac{V_s \Delta P_{so}}{D} \frac{T_d}{T_{do}} \frac{T_{do}}{T_s} \frac{T_s}{T_{so}} \right| \\
 &\quad + \left| \frac{V_s \Delta P_{sv}}{D} \frac{T_{so}}{T_d} \frac{T_d}{T_{do}} \right| + \left| \frac{V_d \Delta P_{do}}{D} \frac{T_s}{T_{so}} \frac{T_{so}}{T_d} \frac{T_d}{T_{do}} \right|
 \end{aligned}$$

Where $D = (P_{so} + \Delta P_{sro}) T_s T_d T_{do} V_s - (\Delta P_{sr} + P_{sv}) T_{so} T_d T_{do} V_s$
 $+ (P_{do} + \Delta P_{dro}) T_s T_{so} T_d V_d - (\Delta P_{dr} + P_{dv}) T_{do} T_s T_{so} V_d$

The relative error of the Absolute and Reference Vessel Methods were evaluated at 14.7 psia, 38 psia, and 60 psia. The results are summarized in Table B. The instrument errors used are as follows:

<u>Instrument</u>	<u>Property Measured</u>	<u>Error</u>
RTD	Temperature	.1 F from 70 F to 100 F
Quartz manometer	Pressure	.032% ($^{+0.010\%}$ reading $^{+0.022\%}$ full scale)
Bi-Directional quartz manometer	Pressure	.012% ($^{+0.010\%}$ reading $^{+0.002\%}$ full scale)
Beckman moisture analyzer	Vapor pressure	1% (full scale)
	Volume	2% (reading)

The variables and their associated values which were used to calculate the relative error are shown in Table A.

TABLE A

<u>Variable</u>	<u>Units</u>	<u>Value</u>
Td = Tso	°R	98.55
Ts = Tso	°R	99.00
Vd	ft ³	154476.00
Vs	ft ³	115800.00
Pso	psia	14.7, 38.0, 60.0
Psro	psia	14.7, 38.00, 60.00
Psro	psia	14.7, 38.00, 60.00
Psr	psia	.1300
Psv	psia	14.7, 38.00, 60.00
Pdc	psia	14.7, 38.00, 60.00
Pdro	psia	14.7, 38.00, 60.00
Pdr	psia	.1300
Pdv		.1
$\Delta T_d = \Delta T_s = \Delta T_{so} = \Delta T_{do}$	°R	3089.52
ΔV_d	ft ³	2316.00
ΔV_s	ft ³	.004704, .01216, .0192
ΔP_{so}	psia	.004704, .01216, .0192
ΔP_{sro}	psia	.001764, .00456, .0072
ΔP_{sr}	psia	.0013
ΔP_{sv}	psia	.004704, .01216, .0192
ΔP_{dc}	psia	.004764, .01216, .0192
ΔP_{dro}	psia	.001764, .00456, .0072
ΔP_{dr}	psia	.0013
ΔP_{dv}		

<u>Test, psia</u>	<u>Method</u>	<u>Relative error</u>	<u>Percent error</u>
14.7	absolute reference	.14202 .08466	14.2 8.47
38	absolute reference	.13538 .08403	13.5 8.40
60	absolute reference	.13410 .07820	13.4 7.82

323BL 03 03-20-74 23.074 LEAK RATE TEST SEGMENT ONE

53 PDREFX EQL AVALUE+H095

54 *

55 TRD01 EQL AVALUE+H095

56 TRD02 EQL AVALUE+H102

57 TRD03 EQL AVALUE+H103

58 TRD04 EQL AVALUE+H116

59 TRD05 EQL AVALUE+H084

60 TRD06 EQL AVALUE+H115

61 TRD07 EQL AVALUE+H085

62 TRD08 EQL AVALUE+H086

63 TRD09 EQL AVALUE+H087

64 TRD1J EQL AVALUE+H056

65 TRD1I EQL AVALUE+H089

66 TRD12 EQL AVALUE+H090

67 TRD13 EQL AVALUE+H091

68 TRD14 EQL AVALUE+H113

69 TRD15 EQL AVALUE+H092

70 TRD16 EQL AVALUE+H093

71 TRD17 EQL AVALUE+H094

72 TRD18 EQL AVALUE+H114

73 *

74 XPD01 EQL AVALUE+H111

75 XSTRH EQL AVALUE+H112

76 XPDG1 EQL AVALUE+H106

77 XSTRH1 EQL ADATA+H112

78 XPDG2 EQL AVALUE+H059

79 CFN2X EQL AVALUE+T078

80 *

81 BARRHX EQL AVALUE+F125

82 DFSRHX EQL AVALUE+F101

83 DPDREHX EQL AVALUE+H100

84 PSOPRX EQL AVALUE+H077

85 PSONLHX EQL AVALUE+H077

86 PANFUX EQL IFNUMBER#214

87 NUM EQL ATNOS

88 LEAVE PAL

CDNO 415

89 C

90 C VARIABLE IFLAG IS THE PROGRAM OPTION NUMBER, THE OPTION

91 C NUMBER IS SET VIA NUMBER (OPERATOR CONSOLE) WHEN DEMANDING

92 C THE LEAK RATE TEST.

93 C

IFLAG=0 = NORMAL OPERATION; (SET BY PROGRAM)

94 C IFLAG=1 * REINITIALIZE

CDNO 66

95 C IFLAG=3 * REINITIALIZE, SETTING TIME TO 0.

CDNO 67

96 C IFLAG=4 * MINIMUM EDIT SELECTED

97 C IFLAG=5 * CURRENT EDIT SELECTED

98 C IFLAG=6 * 24HR EDIT SELECTED

99 C IFLAG=8 * SET BY PROGRAM IF RTD HAS ERROR

CDNO 68

100 C (PROGRAM WILL ENTER WAIT STATE FOR

CDNO 69

101 C OPERATOR ACTION AT CONSOLE)

CDNO 70

102 C IFLAG=9 * ABORT PROGRAM

CDNO 71

3238L 03 03-20-24 23.024 LEAK RATE TEST SEGMENT ONE

C0NO 72

```
105 C
106 1 IF(PANFUD,NE,1)PPIOF GO TO 25
107 IF(TUNITD,EO,0) GO TO 25
108 IFLAG = NOPTC
109 IUNIT = TUNITD
110 TUNITD = 0
111 IF(IFLAG,EO,1) GO TO 2
112 IF(IFLAG,EO,3) GO TO 15
113 IF(IFLAG,EO,9) GO TO 14
114 IF(IFLAG,EO,4) GO TO 16
115 IF(IFLAG,EO,5) GO TO 17
116 IF(IFLAG,EO,6) GO TO 19
117 GO TO 9
118 14 CALL BEGQUE (NTA)
119 WRITE(NTA,1002)
120 CALL ENDOUE (NTA)
121 1002 FORMAT(1H0,37H ILRT TERMINATED BY OPERATOR REQUEST.)
122 NUR = 1
123 CALL TPF02
124 16 IEDIY = 1
125 CALL BEGQUE (NTA)
126 WRITE(NTA,1005)
127 CALL ENDOUE (NTA)
128 1005 FORMAT(1H0,38H ILRT MINIMUM OUTPUT SELECTED.)
129 IFLAG = 0
130 IF(NUM,NE,2) CALL TPF02
131 GO TO 13
132 17 IEDIT = 2
133 CALL BEGQUE (NTA)
134 WRITE(NTA,1006)
135 CALL ENDOUE (NTA)
136 1006 FORMAT(1H0,35H ILRT CURRENT HOUR OUTPUT SELECTED.)
137 IFLAG = 0
138 IF(NUM,NE,7) CALL TPF02
139 GO TO 13
140 18 IEDIT = 3
141 CALL BEGQUE (NTA)
142 WRITE(NTA,1007)
143 CALL ENDOUE (NTA)
144 1007 FORMAT(1H0,34H ILRT LATEST 24HR OUTPUT SELECTED.)
145 IFLAG = 0
146 IF(NUM,NE,7) CALL TPF02
147 GO TO 13
148 19 CALL BEGQUE (NTA)
149 WRITE(NTA,1000)
150 CALL ENDOUE (NTA)
151 1000 FORMAT(1H0,33H ILLEGAL OPTION OF LEAK RATE TEST.,/
152      1H*,47HDEMAND AGAIN WITH EITHER OPTION 1,3,4,5,6 OR 9.)
153 IFLAG = 0
154 IF(NUM,NE,7) CALL TPF02
155 GO TO 13
156 ITNTH = 0
```

348L 03 0320-74 23,074 LEAK RATE TEST SEGMENT ONE

```
157 GO TO 18
158 ? NTH = 5
159 16 CONTINUE
160 NUM = ?
161 CALL BEGQUE (NTA)
162 WRITE(NTA,1003) IFLAG
163 CALL ENDOUE (NTA)
164 1003 FORMAT(1H0,2H4) IFLY INITIALIZED. OPTION ,12,1F,1
165 IEDIT = 1
166 N = 0
167 DO 5 I=1,26
168 WTCOR(I) = 0.0
169 DO 5 J=1,2
170 RATE(J,I) = 0.0
171 CON(J,I) = 0.0
172 STDY(J,I) = 0.0
173 5 CONTINUE
174 15 CALL INHIB.
175 IONTIM = 27.5*60.02, - 27.0
176 IDELAY = TIME+TIME/7200*7200
177 IDELAY = IONTIM*IDELAY
178 IFFIDELAY(LT,0) IDELAY = IONTIM*IDELAY
179 CALL PERMIT
180 CALL DEYGI TL,IDELAY
181 GO TO 1
182 25 N = N+1
183 IFIRST = .T.FUE;
184 30 TREAD( 1) = TRD01
185 TREAD( 2) = TRD02
186 TREAD( 3) = TRD03
187 TREAD( 4) = TRD04
188 TREAD( 5) = TRD05
189 TREAD( 6) = TRD06
190 TREAD( 7) = TRD07
191 TREAD( 8) = TRD08
192 TREAD( 9) = TRD09
193 TREAD(10) = TRD10
194 TREAD(11) = TRD11
195 TREAD(12) = TRD12
196 TREAD(13) = TRD13
197 TREAD(14) = TRD14
198 TREAD(15) = TRD15
199 TREAD(16) = TRD16
200 TREAD(17) = TRD17
201 TREAD(18) = TRD18
202 IF (.NOT.IFFST) GO TO 25
203 VS = 115000,
204 VD = 154476,
```

205 C
206 C *-----*
207 C *
208 C ***GET PPHIVOL FROM MOISTURE ANALYSIS. THIS ROUTINE HAS BEEN CODED FOR NO 457

CDMO 454

CDMO 455

CDMO 456

CDMO 457

3238L 03 03:20:24 234.074 LEAK RATE TEST SEGMENT ONE

```
209 C   FOR EXECUTION ON AN IBM 370, ON THE CAPACITV MUST SEE A SEPERATE SCDIO 456
210 C   PROGRAM EXECUTED 2.5 MIN PRIOR TO LEAK RATE FAIR PROGRAM SCDIO 459
211 C   SCDIO 460
212 C   SCDIO 461
213 C   SCDIO 462
214 C   SCDIO 463
215 C   I = 1
216      XSTFHP = XSTRM
217      SC IF(XSTRMNE,XSTFHP) GO TO 40
218      IF EQU(XSTFHP,27) GO TO 51
219      IF EQU(XSTFHP,23) GO TO 51
220      CALL DLYCJ(115)
221      IF(PARFUN,NE,NR0) GO TO 50
222      IFTIONID,EQ,0, GO TO 50
223      IUNITD = 0
224      CALL BEGQUE(INTA)
225      WRITE(INTA,1004)
226      CALL ENDQUE(INTA)
227      GO TO 50
228      SI CALL BEGQUE(INTA)
229      WRITE(INTA,2000)
230      CALL ENDQUE(INTA)
231      2000 FORSAY1H0,43H LR1T ABORTED, STREAM SELECTED SENSOR BAD.
232      CALL TPF62
233      46 XSTMP = XSTRM
234      TDECKY = 110
235      CALL DLYCJ(11,DELAY)
236      TPF62(TPF62,110) GO TO 41
237      IF(IUNITD,NE,0) GO TO 61
238      IUNITD = 0
239      CALL BEGQUE(INTA)
240      SETP(INTA,3004)
241      CALL ENDQUE(INTA)
242      INPUT FORPATTING,47E-10RT THAT NOT BE DEMANDED WHILE GATHERING DATA.
243      41 CALL ANALYZE(XCODE,XSTRM,XRDG1,XRDG2)
244      1(CNAME,2) GO TO 49
245      TREAD(1) = TR001
246      TREAD(2) = TR002
247      TREAD(3) = TR003
248      TREAD(4) = TR004
249      TREAD(5) = TR005
250      TREAD(6) = TR006
251      TREAD(7) = TR007
252      TREAD(8) = TR008
253      TREAD(9) = TR009
254      TREAD(10) = TR010
255      TREAD(11) = TR011
256      TREAD(12) = TR012
257      TREAD(13) = TR013
258      TREAD(14) = TR014
259      TREAD(15) = TR015
260      TREAD(16) = TR016
```

3238L 03 0320574 23,074 LEAK RATE TEST SEGMENT ONE

```

261      TREN(17) = TRD17
        TPEND(16) = TRADIO
        PSREF = PSREFX
        PEREF = PEREFX
        BARFD = BARFDX
        DPSREF = DPSREFX
        DPREF = DPREFX
        PSURR = PSURRX
        PGULD = PGULDX
265      CFNZ = CFNZY
        CFNP = 0,0
266      ISAVE = ISIRE
267      45 IF(1,EO,5) GO TO 12
268      I = 1*
269      GO TO 502.
270      CONTINUE
271      C.
272      IT'S ASSUMED THAT ERROR EXISTS IF BOTH PTD MEASUREMENTS
273      IN A GIVEN AREA DIFFER BY MORE THAN 2 DEG F
274      C.
275      12
276      C.
277      C.
278      DO 60 12,0
279      C*** CHECK PTD READINGS IN EACH ZONE FOR ERRORS
280      C   IT'S ASSUMED THAT ERROR EXISTS IF BOTH PTD MEASUREMENTS
281      C   IN A GIVEN AREA DIFFER BY MORE THAN 2 DEG F
282      C
283      85 CONTINUE
284      DO 60 12,0
285      K = 1,2
286      KZ = KZ
287      IF (TREAD(K),EQ,0.0) TREAD(K),EQ,0,) GO TO 60
288      DZ = DZ(TREAD(K))-TREAD(K))
289      IF (DZ.LT.EPSDN) GO TO 80
290      IFLAG = E
291      CALL SEGON(NTIA)
292      WRITE(NTA,*) TNAME(K),TRDNE(K)
293      701 FORMATTING OF ENTRY INDEX, A3,4, OR ,A2,7H IS BAD,/
294      10X,7HOPERATOR ACTION REQUIRED TO SET BAD VALUE TO 0,/
295      310X,4HREMOVE POINT FROM SCAN AND USING ENTER VALUE,/
296      140X,2HENTRIES L FOR RAD RD,*/,
297      $10X,5HAFTER FIXUP, SET IFLAG=0 DEMAND OPTION ZERO OF PROGRAM,/,/
298      $10X,5HETO PESUME PROGRAM, OR SET IFLAG=9 DEMAND OPTION NINE OF PR
299      $,24HGRAN) TO ABORT PROGRAM, ,/
300      WRITE(NTA,7C)
301      CALL ENDOUT(NTIA)
302      703 FORMATTING,6X,14H-1-RD RDG,7)
303      DO 73 J=1,1
304      CALL SEGON(NTA)
305      WRITE(NTA,7C) RTDNM(1),TRAD(J)
306      CALL ENDOUT(NTIA)
307      702 FORMATTING,3,2X,F8,2)
308      73 CONTINUE
309      C
310      C   NOW GO TO WAIT STATE UNTIL OPERATOR CHANGES IFLAG TO A
311      C   VALUE OTHER THAN 6
312      C

```

3238L 03 03-20-24 23.074 LEAK RATE TEST SEGMENT ONE

313 74 IF(IFLAG,0,0) GO TO 14
314. IF(IFLAG,0,0) GO TO 30
315 CALL BEGQUE (NTA)
316 WRITE(NTA,2001)
317 CALL ENDOUE (NTA)
318 1001 FORMAT(1H0,43HDEMAND OPTION 0 TO CONTINUE LEAK RATE TEST,/,
319 \$ 1H ,32HOR OPTION 9 TO ABORT THE PROGRAM)
320 CALL DEVIN (1,60)
321 IF(PANFUN,NE,APRIO) GO TO 74
322 IF(IUNITD,EG,0) GO TO 74
323 IFLAG = NOPTC
324 IUNIT = IUNITD
325 IUNITD = 0
326 IF(RST = .FALSE.,
327 GO TO 74
328 80 CONTINUE
329 C
330 C STORE RTD READINGS INTO OUTPUT ARRAY
331 DO E I=1,16
332 RTD(I,N) = TREAD(I)
333 8 CONTINUE
334 C
335 C **** START PROGRAM
336 C
337 C STORE CLOCK TIME (HOURS)
338 TIME = FLOAT(TISAVE)/7200.
339 IF(NTM,EG,1) TIME = FLOAT(N-1)
340 C
341 C IF EITHER RTD IN THE CONTAINMENT AREA IS 0, IGNORE IT IN
342 C COMPUTING AVERAGE TEMPERATURE
343 TAVER(1) = (TREAD(1)+TREAD(2))/2.0
344 TS = TAVER(1)*THTC(1)
345 IF (TREAD(1),EG,0,) TS=TREAD(2)
346 IF (TREAD(2),EG,0,) TS=TREAD(1)
347 SVOT = 0.0
348 DO 10 I=2,9
349 K = 2*I
350 KK = K-1
351 TAVER(1) = (TREAD(K)+TREAD(KK))/2.0
352 IF (TREAD(K),EG,0,) TAVER(1) = TREAD(KK)
353 IF (TREAD(KK),EG,0,) TAVER(1)=TREAD(K)
354 10 SVOT = SVOT+TS(1)/TAVER(1)
355 TD = 1.0/SVOT
356 C
357 C STORE TOTAL PRESSURES AND REFERENCE VOLUMES OF VALUES (PSIA)
358 C
359 PS = PSUPR
360 PR = PRULR
361 DPSR = DPSREF
362 DPDR = DPDRREF
363 C
364 C CONVERT CFN2 TO SCFN2 AND THEN TO WT-M2 BLEED ADDED

CDNO 505
CDNO 507
CDNO 508
CDNO 509
CDNO 510
CDNO 511
CDNO 512
CDNO 513
CDNO 514
CDNO 515

CDNO 517
CDNO 518
CDNO 519
CDNO 520
CDNO 521
CDNO 522
CDNO 523
CDNO 524
CDNO 525
CDNO 526
CDNO 527
CDNO 528
CDNO 529
CDNO 530

CDNO 532
CDNO 533
CDNO 534

323BL 03 03-20-74 23,074 LEAK RATE TEST SEGMENT ONE

```
365 C
366 HTNZ = CFN2*20.73527*PI/14.6964927*(TDV460)
367 C ARRAY PPHV IS PPM BY VOLUME - FIND VAPOR PRESSURES (FSIA) CDNO 539
368 C
369 PSV = 0; CDNO 540
370 DO 15 I=1,3 CDNO 541
371 15 PSV = PSV + (PPHV(I,N)*WATHT(I)*PS)/(1.E6+PPHV(I,N)) CDNO 542
372 FDV = 0; CDNO 543
373 DO 20 I=2,5 CDNO 544
374 20 PDV = PDV + (PPHV(I,N)*WATHT(I)*PDT/(1.E6+PPHV(I,N))) CDNO 545
375 C
376 C *COMPUTE NEW POINTS CDNO 546
377 DEWPTS = TSL(PSV) CDNO 547
378 DEWPTD = TSL(PDV) CDNO 548
379 C
380 C REFERENCE PRESSURES CDNO 549
381 C
382 PSR = PSREF CDNO 550
383 PCR = PDREF CDNO 551
384 C
385 C STORE BAROMETRIC PRESSURE (IN HG) CDNO 552
386 BARUM = BARRD CDNO 553
387 C
388 CALL SEGMENT (29,21) CDNO 562
389 END CDNO 563
592 * THE FOLLOWING SYSTEM SYMBOLS HAVE BEEN USED:
      * NTA, SEGMENT, ENDSUB, BEGOUT, IUNITD, TIME, NOPTC CDNO 567
```

323BL 03 03-20-14 23,107 MASS

1 X CHASS HASS
2 C
3 C FOR FITZPATRICK
4 C SUBROUTINE HASS
5 C
6 C
7 C C664
8 C C664
9 C C664
10 C C664
11 C C664
12 C C664
13 C C664
14 C C664
15 C COMMON /OUTPUT/ RTD(1:8,26),
16 C XTYPE(26), UNIT,
17 C COMMON /DATA/ PS,
18 C PVA,
19 C DNR,
20 C PSR,
21 C DEWPTS,
22 C COMMON /RESULT/ RATE(2,26),
23 C YMASS(2,26), PEAR(26),
24 C COMMON /UNIT/ PSD,
25 C PVO,
26 C PPOD,
27 C NM,
28 C
29 C DOUBLE-PRECISION XTME,YMASS,DMDT,
30 C PDV,PSR,FDR,TSD,VS,VDC,PSO,PSV,PSRO,
31 C DDPROXYCS,YMD,TRATECON,STDMTPAR,WNCGR,WTCR,WKA
32 C DOUBLE PRECISION LEAKS,LEAKD,TRAV,CONV1,CONV2,R
33 C
34 C CONSTANTS
35 C CCNV2=27.70 INCHES H20/PSIA (FOR USE IF NEEDED)
36 C GAS-CONSTANT R=33.35 FT-LB/LB-F
37 C
38 C DATA CCNV1,CCNV2,R/164D3,1277D27,5335D27
39 C
40 C COMPUTE-MASSES-OF-AIR-BY-PERFECT-GAS-LAW
41 C
42 C YMASS(2,1)=1PD-PSV*VS*CCNV1/R/(TS+460.)
43 C YMASS(2,2)=1PD-PSV*VS*CCNV1/R/(TD+460.)
44 C YMASS(3,1)=YMASS(1,1)+YMASS(2,1)
45 C
46 C COMPUTE-MASSES-OF-AIR-BY-REFERENCE-VOLUME-METHOD
47 C FIRST COMPUTE DIFFERENTIAL LEAKAGE RATES
48 C DPSR,DPGRO,PSO ARE IN-INCHES-H20--USE CONV2
49 C
50 C IF TRAD<0.1 GO TO 50
51 C TRAD = (TS0+460.)/(TS+460.)
52 C PLEAKS = (DPGRO*PSV0+PSV0*TRAD)/(PSV0+PSV0)

3230L 03 03-20-74 23,107 MASS

53 TRAT = (TDD+460.)/ (TDD+460.)
54 RLEAKD = (PDD*TRAT-PPURO-PDV0+PDV4TRAT)/(PDD-PDV0) CDMO 212
55 C CDMO 213
56 YMASS(4,N) = YMDS + (1.0-RLEAKD) CDMO 214
57 YMASS(5,N) = YMCD + (1.0-RLEAKD) CDMO 215
58 YMASS(6,N) = YMASS(4,N) + YMASS(5,N) CDMO 216
59 RETURN CDMO 217
60 C CDMO 218
61 50 YMASS(4,N) = YMASS(1,N) CDMO 219
62 YMASS(5,N) = YMASS(2,N) CDMO 220
63 YMASS(6,N) = YMASS(3,N) CDMO 221
64 RETURN CDMO 222
65 C CDMO 223
66 END CDMO 224
67 C CDMO 225

323AL P3 03-20-74 23.110 MASS

67 C CURFIT CURFIT
68 C
69 C FOR FITZPATRICK
70 C SUBROUTINE CURFIT
71 C
72 C
73 C***
74 C***
75 C***
76 C***
77 C***
78 C***
79 C***
80 C***
81 COMMON /OUTPUT/ RTD(18,26), FPHV(5,26), OUT(12,26),
82 \$ XTIME(26), IUNIT, FUH, XSTRMR A
83 COMMON /DATA/ PS, FD, PSV,
84 \$ PCV, TS, TD, DPSR, A
85 \$ DFDR, VS, VD, TYME, B
86 \$ PSR, PDR, EARDH, DERPTD, C
87 \$ DEWPTS, HTN2, WTCOR(26), WTN20 D
88 COMMON /RESULT/ RATE(2,26), EON(2,26), STDH(2,26),
89 \$ YMASS(6,26), PBAR(26), YM0(2), DMDT(2) A
90 COMMON /INIT/ PSO, PDO, PSVO,
91 \$ PDVO, TSO, TDO, DPSRO, A
92 \$ DFDR0, YPOS, YPDO, IFLAG, B
93 \$ NN, N, IEDIT, NTM, C
94 DOUBLE PRECISION XTIME, YMASS, DMDT, YM0, PS, PD, DPSR, DPDR, PSV, FPHV,
95 \$ PDV, PSA, PDR, TS, TD, VS, VD, PSO, PDO, PSVO, FDVO, TSO, TDO, DPSRO, CONF.
96 \$ DFDR0, YMCS, YM0D, RATE, CON, STEM, PBAR, HTN2, WTCOR, WTN20, VAR
97 C CDNO 229
98 DOUBLE PRECISION SX, SY, SXSD, SXY, AN, DENOM, STD, YD, DECY, X, Y, SLPE, B
99 C CDNO 231
100 DIMENSTON X(26), Y(6,26), SLPE(2),
101 \$ B(2) A
102 EQUIVALENCE (XTIME,X), (YMASS,Y), (DMDT,SLPE), (YM0,B)
103 C CDNO 233
104 C FIT MUST BE ON ELAPSED TIME (XTIME-X(1)) CDNO 234
105 C CDNO 235
106 AN = N
107 DO 200 J=1,2 CDNO 237
108 L = J*3 CDNO 238
109 SX = 0, CDNO 239
110 SY = 0, CDNO 240
111 SXSA = 0, CDNO 241
112 SXY = 0, CDNO 243
113 DO 100 I=1,N
114 XD = X(I)-X(1) CDNO 245
115 YY = Y(L,I)-WTCOR(I)
116 SX = SX + XD CDNO 246
117 SY = SY + YY
118 SXY = SXY + XD*YY

3238L 03 03:20-74 23,110 HASS

```
119      SXSO = SX50 + XD*XD          CDNO 249
120 100  CONTINUE
121      DENOM = AN*SX50-SX*SX          CDNO 251
122      SLPE(J) = TAN*SXY-SY*SXY/DENOM   CDNO 252
123      B(J) = (SY*SX50 - SX*SXY)/DENOM  CDNO 253
124      VAR = 0.0                         CDNO 254
125      DO 150 I=1,N
126      YY = Y(L,I)*WTCOR(I)
127      DELY = YY*(SLPE(J)*(X(1)-X(I))+B(J))
128      VAR = VAR+DELY&DELY
129 150  CONTINUE
130      STD = DSORT(VAR/(AN*2.0))       CDNO 259
131      STDM(J,N) = STD/DSORT((SX50-SX*SX/A))
132      CON(J,N) = STDM(J,N)*(2100,7R(J))-T1,95996*2;372267AN*2;822257AN7AN
133      1)
134 200  CONTINUE
135      RETURN
136      END
```

323AL_03 03/20/74 23.113 MASS

```
137 C ANALYZR ANALYZER
138 C
139 C      FOR FITZPATRICK
140 C      SUBROUTINE ANALYZR (XHODE,XSTRM,XRDG1,XRDG2)
141 C*****SUBROUTINE ANALYZR*****
142 C*****CONVERTS MOISTURE ANALYZER READINGS TO PPM BY VOL*****
143 C***  
144 C***  
145 C***  
146 C***  
147 C***  
148 C***  
149 COMMON /OUTPUT/ RTD(18,26); PTHV(5,26); OUT(12,26);
150      S XTIME(26); IUNIT; NDM; XSTRM; A
151      COMMON /DATA/ PS; PD; PSV;
152      S PUV; TS; TD; DPSR; A
153      S DPDR; VS; VP; TYME; B
154      S PSP; PDR; BAROM; DEWPTD; C
155      S DEWPTS; WTN2; WTCOR(26); WTN20; D
156 COMMON /RESULT/ RATE(6,26); CON(2,26); STDH(2,26); A
157      S YMASS(6,26); YHO(2); DMDT(2); A
158 COMMON /INIT/ PSO; PDI; PSVO; A
159      S PDVO; TSO; TDO; DPSRO; B
160      S DPDR0; YMOS; YMOD; IFLAG; B
161      S NN; V; IEDIT; NTM; C
162 DOUBLE PRECISION XTIME,YMASS,DMDT,YHO,PS,PD,DPSF,DPDR,PSV,PPMV,
163      S PDV,FSR,PDR,TS,TI,VS,VD,PSO,FDO,PSVO,PDVO,TSO,TDO,DPSRO;
164      S DPDR0,YMOS,YMOD,FADE,CON,STDH,PBAR,WTN2,FTCOP,WTN20,VAR
165 C
166 C
167 C      IF XHODE=2(MA, BOTH ANALYZERS ARE OPERATING
168 C          ANALYZER 101 MONITORS THE 4 DRY WELL STREAMS
169 C          ANALYZER 102 MONITORS THE 4 DRY WELL STREAMS
170 C          B THROUGH E CONSECUTIVELY
171 C      IF XHODE=3(MA, ONLY ANALYZER 101 IS OPERATING, MONITORING
172 C          ALL 5 STREAMS (A-E) CONSECUTIVELY
173 C      IF XHODE=4(MA, ONLY ANALYZER 102 IS OPERATING, MONITORING
174 C          ALL 5 STREAMS (A-E) CONSECUTIVELY
175 C
176 C      IF XSTRM = 14 MA, STREAM A IS BEING MONITORED
177 C      IF XSTRM = 18 MA, STREAM B IS BEING MONITORED
178 C      IF XSTRM = 22 MA, STREAM C IS BEING MONITORED
179 C      IF XSTRM = 26 MA, STREAM D IS BEING MONITORED
180 C      IF XSTRM = 30 MA, STREAM E IS BEING MONITORED
181 C
182 C      IT IS ASSUMED THAT THE CONVERSION FROM XSTRM TO PPHV IS LINEAR
183 C      XRDG1 = MA SIGNAL FROM ANALYZER 101
184 C      XRDG2 = MA SIGNAL FROM ANALYZER 102
185 C
186 C      ** CONVERT XHODE TO IHODE INTEGER SIGNAL
187 C          AND XSTRM TO ISTRM
188 C
```

J23BL.03 03:20h-74 23.113 MASS

```
189    IF PODE = 0                               CDDO 617
190    IF (IMODE,GT,36) AND (XMODE,LT,44) IMODE=1   CDDO 618
191    IF (IMODE,GT,26) AND (XMODE,LT,34) IMODE=2   CDDO 619
192    IF (IMODE,GT,16) AND (XMODE,LT,24) IMODE=3   CDDO 620
193    IF (IMODE,GT,0) GO TO 5
194    PODE = IFIX((XMODE-15)/10,)                CDDO 621
195    IF (IMODE,GT,3) IMODE=3                  CDDO 622
196    IF (IMODE,LT,1) IMODE=1                  CDDO 623
197    CALL BEQUE(NTA)
198    WRITE(NTA,101) XMODE,IMODE
199    CALL ENDOUE(NTA)
200    101 FORMAT(1H0,3WH0ISTURE ANALYZER MODE READING BAD ,F8.2,/)
201    $ 2X,?3WH0DE INDICATOR SET TO ,I2)
202    E CONTINUE
203    C
204    ISTRM = 0
205    IF (XSTRM,GT,13) AND (XSTRM,LT,15) ISTRM=1   CDDO 628
206    IF (XSTRM,GT,17) AND (XSTRM,LT,19) ISTRM=2   CDDO 629
207    IF (XSTRM,GT,21) AND (XSTRM,LT,23) ISTRM=3   CDDO 630
208    IF (XSTRM,GT,25) AND (XSTRM,LT,27) ISTRM=4   CDDO 631
209    IF (XSTRM,GT,29) AND (XSTRM,LT,31) ISTRM=5   CDDO 632
210    IF (XSTRM,GT,0) GO TO 8
211    ISTRM = IFIX((XSTRM-8,0)/4,0)               CDDO 633
212    IF (XSTRM,GT,32) ISTRM=5
213    IF (XSTRM,L,1,12) ISTRM=1                  CDDO 634
214    CALL DEQUEUE(NTA)
215    WRITE(NTA,102) XSTRM,ISTRM
216    CALL ENDOUE(NTA)
217    100 FORMAT(1H0,4WH0ISTURE ANALYZER STREAM INDEX READING BAD ,F8.2,/
218    $ 2X,?0HSTREAM INDEX SET TO ,I2)
219    E CONTINUE
220    C
221    20 CONTINUE
222    IF (IMODE,GT,1) GO TO 30
223    PPHV(1,N) = XRDG1
224    PPHV(ISTRM,N) = XRDG2
225    30 TO 50
226    C CONTINUE
227    30 CONTINUE
228    IF (IMODE,EO,2) XDEXRDG1
229    IF (IMODE,EO,3) XDXRDG2
230    PPHV(ISTRM,N) = XD
231    50 CONTINUE
232    RETURN
233    END
* THE FOLLOWING SYSTEM SYMBOLS HAVE BEEN USED
* NIA,ENDOUE,REIQUE
```

3238L 63 J3=20=74 23,116 MASS

234 C TSL TSL *
235 C
236 C FOR FITZPATRICK
237 FUNCTION TSL(P)
238 CC*****
239 CC*****
240 CC***
241 C. T GIVEN P SATURATION LINE CONO 519
242 CC***
243 CC*****
244 CC*****
245 DIMENSION A(13) ***
246 DOUBLE PRECISION P
247 DATA A/724.572568,2,1152169,-0.3414474,0,15741642,-0.031329535,
248 13.8650282E-3,-2,4901784E-4,6,d4015591E-6,-8386,0132,2477,7661; CONO 572
249 2=363,44271,25,690978,70,78073813/ CONO 573
250 IF(P<-450,012E4,4
251 2 N=0 00012
252 NN=8 00013
253 TSL=35.157810 00014
254 TPX = 10, *P 00015
255 GOT06
256 4 N=6
257 NN=5
258 TSL=11545.154
259 TPX = P 00017
260 6 DO 5 I=1,NN 00018
261 M=NN 00019
262 XTP = ALOG(TPX) 00020
263 5 TSL=TSL+A(M)*XTP**11 CONO 537
264 100 RETURN 00026
265 END

3238L 03 03-20574 23,102

GEM63'S GEOPAC PAL ASSESSOR

TD	2123
TDO	3523
FINE	2052 • LDA 5646 LDA 5651
VS	2121
T50	3521
TYHE	2135
VD	2131
VS	2131
WCOR	2147
WTN2	2145
WTN20	2233
Z5TRHP	2110
X7HE	2022 FAD 3607 DLD 3630
X7HEY	5716 STA 3632 LDK 3642
VHASS1	5735 STA 5245 LDK 5274
VHASS2	5736 STA 5250 LDK 5276
VHASS3	5737 STA 5253 LDK 5300
VHASS4	5740 STA 5256 LDK 5302
VHASS5	5741 STA 5261 LDK 5304
VHASS6	5742 STA 5264 LDK 5306
VHASS	2725 DLD 5243 DLD 5246 DLD 5254 DLD 5257 DLD 5262
WHO	3501
VHOD	3533
VHOS	3531

3239L 03 03-20-74 23,088 LEAK RATE TEST SEGMENT TWO

1 CLPT(2) LEAK RATE TEST SEGMENT TWO

2 C

3 C

4 C

5 C

6 C

7 C

8 C

9 C

10 C

11 C

12 C

13 C

14 C

15 C

16 C

17 C

18 C

19 C

20 C

21 C

22 C

23 C

24 C

25 C

26 C

27 C

28 C

29 C

30 C

31 C

32 C

33 C

34 C

35 C

36 C

37 C

38 C

39 C

40 C

41 C

42 C

43 C

44 C

45 C

46 C

47 C

48 C

49 C

50 C

51 C

52 C

LEAK RATE TEST SEGMENT TWO

CONTROLLING ROUTINE FOR LEAK RATE TESTS

COMMON /OUTPUT/ RTG(16,26), FPPV(5,26), OUT(12,26), XSTRIP,

COMMON /DATA/ PS, FUH, FSU,

PUV, TS, TDS,

DFDR, VS, VD,

PSR, PDR, TARM,

DEWPTS, HTN2, TCOR(26), HTN20,

COMMON /RESULT/ RATE(2,26), CON(2,26), STEM(2,26),

YASS(6,26), YM(1,2), DM(1,2)

COMMON /INIT/ PSO,

FDO,

PSVO,

DPSRO,

100,

YHGS,

NN,

DOUBLE PRECISION XTINE,YMASS,DMDT,YM0,PSD,DPDR,PSV,FPMV,

PSV,PSR,PDR,TS,VD,VS,PSO,PSV,FDV0,PSO,1DO,DFSRO,

DPDF0,YMC5,TMOD,RATE,CON,STRIPBAR,HTN2,HTCORT,HTN20,VAR

COMMON / 27

COMMON / 29

CDNO 38

CNO 49

CNO 50

CNO 51

CNO 52

CNO 53

CNO 54

CNO 55

CNO 56

CNO 57

CNO 58

CNO 59

CNO 60

CDNO 74

CDNO 75

CDNO 76

CDNO 77

CDNO 78

CDNO 79

CALL HASS
CALCULATE MASS OF AIR IN THE CONTINENTS
CALL HASS

PROGRAM START - ALL SENSOR DATA HAS BEEN SET INTO PROPER:

VARIABLES

3238L 03 03-20-74 23,080 LEAK RATE TEST SEGMENT TWO

58 C		
59 12 IF (N, EQ, 1) GO TO 40	CDNO 81	
55 IF (IFLAG, EQ, 1) GO TO 40	CDNO 82	
56 IF(IFLAG, EQ, 3) GO TO 40	CDNO 83	
57 IF (N, GE, 26) GO TO 15	CDNO 84	
58 GO TO 60		
59 C	CDNO 86	
60 C **COMPRESS DATA AND RESET INITIAL VALUES	CDNO 87	
61 C	CDNO 88	
62 15 CONTINUE	CDNO 89	
63 IFLAG = 0	CDNO 90	
64 N=N+1	CDNO 91	
65 DO 19 I=1,N	CDNO 92	
66 WTCCR(I) = WTCCR(I+1)	CDNO 93	
67 DO 19 J=1,6		
68 YMASS(J,I)*YTRASS(J,I+1)	CDNO 94	
69 19 CONTINUE	CDNO 95	
70 DO 20 I=1,7H	CDNO 96	
71 XTIME(I) = XTIME(I+1)	CDNO 97	
72 DO 20 J=1,2	CDNO 98	
73 RATE(J,I) = RATE(J,I+1)	CDNO 99	
74 CON(J,I) = CON(J,I+1)	CDNO 100	
75 STDH(J,I) = STDH(J,I+1)		
76 20 CONTINUE	CDNO 102	
77 DO 21 I=1,N	CDNO 103	
78 DO 21 J=1,53	CDNO 104	
79 OUT(J,I) = OUT(J,I+1)		
80 21 CONTINUE	CDNO 106	
81 DO 22 I=1,N	CDNO 107	
82 DO 22 J=1,7M	CDNO 108	
83 RTD(J,I) = RTD(J,I+1)	CDNO 109	
84 22 CONTINUE	CDNO 110	
85 DO 24 I=1,N		
86 DO 24 J=1,5	CDNO 111	
87 PPMV(J,I) = PPMV(J,I+1)	CDNO 112	
88 24 CONTINUE	CDNO 113	
89 DPSRD = OUT(7,1)	CDNO 114	
90 DPDRD = OUT(8,1)	CDNO 115	
91 PSO = OUT(1,1)	CDNO 116	
92 PDO = OUT(2,1)	CDNO 117	
93 TSO = OUT(5,1)	CDNO 118	
94 TCO = OUT(6,1)	CDNO 119	
95 PSVO = OUT(3,1)	CDNO 120	
96 PDVO = OUT(4,1)	CDNO 121	
97 WTNDO = OUT(13,1)	CDNO 122	
98 YMOS = YMSS(1,1)	CDNO 123	
99 YMOD = YMSS(2,1)		
100 GO TO 60	CDNO 124	
101 C	CDNO 125	
102 C SET INITIAL VALUES OF VARIABLES IF N=1	CDNO 126	
103 C OR IF IFLAG = 1 OR 3	CDNO 127	
104 C	CDNO 128	
	CDNO 129	

1238L 03 03-20-74 23,088 LEAK RATE TEST SEGMENT TWO

```

105    40 CONTINUE
106    DO 45 I=1,13
107      OUT(I,1) = OUT(I,N)
108    45 CONTINUE
109      XTIME(1) = XTIME(N)
110      IF(IFLAG.EQ.3) XTIME(1)=0.
111      IFLAG = 0
112      DO 46 J=1,3
113        YMASS(J,1)=YMASS(J,N)
114        YMASS(J+3,1)=YMASS(J,N)
115    46 CONTINUE
116      YM0D = YMASS(2,N)
117      YM0S = YMASS(1,N)
118      P50 = P5
119      P00 = PD
120      T50 = TS
121      T00 = TD
122      PSV0 = PSV
123      P0V0 = PDV
124      DPSR0 = DPDG
125      DPDR0 = DDDR
126      WTN20 = WTN2
127      HTCOR(1) = 0.0
128    C
129    60 CONTINUE
130      HTCORNT = HTN20-WTN2
131    C
132    C   IF TEST HAS LESS THAN 3 RODS ONLY THE CONTAINMENT MASS
133    C   IS COMPUTED AND PRINTED
134    C   IF (N,LT,3) GO TO 64
135    C   GO TO 65
136    64 NN = 2
137      CALL SEGMENT(29,3)
138    C
139    65 CALL CURFIT
140    C
141    C   COMPUTE LEAKAGE RATES (FRACTION OF CONTAINED MASS PER 24 HRS)
142    C
143    DO 70 J=1,2
144      RATE(J,N) = DMDT(J)/YH0(J) * (-2400.)
145    70 CONTINUE
146    C
147      NN = 1
148      CALL SEGMENT(29,3)
149    C
150    END
* THE FOLLOWING SYSTEM SYMBOLS HAVE BEEN USED!
* SEGMENT

```

C-211111-1074-1162

CDNO 133
CDNO 134
CDNO 135
CDNO 136
CDNO 137
CDNO 138
CDNO 139
CDNO 140
CDNO 141
CDNO 142
CDNO 143
CDNO 144
CDNO 145
CDNO 146
CDNO 147
CDNO 148
CDNO 149
CDNO 150
CDNO 156
CDNO 157
CDNO 158
CDNO 160
CDNO 161
CDNO 166
CDNO 168
CDNO 169
CDNO 170
CDNO 171
CDNO 173
CDNO 174
CDNO 176
CDNO 179

3238L 03 03-20-74 23:081

GE-632 GE-PAC PAL ASSEMBLER

TRD16	32567	LDA	4370	LDA	4657
TRD17	32570	LDA	4373	LDA	4662
TRD18	31465	LDA	4376	LDA	4665
TBEAD	6030	DST	4315	DST	4320
		DST	4345	DST	4350
		DST	4375	DST	4400
		DST	4626	DST	4631
		DST	4656	DST	4661
		LDK	5652	DLO	5617
		DLO	5613	FAD	5615
TS	2121	DST	5447	DST	5455
TSL	6162	SFB	5757	SFB	5762
TSO	3521				
THY	5752	FMP	5746	DLO	5734
		LOC	5766	LOC	5770
TYME	2135	STA	5430	STA	5440
VD	2133	DST	4407		
VS	2131	DST	4405		
WATHT	5774	FMP	5615	FMP	5750
WTCOR	2147	DST	4223		
WTN2	2145	DST	5570		
WTN20	2233				
XNODE	31465	LDK	4572		
XRDG1	31465	LDK	4574		
XRDG2	32542	LDK	4575		
XSTRH	31465	LDA	4412	FSU	4416
XSTRMA	27725	LDA	4421	LDA	4512
XSTRMP	2110	STA	4413	LDA	4414
XTIME	2022			STA	4513
VHASS	2725				
VHO	3501				
VHOD	3533				
VHOS	3531				

3230L 03 03-20-74 23,096 LEAK RATE TEST SEGMENT THREE

```
1 CLRTO3      LEAK RATE TEST SEGMENT THREE
2 C
3 C          FOR FITZPATRICK
4 CCooooooooooooo
5 CCooooooooooooo
6 CCooo
7 CCooo      LEAK RATE TEST SEGMENT THREE
8 CCooo
9 CCooooooooooooo
10 CCooooooooooooo
11 C  ROUTINE PRINTS INPUT AND OUTPUT VALUES
12 C  TEMPERATURE,RTD, DEG F      - TREAD(18)           CDNO 266
13 C  MOISTURE CONTENT, PPM BY VOL - FPMV(5)           CDNO 267
14 C  TOTAL PRESS,TORUS AND BULB (PSIA)                 PS,PD   CDNO 268
15 C  RFF VOL AND CONTAINMENT (PSIA)                   DPSR,DPDR CDNO 269
16 C  REFERENCE VOLUME PRESS,TORUS,BULB (PSIA)         PSP,PDR  CDNO 270
17 C  DIFFERENTIAL PRESSURES -
18 C  BAROMETRIC PRESS, IN HG      - BAROM             CDNO 271
19 C  LEAKAGE RATE - FRACTION OF CONTAINED            CDNO 272
20 C  MASS PER 24 HOURS          - RATE(5)            CDNO 273
21 C  VARIANCE OF LEAK RATE DATA - VARI(6)           CDNO 274
22 C  STANDARD DEVIATION OF SLOPE - STDH(6)          CDNO 275
23 CCooooooooooooo
24 COMMON /OUTPUT/ RTD(16,26), PP4V(5,26), OUT(12,26),
25 $ XTIME(26), IUNIT, NUM, XSTRMP A
26 COMMON /DATA/ PS, PDT, PSV,
27 $ PDV, TS, TD, DPSR, A
28 $ DPDR, VS, VD, TYME,
29 $ PSR, PDR, BAROM, DEWPTD, C
30 $ DEKPTS, WTN2, HTCOR(26), HTN20 D
31 COMMON /RESULT/ RATE(2,26), CON(2,26), STDH(2,26),
32 $ YMASS(6,26), PBAR(26), YHDT(2) A
33 COMMON /INIT/ PSO, PDO, PSV, DMDT(2),
34 $ PDVO, TS0, TD0, DPSR0, A
35 $ DPDR0, YMOS, YM0D, IFLAG, B
36 $ NN, N, IEDIT, NTH, C
37 DOUBLE PRECISION XTIME, YMASS, DMDT, YM0D, PS,PD, DPSR, DPDR, PSV, PP4V,
38 $ PDV, PSR, PDT, TS, TD, VS, VD, PSO, PDO, PSV0, PDV0, TS0, TD0, DPSR0,
39 $ DPDR0, YMOS, YM0D, RATE, CON, STDH, PBAR, WTN2, HTCOR, HTN20, VAR CDNO 276
40 C
41 INTEGER TIME
42 TIME = XTIME(N)+0.5
43 C
44 TPD = PD*0.5
45 XTIMEX = XTIME(N)
46 CALL BEGOUT(110)
47 WRITE(110,900) IPD,XTIMEX
48 900 FORMAT(1H1,34X,5H***** ,10HQAFLPP-1 ,12A
49 127H PSIA LEAK RATE TEST AFTER ,F6.2,
50 11H HRS *****)
51 C
52 ISYRT = 1 CDNO 277
CDNO 278
CDNO 279
CDNO 292
```

03 03-20-74 23.096 LEAK RATE TEST SEGMENT THREE

```
53      GO TO (1,2,3),IEDIT
54 C
55 C OPTION 1 - PRINT ONLY RATE, CONFIDENCE LEVEL AND MOISTURE
56 C CONTENT OF STREAMS.
57 C
58 1 CONTINUE
59      WRITE(N10,653)
60 653 FORMAT(1H0,10H TOTAL RATE,5X,10H95PCT CONF,5X,10X,38H MOISTURE READI
61 1NG STREAMS - PPHV VOLUME,/2X,9H(PCT/DAY),5X,9H(PCT/DAY),14X,1HA,7X
62 2,1HG,7X,1HC,7X,1HD,7X,1HE)
63      RATE1 = RATE(1,N)
64      RATE2 = RATE(2,N)
65      CON1 = CON(1,N)
66      CON2 = CON(2,N)
67      PPHV1 = PPHV(1,N)
68      PPHV2 = PPHV(2,N)
69      PPHV3 = PPHV(3,N)
70      PPHV4 = PPHV(4,N)
71      PPHV5 = PPHV(5,N)
72      WRITE(N10,954) RATE1,CON1,PPHV1,PPHV2,PPHV3,PPHV4,PPHV5
73 954 FORMAT(1H ,2F10.4,10X,5F10.2)
74      WRITE(N10,955) RATE2,CON2
75 955 FORMAT(1H ,2F10.4)
76      CALL ENDDUE(N10)
77      GO TO 100
78 C
79 C OPTION 2 - PRINT ALL DATA AND CALCULATIONS FOR CURRENT HOUR
80 C (SET ISTART = N AND USE SAME CODE AS OPTION 3)
81 C
82 2 ISTART = N
83 C
84 3 CONTINUE
85      WRITE( N10,908)
86 908 FORMAT(1H ,4X,31H REF,DWG 11825-FM-49A AND FM-18A)
87 C
88      WRITE( N10,901)
89 901 FORMAT(1H0,45X,36H TEMPERATURE (DEG F) 16-1-RTD#/AREA#)
90      WRITE( N10,902)
91      CALL ENDDUE (N10)
92 902 FORMAT(1H ,52HRS 113/8 114/8 103/1 120/1 102/1 119/1 103/
93 $ ,57/2 104/2 105/3 106/3 107/4 108/4 109/5 117/5 110/6
94 $ ,21H 111/6 112/7 116/7.7)
95      DO 10 K=ISTART,N
96      KK = ITIME + N + K
97      CALL BEGQUE (N10)
98      WRITE( N10,915) KK,(RTD(J,K):J=1-18)
99      CALL ENDDUE (N10)
100 915 FORMAT(1X,I2,2X,9F7.2,9F7.2)
101 10      CONTINUE
102 C
103      CALL BEGQUE (N10)
104      WRITE( N10,904)
```

CDNO 295

CDNO 303

CDNO 306
CDNO 307

3238C 03 03-20-74 23.096 LEAK RATE TEST SEGMENT THREE

```
105      CALL ENDOUE (N10)
106      904 FORMAT(1H1,1HRS,9X,BHAVE TEHP,35X,
107          17HPRESSURE,1PSIA),2P1,10HAROMETRIC,/
108          28X,5HTORUS,5X,7HDRYWELL,18X,5HTORUS,
109          328X,7HDRYWELL,20X,BHPRESSURE,133X,27H TOTAL REF VOL DP;
110          47X,24HTOTAL REF VOL DP,10X,5HINCHES HG,7S'/
111          563H (P1-104) (P1-103) (DP1-102) (P1-102) (P1 104) (DP1-
112          6,4H101),/
113          DO 12 K=1STFT,N
114          KK = ITIME - N + K
115          PBARY = PBAF(K)
116          CALL BEGOUE (N10)
117          WRITE(N10,916) KK,OUT(5,K),OUT(6,K),OUT(1,K),OUT(9,K),OUT(7,K),
118          IOUT(2,K),OUT(10,K),OUT(8,K),PBARY
119          CALL ENDOUE (N10)
120          916 FORMAT(1X,I2,3X,2F10.2,5X+2F10.2,F10.4,73X,2F10.2,F10.4,5X,F10.2)
121          12 CONTINUE
122          C
123          CALL BEGOUE (N10)
124          WRITE(N10,907)
125          CALL ENDOUE (N10)
126          907 FORMAT(1H1,15X,19HMOISTURE READINGS,27X,5HTOPUS,23X,7HDRYWELL,/
127          $3X,3HRS,15),26HFM VOLUME FOR STREAMS A-E,15X,
128          $23HVAPOR PRES DEW POINT,5X,23HVAFOR PBES DEW POINT,/
129          36X,45H   A       B       C       D       E,
130          19X,21H (PSI), (DEC F),7X,21H (PSIA) (DEC F),/
131          DO 16 K=1STFT,N
132          KK = ITIME - N + K
133          PPHV1 = PPHV(1,K)
134          PPHV2 = PPHV(2,K)
135          PPHV3 = PPHV(3,K)
136          PPHV4 = PPHV(4,K)
137          PPHV5 = PPHV(5,K)
138          CALL BEGOUE (N10)
139          WRITE(N10,917) KK,PPHV1,PPHV2,PPHV3,PPHV4,PPHV5,OUT(3,K),
140          S      OUT(11,K),OUT(4,K),OUT(12,K)
141          CALL ENDOUE (N10)
142          917 FORMAT(1X,I2,F10.2,4F11.2,F13.4,F13.2,IX,F13.4,F13.2)
143          16 CONTINUE
144          C
145          CALL BEGOUE (N10)
146          WRITE(N10,909)
147          CALL ENDOUE (N10)
148          909 FORMAT(1H1,45X,31HMASS AIR IN CONTAINMENTS - LBS,/
149          $ 40X,13HIDEAL GAS LAW,20X,17HREF VESSEL METHOD,/
150          $ 25X,3HHPG,6X,23HTORUS DRYWELL SUM,12X,
151          $ 23HTORUS DRYWELL SUM,/
152          DO 18 K=1STFT,N
153          KK = ITIME - N + K
154          YMASS1=YMASS1,K)
155          YMASS2=YMASS2,K)
156          YMASS3=YMASS3,K)
```

3238L 07 13-20-71 23,095 LEAK RATE TEST SEGMENT THREE

```
157      YMASS4 = YMASS(4,K)
158      YMASS5 = YMASS(5,K)
159      YMASS6 = YMASS(6,K)
160      CALL BEGQUE (N10)
161      WRITE( N10, 918 ) XK, YMASS1, YMASS2, YMASS3, YMASS4, YMASS5, YMASS6
162      CALL ENDOUE (N10)
163      918 FORMAT(23X,[5.3F11.2,2X,3F11.2])
164      16 CONTINUE
165      C
166      C ** IF LOW PRESSURE TEST, NOW THROUGH
167      C
168      IF (NN.EQ.2) GO TO 100
169      C
170      CALL BEGQUE (N10)
171      WRITE( N10, 910 )
172      CALL ENDOUE (N10)
173      910 FORMAT(1H1,47X,20H INTEGRATED LEAK RATE, // 29X, 15H ABSOLUTE METHOD,
174      & 25X, 17H REF VESSEL METHOD, /
175      214X, 3HHRS, 4X, 9H CALC 24H, 6X, 9H STD DEV , 5X, 10H 95%CT CONF,
176      3          10X, 9H CALC 24H, 6X, 9H SYD DEV , 5X, 10H 95%CT CONF, /
177      418X, 14H LEAK RATE(PCT), 1X, 14H(LBS PER HOUR), 3X, 10H LIMIT(PCT),
178      3 7X, 14H(LIMIT RATE(PCT)), 1X, 14H(LBS PER HOUR), 3X, 10H(LIMIT(PCT))
179      DO 20 I=ISTRT,N
180      J = ITIME + N + I
181      RATE1 = RATE(1,I)
182      RATE2 = RATE(2,I)
183      CON1 = CON(1,I)
184      CON2 = CON(2,I)
185      STD1 = STD(1,I)
186      STD2 = STD(2,I)
187      CALL BEGQUE (N10)
188      WRITE(N10,911) J,RATE1,STD1,CON1,RATE2,STD2,CON2
189      CALL ENDOUE (N10)
190      911 FORMAT(1H- 9X,16F4X,F10.4,F4X,F10.4,F6X,F10.4,F4X,F10.4,F7X,
191      1F10.4)
192      23 CONTINUE
193      C
194      100 CALL INRATBY
195      ICNTIM = 27.5+50.*2, -> 2, 27.0
196      IDELAY = TIME*ETIME/7200)*7200
197      IDELAY = ICNTIM-IDELAY
198      IF (IDELAY.LT.0) IDELAY = ICNTIM+IDELAY
199      CALL PERMIT
200      CALL DLY01 (3, IDELAY)
201      CALL SEGMENT (29,1)
202      END
* THE FOLLOWING SYSTEM SYMBOLS HAVE BEEN USED:
* SEGMENT, ENDOUE, BEGQUE, N10, TIME
```

CDNO 343

CDNO 344

CDNO 345

CDNO 346

CDNO 347

CDNO 348

CDNO 356

CDNO 359

CDNO 360

CDNO 362

J238L.03 DD=20-74 23,096 LEAK RATE TEST SEGMENT THREE

```
1 CLRT03      LEAK RATE TEST SEGMENT THREE
2 C
3 C          FOR KITZPATRICK
4 CCooooooooooooo
5 CCooooooooooooo
6 CCooo
7 CCooo      LEAK RATE TEST SEGMENT THREE
8 CCooo
9 CCooooooooooooo
10 CCooooooooooooo
11 C          ROUTINE PRINTS INPUT AND OUTPUT VALUES
12 C          TEMPERATURE, RTD, DEG F      - TREAD(18)           CDNO 266
13 C          MOISTURE CONTENT, PPM BY VOL - FPMV(5)           CDNO 267
14 C          TOTAL PRESS, TORUS AND BULB (PSIA)      - FS,PD           CDNO 268
15 C          REF VOL AND CONTAINMENT (PSIA)      - EPSR,DPDR        CDNO 269
16 C          REFERENCE VOLUME PRESS, TORUS,BULB (PSIA) - FSP,PDR         CDNO 270
17 C          DIFFERENTIAL PRESSURES -                   CDNO 271
18 C          BAROMETRIC PRESS, IN HG                - BAROM           CDNO 272
19 C          LEAKAGE RATE - FRACTION OF CONTAINED    - RATE(5)          CDNO 273
20 C          MASS PER 24 HOURS                     CDNO 274
21 C          VARIANCE OF LEAK RATE DATA       - VAR(6)          CDNO 275
22 C          STANDARD DEVIATION OF SLOPE     - STDN(6)          CDNO 276
23 C          CCooooooooooooo
24 COMMON /OUTPUT/  RTD(16,26);  PP4V(5,26);  OUT(12,26);
25 $ XTIME(26);   IUNIT;      NUM;      XSTRMP;
26 COMMON /DATA/   PS;        PDI;      PSV;      A
27 $ PDV;         TS;        TD;       DPSR;
28 $ DPDR;        VS;        VD;       TYME;
29 $ PSR;         PDR;      RAROM;    DEWPTD;
30 $ DEWPTS;      WTN2;      WTCOR(26); WTN20;
31 COMMON /RESULT/ RATE(2,26); CON(2,26); STEM(2,26);
32 $ YMASS(6,26); PRAR(26); YH(21);  DHDT(2);
33 COMMON /INIT/   PSO;      PDD;      PSVO;      A
34 $ PEVO;        TSO;      TDD;      DPSRO;
35 $ DPDRO;       YMOS;     YMDD;     IFLAG;
36 $ NN;          N;        IEDIT;    NTH;
37 DOUBLE PRECISION XTIME, YMASS,DHDT, YMO, PS, PD, DPSR, DPDR, PSV, PPMV,
38 $ PDV,PSR,PDR,TS,TD,VS,VJ,PSO,PDD,PSVO,PDV0,TSD,TDD,DPGRO;
39 $ DPDR0,YMOS,YMDD,RATE,CON,STDN,PRAR,WTN2,WTCOR,WTN20,VAR
40 C
41 INTEGER TIME
42 ITIME = XTIME(N)+0.5                                     CDNO 273
43 C
44 IPD = PD+0.5                                         CDNO 287
45 XTIMEX = XTIME(N)
46 CALL BEGQUE(N10)
47 WRITE( N10,900) IPD,XTIMEX
48 900 FORMAT(1H1;34X,6H***** 10HJAENPP-1 ,12A
49 127H PSIA LEAK RATE TEST AFTER ,F6.2,
50 $ 11H-HRS *****)
51 C
52 ISRT = 1                                              CDNO 292
```

3230L 83 03-20-74 23.102

GE-635 GE-PAO PAL ASSEMBLER

5/5

- * COMMON /DATA/ PS_i PD_i PSV,
* \$ PDVi TS_i TD_i DPSR,
* \$ DPDR_i VS_i VD_i TYME,
* \$ PSR_i PDR_i BAROM_i DEWPTD,
* \$ DEWPTS_i WTN2_i HTCOR(26)_i WTN20
* COMMON /RESULT/ RATE(2726), CON(2726), STDH(2726),
* \$ YHASS(6,26), PBARI(25), YHO(25), DHDT(25)
* COMMON /INIT/ PSO_i PDO_i PSVO_i,
* \$ PDVO_i TSO_i TDO_i DPSRO_i,
* \$ DPDR0_i YHOS_i YHOD_i IFLAG,
* \$ NN_i N_i IEDIT_i NTH
* DOUBLE PRECISION XTIME, YHASS, DROT, YHO, PS, PD, DPSR, DPDR, PSV, PPHV,
* \$ PDV, PSR, PDR, TS, VS, VD, PSO, PDO, PSVO, PDVO, TSO, TDO, DPSRO,
* \$ DPDR0, YHOS, YHOD, RATE, CON, STDH, PBAR, WTN2, HTCOR, WTN20, VAR

CDNO 278

000001	14003600	14043577	INTEGER TIME
	623652524	623652524	BRU \$41
	624052524	624052524	CHD OUTPUT
000002	300002107	300002107	\$60 BSS 1095
	0C000C002		RTD EQL \$80+0
	0C000C726		PPHV EQL \$80+468
	0C001332		OUT EQL \$80+728
	0C002022		XTIME EQL \$80+1040
	0C002106		IUNIT EQL \$80+1092
	0C002107		NUM EQL \$80+1093
	0C002110		XSTRMP EQL \$80+1094
	621040524	621040524	CHD DATA
	620220040	620220040	
0002111	300000124	300000124	\$B1 BSS 84
	0C002111		PS EQL \$P1+0
	0C002113		PD EQL \$P1+2
	0C002115		PSV EQL \$P1+4
	0C002117		PDV EQL \$P1+6

00002121	TS	EOL \$R1+8
00002123	TP	EOL \$R1+10
00002125	DPSR	EOL \$R1+12
00002127	DPDR	EOL \$R1+14
00002131	VS	EOL \$R1+16
00002133	VD	EOL \$R1+18
00002135	TYME	EOL \$R1+20
00002136	PSR	EOL \$R1+21
00002140	PDR	EOL \$R1+23
00002142	BAROF	EOL \$R1+25
00002143	DEWPID	EOL \$R1+26
00002144	DEWPTS	EOL \$R1+27
00002145	WTN2	EOL \$R1+28
00002147	WTCOF	EOL \$R1+30
00002233	WTN20	EOL \$R1+82
524442523	624442523	CMD RESULT
625246124	625246124	

002235	300001254	300001254	\$B2 BSS 684
	00002439	RATE	EOL \$R2+0
	00002405	CON	EOL \$R2+104
	00002555	STDW	EOL \$R2+208
	00002725	YMASS	EOL \$R2+312
	00003415	PBAR	EOL \$R2+624
	00003501	YMO	EOL \$R2+676
	00003505	DHDT	EOL \$R2+680
622247111	622247111	CMD INIT	
625020040	625020040		

003511	300000031	300000031	\$B3 BSS 25
	00003511	PSO	EOL \$R3+0
	00003513	PDO	EOL \$R3+2
	00003515	PSVO	EOL \$R3+4
	00003517	PDVO	EOL \$R3+6
	00003521	TSO	EOL \$R3+8
	00003523	TDO	EOL \$R3+10
	00003525	DPSRO	EOL \$R3+12
	00003527	DFDRO	EOL \$R3+14
	00003531	YHOS	EOL \$R3+16
	00003533	YHOD	EOL \$R3+18
	00003535	IFLAG	EOL \$R3+20
	00003536	NN	EOL \$R3+21
	00003537	V	EOL \$R3+22
	00003540	IEDIT	EOL \$R3+23
	00003541	NTM	EOL \$R3+24
003542	300000036	300000036	BSS +63/64+64=
003600	14003601	14040001	\$M1 BRU \$M2

* ITIME = XTIME(N)*0.5

003601	42003537	42077736	\$M2 LDQN
003602	30005675	00042073	LDA \$FXCON
003603	35005676	55042073	MPS \$FXCON+1

3230L_03_03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

003604	44000003	44000003	*	STC 3
003605	41005712	41042105		DLD \$DPCON
003606	74014002	74014002		FHS 2
003607	70302020	70376211		FAD XTIME=273
003610	15045627	05045627		TFR 23
003611	74000027	74000027		FIX 23
003612	34003614	34040002		BTS **2
003613	15013000	05013000		NEG
003614	32005714	32042100		STA ITIME

CDNO 287

*	IPD * PD+0;5			
003615	15005712	41042075		DLD \$DPCON
003616	70002113	70076275		FAD PD
003617	15045627	05045627		TFR 23
003620	74000027	74000027		FIX 23
003621	34003623	34040002		BTS **2
003622	15013000	05013000		NEG
003623	32005715	32042072		STA IPD

*	XTIME=XTIME(N)			
003624	42007537	42077713		LDK N
003625	37005675	00042050		LDA \$FXCON
003626	55005676	55042050		MPY \$FXCON+1
003627	13000003	44000003		STC 3
003630	11302020	41376170		DLD XTIME=273
003631	13005751	33042120		SPB SCRCHT
003632	32005716	32142064		STA XTIME

*	CALL BEGOUE (NIO)			
003633	33000576	33000576		SPB BEGOUE
003634	40022446	40022446		LDK NIO

*	WRITER(NIO,900) IPD,XTIME			
003635	45003645	20040011		LDK \$900
003636	42022446	42022446		LDK NIO
003637	33000561	33000561		SPB \$FBEGR
003640	40005715	40042055		LDK IPD
003641	33001562	33000562		SPB \$FPROW
003642	40005716	40042054		LDK XTIME
003643	33001562	33000562		SPB \$FPROW
003644	33000563	33000563		SPB \$FHLTW

* 900 FORMAT(1H1;34X,6H***** ,10HJA FNPP=1 ,12*

* 127H PSIA LEAK RATE TEST AFTER ,F6;2.

* S 11H HRS *****

003645 14003705 14040040

BRU \$H3

3232L 03

GE-20-76 23.102 GE-635 GE-PAC PAI ASSEMBLER

003626	669C3700	60000000	*	5900	CON 0, 60001000
003627	100010001	00010001			CON 0, 00010001
003650	420C000	14200000			CON 0, 14200000
003651	10007601	40007601			CON 0, 40007601
003652	60002601	40000601			CON 0, 40000601
003653	100062001	00060001			CON 0, 00060001
003654	2425052	12425052			CON 0, 12425052
003655	2425040	12425040			CON 0, 12425040
003656	100020001	00120001			CON 0, 00120001
003657	1240C506	2240506			CON 0, 2244506
003660	350120	23450120			CON 0, 23450120
003661	3230440	13230440			CON 0, 13230440
003662	10000000	10000000			CON 0, 10000000
003663	00000002	20000002			CON 0, 20000002
003664	0030001	00730001			CON 0, 00350001
003665	5050123	10050123			CON 0, 10050123
003666	2240440	22240440			CON 0, 22240440
003667	23042501	23042501			CON 0, 23042501
003670	2262122	2262122			CON 0, 2262122
003671	40052105	20252105			CON 0, 20252105
003672	10052105	10052105			CON 0, 10052105
003673	24652040	24652040			CON 0, 24652040
003674	6243124	20243124			CON 0, 20243124
003675	21231040	21251040			CON 0, 21251040
003676	21404024	21404024			CON 0, 21404024
003727	0043C001	00130001			CON 0, 00130001
003700	10044122	10044122			CON 0, 10044122
003701	24621040	24620040			CON 0, 24620040
003702	12425052	12425052			CON 0, 12425052
003703	12425000	12425000			CON 0, 12425000
003704	7777420	7777420			CON 0, 7777420

CDNO 292

003705	C0005K77	00041772	3H3	LDA 3FXCON#2
003706	22005717	32042011	STA 1STR1	
* 1STR1 = 1				
* GO TO (1,2,3).EDIT				
003707	00001540	000077631	LDA 1EDIT	
003715	3300571	3300571	SP6 1CGOTO	
* 003711	44737775	24737775	TXH 3,7	
003712	14003715	14004003	BRU \$1	
- 003713	14004131	14040216	BRU \$2	
003714	14004133	14040217	BRU \$3	

* OPTION 1 - PRINT ONLY RATE, CONFIDENCE LEVEL AND MOISTURE

3230L.03 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

* CONTENT OF STREAMS.

* 1 CONTINUE

* WRITE(NIO,653)

003715	40003722	40010005	\$1	LDK \$653
003716	42022446	42022446		LDQ NIO
003717	33000561	33000561		SPB \$FBEGH
003720	33000563	33000563		SPB \$FHLTW

* 653 FORMAT(1H0,10HTOTAL RATE,5X,10H95PCT CONF,5X,10X,38HMOISTURE READI

* 1NG STREAMS = PPMV VOLUME,/2X,9H(PCT/DAY),5X,9H(FCT/DAY),14X,1HA,7X

* 2,1H2,7X,1H2,7X,1H2,7X,1H2}

003721	14004013	14040072	3653	GRU \$M4
003722	60000000	60000000		CON 0,60000000
003723	00010001	00010001		CON 0,00010001
003724	14000000	14000000		CON 0,14000000
003725	00120001	00120001		CON 0,00120001
003726	25047524	25047574		CON 0,25047524
003727	21246040	20246040		CON 0,20246040
003730	24440524	24440524		CON 0,24440524
003731	21200000	21200000		CON 0,21200000
003732	40001201	40001201		CON 0,40001201
003733	00120001	00120001		CON 0,00120001
003734	16232520	16232520		CON 0,16232520
003735	20652040	20652040		CON 0,20652040
003736	20647516	20647516		CON 0,20647516
003737	21400000	21400000		CON 0,21400000
003740	40001201	40001201		CON 0,40001201
003741	40002401	40002401		CON 0,40002401
003742	00460001	00460001		CON 0,00460001
003743	23247511	23247511		CON 0,23247511
003744	24652125	24652125		CON 0,24652125
003745	24442440	24442440		CON 0,24442440
003746	24442501	24442501		CON 0,24442501
003747	21044516	21044516		CON 0,21044516
003750	21620123	21620123		CON 0,21620123
003751	25051105	25051105		CON 0,25051105
003752	20246523	20246523		CON 0,20246523
003753	10026440	10026440		CON 0,10026440
003754	24050115	24050115		CON 0,24050115
003755	2542126	2542126		CON 0,25420126
003756	23646125	23646125		CON 0,23646125
003757	23242400	23242400		CON 0,23242400
003760	40000100	40000100		CON 0,40000100
003761	40000401	40000401		CON 0,40000401

0239L 03 JUN 20-74 23.102

GE-635 GE-PAC PAL MHLER

003762	0C112001	00110001	CON 0,00110001
0C3763	12652103	12050103	CON 0,12050103
0C3764	23027504	25027504	CON 0,25027504
003765	23221451	20234451	CON 0,20234451
003766	40001201	40001201	CON 0,40001201
003767	00112001	00110001	CON 0,00110001
003770	12052103	12050103	CON 0,12050103
003771	23027504	25027504	CON 0,25027504
003772	20254451	20254451	CON 0,20254451
003773	40603401	40003401	CON 0,40003401
003774	00011201	00010001	CON 0,00010001
003775	23202060	20200060	CON 0,20200000
003776	40601601	40001601	CON 0,40001601
003777	05012001	0C010001	CON 0,00010001
004000	23403000	20400060	CON 0,20400000
004001	40001601	40001601	CON 0,40001601
004002	230612001	00010061	CON 0,00010001
004003	23623000	20600060	CON 0,20600000
004004	46601601	40001601	CON 0,40001601
004005	0D010001	00010001	CON 0,00010001
004006	21600000	21000060	CON 0,21000000
004007	42001601	40001601	CON 0,40001601
004010	00011001	02010001	CON 0,00010001
004011	21202000	21200070	CON 0,21200000
004012	77777100	77777160	CON 0,77777100

13 RATE1 = RATE(1,N)

004013	42C03537	42077524	\$M4	LDC N
004014	01605675	00041661	LDA	SFXCON
004015	53005700	52041661	MPY	SFXCON+3
004016	41602003	42000053	ST2	3
004017	41202231	41376212	DLO	RATE=4,3
004018	35005751	33041731	SP2	SDWCVT
004019	32005720	32041677	STA	RATE1

14 RATE2 = RATE(2,N)

004022	41302233	41376354	DLD	RATE=2,3
004023	33005751	33041723	SP2	SDRCVT
004024	32005721	32041675	STA	CON1
004025	41302401	41376353	DLD	CON=4,3
004026	33005751	33041720	SP2	SDRCVT
004027	32005722	32041671	STA	CON2

03 131204/4 23.102

GE-635 GE-PAC PAL ASSEC

R

			PPMV1 = PPMV{1,N}
153	42003537	42077564	LDD N
154	32005753	00041641	LDA \$FXCON
155	33005701	55041642	MPY \$FXCON+4
156	44000004	44000004	STD 4
157	41400713	41474655	DLD PPMV-1074
158	33005751	33041711	SPB \$DRCVT
159	32005724	32041663	STA PPMV1
			PPMV2 = PPMV{2,N}
160	41400716	41474654	DLD PPMV-B,4
161	33005751	33041706	SPB \$DRCVT
162	32005725	32041661	STA PPMV2
			PPMV3 = PPMV{3,N}
163	41400720	41474653	DLD PPMV-6,4
164	33005751	33041703	SPB \$DRCVT
165	32005726	32041657	STA PPMV3
			PPMV4 = PPMV{4,N}
166	41400722	41474652	DLD PPMV-4,4
167	33005751	33041700	SPB \$DRCVT
168	32005727	32041655	STA PPMV4
			PPMV5 = PPMV{5,N}
169	41400724	41474651	DLD PPMV-2,4
170	33005751	33041675	SPB \$DRCVT
171	32005730	32041653	STA PPMV5
			ARITETN(0,954) RATE1,CDN1,PPMV1,PPMV2,PPMV3,PPMV4,PPMV5
172	40004101	40040023	LDD 3254
173	42022446	42022446	LDD N10
174	33000561	33000561	SPB \$FBEGW
175	41000720	20041637	LDD RATE1
176	33200562	33000562	SPB \$FPROW
177	43000562	40041637	LDD CON1
178	33000562	33000562	SPB \$FPROW
179	24000524	40041637	LDD PPMV1
180	33000562	33000562	SPB \$FPROW
181	42000525	40041636	LDD PPMV2
182	33000562	33000562	SPB \$FPROW
183	23000526	40041635	LDD PPMV3
184	33000562	33000562	SPB \$FPROW
185	43000527	40041634	LDD PPMV4
186	33000562	33000562	SPB \$FPROW
187	42000528	40041633	LDD PPMV5
188	33000562	33000562	SPB \$FPROW
189	33000563	33000563	SPB \$FHCTW

* 954 FORMAT(1H ;2F10.4;10X;5F10.2)

30L 03

74 23.102

GE-635 RE-PAC PAL AMBLER

04100	11004110	14040010		BRU \$M5
04101	63000000	60000000	\$954	CON 0,60000000
04102	01010001	00010001		CON 0,00010001
04103	11000000	10600000		CON 0,10000000
04104	22414044	22414044		CON 0,22414044
04105	40002401	40002401		CON 0,40002401
04106	22444724	22444024		CON 0,22444024
04107	77777720	77777720		CON 0,77777720

* WRITE(N10,955)-RATE2;CON2

004110	40004121	40040011	\$M5	LDK \$055
004111	42022446	42022446		LDO N10
004112	33002561	33000561		SP2 \$FBEGH
004113	41005721	40041606		LDK RATE2
004114	33002562	33000562		SP2 \$FPROW
004115	40005723	40041606		LDK CON2
004116	33002562	33000562		SP2 \$FPROW
004117	33002563	33000563		SP2 \$FHLTW

* 955 FORMAT(1H,2F10,4)

004120	14004126	14040006		BRU \$M6
004121	56000000	60000000	\$955	CON 0,60000000
004122	00010001	00010001		CON 0,00010001
004123	10000000	10000000		CON 0,10000000
004124	22414044	27414044		CON 0,22414044
004125	77777240	77777740		CON 0,77777740

* CALL ENQUEUE(N10)

004126	33002577	33000577	\$M6	SP2 ENQUEUE
004127	40022446	40022446		LDK N10

* GO TO 100
BRU \$100

004130 14005634 14041504

* OPTION 2 - PRINT ALL DATA AND CALCULATIONS FOR CURRENT HOUR

(SET ISTRT = N AND USE SAME CODE AS OPTION 3)

004131 00003537 00077406
004132 32005717 32041565

2 ISTRT = N

LDA N
STA ISTRT

* 3 CONTINUE

3238L 03 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

* WRITE(NIO,908)

004133	40004140	40040005	\$13	LDK \$905
004134	42022446	"42022446		LDQ NIO
004135	33000551	33000551		SPB \$FBEGW
004136	33000563	33000563		SPG \$FHLTW

* 908 FORMAT(1H ,44X,31HREF,DNG 11R25+FM-49A AND FM+18A)

004137	14004162	14040023	\$908	BRU \$M7
004140	60000000	60000000		CON 0,60000000
004141	00010001	00010001		CON 0,00010001
004142	10000000	10000000		CON 0,10000000
004143	40007601	40007601		CON 0,40007601
004144	40003201	40003201		CON 0,40003201
004145	00370001	00370001		CON 0,00370001
004146	24442506	24442506		CON 0,24442506
004147	13442127	13442127		CON 0,13442127
004150	21620061	21620061		CON 0,21620061
004151	14234062	14234062		CON 0,14234062
004152	15226506	15226506		CON 0,15226506
004153	23226464	23226464		CON 0,23226464
004154	15240440	16240440		CON 0,16240440
004155	21247104	20247104		CON 0,20247104
004156	11043115	10043115		CON 0,10043115
004157	13230470	13230470		CON 0,13230470
004160	20200000	20200000		CON 0,20200000
004161	77777570	77777570		CON 0,77777570

CDNO 295

* WRITE(NIO,901)

004162	40004167	40040005	\$M7	LDK \$901
004163	42022446	42022446		LDQ NIO
004164	33000551	33000551		SPB \$FBEGW
004165	33000563	33000563		SPG \$FHLTW

* 901 FORMAT(1H0,45X,36HTEMPERATURE (DEG F) 16-1-RTD-ZAREA)

004166	14004212	14040024	\$901	BRU \$M8 *
004167	60000000	60000000		CON 0,60000000
004170	00010001	00010001		CON 0,00010001
004171	14000000	14000000		CON 0,14000000
004172	40007601	40007601		CON 0,40007601
004173	40003401	40003401		CON 0,40003401
004174	00440001	00440001		CON 0,00440001
004175	25042515	25042515		CON 0,25042515
004176	24042522	24042522		CON 0,24042522
004177	20252125	20252125		CON 0,20252125
004200	24442440	24442440		CON 0,24442440
004201	12042105	12042105		CON 0,12042105
004202	21620106	21620106		CON 0,21620106
004203	12220040	12220040		CON 0,12220040

3230L 03 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

004204 1303466 10030466 CON 0,10030466
004205 13230455 13230455 CON 0,13230455
004206 24452104 24452104 CON 0,24452104
004207 13227501 13227501 CON 0,13227501
004210 24442501 24442501 CON 0,24442501
004211 77777560 77777560 CON 0,77777560

004212 4004221 40040077 * WRITER N10,9021
004213 42022445 42022446 LDK 5902
004214 31002561 33000561 LDQ N10
004215 33002563 33000553 SPB 5FAGW
SPD FFHLTW

004216 33000577 33000577 CALL ENQUEUE (N10)

SPB ENQUEUE

LDK N10

* 902 FORMATT(1H,52HPRS 11373 11478 10171 12071 11971 1037
* \$ 57H2 104/2 105/3 106/3 107/4 107/5 108/4 109/5 117/5 110/6

004220 14004305 14040055 * 21H 11176 11277 11377,77
004221 63002600 60000000 \$902 BRU EM? CON 0,60000000
004222 34013001 0C110031 CON 0,00010301
004223 12002300 10000000 CON 0,10000000
004224 30540001 00640001 CON 0,00640001
004225 22051123 22051123 CON 0,22051123
004226 10022040 10020040 CON 0,10020040
004227 14235463 14230453 CON 0,14230463
004228 13543040 13634040 CON 0,13634040
004229 12032461 10030451 CON 0,10030451
004232 15027470 15027470 CON 0,15027470
004233 16020061 10020051 CON 0,10020061
004234 14035457 14030457 CON 0,14030457
004235 14220040 14220040 CON 0,14220040
004236 14231060 14231060 CON 0,14231060
004237 13632440 13630440 CON 0,13630440
004240 10032460 10030450 CON 0,10030460
004241 14427461 14427461 CON 0,14427461
004242 10020061 10020061 CON 0,10020061
004243 14234457 14234457 CON 0,14234457
004244 14220040 14220040 CON 0,14220040
004245 14232063 14230063 CON 0,14230063
004246 13602600 13600000 CON 0,13600000
004247 00710001 00710001 CON 0,0071001
004250 14420040 14420040 CON 0,14420040
004251 14230064 14230064 CON 0,14230064
004252 13531040 13631040 CON 0,13631040
004253 1C030460 10030460 CON 0,10030460

P08L_03 03-20-74 23.102

GE-635 GE-PAC PAL ASSEMBLER

04254	15227463	15227453	CON 0.15227463
04255	10020061	10020051	CON 0.10020061
04256	14033057	14033057	CON 0.14033057
04257	14620040	14420040	CON 0.14620040
04258	14230057	14230057	CON 0.14230057
04261	13632040	13632040	CON 0.13632040
04262	10030450	10030450	CON 0.10030450
04263	16027464	16027464	CON 0.16027464
04264	10020061	10020061	CON 0.10020061
04265	14033457	14033457	CON 0.14033457
04266	15227460	15227460	CON 0.15227460
04267	14230467	14230467	CON 0.14230467
04270	13632440	13632440	CON 0.13632440
04271	10030451	10030451	CON 0.10030451
04272	14027466	14027466	CON 0.14027466
04273	00250001	00250001	CON 0.00250001
04274	10020061	10020051	CON 0.10020061
04275	14230457	14230457	CON 0.14230457
04276	15420040	15420040	CON 0.15420040
04277	14230452	14230452	CON 0.14230452
04300	13633440	13633440	CON 0.13633440
04301	10030451	10030451	CON 0.10030451
04302	16027457	16027457	CON 0.16027457
04303	40000100	40000100	CON 0.40000100
04304	77777150	77777150	CON 0.77777150

* DO 10 K=1STFT,N

IHQ LDX 1STRT,J
SH10 STX K,J

CDNO 303

* KK = ITIME + N * K

LDA ITIME

ADD K

SUB N

STA KK

* CALL BEGQUE (N10)

SPB BEGQUE

LDK N10

* WRITE(N10,\$15) KK,(RTD(J,K),J=1,18)

LDK \$915

LDG N10

SPB BEGQUE

LEK KK

SPB BEPROW

LXK 1,4

STX J,4

LDQ K

LDA J

004305	16305717	16341412
004306	16305731	06341423

004307	00005714	00041405
004310	11005731	11041421
004311	31005537	31h77220
004312	22005732	32041420

004313	23000576	23000576
004314	40022446	40022446

004315	40004341	40040024
004316	42022446	42022446
004317	23000561	33000561
004320	40005732	40041412
004321	23000552	33000552
004322	17400001	07400001
004323	16405733	06441410
004324	12005731	42041405
004325	16005733	06041406

1238L_03 03-20-74 23:102

UC-830 UC-FAR FAL FASCHLER

PAGE 10

004326	55005702	550041354	MPY IFXCON+5
004327	44000005	44000005	STG 5
004330	40577757	40573427	I LDK RTD-19,5
004331	33000552	33000562	SPB SFPROW
004332	26400001	26400001	INX 1,4
004333	24437755	24437755	TXR 19,4
004334	30004323	30077767	BTR SM11
004355	33000553	33000563	SPB SFHLTH

CALL ENDOQUE (N10)

004336	33000577	33000577	SPB ENDOQUE
004337	40022446	40022446	LDK N10

* 915 FORMAT(1X,1Z;2X,9F7;2,9F7;2)

004340	14004350	14040010	BRU SM12
004341	60000000	60000000	S915 CON 0,60000000
004342	20000201	40000201	CON 0,40000201
004343	20400002	20400002	CON 0,20400002
004344	20000401	40000401	CON 0,40000401
004345	21704024	21704024	CON 0,21704024
004346	21704024	21704024	CON 0,21704024
004347	77777720	77777720	CON 0,77777720

CDNO 306

004350	300000000	300000000	*10 CONTINUE
004350	163005731	16341361	\$H12 BSS 0
004351	26300001	26300001	*10 LDX K,3
004352	00003537	00077155	INX 1,3
004353	31000003	31000003	LCA N
004354	05004727	05004727	SUB 3
004355	30004306	30077731	TOD 23
			BTR SM10

CDNO 307

CALL BEGOUE (N10)

004356	33000576	33000576	SPB BEGOUE
004357	40022446	40022446	LDK N10

* WRITE(N10, "04")

004360	40004367	40040007	LDK \$904
004361	42022446	42022446	LDQ N10
004362	33000561	33000561	SPB SFUEGW
004363	33000563	33000563	SPB SFHLTH

CALL ENDOQUE (N10)

004364	33000577	33000577	SPB ENDOQUE
004365	40022446	40022446	LDK N10

* 904 FORMAT(1H1;3HHR5Z9X,BHAVE TEMP,35X,

3238L 03 03-20-71 23,102

GE-635 GE-PAC PAL ASSEMBLER

- 117HPRESSURE'S (PSIA) ;25X,10HAROMETRIC, /
- 28X,5HTORUS,3X,7HDRYWELL,18X,5HTORUS, /
- 128X,7HDRYWELL,20X,8HPRESSURE, /33X,27H TOTAL REF VOL DP,
- 47X,24HTOTAL REF VOL DP,10X,9HINCHES HG, /30X, /
- 563H (P1-101) (P1-103) (DP1-102) (P1-102) (P1-101) (DP1-102)
- 5,4H101), /

004366	14004541	14046153	3P015413
004367	50000000	60000000	\$904 CON 0,60000000
004370	10010001	60010001	CON 0,00010001
004371	14201000	14200000	CON 0,14200000
004372	30030001	03030001	CON 0,00030001
004373	22051123	22051123	CON 0,22051123
004374	40002201	40002201	CON 0,40002201
004375	30100001	00100001	CON 0,00100001
004376	10253105	20253105	CON 0,20253105
004377	10052105	10052105	CON 0,10052105
004400	23250000	23250000	CON 0,23250000
004401	10007601	40007601	CON 0,40007601
004402	10001001	40001001	CON 0,40001001
004403	10210001	00210001	CON 0,00210001
004404	24051105	24051105	CON 0,24051105
004405	24651525	24651525	CON 0,24651525
004406	24442523	24442523	CON 0,24442523
004407	10024120	10024120	CON 0,10024120
004410	24644501	24644501	CON 0,24644501
004411	12220000	12220000	CON 0,12220000
004412	10007001	40007001	CON 0,40007001
004413	10120001	00120001	CON 0,00120001
004414	20440522	20440522	CON 0,20440522
004415	23646505	23646505	CON 0,23646505
004416	25051111	25051111	CON 0,25051111
004417	20600000	20600000	CON 0,20600000
004420	10000100	40000100	CON 0,40000100
004421	40002001	40002001	CON 0,40002001
004422	30050001	00050001	CON 0,00050001
004423	25047522	25047522	CON 0,25047522
004424	25251400	25251400	CON 0,25251400
004425	40001201	40001201	CON 0,40001201
004426	30070001	00070001	CON 0,00070001
004427	21051131	21051131	CON 0,21051131
004430	25642514	25642514	CON 0,25642514
004431	23000000	23000000	CON 0,23000000
004432	40004401	40004401	CON 0,40004401
004433	20050001	00050001	CON 0,00050001
004434	25047522	25047522	CON 0,25047522

323BL 03 03-20-74 231102

GE-635 GE-PAC PAL ASSEMBLER

004435	25251400	25251400	CON 0.25251400
004436	40007001	40007001	CON 0.40007001
004437	50070001	00070001	CON 0.00070001
004440	21051131	21051131	CON 0.21051131
004441	25642514	25642514	CON 0.25642514
004442	23000000	23000000	CON 0.23000000
004443	40005001	40005001	CON 0.40005001
004444	00100001	00100001	CON 0.00100001
004445	24051105	24051105	CON 0.24051105
004446	24651525	24651525	CON 0.24651525
004447	24442400	24442400	CON 0.24442400
004450	40000100	40000100	CON 0.40000100
004451	40007601	40007601	CON 0.40007601
004452	400002401	40000401	CON 0.40000401
004453	00330001	00330001	CON 0.00330001
004454	10020124	10020124	CON 0.10020124
004455	23652101	23652101	CON 0.23652101
004456	23020040	23020040	CON 0.23020040
004457	10020122	10020122	CON 0.10020122
004460	21243040	21243040	CON 0.21243040
004461	25447514	25447514	CON 0.25447514
004462	10020040	10020040	CON 0.10020040
004463	10020040	10020040	CON 0.10020040
004464	10042120	10042120	CON 0.10042120
004465	40001601	40001601	CON 0.40001601
004466	00300001	00300001	CON 0.00300001
004467	25047524	25047524	CON 0.25047524
004470	20246040	20246040	CON 0.20246040
004471	10020040	10020040	CON 0.10020040
004472	24442506	24442506	CON 0.24442506
004473	10053117	10053117	CON 0.10053117
004474	23020040	23020040	CON 0.23020040
004475	10020040	10020040	CON 0.10020040
004476	10042120	10042120	CON 0.10042120
004477	40002401	40002401	CON 0.40002401
004500	00110001	00110001	CON 0.00110001
004501	22247103	22247103	CON 0.22247103
004502	22042523	22042523	CON 0.22042523
004503	10044107	10044107	CON 0.10044107
004504	40000100	40000100	CON 0.40000100
004505	40007401	40007401	CON 0.40007401
004506	00770001	00770001	CON 0.00770001
004507	10020050	10020050	CON 0.10020050
004510	24030455	24030455	CON 0.24030455
004511	14230064	14230064	CON 0.14230064
004512	12220040	12220040	CON 0.12220040
004513	10024120	10024120	CON 0.10024120
004514	14226461	14226461	CON 0.14226461
004515	14031451	14031451	CON 0.14031451
004516	10020040	10020040	CON 0.10020040

3235L.03 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

004517	12042120	12042120	CON 0.12042120
004520	14226461	14226461	CON 0.14226461
004521	14031051	14031051	CON 0.14031051
004522	14025040	14025040	CON 0.14025040
004523	12053061	12053061	CON 0.12053061
004524	13230460	13230460	CON 0.13230460
004525	14424440	14424440	CON 0.14424440
004526	18026050	18026050	CON 0.18026050
004527	24030455	24030455	CON 0.24030455
004528	14230061	14230061	CON 0.14230061
004529	12220040	12220040	CON 0.12220040
004530	14024104	14024104	CON 0.14024104
004531	24030455	24030455	CON 0.24030455
004532	00040001	00040001	CON 0.00040001
004533	14230061	14230061	CON 0.14230061
004534	12200000	12200000	CON 0.12200000
004535	40000100	40000100	CON 0.40001000
004536	77776270	77776270	CON 0.77776270

* DO 12 K=1 STRT,N

004541	16305717	16341156	SM13 LDX ISTRT,3
004542	06305731	06341167	SM14 STX K,3

COND 315

* KK = ITIME F N * K

004543	00005714	00041151	LDA ITIME
004544	11005731	31041165	ADD K
004545	31003537	31076772	SUB N
004546	32005732	32041164	STA KK

* PBARX = PB7R(K)

004547	42005731	42041162	LDG K
004550	37005675	00041125	LDA \$FXCON
004551	55005676	55041125	MPS \$FXCON+1
004552	42000002	42000002	STG 4
004553	41403413	41476640	DLI PRAR-2,4
004554	33005751	33041175	SPE \$DRCV
004555	32005734	32041157	STA PRAX

* CALL BEGOUE (N10)

004556	33005576	33000576	SPE BEGOUE
004557	40022446	40022446	LDK N10

* WRITE(N10,\$16) KK,OUT(5,K),OUT(6,K),OUT(1,K),OUT(9,K),OUT(7,K)

* 1OUT(2,K),OUT(10,K),OUT(8,K),PBARX

004558	40003617	40040037	LDK 3916
004561	42022446	42022446	LDO N10
004562	37005561	33000561	SPE \$FBEGH
004563	40005732	40041147	LDK KK
004564	33005562	33000562	SPE \$FPROF

3-294 "3 13-41" #74 43,102

GE-630 GE-PAC P/L ASSEMBLER

004565	4200573	42041114	LDC K
004566	00005675	00041107	LDA \$FXCOM
004567	55005703	55041114	MPS \$FXCOL+6
004570	44000604	44000004	STC 4
004571	40401322	40474531	LDK OUT-8,4
004572	33000562	33000562	SPB \$FPROM
004573	40401323	40474530	LDK OUT-7,4
004574	33000562	33000562	SPB \$FPROM
004575	40401314	40474521	LDK OUT-12,4
004576	33000562	33000562	SPB \$FPROM
004577	40401326	40474527	LDK OUT-4,4
004600	33000562	33000562	SPB \$FPROM
004601	40401324	40474523	LDK OUT-6,4
004602	33000562	33000562	SPB \$FPROM
004603	40401317	40474514	LDK OUT-11,4
004604	33000562	33000562	SPB \$FPROM
004605	40401327	40474522	LDK OUT-3,4
004606	33000562	33000562	SPB \$FPROM
004607	40401325	40474516	LDK OUT-5,4
004610	33000562	33000562	SPB \$FPROM
004611	40005734	40041123	LDK PRARX
004612	33000562	33000562	SPB \$FPROM
004613	33000563	33000563	SPB \$FHLLT

* CALL ENDOUE {NIO}

004614	33000577	33000577	SPB/ENDOUE
004615	40022446	40022446	LDK NIO

* 914 FORMAT(1X,12'3X,2F10.2,5X,2F10.2,F10.4,3X,2F10.2,F10.4,5X,F10.2)

004616	14004635	14040017	BRU \$M15
004617	60000006	60000000	\$916 CON 0,600F0000
004620	40000201	40000201	CON 0,400F0201
004621	21400002	20400002	CON 0,234F0002
004622	40000601	40000601	CON 0,400F0601
004623	22414024	22414024	CON 0,22414024
004624	30001201	40001201	CON 0,400C1201
004625	22414024	22414024	CON 0,22414024
004626	22404044	22404044	CON 0,224D4044
004627	40000601	40000601	CON 0,400F0601
004630	22414024	22414024	CON 0,22414024
004631	22404044	22404044	CON 0,224C4044
004632	40001201	40001201	CON 0,400D1201
004633	22404024	22404024	CON 0,224D4024
004634	77777630	77777630	CON 0,77777630

*12 CONTINUE

004635	50000006	300006000	\$H15 BSS 0
004635	16305731	16341074	T12 LDX K,3
004636	26303001	26300001	INX 1,3
004637	00003537	00076760	LDA N

CDNO 319

1238L 03, 03, 20, 74 23, 102

GE-63 GE-PAC PAL ASSEMBLER

004640 31000003 31000003
 004641 05004727 05004727
 004642 30004542 30077700

SUB 3
 TOT 23
 BTF SH14

CDNO 320

004643 33000576 33000576
 004644 40022446 40022446

* CALL BFGQUE (N10)
 SPB BFGQUE
 LDK N10

004645 40004634 40040007
 004646 42022446 42022446
 004647 33000563 33000561
 004650 33000563 33000563

* WRITER N10, 907
 LDK \$907
 LDQ N10

SPE \$FBEGW
 SPB \$FHLLW

004651 33000577 33000577
 004652 40022446 40022446

* CALL ENDQUE (N10)
 SPB ENDQUE
 LDK N10

* 907 FORMAT(1H1,25X,18HM01STUFE READINGS,27X,5HTORUS,23X,7HDRYVELL,/

* \$3X,3HHRS,15X,26HPPM VOLUME FOR STREAMS A-E,15X*

* \$23HVAPOR PFES DEW POINT,5X,23RVAPOR PRES DEW POINT,/

* \$6X,45H A R C D E*

* \$9X,21H (PSIA) (DEG F),7X,21H (PSIA) (DEG F),/

004653	14005011	14040136	BRC SH16
004654	60000000	60000000	CON 0,60000000
004655	00010001	00010001	CON 0,00010001
004656	14200000	14200000	CON 0,14200000
004657	40006201	40006201	CON 0,40006201
004660	00220001	00220001	CON 0,00220001
004661	23247511	23247511	CON 0,23247511
004662	24652125	24652125	CON 0,24652125
004663	24442440	24442440	CON 0,24442440
004664	24442501	24442501	CON 0,24442501
004665	21044516	21044516	CON 0,21044516
004666	21651440	21651440	CON 0,21651440
004667	40006601	40006601	CON 0,40006601
004670	00050001	00050001	CON 0,00050001
004671	25047522	25047522	CON 0,25047522
004672	25251400	25251400	CON 0,25251400
004673	40005601	40005601	CON 0,40005601
004674	00070001	00070001	CON 0,00070001
004675	21051131	21051131	CON 0,21051131
004676	25642514	25642514	CON 0,25642514
004677	23000000	23000000	CON 0,23000000

0000000	40000000	400000100	CON 0, 400000100
0000001	40000001	400000601	CON 0, 400000601
0000002	00030001	00030001	CON 0, 00030001
0000003	22051123	22051123	CON 0, 22051123
0000004	40003601	40003601	CON 0, 40003601
0000005	00320001	00320001	CON 0, 00320001
0000006	24050115	24050115	CON 0, 24050115
0000007	10053117	10053117	CON 0, 10053117
0000008	23052515	23052515	CON 0, 23052515
0000009	21220106	21220106	CON 0, 21220106
0000010	23651040	23651040	CON 0, 23651040
0000011	24652122	24652122	CON 0, 24652122
0000012	21245115	21245115	CON 0, 21245115
0000013	24620101	24620101	CON 0, 24620101
0000014	12242400	12242400	CON 0, 12242400
0000015	40003601	40003601	CON 0, 40003601
0000016	00270001	00270001	CON 0, 00270001
0000017	25445320	25445320	CON 0, 25445320
0000018	23651140	23651140	CON 0, 23651140
0000019	22051105	22051105	CON 0, 22051105
0000020	24620040	24620040	CON 0, 24620040
0000021	23451040	23451040	CON 0, 23451040
0000022	23651105	23651105	CON 0, 23651105
0000023	24620040	24620040	CON 0, 24620040
0000024	10020104	10020104	CON 0, 10020104
0000025	21253410	21253410	CON 0, 21253410
0000026	22047511	22047511	CON 0, 22047511
0000027	23452000	23452000	CON 0, 23452000
0000028	40001201	40001201	CON 0, 40001201
0000029	00270001	00270001	CON 0, 00270001
0000030	00244520	00244520	CON 0, 00244520
0000031	23651040	23651040	CON 0, 23651040
0000032	24651105	24651105	CON 0, 24651105
0000033	24620040	24620040	CON 0, 24620040
0000034	10020104	10020104	CON 0, 10020104
0000035	21253440	21253440	CON 0, 21253440
0000036	24047511	24047511	CON 0, 24047511
0000037	23452000	23452000	CON 0, 23452000
0000038	40001201	40001201	CON 0, 40001201
0000039	00270001	00270001	CON 0, 00270001
0000040	00244520	00244520	CON 0, 00244520
0000041	23651040	23651040	CON 0, 23651040
0000042	24651105	24651105	CON 0, 24651105
0000043	24620040	24620040	CON 0, 24620040
0000044	10020104	10020104	CON 0, 10020104
0000045	21253440	21253440	CON 0, 21253440
0000046	24047511	24047511	CON 0, 24047511
0000047	23452000	23452000	CON 0, 23452000
0000048	40001200	40001200	CON 0, 40001200
0000049	00270001	00270001	CON 0, 00270001
0000050	00244520	00244520	CON 0, 00244520
0000051	23651040	23651040	CON 0, 23651040
0000052	24651105	24651105	CON 0, 24651105
0000053	24620040	24620040	CON 0, 24620040
0000054	10020104	10020104	CON 0, 10020104
0000055	21253440	21253440	CON 0, 21253440
0000056	24047511	24047511	CON 0, 24047511
0000057	23452000	23452000	CON 0, 23452000
0000058	40001200	40001200	CON 0, 40001200
0000059	00270001	00270001	CON 0, 00270001
0000060	00244520	00244520	CON 0, 00244520
0000061	23651040	23651040	CON 0, 23651040
0000062	24651105	24651105	CON 0, 24651105
0000063	24620040	24620040	CON 0, 24620040
0000064	10020104	10020104	CON 0, 10020104
0000065	21253440	21253440	CON 0, 21253440
0000066	24047511	24047511	CON 0, 24047511
0000067	23452000	23452000	CON 0, 23452000
0000068	40001200	40001200	CON 0, 40001200
0000069	00270001	00270001	CON 0, 00270001
0000070	00244520	00244520	CON 0, 00244520
0000071	23651040	23651040	CON 0, 23651040
0000072	24651105	24651105	CON 0, 24651105
0000073	24620040	24620040	CON 0, 24620040
0000074	10020104	10020104	CON 0, 10020104
0000075	21253440	21253440	CON 0, 21253440
0000076	24047511	24047511	CON 0, 24047511
0000077	23452000	23452000	CON 0, 23452000
0000078	40001200	40001200	CON 0, 40001200
0000079	00270001	00270001	CON 0, 00270001
0000080	00244520	00244520	CON 0, 00244520
0000081	23651040	23651040	CON 0, 23651040
0000082	24651105	24651105	CON 0, 24651105
0000083	24620040	24620040	CON 0, 24620040
0000084	10020104	10020104	CON 0, 10020104
0000085	21253440	21253440	CON 0, 21253440
0000086	24047511	24047511	CON 0, 24047511
0000087	23452000	23452000	CON 0, 23452000
0000088	40001200	40001200	CON 0, 40001200
0000089	00270001	00270001	CON 0, 00270001
0000090	00244520	00244520	CON 0, 00244520
0000091	23651040	23651040	CON 0, 23651040
0000092	24651105	24651105	CON 0, 24651105
0000093	24620040	24620040	CON 0, 24620040
0000094	10020104	10020104	CON 0, 10020104
0000095	21253440	21253440	CON 0, 21253440
0000096	24047511	24047511	CON 0, 24047511
0000097	23452000	23452000	CON 0, 23452000
0000098	40001200	40001200	CON 0, 40001200
0000099	00270001	00270001	CON 0, 00270001
0000100	00244520	00244520	CON 0, 00244520

3238L 03 03-20-74 23.102

GE-635 GE-PAC PAI ASSEMBLER

004762	10020040	10020040	CON 0.10020040
004763	10020040	10020040	CON 0.10020040
004764	10020105	10020105	CON 0.10020105
004765	10002201	40002201	CON 0.40002201
004766	10250001	00250001	CON 0.00250001
004767	10024120	10024120	CON 0.10024120
004770	24644501	24644501	CON 0.24644501
004771	12220040	12220040	CON 0.12220040
004772	10020040	10020040	CON 0.10020040
004773	10024040	10024040	CON 0.10024040
004774	21042507	21042507	CON 0.21042507
004775	10043051	10043051	CON 0.10043051
004776	40001601	40001601	CON 0.40001601
004777	10025001	00250001	CON 0.00250001
005000	10024120	10024120	CON 0.10024120
005001	24644501	24644501	CON 0.24644501
005002	12220040	12220040	CON 0.12220040
005003	10020040	10020040	CON 0.10020040
005004	10020050	10020050	CON 0.10020050
005005	21042507	21042507	CON 0.21042507
005006	10043051	10043051	CON 0.10043051
005007	40000100	40000100	CON 0.40000100
005010	77776440	77776440	CON 0.77776440

005011	16305717	16340706	* DO 16 K=ISTRT,N
005012	16305731	06340717	\$H16 LDX ISTRT, \$M17 STX K,3

005013	10005714	00040701	* KK = ITIME - N * K
005014	11005731	11040715	LDA ITIME
005015	31005737	31076322	ADD K
005016	32005732	32040714	SUB N
			STA KK

CDNO 328

005017	42005731	42040712	* PPMV1 = PPMV{1,K}
005020	10005675	00040655	LDD K
005021	15005701	55040660	LDA \$FXCON
005022	44000004	44000004	MPY \$FXCON-4
005023	31405714	41473671	STO 4
005024	33005751	33040725	DLD PPMV-1074
005025	32005724	32040677	SPG \$DRCVT
			STA PPMV1

005026	41400716	41473670	* PPMV2 = PPMV{2,K}
005027	33005751	33040722	DLD PPMV-8,4
005030	32005725	32040675	SPG \$DRCVT
			STA PPMV2

005031	41400720	41473667	* PPMV3 = PPMV{3,K}
			DLD PPMV-6,4

230L 03 03420-74 23,102

GF-635 GE-PAC PAL ASSEMBLER

05032 33005751 33040717 SPB SDRCVT
05033 32005726 32040673 STA PPHV3

05034 41400722 41473666 PPHV4 = PPMV(4,K)
05035 33005751 33040714 DLD PPMV-4,4
05036 32005727 32040671 SPB SDRCVT
STA PPHV4

05037 41400724 41473665 PPHV5 = PPMV(5,K)
05040 33005751 33040711 DLD PPMV-2,4
05041 32005730 32040667 SPB SDRCVT
STA PPHV5

05042 33000576 33000576 CALL BEGQUE(N10)
05043 40022446 40022446 SPB BEGQUE
LDK N10

* WRITER(N10,517) KK,PPMV1,PPMV2,PPMV3,PPHV4,PPHV5,OUT(3,K),
OUT(11,K),OUT(4,K),OUT(12,K)

05044 40005103 40040037 LDK \$917
05045 42022446 42022446 LDQ N10
05046 33000561 33000561 SPB \$FBEGW
05047 40040732 40040663 LDK KK
05050 33000562 33000562 SPB \$FPROW
05051 40000724 40040653 LDK PPMV1
05052 33000562 33000562 SPB IFPROW
05053 40000725 40040652 LDK PPMV2
05054 33000562 33000562 SPB \$FPROW
05055 40000726 40040651 LDK PPMV3
05056 33000562 33000562 SPB \$FPROW
05057 40000727 40040650 LDK PPMV4
05060 33000562 33000562 SPB \$FPROW
05061 40000730 40040647 LDK PPMV5
05062 33000562 33000562 SPB \$FPROW
05063 42000731 42040645 LDO K
05064 40000675 40040611 LDA \$FXCON
05065 55000703 55040616 MPY \$FXCON#6
05066 44000004 44000004 STQ 4
05067 40401320 40474231 LDX OUT-10,4
05070 33000562 33000562 SPB \$FPROW
05071 40401330 40474237 LDK OUT-2,4
05072 33000562 33000562 SPB \$FPROW
05073 40401321 40474226 LDK OUT-9,4
05074 33000562 33000562 SPB \$FPROW
05075 40401331 40474234 LDK OUT-17,4
05076 33000562 33000562 SPB \$FHLLTH
05077 33000563 33000563 SPB \$FHLLTH

* CALL ENDQUE(N10)

30L 03 03/20/74 23,102

GE-635 GE-PAC PAL ASSEMBLER

05100 33000577 33000577
 05101 40022446 40022446

SPB ENDQUE
 LDK NIO

* 917 FORMAT(1X,1E/F10.2,F11.2,F13.4,F13.2,F13.2)
 05102 * 14003116 14040014
 05103 40000000 60000000
 05104 40000201 40000201
 05105 10400002 20400002
 05106 72404024 22404024
 05107 22634024 22634024
 05108 23204044 23204044
 05109 23204024 23204024
 05110 40000701 40000701
 05111 23204044 23204044
 05112 23204024 23204024
 05113 23204044 23204044
 05114 23204024 23204024
 05115 77777660 77777660

* 816 CONTINUE

CDNO 332

05116 300000000 300000000
 05116 36305731 15340613
 05117 26300h51 26200001
 05120 76003537 00076417
 05121 31000003 31000003
 05122 05004727 05004727
 05123 30005012 30077667

SH18 955 0

\$16 LDX K,3

INX 1,3

LDA N

SUB 3

TOD 23

BTR SH17

CDNO 333

05124 33000576 33000576
 05125 40022446 40022446

* CALL BEGQUE (NIO)

SPB BEGQUE

LDK NIO

05126 70005335 40040007
 05127 12022446 12022446
 05130 33000561 33000561
 05131 33000563 33000563

* WRITE(NIO,509)

LDK \$909

LDQ NIO

SPB SFREGW

SPB SFHLTW

05132 33000577 33000577
 05133 40022446 40022446

* CALL ENDQUE (NIO)

SPB ENDQUE

LDK NIO

* 909 FORMAT(1H1,45X,31HMASS AIR IN CONTAINMENTS - LES, /

* \$ 4(X,13H)REAL GAS LAW,20X,17HREF VESSEL METHOD, /

* \$ 25X,3HHR5,6X,23HTORUS DRYHELL SUM,12X,

* \$ 23HTORUS DRYHELL SUM, /)

05134 34005231 14040075

BRU SH19

025135	60000000	60000000	\$909	CON 0,60000000
005136	00012001	00010001		CON 0,00010001
005137	14200000	14200000		CON 0,14200000
005140	40007601	40007601		CON 0,40007601
005141	40005401	40003401		CON 0,40005401
005142	16370021	00370001		CON 0,00370001
005143	1324523	23240523		CON 0,23240523
005144	14620101	24620101		CON 0,24620101
005145	12251040	22251040		CON 0,22251040
005146	12247040	22247040		CON 0,22247040
005147	16647516	20647516		CON 0,20647516
005150	15042511	25040511		CON 0,25040511
005151	13446525	23446505		CON 0,23446505
005152	13452123	23452123		CON 0,23452123
005153	16026440	10026440		CON 0,10026440
005154	13041123	23041123		CON 0,23041123
005155	12000000	13000000		CON 0,13000000
005156	60000000	400000200		CON 0,400000200
005157	600007601	400007601		CON 0,400007601
005160	60002201	40002201		CON 0,40002201
005161	60155601	00150001		CON 0,00150001
005162	72242105	22242105		CON 0,22242105
005163	70246040	20246040		CON 0,20246040
005164	7162523	21640523		CON 0,21640523
005165	10046101	10046101		CON 0,10046101
005166	75600000	25600000		CON 0,25600000
005167	70005601	40005001		CON 0,400005001
005170	00210001	00210001		CON 0,00210001
005171	74442506	24442506		CON 0,24442506
005172	10053103	10053105		CON 0,10053105
005173	24651505	24651505		CON 0,24651505
005174	73022115	23020115		CON 0,23020115
005175	21252110	21252110		CON 0,21252110
005176	23642000	23642000		CON 0,23642000
005177	460007100	400000100		CON 0,40000100
005178	10000201	400006201		CON 0,400006201
005201	00030001	00030001		CON 0,00030001
005202	72051123	2051123		CON 0,22051123
005203	10001401	40001401		CON 0,40001401
005204	10270001	00270001		CON 0,00270001
005205	25947522	25947522		CON 0,25947522
005206	15251240	25251440		CON 0,25251440
005207	10020040	10020040		CON 0,10020040
005210	21051131	21051131		CON 0,21051131
005211	25642514	25642514		CON 0,25642514
005212	23020040	23020040		CON 0,23020040
005213	10020123	10020123		CON 0,10020123
005214	25246400	25246400		IN 0,25246400
005215	10003001	40003001		CON 0,40003001
005216	10270001	00270001		CON 0,00270001

238L P3 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

05217	25047522	25047522	CON 0,25047522
05220	25251440	25251440	CON 0,25251440
05221	10020040	10020040	CON 0,10020040
05222	21051131	21051131	CON 0,21051131
05223	25647514	25647514	CON 0,25647514
05224	23020040	23020040	CON 0,23020040
05225	10020123	10020123	CON 0,10020123
05226	25246400	25246400	CON 0,25246400
05227	40000100	40000100	CON 0,40000100
05230	77777050	77777050	CON 0,77777050

05231	16305717	16340466	* DO 19 K=1STR,T,N SM19 LDX ISTR,T,3
05232	16305731	06340477	SM20 STX K,3

COND 340

05233	10305714	00040461	* KK = ITIME - N 4 K LDA ITIME
05234	11005731	11040475	ADD K
05235	31005737	31076302	SUB N
05236	32005732	32040474	STA KK

05237	42005731	42040472	* YMASS1 = YMASS(1,K) LDQ K
05240	00005675	00040435	LDA \$FXCON
05241	55005703	55040442	MPY \$FXCON+6
05242	44000004	44000004	STQ 4
05243	41402711	41475446	DLD YMASS=12,4
05244	33005751	33040505	SPE \$DRCVT
05245	32005735	32040470	STA YMASS1

05246	41402713	41475445	* YMASS2 = YMASS(2,K) DLD YMASS=10,4
05247	33005751	33040502	SPE \$DRCVT
05250	32005736	32040466	STA YMASS2

05251	41402715	41475444	* YMASS3 = YMASS(3,K) DLD YMASS=8,4
05252	33005751	33040477	SPE \$DRCVT
05253	32005737	32040464	STA YMASS3

05254	41402717	41475443	* YMASS4 = YMASS(4,K) DLD YMASS=6,4
05255	33005751	33040474	SPE \$DRCVT
05256	32005740	32040462	STA YMASS4

05257	41402721	41475442	* YMASS5 = YMASS(5,K) DLD YMASS=4,4
05260	33005751	33040471	SPE \$DRCVT
05261	32005741	32040460	STA YMASS5

005262 41402723 41475441 * YMASS6 = YMASS(6,K)
 005263 33005751 33040466 \$LD YMASS=2*4
 005264 32005742 32040456 SPE \$DRCV1
 STA YHASSE

005265 33000576 33000576 * CALL BEGQUE(N10)
 005266 40022446 40022446 SPR BEGQUE
 LDK N10

005267 40005314 40040025 * WRITE(N10,918) KK,YMASS1,YMASS2,YMASS3,YMASS4,YMASS5,YMASS6
 005270 42022446 42022446 LDK \$918
 005271 33000561 33000561 LNG N10
 005272 40005732 40040440 SPB \$FBEGW
 005273 33000562 33000562 LDK KK
 005274 40005735 40040441 SPB \$FPROV
 005275 33000562 33000562 LDK YMASS1
 005276 40005776 40040440 SPB \$FPROV
 005277 33000562 33000562 LDK YMASS2
 005300 40005737 40040437 SPB \$FPROV
 005301 33000562 33000562 LDK \$FPROV
 005302 40005740 40040436 LDK YMASS4
 005303 33000562 33000562 SPB \$FPROV
 005304 40005741 40040435 LDK YMASS5
 005305 33000562 33000562 SPB \$FPROV
 005306 40005742 40040434 LDK YMASS6
 005307 33000562 33000562 SPB \$FPROV
 005310 33000563 33000563 SPB \$FHLYTF

005311 33000577 33000577 * CALL ENQUEUE(N10)
 005312 40022446 40022446 SPR ENQUEUE
 LDK N10

005313 14005323 14040010 * 91E FORMAT(23X,I5,F11.2,F2X,F11.2)
 005314 60000000 60000000 \$918 HRU \$M21
 005315 40005601 40005601 CON 0.60000000
 005316 21200002 21200002 CON 0.40005601
 005317 22624024 22624024 CON 0.21200002
 005320 40000401 40000401 CON 0.22624024
 005321 22624024 22624024 CON 0.40000401
 005322 77777720 77777720 CON 0.22624024

005323 70000000 300000000 #18 CONTINUE
 005323 16305735 16340406 \$M21 BSS 0
 005324 26300001 26300001 \$16 LDX K,3
 005325 00003537 0C076212 INX 1,3
 005326 31000003 31000003 LDA N
 005327 05004727 05004727 SUH 3
 005327 05004727 05004727 TOP 23

CDNO 343

3238L 03 03-20-74 23:102

GE-635 GE-PAC PAL ASSEMBLER

005330 30005232 30077702

BTR \$M20

CDNO 344

* * IF LOW PRESSURE TEST, NOW THROUGH

CDNO 345

*

* IF (NN,EQ,1) GO TO 100

CDNO 346

005331	00003536	00076205
005332	31005676	31040344
005333	05004676	05004676
005334	34005634	34040300

LDA NN

SUU \$FXCOM+1

TZE

BTS \$100

CDNO 347

*

* CALL BEGQUE (N10)

CDNO 348

005335	33000576	33000576
005336	40022446	40022446

SPR BEGQUE

LDK N10

* WRITE(N10,910)

LDK \$910

LDQ N10

SPR \$FBEGIN

SPR \$FHLTW

005343	33000577	33000577
005344	40022446	40022446

* CALL ENDQUE (N10)

SPR ENDQUE

LDK N10

* 910 FORMAT(1H1,47X,20HINTEGRATED LEAK RATE, //29X,1EABSOLUTE METHOD,

* 25X,17HREL VESSEL METHOD, /

* 214X,3HRS, "X"9HCALC 24HR,6X,9H STD DEV ,5X,10H,5PCT CONF,

* 3 10X,9HCALC 24HR,6X,9H STD DEV ,5X,10H,5PCT CONF, /

* 418X,14HLEAK RATE(PCT),1X,14H(LBS PER HOUR),3X,10HLIMIT(PCT),

* 5 7X,14HLEAK RATE(PCT),1X,14H(LBS PER HOUR),3X,10HLIMIT(PCT))

005345	14005521	14040154
005346	60000000	60000000
005347	00010001	00010001
005350	14200000	14200000
005351	40007602	40007601
005352	40004001	40004001
005353	00240001	00240001
005354	22247124	22247124
005355	21243522	21243522

BRU \$M22

CON 0,600#0000

CON 0,0005,0001

CON 0,142#0000

CON 0,400#7601

CON 0,400#4001

CON 0,002#0001

CON 0,222#7124

CON 0,212#3522

1238L 03 03-20-74 23,102

GE-635 GE-PAC PAL ASSEMBLER

005440	21253040	21253040	CON 0.21253040
005441	40001201	40001201	CON 0.40001201
005442	00120001	00120001	CON 0.00120001
005443	16232520	16232520	CON 0.16232520
005444	20652040	20652040	CON 0.20652040
005445	20647516	20647516	CON 0.20647516
005446	21402000	21400000	CON 0.21400000
005447	40002100	40000100	CON 0.40000100
005450	40004401	40004401	CON 0.40004401
005451	00160001	00160001	CON 0.00160001
005452	23042501	23042501	CON 0.23042501
005453	22621124	22620122	CON 0.22620122
005454	20252105	20252105	CON 0.20252105
005455	12050103	12050103	CON 0.12050103
005456	25024400	25024400	CON 0.25024400
005457	40030201	40030201	CON 0.40030201
005460	00160005	00160005	CON 0.00160005
005461	12046102	12046102	CON 0.12046102
005462	24622420	24620120	CON 0.24620120
005463	21251048	21251040	CON 0.21251040
005464	22047525	22047525	CON 0.22047525
005465	24424400	24424400	CON 0.24424400
005466	40000601	40000601	CON 0.40000601
005467	00120001	00120001	CON 0.00120001
005470	23044515	23044515	CON 0.23044515
005471	22252050	22252050	CON 0.22252050
005472	24041524	24041524	CON 0.24041524
005473	12200004	12200000	CON 0.12200000
005474	40001604	40001601	CON 0.40001601
005475	00160002	00160001	CON 0.00160001
005476	23044250	23044250	CON 0.23044250
005477	22620122	22620122	CON 0.22620122
005479	20252105	20252105	CON 0.20252105
005480	12050103	12050103	CON 0.12050103
005481	24620120	24620120	CON 0.24620120
005482	25024400	25024400	CON 0.25024400
005483	40000201	40000201	CON 0.40000201
005504	00160001	00160001	CON 0.00160001
005505	12046102	12046102	CON 0.12046102
005506	24521120	24521120	CON 0.24521120
005507	21251140	21251140	CON 0.21251140
005510	21247525	21247525	CON 0.21247525
005511	24424400	24424400	CON 0.24424400
005512	40000601	40000601	CON 0.40000601

005555	33005576	33000576
005556	46022446	46022446
005557	46030205	46030201
005558	00163002	00160501
005559	12045102	12046102
005560	24621120	24621120
005561	24621040	24621040
005562	22047525	22047525
005563	24424400	24424400
005564	40000601	40000601
005565	00122301	00122301
005566	23044515	23044515
005567	00122301	00122301
005568	22252050	22252050
005569	24041524	24041524
005570	12200000	12200000
005571	46001601	46001601
005572	00162001	00162001
005573	23042501	23042501
005574	22621122	22621122
005575	20252105	20252105
005576	12052103	12052103
005577	25024400	25024400
005578	45000201	45000201
005579	00166001	00166001
005580	12046102	12046102
005581	24622120	24622120
005582	24251140	24251140
005583	24247525	24247525
005584	24424410	24424410
005585	40000601	40000601
005586	00122301	00122301
005587	23044515	23044515
005588	22252050	22252050
005589	24041524	24041524
005590	12200000	12200000
005591	77776260	77776260

005557	40005604	40040025
005558	33005751	33040201
005559	32005744	32040173
005560	33005751	33040176
005561	32005744	32040171
005562	41402553	41475001
005563	33005751	33040176
005564	32005744	32040171
005565	33005751	33040176
005566	46022446	46022446
005567	33005576	33000576
005568	46030205	46030201
005569	00163002	00160501
005570	12045102	12046102
005571	24621120	24621120
005572	24621040	24621040
005573	22047525	22047525
005574	24424400	24424400
005575	40000601	40000601
005576	00122301	00122301
005577	23044515	23044515
005578	22252050	22252050
005579	24041524	24041524
005580	12200000	12200000
005581	77776260	77776260

SPB TORCV7
STA STDH1

STDH2 = STDH1#2#4
DLU STDH2#2#4

SPB TORCV7
STA STDH2

CALL BEGOU: (N10)
SPB BEGOU:
LDK N!0
LUK \$911

WRITE(N10,"111") J\$RATE1,STDH1,CON1,RATE2,STDH2,CON2
005557

005558

005559

13 03.20-74 73.102

GE-535: GE-PAC PAL ASSIMILER

0 40022446 42022446
1 37395768 37395768
2 40040151 40040151
3 3600562 3600562
4 41005720 41005720
5 3500562 3500562
6 40040156 40040156
7 3500562 3500562
8 40040152 40040152
9 3500562 3500562
0 40040172 40040172
1 3500562 3500562
2 40040154 40040154
3 3500562 3500562
4 40040125 40040125
5 3500562 3500562
6 3500564 3500564
7 3500564 3500564
8 3500564 3500564
9 3500564 3500564

04 3300577 3300577
02 40022446 40022446

* CALL ENDQUE (N10)
SPG ENDQUE
LDK N10 *

* 015 FORMAT(1H ,9X,16X,F10.4,4X,F10.4,6X,F10.4,4X,F10.4,7X)

* 1F10.4
GRU SM24
CON 0,60000000
CON 0,00000001
CON 0,10000000
CON 0,40002001
CON 0,24400002
CON 0,40011001
CON 0,2244404
CCR 0,40011001
CON 0,22444044
CON 0,40011401
CON 0,22444044
CON 0,40012001
CON 0,22444044
CON 0,40011601
CON 0,22444044
CON 0,7777570

* 20 CONTINUE
SM24 RSS 0
320 LDX 1,3
INX 1,3
LDN

01000006 30000000
1634015 1634015
2630001 2630001
05003537 05003537

CDNO 359

1036L 03 03-20474 23,102

GE-63% GE-PAC PAL ASSEMBLER

05631	35000003	31000003	SUB 3
05632	05004727	05004727	TOD 23
05633	30005522	30077667	BTR \$H23

CDNO 360

* 100 CALL INHIBT
05634 33005752 33040016 \$100 SPS INHIBT

* IONTIM = 27,5*60+2
05635 00005707 00040052 LDA \$FLCOM
05636 74014001 74014001 FMS 1
05637 72005710 72040051 FMP \$FLCOM+1
05640 72005711 72040051 FMP \$FLCOM+2
05641 05045627 05045627 TER 23
05642 7400027 74000027 FIX 23
05643 34005645 34040002 BTS +2
05644 05013000 05013000 NEG
05645 32005746 32040101 STA IONTIM

* IDLAY = TIME-(TIME/7200)*7200
05646 00002052 00002052 LDA TIME
05647 45004427 45004427 DRA 23
05650 75005704 75040034 DVH \$FXCON*7
05651 00002052 00002052 LDA TIME
05652 55005705 55040033 HPY \$FXCON+8
05653 45006467 45006467 DLA 23
05654 32005747 32040073 STA IDELAY

* IDELAY = IONTIM-IDLAY
05655 31005746 31040071 SUE IONTIM
05656 05013000 05013000 NEG
05657 32005756 32040071 STA IDELAY

* IF(IDELAY.LT;0) IDELAY = IONTIM-IDLAY
05660 31005675 31040015 SUE \$FXCON
05661 05004727 05004727 TOD 23
05662 30005666 30040004 BTR \$H25
05663 00005746 00040063 LDA IONTIM
05664 11005747 11040063 ADD IDELAY
05665 32005756 32040063 STA IDELAY

* CALL PERMIT
05666 33005753 33040065 \$H25 SPH PERMIT

* CALL DLY01 (1,IDELAY)
05667 33005754 33040065 SPH DLY01
05670 40005677 40040007 LDK \$FXCON*2
05671 40005756 40040057 LDK IDELAY

2381.03 03-20-74 23.102

GE-63F GE-PAC PAL ASSEMBLER

* CALL SEGMENT (29,1)

SPE SEGMENT
LDK \$FXCON+9
LDK \$FXCOF+2

* END

CONO 362

* THE FOLLOWING SYSTEM SYMBOLS HAVE BEEN USED:

* SEGMENT, ENDOLE, BEGQUE, NICK, TIME

005672	33021043	33021043	\$FXCON CON D,C
005673	40005706	40040013	CON D,2
005674	40005677	40040003	CON D,1
			CON D,4
005700	00000C04	00000004	CON D,10
005701	00000C012	00000012	CON D,18
005702	00000C022	00000022	CON D,12
005703	00000C014	00000014	CON D,-72E0
005704	77761740	77761740	CON D,7200
005705	00016040	00016040	CON D,29
005706	00000035	00000035	CON F,0:275E2
005707	22734000	22734000	SFLOCN CON F,0:275E2
005710	22360000	22360000	CON F,0:6F2
005711	21200000	21200000	CON F,0:2F1
005712	21022700	21022700	SDPCN DCN F,0:5
005713	00000001	00000000	
005714	30100001	30100001	ITIME BSS 1
005715	30000001	30000001	IPD BSS 1
005716	30000001	30000001	XTIME BSS 1
005717	30000001	30000001	ISTR1 BSS 1
005720	30000001	30000001	RATE1 BSS 1
005721	30000001	30000001	RATE2 BSS 1
005722	30000001	30000001	CON1 BSS 1
005723	30000001	30000001	CON2 BSS 1
005724	30000001	30000001	PPHV1 BSS 1
005725	30000001	30000001	PPHV2 BSS 1
005726	30000001	30000001	PPHV3 BSS 1
005727	30000001	30000001	PPHV4 BSS 1
005730	30000001	30000001	PPHV5 BSS 1
005731	30000001	30000001	K BSS 1
005732	30000001	30000001	KK BSS 1
005733	30000001	30000001	J BSS 1
005734	30000001	30000001	PBARX BSS 1
005735	30000001	30000001	YMASE1 BSS 1
005736	30000001	30000001	YMASE2 BSS 1
005737	30000001	30000001	YMASE3 BSS 1
005740	30000001	30000001	YMASE4 BSS 1
005741	30000001	30000001	YMASE5 BSS 1
005742	30000001	30000001	YMASE6 BSS 1
005743	30000001	30000001	I BSS 1
			STDM1 BSS 1

OL 03 03-20-74 23,1C2

GF#634 GE-PAC PEL ASSİSYÜLER

5745	30000001	300000001	S1DM2 BSS 1
5746	20000001	300000001	IONTIM BSS 1
5747	200000001	300000001	IDLAY BSS 1
5750	200000001	300000001	IDELAY BSS 1
5751	61042122	91042122	IDRCV1 L1B
	620653122	520653124	
5752	522247115	922247110	INHET LIB
	522241124	922241124	
5753	524042522	924042522	PEPHIT LIB
	523244522	923244524	
5754	521046131	921046131	DLY01 L1B
	512072440	914030440	
	400000000	000000000	END

3230L 03 03-20-74 23:102

GE-635 GE-PAC PAL ASSEMBLER

PLRT03 LEAK RATE TEST SEGMENT THREE

*

* FCR FITZPATRICK

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* Стартованием ввода данных в базу данных и проверки введенных

* ROUTINE PRINTS INPUT AND OUTPUT VALUES CDNO 265

* TEMPERATURE, RTD1 DEG F - TREAD(18) CDNO 267

* MOISTURE CONTENT, PPM BY VOL PPHV(5) CDNO 268

* TOTAL PRESS, TORUS AND BULB (PSIA) PS,PD CDNO 269

* REF VOL AND CONTAINMENT (PSIA) DPSR,DPDR CDNO 270

* REFERENCE VOLUME PRESS,TORUS,BULB (PSIA) PSR,PDR CDNO 271

* DIFFERENTIAL PRESSURES CDNO 272

* BAROMETRIC PRESS, IN HG BAROM CDNO 273

* LEAKAGE RATE & FRACTION OF CONTAINED CDNO 274

* MASS PER 24 HOURS RATE(6) CDNO 275

* VARIANCE OF LEAK RATE DATA VAR(6) CDNO 276

* STANDARD DEVIATION OF SLOPE STDM(6) CDNO 277

* Стартованием ввода данных в базу данных и проверки введенных

* COMMON /OUTPUT/ RTD(10,26), PPHV(5,26), OUT(12,26)

* \$ XTIME(26), IUNIT, NUM, XSTRNP

3L 03 03-20-74 23,092

GF-632 GE-PAC PAL ASSEMBLER

13	2131	ELD	3721	DST	3722	DST	4246	DST	4256
14CIR	2137	ELD	3661	DLD	4243	FSU	4255		
14N2	2145	DLD	3661	DLD	4244	DLD	4253		
14N20	2233	DST	4132	DST	4244	DLD	4253		
15STAMP	2110	DST	3667	DLD	3754	DST	3755	DLD	4160
15TIME	2024	DLD	3733	DST	3734	DLD	4133	DLD	4205
152S	2725	DLD	4221						
V10	3501	FDV	4310						
V10D	3533	DST	4116	UST	4220				
V10S	3531	DST	4134	DST	4222				