



Robert McKeon  
Assistant V. President  
and Manager, Operations

Fermi 2  
6400 North Dixie Hwy  
Newport, Michigan 48166  
(313) 586-5249



10CFR50.73

March 13, 1995  
NRC-95-0020

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Reference: Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 95-001

Please find enclosed LER No. 95-001, dated March 13, 1995 for a reportable event that occurred on February 11, 1995. A copy of this LER is also being sent to the Regional Administrator, USNRC Region III.

The following commitments are made in this LER:

1. Provide Lessons Learned Training from this event and other events related to monitoring and test equipment use and control to Plant Engineering, Technical Engineering, Maintenance, Operations and Work Control personnel.
2. Clarify procedure requirements to distinguish between the use of test equipment to take momentary readings and the actual connection of data acquisition and monitoring equipment requiring the use of temporary modification process.
3. Evaluate industry good practices regarding test control and use of monitoring and test equipment to identify any necessary programmatic improvements.
4. Control the Diagnostic Data Acquisition System (DAS) instruments to ensure they will not be connected to plant instrumentation where the installation may be intrusive.

170021

9503170122 950313  
PDR ADDCK 05000341  
S PDR

JE22

March 13, 1995  
NRC-95-0020  
Page 2

If you have any questions, please contact Jim L. Martin,  
Compliance Engineer at (313) 586-4225.

Sincerely,

*Robert McKen*

Enclosure: NRC Forms 366, 366A

cc: T. G. Colburn  
J. B. Martin  
M. P. Phillips  
P. L. Torpey  
A. Vogel

Wayne County Emergency  
Management Division