



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN

VICE PRESIDENT  
NUCLEAR

October 21, 1983  
PY-CEI/NRR-0075 L

Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Response to Request for Clarification  
on Quencher Tie-Down Loads

Dear Mr. Youngblood:

This letter is provided as a clarification to the staff regarding the applicability of the acceptance criteria given in NUREG 0802, Appendix B, Paragraph B.2, to the Perry Nuclear Power Plant's (PNPP's) quencher.

For Perry, the design dynamic stress from the bending moment on the quencher arm is greater than 5,000 psi. Thus, the Perry design meets the above referenced acceptance criteria.

If you have any additional questions, please call.

Very truly yours,

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:kay

cc: Jay Silberg, Esq.  
John Stefano  
Max Gildner

13001  
1/0