

**Detroit
Edison**

Robert McKeon
Assistant Vice President
and Manager, Operations

Fermi 2
6400 North Dixie Hwy
Newport, Michigan 48186
(313) 586-5249



10CFR50.73

March 17, 1995
NRC-95-0015

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Reference: Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 94-003-03

Please find enclosed LER No. 94-003-03, dated March 17, 1995. A copy of this LER is also being sent to the Regional Administrator, USNRC Region III.

The following commitments are made in this LER:

- 1) A set of electrical surveillance overlap drawings will be created and maintained. This will be completed by February, 1996.
- 2) Test overlap requirements will be periodically reviewed in the I&C continuing training.
- 3) Alternate Shutdown isolation function procedures will be revised by September 1, 1995.
- 4) Lessons Learned from this LER will be presented to Operations, Maintenance and Technical Engineering.
- 5) Affected procedures will be modified to clearly indicate Technical Specification compliance steps.
- 6) Specific individuals will be trained on Technical Specification (TS) compliance to ensure TS compliance is maintained.
- 7) The surveillance tracking system will be improved for component level tracking of Logic System Functional testing.

200056

9503200132 950317
PDR ADCK 05000341
S PDR

IF22
11

March 17, 1995
NRC-95-0015
Page 2

The expected supplement date of February 16, 1995 could not be met. An extension was requested and approved by NRC Region III.

If you have any questions, please contact Elizabeth A. Hare, Compliance Engineer, at (313) 586-1427.

Sincerely,

Robert M. Keon

Enclosure: NRC Forms 366, 366A

cc: T. G. Colburn
J. B. Martin
M. P. Phillips
P. L. Torpey
A. Vogel

Wayne County Emergency
Management Division