

## ATTACHMENT 2

### PROPOSED TECHNICAL SPECIFICATION CHANGES

## CONTAINMENT LEAKAGE

### LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to  $L_a$ , 0.30% by weight of the containment air per 24 hours at  $P_a$ , 41.2 psig.
- b. A combined leakage rate of less than 0.60  $L_a$  for all penetrations and valves subject to Type B and C tests, when pressurized to  $P_a$ .

APPLICABILITY: MODES 1, 2, 3, and 4.

### ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75  $L_a$  or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60  $L_a$ , restore the overall integrated leakage rate to less than 0.75  $L_a$  and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60  $L_a$  prior to increasing the Reactor Coolant System temperature above 200°F.

### SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates ~~shall be demonstrated at the following test schedule and~~ shall be determined in conformance with the test schedule, criteria, methods and provisions specified or endorsed in Appendix J ~~on~~ of 10 CFR Part 50:

- a. ~~Three~~ Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted ~~at 40 ± 10 month intervals~~ during shutdown at intervals as specified by Appendix J of 10CFR Part 50 or as permitted by Nuclear Regulatory Commission approved exemptions, at a pressure not less than  $P_a$ , 41.2 psig; ~~during each 10 year service period. The third test of each set shall be conducted during the shutdown for the 10 year plant inservice inspection;~~

SOUTH TEXAS-UNITS 1 & 2

3/4 6-2

Unit 1 - Amendment No. 26, 61

Unit 2 - Amendment No. 46, 50