

50-400  
401

**CP&L**

Carolina Power & Light Company

83 OCT 27 10:49

P. O. Box 101, New Hill, N. C. 27562  
October 19, 1983

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest (Suite 2900)  
Atlanta, Georgia 30303

NRC-132

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT  
1986-90 - 900,000 KW - UNITS 1 & 2  
UNMARKED BOLTS, ITEM 146


Dear Mr. O'Reilly:

On September 23, 1983, Mr. N. J. Chiangi notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The NRC was informed that bolts procured under site order H-42307 and site contract NPCD-80-10 were received and installed without the ASTM A-307 Grade A marking requirement.

CP&L has established a sampling plan to randomly select the affected bolts throughout the power block. Once the sampling plan is completed, the bolts will be destructively tested. In order to complete our sampling plan and the required testing, we will require until January 5, 1984 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons  
Project General Manager  
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)  
Mr. R. C. DeYoung (NRC)

OFFICIAL COPY

IE 27  
1/0

8311010162 831019  
PDR ADOCK 05000400  
S PDR