



NIAGARA MOHAWK POWER CORPORATION/NINE MILE POINT NUCLEAR STATION, P.O. BOX 63, LYCOMING, N.Y. 13093 /TEL. (315) 349-7263
FAX (315) 349-4753

CARL D. TERRY
Vice President
Nuclear Engineering

March 9, 1995
NMP2L 1530

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to the Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed is the proposed change to the Technical Specifications in Appendix A of the above mentioned license. Supporting information and analysis demonstrating that the proposed change involves no significant hazards consideration pursuant to 10CFR50.92 are included in Appendix B.

The proposed Technical Specification change contained herein represents a revision to Surveillance Requirement 4.6.1.2.a. Specifically, this change allows the second Primary Containment Integrated Leakage Rate Test (Type A) to be performed at refueling outage 5 (RF-05), or 72 months after the first Type A test. This change will also require an exemption from the Type A testing intervals as defined in 10CFR50 Appendix J, Section III.D.1.(a). Niagara Mohawk, under separate cover letter, dated March 9, 1995 (NMP2L 1531) has requested an exemption from the requirements of 10CFR50 Appendix J stated above. The exemption request demonstrates that the requested exemption presents no undue risk to the health and safety of the public and that special circumstances are present to justify granting of the exemption.

In order to support the upcoming Nine Mile Point Unit 2 refueling outage, approval of this application is requested by April 30, 1995.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazards consideration to the appropriate state representative.

Sincerely,

C. D. Terry
Vice President - Nuclear Engineering

210030

CDT/MGM/lmc
Attachments

9503210210 950309
PDR ADOCK 05000410
PDR

ADD1

xc: Regional Administrator, Region I
Mr. B. S. Norris, Senior Resident Inspector
Mr. L. B. Marsh, Director, Project Directorate I-1, NRR
Mr. G. E. Edison, Project Manager, NRR
Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223
Records Management