



PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

March 14, 1995

Docket Nos. 50-277
50-278
License Nos. DPR-44
DPR-56

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

SUBJECT: Peach Bottom Atomic Power Station, Units 2 and 3
Facility Operating License Change Request 94-08, Supplement 1

REFERENCE: Letter from G. A. Hunger, Jr., (PECO Energy) to NRC dated January 13, 1995.

Dear Sir:

The referenced letter transmitted PECO Energy Company's License Change Request (LCR) 94-08 requesting changes to Appendix A of the Peach Bottom Atomic Power Station (PBAPS) Facility Operating Licenses.

The proposed changes were requested to support PBAPS Modification P00068-3, which upgrades the major components of the Traversing In-core Probe (TIP) System.

This letter supplements our earlier submittal by providing additional information which was requested by the NRC. Additionally, we have included as Attachment 1, the most current Unit 3 marked-up Technical Specifications pages.

If you have any questions concerning this submittal, please contact us.

Sincerely,

G. A. Hunger, Jr.

G. A. Hunger, Jr.,
Director - Licensing

Enclosures: Affidavit, Attachment

cc: T. T. Martin, Administrator, Region I, USNRC
W. L. Schmidt, Senior Resident Inspector, PBAPS, USNRC
R. R. Janati, Commonwealth of Pennsylvania

9503210528 950314
PDR ADOCK 05000277
P PDR

ADD 1


COMMONWEALTH OF PENNSYLVANIA :

: SS.

COUNTY OF CHESTER :


D. M. Smith, being first duly sworn, deposes and says:

That he is Senior Vice President and Chief Nuclear Officer of PECO Energy Company; the applicant herein; that he has read the attached License Change Request (LCR 94-08, Supplement 1) for changes to the Peach Bottom Facility Operating Licenses DPR-44 and DPR-56, and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.




Senior Vice President and
Chief Nuclear Officer

Subscribed and sworn to
before me this 13th day
of March 1995.



Notary Public



PECO Energy Response to NRC Request for Additional Information

By telephone call, the NRC requested additional information regarding Modification P00068-3. Specifically, the NRC requested information regarding PECO Energy's plan for conducting post modification and future testing of the spare containment penetrations resulting from Modification P000683-3.

As a result of the modification, containment penetrations N-35B and N-35D will no longer be required for TIP system operation. The TIP tubing which passes through these penetrations will be cut on both sides of the drywell penetration. Both sides of the tubing will then be fitted with a flare union and capped with a Swagelock cap.

As part of the Modification P00068-3 acceptance test, the capped tubing in containment penetrations N-35B and N-35D will be pressure tested with air or nitrogen at 75 ± 5 psig. The test will be deemed acceptable when no leakage, (as determined by the capped area being "bubble free" by using leak detection fluid for > 1 minute) is observed. The 75 ± 5 psig test pressure is based on 125% of drywell rated pressure of 56 psig plus a 5 psig tolerance.

There are no other tests planned for these penetrations.