

CONTROL BLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

CON'T

0	7
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	3	3	7	1	0	0	4	8	3	8	1	1	1	1	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

0 2 | During a management review it was discovered that surveillance test F-ST-5B,
0 3 | "Average Power Range Monitor Instrument Functional Test" had exceeded the required
0 4 | frequency of seven days +/-25 percent as per Technical Specification Table 4.1-1 by
0 5 | eighteen minutes. F-ST-5B was immediately conducted and found satisfactory. No
0 6 | Hazards existed to public health and safety.
0 7 |
0 8 |

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	9	I	A	A		Z	Z	Z	Z	Z		Z					
7	8	9	10	11	12	12	13	13	18	19	15	20	16				
(17) LER-RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
8 3		8 3		0 4 5		0 3		X		1							
21 22		23 24		25 26		27 28		29 30		31 32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
H	Z	Z		Z		0 0 0	N	N		N		Z		Z	9 9 9		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48		

1 0 During a routine review of the surveillance schedule by the Shift Supervisor, it was

1 1 noted that surveillance test F-ST-5B was overdue on the surveillance schedule computer

1 2 printout. Responsible individuals involved have been counselled as to the importance

1 3 of timely surveillance schedule update and distribution. (See Attachment) Revision 1

1 4 submitted to correct typographical and editorial errors.

[illegible]

PHONE: (315) 342-3840 Ext. 302

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT

DOCKET NO. 50-333


ATTACHMENT TO LER 83-045/03X-1

Page 1 of 1

During a routine review of the surveillance schedule by the Shift Supervisor it was noted that surveillance test F-SI-5B was overdue on the surveillance schedule computer printout. Investigation revealed that the printout was not obtained and distributed until after surveillance test F-SI-5B was overdue.

Individuals involved have been counselled in the importance of timely surveillance schedule update and distribution. In addition, a change in the scheduling and updating of the surveillance schedule is being implemented to further reduce the probability of recurrence.

James A. FitzPatrick
Nuclear Power Regs.
P.O. Box 41
Lycoming, New York 13093
315 342.3840



Corbin McNeill
Resident Manager

November 1, 1983
JAFP 83-1088

Dr. Thomas E. Murley, Regional Administrator
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 83-045/03X-1

Dear Mr. Murley:

We have enclosed the referenced Licensee Event Report in accordance with Section 6.0 of Technical Specifications and USNRC Regulatory Guide 1.16.

If there are any questions concerning this report, please contact Mr. Douglas J. Lindsey at (315) 342-3840, Extension 302.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'Corbin', followed by a stylized flourish.

CORBIN A. McNEILL, JR.
RESIDENT MANAGER

CAM:RTL:dmh
Enclosure

CC: USNRC Document Control Desk (1)
Asst. Director of Operating Reactors,
USNRC Directorate of Licensing (1)
INPO Records Center, Atlanta, Georgia (1)
Internal Power Authority Distribution
NRC Resident Inspector
Document Control Center
LER/OR File

IE22
1/1