



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

April 6, 1995

TVA-SQN-TS-95-02

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

)
)

Docket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS)
CHANGE 95-02, "ADDITION OF PROVISIONS FOR OPERABILITY TESTING AND
DEFINITION OF TIME INTERVAL TO BYPASS CONDITION"

In accordance with 10 CFR 50.90, we are enclosing an amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change adds a new limiting condition for operation to Section 3.0 that allows equipment to be returned to service under administrative control to perform operability testing. This revision also defines the time interval to place a channel in bypass to be six hours in accordance with Action 18 of TS Table 3.3-3.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant safety hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

TVA requests a 45-day implementation period for this TS change following issuance.

110028

9504110261 950406
PDR ADDCK 05000327
P PDR

DO30

U.S. Nuclear Regulatory Commission
Page 2
April 6, 1995

Please direct questions concerning this issue to Keith Weller at (615) 843-7527.

Sincerely,

R. H. Shell

R. H. Shell
Manager
SQN Site Licensing

Sworn to and subscribed before me
this 6th day of April 1995

Peggy M. Billispley

Notary Public

My Commission Expires Oct. 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission

Page 3

April 6, 1995

(Enclosures):

Mr. D. E. LaBarge, Project Manager
Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
3rd Floor
L & C Annex
401 Church Street
Nashville, Tennessee 37243-1532

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711