

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

November 16, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Technical Specification Change
Mechanical Snubbers

Dear Mr. Denton:


South Carolina Electric and Gas Company (SCE&G) hereby requests a revision to Technical Specification Table 3.7-4b, "Safety Related Mechanical Snubbers," as shown on Attachment I. These changes have been determined to be necessary as a result of recent Feedwater System modifications and an engineering evaluation which was conducted to identify Mechanical Snubbers essential to plant safety, as addressed by the subject Technical Specification basis. Subsequent to installation, all snubbers included on the revised Table 3.7-4b have been subjected to the same examination and testing program as the Mechanical Snubbers previously identified in the Table.

SCE&G has determined that a finding of no significant hazards consideration is appropriate in that additional requirements are being added to the Technical Specifications.

This change has been reviewed and approved by our Plant Safety Review Committee (PSRC) and the Nuclear Safety Review Committee (NSRC). A check in the amount of Four Thousand Dollars (\$4000.00) is enclosed for processing this change.

If there should be any questions, please advise.

Very truly yours,



O. W. Dixon, Jr.

8311280364 831116
PDR ADOCK 05000395
P PDR

ARK:OWD:mac/fjc
Attachments
cc: See Page Two

CHECK #327261 A001
ENCLOSED
\$4,000.00
1/1

Mr. Harold R. Denton
Technical Specification Change
Mechanical Snubbers
Page Two
November 16, 1983

cc: V. C. Summer
T. C. Nichols, Jr./O. W. Dixon, Jr.
E. H. Crews, Jr.
E. C. Roberts
W. A. Williams, Jr.
D. A. Nauman
J. P. O'Reilly
Group Managers
O. S. Bradham
N. E. Clark
R. B. Clary
C. A. Price
A. R. Koon
C. L. Ligon (NSRC)
G. J. Braddick
D. J. Richards
NRC Resident Inspector
J. B. Knotts, Jr.
NPCF
File

Table 3.7-4b

Safety-Related Mechanical Snubbers*

System	Pacific-Scientific						
	Small		Size (Kips)			Large	
	<u>1/4</u>	<u>1/2</u>	<u>1</u>	<u>3</u>	<u>10</u>	<u>35</u>	<u>100</u>
BD	11	6	21	7			
CC	4	3	3	12	19	12	
CS	32	24	49	17			
DG				2	16		
EF	7		21	6	1		
FW	11	1	6	8	15	11	
MS	18	20	29	17	9	31	3
ND	1						
NG	2						
RC	12	31	94	50	13	3	
RH	8		17	87	50	3	
SF				1			
SI	58	19	32	47	44	5	
SP	3		5	53	7		
SW				12	13	3	
VU			2	2			
WD			5				
Subtotal-1	166	104	284	321	187	68	3
Subtotal-2		270		792		71	
TOTAL	1133						

*Snubbers may be added to safety-related systems without prior License Amendment to Table 3.7-4b provided that a revision to Table 3.7-4B is included in the next License Amendment request.