

  
**PECO ENERGY**

PECO Energy Company  
Nuclear Group Headquarters  
965 Chesterbrook Boulevard  
Wayne, PA 19087-5691

April 6, 1995

Docket No. 50-352  
License No. NPF-39

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Limerick Generating Station, Unit 1  
Revision of Inservice Inspection Interval Dates  
for the First Ten-Year Interval

Gentlemen:


PECO Energy Company has determined that it is necessary to revise the dates of the First Ten-Year Inservice Inspection (ISI) Interval for Limerick Generating Station (LGS), Unit 1, in order to effectively implement the requirements of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (B&PV) Code. This revision is required in order to allow the end of the inspection interval to envelope a scheduled refueling outage.

In accordance with 10CFR50.55a(g)(4), the First Ten-Year Interval ISI Program for LGS, Unit 1, conforms to the 1986 Edition of Section XI of the ASME Code. As stipulated in this edition of the Code (i.e., IWA-2430(d)), an inspection interval can be extended by as much as one (1) year to accommodate changes in outage schedules.

The LGS, Unit 1, First Ten-Year ISI Interval began on February 1, 1986, and is scheduled to end on February 1, 1996. The next refueling outage (i.e., Sixth, 1R06) for LGS, Unit 1, is presently scheduled to occur during the January 27, 1996 through March 1, 1996, time frame. Since Section XI of the ASME Code permits the ISI inspection interval to be adjusted by as much as one (1) year for outage correlation, the First Ten-Year ISI Interval for LGS, Unit 1, will be extended until the end of the Sixth Refueling Outage, which is currently scheduled to be March 1, 1996.

If you have any questions or require addition information, please do not hesitate to contact us.

Very truly yours,



G. A. Hunger, Jr.  
Director - Licensing

cc: T. T. Martin, Administrator, USNRC, Region I  
N. S. Perry, USNRC Senior Resident Inspector, LGS

140078

9504140173 950406  
PDR ADDCK 05000352  
Q PDR

A047  
1/0