



Job No. 11406-130
6600-1

CALCULATION COVER SHEET

DISCIPLINE Civil/Struct.



Calc. No. 11406-130
No. of Sheets 31

TITLE

A. P. & L. AUXILIARY BLDG. MISCELLANEOUS

SUBJECT

Spent Fuel Shipping Cask drop.

STATEMENT OF PROBLEM

In case of shipping cask drop in the 4th story
with impact on the floor, the floor was analyzed
to determine if it was sufficient to support the
cask without excessive deflection.

SAR CHECKED ☒

SAR CHANGE REQ'D ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA

Max. vert. dist. 9', Cask diameter 6'-0"
Concrete strength test = 467, 500, 551, 632.
Rein. min. 0.0018 in. Area 1.00 in. for 1 ft.
(FOR SH. 13-21) CASK DIMENSIONS 4'-2"

SOURCES OF FORMULAE & REFERENCES

ACI 318-71, Structures to resist the effects of accidental explosion
TM5-1300 Dept of the Army, June 1969
BC-TOP 9A 1012, CATALOGUE "TSE 122" FROM HEYCEL
"DESIGN OF CONCRETE STRU." BY WINTER, URBAN, O'ROURKE,
AND NILSON, 7TH ED. ACI-318-63

PRELIMINARY CALC ☐

FINAL CALC ☒

SUPERSEDES CALC NO. _____

REV. NO.	REVISION	CALCULATION BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
2	SH. 27-31	F. CHEN	9/78	T. Yeh	10/78	[Signature]	10/11/78
1	SH. 13-26	F. CHEN	3/78	BCM, Connell	3-25-78	[Signature]	10/11/78
	Final calc 1-125	Latouche	7-78		4-78	[Signature]	4/26/78



CALCULATION SHEET

0510 (11-74)

DESIGN BY L. T. Jerng DATE Feb 76 CHECKED BY KK's SHEET NO. 1
 PROJECT A #2 L - Aux 2-12 Unit #1 JOB NO. 11406-13
 SUBJECT Cable D-r CALCULATION NO. 11406-130 FILE NO. 11406-20

The calculation of unit "Cable drop" is followed the same procedure of unit #2

Data: Between (C) and (D)

Bottom rebar (#11 @ 6" & #11 @ 12") See DWG C-212

Top rebar (#10 @ 12") See DWG C-312

Stirrups 7-#5 per ft @ 12" See DWG C-212

Based on actual field certificates (See File 2-230)

$$F_y = 43.7 \text{ ksi} \quad (SHT 12A) \quad \text{Aux. Bldg.}$$

Concrete compressive strength is assumed $f'_c = 6500$ which is based on actual 6" x 12" cylinder. Strengths at 28 and 90 days extrapolated to four years. Because this part of concrete was approximately placed in Jan 1977 (SHT 12A)

From Table 5-3 "Structures to resist the effects of accidental explosions" TM5-1300 D-PT. of the Army, Washington D.C. Dated June 1969

Dynamic Increase Factor D.I.F. = 1.10

Slab $D = 3'-6"$ effective $d = 38"$ $d' = 3"$

Cable WT. $W_o = 225 \text{ K}$

$$E_c = 57,000 \sqrt{f'_c} = 57,000 \sqrt{6500} = 460,000 \text{ psi}$$

Poisson's Ratio $\nu = 0.2$

$$\text{Shear modulus } G = \frac{E}{2(1+\nu)} = \frac{460,000 \text{ ksi}}{2(1+0.2)} = 192,000 \text{ ksi}$$

Assumed slab $D = 3'-0"$ $d = 21"$

Rebar #5 $F_y = 55.2 \text{ ksi}$

From field certificates
File 2-2300

0057



CALCULATION SHEET

DB10 (11-74)

DESIGN BY L. T. Chang DATE MAR '76 CHECKED BY KV SHEET NO. 2
 PROJECT A F - L AUX. Bldg. unit #1 JOB NO. 11406-13
 SUBJECT Curb Drop CALCULATION NO. 11406-130 FILE NO. 11406-130

Slab @ 404's Between (C) & (D)

$$L \text{ at } B = 18'-0" = 216" \quad \frac{T_{ud}}{M_u} = 1.0$$

$$\rho = 0.0103 \left(= \frac{3 \times 1.56}{12 \times 38} \right)$$

$$W_{HL} = 0.15 \times 3.5 \times 18 = 9.45 \text{ K/FT}$$

$$A = 42 \times 216 = 9072 \text{ IN}^2$$


$$I_g = \frac{BD^3}{12} = \frac{216 \times 42^3}{12} = 1333,584 \text{ IN}^4$$

Allowable shear at a distance from support

$$V_c = [1.9 \sqrt{f'_c} + 2500 \rho \frac{T_{ud}}{M_u}] (DIF)$$

$$V_c = [1.9 \sqrt{6500} + 2500 \times 0.0103 \times 1] 1.1$$

$$= (153.5 + 25.7) 1.1 = 179 \text{ PSI}$$



0058



CALCULATION SHEET

DB 10 (11-76)

DESIGN BY L.T. Chang DATE 1/16/76 CHECKED BY KK SHEET NO. 3
 PROJECT A.P.L. Aux. Bldg. Unit #1 JOB NO. 11406-130
 SUBJECT Cable Drop CALCULATION NO. 11406-130 FILE NO. 11416-130

$$V_c = v_c B d = 0.179 \times 216 \times 38 = 1469.5$$

$$A_s f_y = 3(5 \times 0.31 \times 55.2) = 257 \quad \Sigma V_c = 1726$$

Available shear resistant force R_s

$$R_s = \frac{(2V_c - w_u C_1)L}{C_2/L} = \frac{1726 - 9.45 \times 7.53}{2/3} = 2482^K$$

$$\therefore R_s = 2482 \text{ kips}$$

Slab Response

(a) Initial Mode

Modulus of Rupture

$$f_r = 7.5 \sqrt{f'_c} D = F = 7.5 \sqrt{6500} \times 1.1 = 666 \text{ PSI}$$

Cracking moment

$$M_{cr} = f_r S = 0.666 \left(\frac{216 \times 42^2}{6} \right) = 42,294 = 3524 \text{ K-FT}$$

$$M_{uL} = \frac{w_u L^2}{12} = \frac{9.45 \times 24^2}{12} = 453.6 \text{ K-FT} = 5443.2 \text{ K-4}$$

Find available R_{cr}


$$R_{cr} = \frac{(M_{cr} - M_{uL})L^2}{C_1 C_2^2} = \frac{(42,294 - 5443)}{\frac{1}{3} \left(\frac{2}{3} \right)^2 \times 24 \times 12} = 863.7^K$$

Displacement at point of load

(Both bending & shear)

$$S_{cr} = \frac{R_{cr} C_1^3 C_2^3}{3 E_c I_g L^3} + \frac{R_{cr} C_1 C_2}{G A L} + \frac{w_u C_1^3 C_2^2}{24 E_c I_g} + \frac{w_u L^2}{6 G A}$$

$$R_{cr} = 864^K$$



6500



CALCULATION SHEET

0510 (11-74)

DESIGN BY L. T. Chang DATE MAR '76 CHECKED BY W.S. SHEET NO. 4
 PROJECT A F 2 L Aux Pldg Unit #1 JOB NO. 11406-130
 SUBJECT Cable Drop CALCULATION NO. 11406-130 FILE NO. 11466-130

AT one-third point

$$\delta_{cr} = \frac{864' \times 96^3 \times 0.67^3}{3 \times 4600 \times 1333.584} + \frac{864' \times 96 \times 0.67}{1920 \times 9072}$$

$$+ \frac{9.45 \times 8^2 \times 16^2 \times 1728}{24 \times 4600 \times 1333.584} + \frac{9.45 \times 24^2 \times 12}{6 \times 1920 \times 9072}$$

$$= 0.01248 + 0.00319 + 0.00182 + 0.00062$$

$$\delta_{cr} = 0.01811$$

(b) First Mode

Moment capacity

$$A_s' = 1.27 \times 18 = 22.86 \square$$

$$A_s = 3 \times 1.56 \times 18 = 84.24$$

$$a = \frac{A_s f_y}{0.85 f_c' B} = \frac{84.24 \times 48.3}{0.85 \times 6.5 \times 216} = 3.4''$$

$$+ M_u = A_s' f_y (d - d') + (A_s - A_s') f_y \left(1 - \frac{a}{2}\right)$$

$$M_u = 22.86 \times 48.3 (38 - 3) + (84.24 - 22.86) 48.3 \left(38 - \frac{3.4}{2}\right)$$

$$= 38644.8 + 107616.9 = 146261.7 \text{ K-in}$$


$$M_u = 12,188 \text{ K-FT}$$

$$M_u' = A_s' f_y (d - d') = 22.86 \times 48.3 (38 - 3)$$

$$M_u' = 38644.8 \text{ K-in} = 3220 \text{ K-FT}$$

$$R_1 = \frac{(M_u' - M_{u1}) L^2}{C_1 C_2^2} = \frac{3220 - 454}{8 \times \left(\frac{3}{3}\right)^2}$$

$$R_1 = 778 \text{ Kips}$$

R₁ = 77.



DESIGN BY L.T. Chang DATE MAR '76 CHECKED BY W.L. SHEET NO. 5
 PROJECT A P 2 L Aux. Bldg. JOB NO. 11406-130
 SUB. "CC" Cash Drop CALCULATION NO. 11406-130 FILE NO. 11406-130

(c) Second Mode

$$M_{F.D.L} = \frac{w_{DL} L^2}{8} = \frac{9.45 \times 24^2}{8}$$


$$M_{F.D.L} = 680.4 \text{ K-FT}$$

$$R_2 = \frac{2L^2 (M_u' - M_{F.D.L})}{C_1 C_2 (C_1 + L)}$$

$$R_2 = \frac{2 \times 24^2 (7220 - 680)}{8 \times 16 \times 32} = 714.4 \text{ K}$$

$$R_1 \text{ \& } R_2 < R_{cr}$$

Therefore the top rebar will pull out about the same time or shortly after concrete cracks



(d) Third Mode


$$M_p = \frac{w_{DL} C_1 C_2}{2}$$

$$M_p = \frac{9.45 \times 8 \times 16}{2} = 604.8 \text{ K-FT}$$

$$R_3 = \frac{(M_u - M_p)L}{C_1 C_2} = \frac{(12188 - 605) 24}{8 \times 16}$$

$$R_3 = 2172 \text{ K} < R_2 = 2482 \text{ K}$$

The slab failure will be governed in flexural mode.





DESIGN BY L.T. Chang DATE MAR '76 CHECKED BY KK SHEET NO. 6
 PROJECT AP 3 L Aux. Blig unit #1 JOB NO. 11406-130
 SUBJECT Crate Drop CALCULATION NO. 11406-130 FILE NO. 11406-130

$$\frac{M_{cr}}{M_u} = \frac{M_{cr}}{M_u} = \frac{3524^{K\cdot ft}}{12.188^{K\cdot ft}} = 0.289$$

$$\left(\frac{M_{cr}}{M_u}\right)^3 = 0.0242$$

$$p_n = 0.0103 \times 6.5 = 0.067$$

From Figure 4-1 BC TOP 9A REV. 2

$$F = 0.043$$

$$I_{cr} = F b d^3 = 0.043 \times 216 \times 38^3 = 509,651 \text{ in}^4$$


ACI-318-71 Section 9.5 Eq. 9-4

$$I_e = \left(\frac{M_{cr}}{M_u}\right)^3 I_g + \left[1 - \left(\frac{M_{cr}}{M_u}\right)^3\right] I_{cr}$$

$$I_e = 0.0242 \times 1333524 + [1 - 0.0242] 509,651$$

$$I_e = 32272.7 + 497,317.4 = 529,590.1 \text{ in}^4$$

$$\delta_y = \frac{R_3 C_1^2 C_2^2}{3 E_c I_e L} + \frac{R_3 C_1 C_2}{G A L} + \frac{w_{DL} L^2}{6 G A} + \frac{w_{DL}}{24 E I_e} (L^3 - 2 L C_1^2 + C_1^3)$$



$$\delta_y = \frac{2172 \times 76^2 \times 192^2}{3 \times 4600 \times 529,590 \times 288}$$

$$+ \frac{2172 \times 76 \times 192}{1920 \times 288 \times 9072} + \frac{9.45 \times 24^2 \times 12}{6 \times 1920 \times 9072}$$

$$+ \frac{9.45 \times 8}{24 \times 4600 \times 529,590} (288^3 - 2 \times 288 \times 76^2 + 76^3)$$

$$\delta_y = 0.3506 + 0.00798 + 0.000625 + 0.03775 = 0.397 \text{ in}$$



CALCULATION SHEET

0510 (11-74)

DESIGN BY L.T. Chang DATE MAR '76 CHECKED BY WMC SHEET NO. 7
 PROJECT A P & L Aux. Bldg unit #1 JOB NO. 11406-130
 SUBJECT Cask Drop CALCULATION NO. 11406-130 FILE NO. 11406-130

Energy Balance:

The slab will deform to three plastic hinges

$$\lambda W_0 H + W_0 \mu \delta_y + \frac{D}{2} \mu \delta_y = R_3 \delta_y (\mu - \frac{1}{2})$$

where

$$D = 0.15 \times 3.5 \times 18 (24 - 2.25) = 205.5$$

$$\lambda = \frac{W_0}{W_0 + D} = \frac{225}{225 + 103} = 0.686$$

$$0.686 \times 225 \times 9 + 225 \times 0.397 \mu + 103 \times 0.397 \mu = 2172 \times 0.397 (\mu - 0.5)$$

$$\mu = \frac{1389 + 431}{862 - 89 - 41} = 2.44 < \mu_c = 10$$

Available bending strain energy

$$B.E = R_3 \delta_y (\mu_{max} - \frac{1}{2}) = 2172 \times 0.397 (10 - 0.5) = 8192 \text{ K-in}$$

$$\mu \delta_y = 2.45 \times 0.397 = 0.99" = \delta_1$$

Cask drop energy transmitted to slab

$$K.E = W_0 [\lambda H + \mu \delta_y] + \frac{D}{2} \mu \delta_y$$

$$K.E = 225 [0.686 \times 9 + 2.49 \times 0.397] + 103 \times 0.99 = 1944 + 102 = 2046 \text{ K-in}$$

0063




CALCULATION SHEET

DS10 (11-74)

DATE 1.10.76

DESIGN BY L. T. Chan DATE MAR 76 CHECKED BY W. C. SHEET NO. 8
PROJECT A F 2 L Aux. Bldg Unit #1 JOB NO. 11406-130
SUBJECT Cable Drop CALCULATION NO. 11406-130 FILE NO. 11406-130



Force-Displacement Diagram
Between (C) and (D)



CALCULATION SHEET

0510 (6-71)

DESIGN BY L. T. Chang DATE MAR '76 CHECKED BY VKS SHEET NO. 9
 PROJECT A P 2 L Aux. Elev. unit #1 JOB NO. 11406-130
 SUBJECT Curb Drop FILE NO. 11406-130

This is a back up calculation for top reinf.
 exceeded $\mu = 10$ at column line C so
 that becomes hinge due to M_u
 C) CONT. Bending deflection
 δ_1 (due to dead load)

$$\delta_1 = \frac{w_0 C_1}{48 EI} (L^3 - 3LC_1^2 + 2C_1^3)$$

$$= \frac{9.45 \times 7.58}{48 EI} (288^3 - 3 \times 288 \times 91^2 + 2 \times 91^3)$$

$$\delta_1 = \frac{27.22 \times 10^6}{EI}$$

δ_2 (due to R_2)

$$\delta_2 = \frac{R_2 C_2^3}{12 EI L^3} (3L + C_2)$$

$$= \frac{1714 \times 91^2 \times 0.684^3 (3 \times 288 + 91)}{12 EI} = \frac{150.6 \times 10^6}{EI}$$

$$\delta_b = \frac{177.8 \times 10^6}{EI} = \frac{177.8 \times 10^6}{4600 \times 1.33 \times 10^6} = 0.029"$$

$$E_c = 4600 \text{ ksi} \quad I = 333.584 \text{ in}^4$$

Shear deflection

$$\delta_s = \frac{R_2 C_2}{GA L} + \frac{w_0 L^2}{6GA}$$

$$= \frac{714 \times 91 \times 0.684}{1920 \times 7072} + \frac{9.45 \times 24^2 \times 12}{6 \times 1920 \times 7072}$$

$$= 0.00255 + 0.00063 = 0.0032"$$

$$\Sigma \delta = 0.029 + 0.0032 = 0.0322"$$

0045



CALCULATION SHEET

0510 (8-71)

DESIGN BY L. T. Chang DATE MAR '76 CHECKED BY WV SHEET NO. 10
 PROJECT A P & L' Aux Bldg unit #1 JOB NO. 11406-130
 SUBJECT Cable Drop FILE NO. 11406-130


(d) Third Mode

$$L = 24'-0" = 288"$$

$$C_1 = 7'-7" = 91 \text{ IN}$$

$$C_2 = 16'-5" = 197 \text{ IN}$$

$$= 0.684 L$$



$$M_{DL} = \frac{W_{DL} C_1 C_2}{2}$$

$$M_{DL} = \frac{9.45 \times 7.58 \times 16.42}{2} = 588 \text{ K-FT}$$

$$M_u' = A_s' f_y (d - d')$$

$$= 22.86 \times 48.3 (37 - 3) = 38645 \text{ K-IN} = 3220 \text{ K-FT}$$

$$M_L + M_u' \frac{C_1}{L} - M_{DL} = \frac{R_3 C_1 C_2}{L}$$

$$12.188 + 3220 \times \frac{91}{216} - 588 = 12,957 \text{ K-FT}$$

$$R_3 = \frac{12,957 \times 24}{7.58 \times 16.42} = 2498 \text{ K}$$

$$\frac{M_{DL}}{M_u} = \frac{3524 \text{ K-IN}}{12188 \text{ K-IN}} = 0.289$$

$$\left(\frac{M_{DL}}{M_u} \right)^3 = 0.0242$$

$$p_n = 0.0103 \times 6.5 = 0.067$$

From Figure 4-1 BC TOP 9A RW. 2

$$F = 0.043$$

$$I_{cr} = F B d^3 = 0.043 \times 216 \times 37^3 = 509,651 \text{ IN}^4$$

$$I_C = \frac{M_{DL}}{M_u} I_g + \left[1 - \left(\frac{M_{DL}}{M_u} \right)^3 \right] I_{cr} = 0.0242 \times 1218584$$

$$+ [1 - 0.0242] 509,651 = 529,570 \text{ IN}^4$$

0066



CALCULATION SHEET

0810 (8-71)

DESIGN BY L. T. Chang DATE APR 76 CHECKED BY WZ SHEET NO. 11
 PROJECT A.P. 2.1 Aux. Bldg Unit #1 JOB NO. 11406-130
 SUBJECT Cable Drop FILE NO. 11406-130

(d) deflection

 δ_1 (due to dead load)

$$\delta_1 = \frac{w_3 C_1}{24EI} (L^3 - 2LC_1^2 + C_1^3)$$

$$= \frac{9.45 \times 7.58 (288^3 - 2 \times 288 \times 91^2 + 91^3)}{24 EI}$$

$$= \frac{59.3 \times 10^6}{EI}$$

 δ_2 (due to R_3)

$$\delta_2 = \frac{R_3 C_1^2 C_2^2}{3EI L} = \frac{2528 \times 91^2 \times 197 \times 0.684}{3EI} = \frac{940 \times 10^6}{EI}$$

 δ_3 (due to M_u')

$$\delta_3 = \frac{M_u'}{6EI} \left(3C_2^2 - \frac{C_2^3}{L} - 2LC_2 \right) \quad \text{see Roark's}$$

$$= \frac{43261 \text{ K-in}}{6EI} (2 \times 197^2 - 197^2 \times 0.684 - 2 \times 288 \times 197)$$

$$= \frac{169.3 \times 10^6}{EI}$$

Bending deflection

$$\delta_b = (59.3 + 940 + 169.3) \frac{10^6}{EI_e}$$

$$\delta_b = \frac{1163.6 \times 10^6}{4600 \times 529590} = 0.497''$$

00667



CALCULATION SHEET

0810 (5-71)

DESIGN BY L.T. Trang DATE MAR '76 CHECKED BY KES DATE 1/2/76
PROJECT A P L Aux. Bldg Wind #1 SHEET NO 12
SUBJECT Crack Drop JOB NO 11406-130
FILE NO 11406-130

Shear deflection

$$\delta_s = \frac{R_3 C_1 C_2}{G A L} + \frac{w_0 L^2}{6 G A}$$

$$= \frac{2492 \times 91 \times 0.684}{1920 \times 9072} + \frac{9.45 \times 24^2 \times 12}{6 \times 1920 \times 9072}$$

$$= 0.00392 + 0.0032 = 0.01212''$$

$$\delta_y = \delta_b + \delta_s = 0.497 + 0.012 = 0.509''$$

$$U = \frac{\delta_y}{\sum \delta} = \frac{0.509''}{0.0322} = 15.8 > U_{max} = 10$$

0068

4705 A to D

~~SH. 12A~~

SH. 12A

Concrete strength Test 505.1150-100

FILE NO. 114064

Init #1

		<u>28 DAY</u>	<u>90 DAY</u>	avg
A to C / 4705		4210	5340	1.27
pour # 375	B-2 # 469	4240	4530 *	
Elev. 404				
C to D / 1405	B-1	4850	6230	1.285
pour # 517	630	4950	6510	1.315
Elev. 404				
282 th g L.	631	4240	6370	1.50
		4920	6260	1.42
	632	4370	6010	1.375
		3400 *	5810	

These concrete strength and its age data, and rebar mill test reports are obtained from our field in 1975. The purpose is to check floor slab at 4.04' above control room whether failure mode in bending or shear under the extreme catastrophic accident i.e. the shipping cask 22.5 Kips drops from 9" above the floor. Calculation file number is 5.4
2.12

Lion T. Chan
4/6/76

68-10, 68-11

6-1-87

0100

2000

but its

Customer Care 1-800-444-4444

555-5-1-1111

Cit. No.

1000

15-16

[illegible]

Submitted and sworn to before me at Tulsa, Oklahoma, this 11th day of July, 2011.

2000 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042 2043 2044 2045 2046 2047 2048 2049 2050 2051 2052 2053 2054 2055 2056 2057 2058 2059 2060 2061 2062 2063 2064 2065 2066 2067 2068 2069 2070 2071 2072 2073 2074 2075 2076 2077 2078 2079 2080 2081 2082 2083 2084 2085 2086 2087 2088 2089 2090 2091 2092 2093 2094 2095 2096 2097 2098 2099 2100 2101 2102 2103 2104 2105 2106 2107 2108 2109 2110 2111 2112 2113 2114 2115 2116 2117 2118 2119 2120 2121 2122 2123 2124 2125 2126 2127 2128 2129 2130 2131 2132 2133 2134 2135 2136 2137 2138 2139 2140 2141 2142 2143 2144 2145 2146 2147 2148 2149 2150 2151 2152 2153 2154 2155 2156 2157 2158 2159 2160 2161 2162 2163 2164 2165 2166 2167 2168 2169 2170 2171 2172 2173 2174 2175 2176 2177 2178 2179 2180 2181 2182 2183 2184 2185 2186 2187 2188 2189 2190 2191 2192 2193 2194 2195 2196 2197 2198 2199 2200 2201 2202 2203 2204 2205 2206 2207 2208 2209 2210 2211 2212 2213 2214 2215 2216 2217 2218 2219 2220 2221 2222 2223 2224 2225 2226 2227 2228 2229 2230 2231 2232 2233 2234 2235 2236 2237 2238 2239 2240 2241 2242 2243 2244 2245 2246 2247 2248 2249 2250 2251 2252 2253 2254 2255 2256 2257 2258 2259 2260 2261 2262 2263 2264 2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283 2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302 2303 2304 2305 2306 2307 2308 2309 2310 2311 2312 2313 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2334 2335 2336 2337 2338 2339 2340 2341 2342 2343 2344 2345 2346 2347 2348 2349 2350 2351 2352 2353 2354 2355 2356 2357 2358 2359 2360 2361 2362 2363 2364 2365 2366 2367 2368 2369 2370 2371 2372 2373 2374 2375 2376 2377 2378 2379 2380 2381 2382 2383 2384 2385 2386 2387 2388 2389 2390 2391 2392 2393 2394 2395 2396 2397 2398 2399 2400 2401 2402 2403 2404 2405 2406 2407 2408 2409 2410 2411 2412 2413 2414 2415 2416 2417 2418 2419 2420 2421 2422 2423 2424 2425 2426 2427 2428 2429 2430 2431 2432 2433 2434 2435 2436 2437 2438 2439 2440 2441 2442 2443 2444 2445 2446 2447 2448 2449 2450 2451 2452 2453 2454 2455 2456 2457 2458 2459 2460 2461 2462 2463 2464 2465 2466 2467 2468 2469 2470 2471 2472 2473 2474 2475 2476 2477 2478 2479 2480 2481 2482 2483 2484 2485 2486 2487 2488 2489 2490 2491 2492 2493 2494 2495 2496 2497 2498 2499 2500 2501 2502 2503 2504 2505 2506 2507 2508 2509 2510 2511 2512 2513 2514 2515 2516 2517 2518 2519 2520 2521 2522 2523 2524 2525 2526 2527 2528 2529 2530 2531 2532 2533 2534 2535 2536 2537 2538 2539 2540 2541 2542 2543 2544 2545 2546 2547 2548 2549 2550 2551 2552 2553 2554 2555 2556 2557 2558 2559 2560 2561 2562 2563 2564 2565 2566 2567 2568 2569 2570 2571 2572 2573 2574 2575 2576 2577 2578 2579 2580 2581 2582 2583 2584 2585 2586 2587 2588 2589 2590 2591 2592 2593 2594 2595 2596 2597 2598 2599 2600 2601 2602 2603 2604 2605 2606 2607 2608 2609 2610 2611 2612 2613 2614 2615 2616 2617 2618 2619 2620 2621 2622 2623 2624 2625 2626 2627 2628 2629 2630 2631 2632 2633 2634 2635 2636 2637 2638 2639 2640 2641 2642 2643 2644 2645 2646 2647 2648 2649 2650 2651 2652 2653 2654 2655 2656 2657 2658 2659 2660 2661 2662 2663 2664 2665 2666 2667 2668 2669 2670 2671 2672 2673 2674 2675 2676 2677 2678 2679 2680 2681 2682 2683 2684 2685 2686 2687 2688 2689 2690 2691 2692 2693 2694 2695 2696 2697 2698 2699 2700 2701 2702 2703 2704 2705 2706 2707 2708 2709 2710 2711 2712 2713 2714 2715 2716 2717 2718 2719 2720 2721 2722 2723 2724 2725 2726 2727 2728 2729 2730 2731 2732 2733 2734 2735 2736 2737 2738 2739 2740 2741 2742 2743 2744 2745 2746 2747 2748 2749 2750 2751 2752 2753 2754 2755 2756 2757 2758 2759 2760 2761 2762 2763 2764 2765 2766 2767 2768 2769 2770 2771 2772 2773 2774 2775 2776 2777 2778 2779 2780 2781 2782 2783 2784 2785 2786 2787 2788 2789 2790 2791 2792 2793 2794 2795 2796 2797 2798 2799 2800 2801 2802 2803 2804 2805 2806 2807 2808 2809 2810 2811 2812 2813 2814 2815 2816 2817 2818

Thos. B. Bickel
New Britain Towne Cntry. Ods. 1

My Committee Expires 1st - 7-71.

 $M \cong K_0(T) \oplus \frac{1}{n}K_0(M^n)$

THIS CERTIFIED TEST REPORT HAS BEEN DELIVERED TO A CONSIGNEE OF MATERIAL PURCHASED FROM ARMO STEEL CORPORATION TO AVOID THE POSSIBILITY OF ITS MISUSE ON THE DELIVERY OF THIS REPORT TO A THIRD PARTY IT MUST BE IDENTIFIED BY

The Council, British, or National Tax Association

13

1871

1931-1932

6



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 3-12-78 CHECKED BCM DATE 3-22-78
PROJECT AP 4 L AUXILIARY SLAB UNIT #1 JOB NO. 11406-130
SUBJECT CASK DROP EVALUATION SHEET NO. 13

P.S. THE EVALUATION WAS TRANSMITTED TO AP 4 L BY LETTER
BL-G-369 DATED 3/11/78.

PROBLEM: A SHIPPING CASK OF TEST CONTROL RODS
WILL TRAVEL FROM THE RAILROAD MATCH
TO THE WASH DOWN AREA AND BACK
OVER THE CONTROL ROOM. BEFORE NRC
APPROVES THE OPERATION, A DROP
EVALUATION ALONG THE MOVEMENT ROUTE
MUST BE COMPLETED.

GIVEN: WEIGHT OF CASK = 25 TONS.
DIAMETER OF CASK = 4'-2"
MAX. HEIGHT OF VERTICAL DROP = 9"
FROM CAL. 2.12 CH 2, WE KNOW SLAB
CAPACITY GOVERNS. IF THE CASK DROPS
AT ABOUT 7'-0" FROM CENTER OF COL. C
OR D BETWEEN COL. LINE C AND D, IT
WILL GIVE MAX. SHEAR STRESS AT A
DISTANCE OF ONE EFFECTIVE DEPTH OF
THE SLAB FROM THE FACE OF THE WALL.

REQUIRED: 1. TO ANALYZE IF 9" MAX. DROP WILL CAUSE
ANY FAILURE OF SLAB OR NOT? IF IT
WILL, THEN.

2. WHAT IS THE MAX. DROP ALLOWED? OR


3. WHAT ARE OTHER OPTIONS?

SOURCES OF FORMULAE: BC-TOP-9, REV. 1, ACI-318-63
CATALOGUE "TDB 122" FROM HEXCEL.



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 2-21-78 CALC. NO. 11406-130 REV. NO. 2
PROJECT SFP-2 AUXILIARY BLDG-UNIT #1 CHECKED BCW DATE 3-22-78
SUBJECT CASK DROP EVALUATION JOB NO. 11406-130 SHEET NO. 14



DATA: REF. DWG. C-206 REV. 14 & C-212 REV. 9

$f'_c = 4,850 \text{ PSI @ 28 DAYS (FOUR NO. 517)}$

$f'_c = 6,500 \text{ PSI @ 4 YEARS BY INTERPOLATION}$
PER FIG 1.4 P. 15 OF "DESIGN OF CONCRETE
STRUCTURES" BY WINTER, URQUHART, O'ROURKE,
AND NELSON, 7TH EDITION.

$f_y = 40,000 \text{ PSI MIN. (48,300 PSI FROM MILL}$
CERTIFICATE (SEE FILE: 2-2300 AUX. BLDG)

SLAB: $t = 3'-6"$, $d = 38"$

PER AP & L LETTER NDC-6969 DATED 2/15/78

CASK WEIGHT = 50,000^{lb}

CASK DIAMETER = 4'-2"



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 2-27-78 CALC. NO. 1126-130 REV. NO. 2
 PROJECT AP & C AUXILIARY BLDG - UNIT #1 CHECKED Ben DATE 2-27-78
 SUBJECT CASK DROP EVALUATION JOB NO. 1126-130 SHEET NO. 15

1. P - Δ CURVE

USING FORMULA (4-2) OF EC-TOP-9

$$I_a = \frac{1}{2} (I_g + I_c) = \frac{1}{2} \left(\frac{bt^3}{12} + Fbd^3 \right)$$

$$\eta = \frac{As}{bd} = \frac{3 \times 1.56}{12 \times 38} = 0.010263$$

$$\begin{aligned}
 E_c &= 46^{1.5} \approx 3 \sqrt{\frac{f_c}{10}} \\
 &= (14.5)^{1.5} \times 33 \times \sqrt{4850} \\
 &= 4012699 \text{ PSI}
 \end{aligned}$$

$$\eta = \frac{E_s}{E_c} = \frac{29000000}{4012699} = 7.23 \text{ SAY } 7$$

CHECKERS' NOTE:

$f_c = 6500$ PSI FROM ACI 14.
 THIS WILL RESULT IN A
 CONSERVATIVE UNDERESTIMATE
 IN THE ENERGY ABSORPTION
 CAPACITY OF THE SYSTEM.

NO CALC REVISION
 REQUIRED Ben
 2-29-78

FROM FIG 2-1 OF EC-TOP-9

($\eta = 0.010263$, $\eta = 7$) GIVES $F = 0.045$

EFFECTIVE WIDTH OF BEAM

$$\begin{aligned}
 &= T + 2d \\
 &= 4'-2" + 2 \times (3'-2") \\
 &= 10'-6" \\
 &= 126" \\
 &t = 42"
 \end{aligned}$$

$$\begin{aligned}
 I_a &= \frac{1}{2} \times \left[\frac{126 \times (42)^3}{12} + 0.045 \times 126 \times (38)^3 \right] \\
 &= \frac{1}{2} \times (777924 + 311125) \\
 &= 544524 \text{ IN.}^4
 \end{aligned}$$



CALCULATION SHEET

ORIGINATOR F. CHEM DATE 2-27-78 CALC. NO. 11406-130 REV. NO. 2
 PROJECT AP-3 AUXILIARY ELDG-UNIT #1 CHECKED YCW DATE 3-27-78
 SUBJECT CASK DROP EVALUATION JOB NO. 11406-130 SHEET NO. 16

$$M_u = \phi \left[A_s f_y \left(d - \frac{a}{2} \right) \right]$$

$$\phi = 0.90$$

$$a = \frac{A_s f_y}{0.85 f_c' b} = \frac{3 \times 1.56 \times 10.5 \times 48.3}{0.85 \times 4.7 \times 10.5 \times 12} = 4.715"$$

$$M_u = 0.90 \times \left[3 \times 1.56 \times 10.5 \times 48.3 \times \left(38 - \frac{4.715}{2} \right) \right] \times \frac{1}{12}$$

$$= 6344.71 \text{ ft-k}$$

$$(P_3)_{\text{sl}} = \frac{24}{7 \times 17} \times 6344.71 - \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 \times 17 + \frac{1}{2} \times 10.5 \times 3.5 \times 0.15 \times 17$$

$$= 1279.51 \text{ k} - 66.15 \text{ k} = 1213.46 \text{ k}$$

$$\Delta_u = \frac{P a^2 b^2}{3 E_c I} + \Delta_0$$

$$= \frac{1213.46 \times (7 \times 17)^2 \times (12)^3}{3 \times 3950.159 \times 544524 \times 24} + 0.015$$

$$= 0.207 \text{ in.}$$

Δ_0 (INITIAL DEFLECTION DUE TO WT OF BEAM)

$$= \frac{w a}{24 E_c I} (l^3 - 2 f a^2 + a^3)$$

$$= \frac{10.5 \times 3.5 \times 0.15 \times 7}{24 \times 4012.699 \times 544524} \left[(24)^3 - 2 \times 24 \times (7)^2 + (7)^3 \right] \times (12)^3$$

$$= 0.015 \text{ in.}$$

$(P_0)_{\text{approximate}}$

$$= \frac{24}{7 \times 17} \times \left(\frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 \times 17 - \frac{1}{2} \times 10.5 \times 3.5 \times 0.15 \times 17^2 \right)$$

$$= 66.15 \text{ k}$$



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 2-27-78 CALC. NO. 11406-130 REV. NO. 2
 PROJECT APL AUXILIARY BLDG - UNIT #1 CHECKED Bcm DATE 3-28-78
 SUBJECT CASK DROP EVALUATION SHEET NO. 17

MAX. SHEAR CAPACITY

(1) FOR SHEAR CARRIED BY CONCRETE

$$\begin{aligned}
 V_c &= 1.9\sqrt{f'_c} + 2500 \rho_m \frac{Vd}{M} \\
 &= 1.9\sqrt{6500} + 2500 \times \frac{3 \times 1.55}{12 \times 38} \times 0.7 \quad \left(\frac{Vd}{M} = \frac{V \times 38}{V \times 54} = 0.7 \right) \\
 &= 153.18 + 17.96 \\
 &= 171.14 \text{ PSI} < 3.5\sqrt{f'_c} (= 282.13 \text{ PSI}) \quad \text{O.K.}
 \end{aligned}$$

$$V_c = \phi V_c b d = 0.85 \times 171.14 \times 126 \times 38 = 696506^{\text{N}} = 696.51^{\text{K}}$$

(2) FOR SHEAR CARRIED BY WEB REINFORCEMENT

$$\begin{aligned}
 V_c' &= \frac{A_v f_y}{b_w s} \\
 &= \frac{0.31 \times 48000}{46 \times 12} \quad \left(\#5 \text{ STIRRUP @ } \begin{matrix} 3'-10" \text{ IN E-W} \\ 1'-0" \text{ IN N-S} \end{matrix} \right) \\
 &= 27.12 \text{ PSI}
 \end{aligned}$$

$$V_c' = \phi V_c' b d = 0.85 \times 27.12 \times 126 \times 38 = 110372^{\text{N}} = 110.37^{\text{K}}$$

$$V_{\text{max}} = V_c + V_c' = 696.51 + 110.37 = 806.88^{\text{K}}$$

$$\frac{(P_s)_{\text{max}} \times 17}{24} + \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 - 4.7 \times 10.5 \times 3.5 \times 0.15 = 806.88^{\text{K}}$$

$$(P_s)_{\text{max}} = 1082.31^{\text{K}}$$

BOND STRESS AT FACE OF COLUMN

$$u = \frac{806.88 + 3.5 \times 10.5 \times 3.2 \times 0.15}{4.43 \times 3 \times 10.5 \times 0.852 \times 38} \times 1000 = 182.5 \text{ PSI}$$

$$< 543.2 \text{ PSI} \left(= \frac{9.5\sqrt{6500}}{1.41} \right)$$

O.K.



CALCULATION SHEET

CALC. NO. 11406-130 REV. NO. 2ORIGINATOR F. L. WEN DATE 2-27-78 CHECKED B. M. I. DATE 2-28-78PROJECT AP-1 L AUXILIARY BLDG - UNIT #1 JOB NO. 11406-130SUBJECT PACK 20-0 EVALUATION SHEET NO. 15

FOR P_1

$$\Delta = 0.207''$$
$$P = 1213.46 + 66.15 = 1279.61^K$$

FOR P_2

SEE PREVIOUS SHEET

$$P = 1082.31^K$$

$$\Delta = 0.207 \times \frac{1082.31}{1279.61} = 0.175 \text{ IN.}$$

FOR P_0

$$P = 66.15^K$$

$$\Delta = 0.015''$$




CALCULATION SHEET

ORIGINATOR E. CHEN DATE 2-27-78 CALC. NO. 11406-130 REV. NO. 2
PROJECT APPL AUXILIARY BLDG - UNIT #1 CHECKED BGM DATE 3-27-78
SUBJECT CASK DROP EVALUATION JOB NO. 1406-130 SHEET NO. 19

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34

P-Δ CURVE @ 7' TRIM SUPPORT



Δ, IN.



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 2-27-78 CALC. NO. 11406-130 REV. NO. 2
 PROJECT APPL AUXILIARY BLDG - UNIT #1 CHECKED Jem DATE 2-28-78
 SUBJECT CASK DROP EVALUATION JOB NO. 11406-130 SHEET NO. 20

2. ALLOWABLE HEIGHT OF DROP.

$$V_s^2 = 2gh, \quad M_m = \frac{50^k}{g}$$

$$M_e = \frac{\gamma_c T}{g} (D_x + 2T)(D_y + 2T) \quad (\text{FROM EQ 3-15 OF BC-7CP-5})$$

BECAUSE CASK IS CIRCLE, USE $M_e = \frac{\gamma_c T}{g} \times \frac{\pi (D+2T)^2}{4}$

$$M_e = \frac{1}{g} \times \left[\frac{\pi}{4} \times (11.1)^2 \times 3.5 \times 0.15 \right]$$

$$= \frac{50}{g}$$

$$E_s = \frac{M_m^2 V_s^2}{2(M_m + M_e)}$$

$$\frac{\left(\frac{50}{g}\right)^2 2gh}{2\left(\frac{50}{g} + \frac{50}{g}\right)} = \frac{1}{2} \times (10.8231 - 66.15) \times (0.175 - 0.015)$$

$$\therefore h = 3.19 \text{ IN.}$$

3. REQUIRED THICKNESS OF HEXCELL FOR 9" DROP.

FROM "DESIGN DATA FOR THE PRELIMINARY SELECTION OF HONEYCOMB ENERGY ABSORPTION SYSTEMS TSB/22 BY HEXCELL" P. 12

$$K.E. = f_{cr} \cdot A \cdot 0.7 t_c$$

$$\text{FOR } f_{cr} = 450 \text{ PSI}$$

$$t_c = \frac{\frac{1}{2} \times \frac{50000}{32.2} \times (2 \times 3.14 \times 9)}{450 \times \frac{\pi}{4} \times (50)^2 \times 0.7} = 0.728 \text{ IN.}$$

$$\text{FOR } f_{cr} = 400 \text{ PSI}$$

$$t_c = \frac{450}{400} \times 0.728 = 0.819 \text{ IN.}$$



CALCULATION SHEET

ORIGINATOR F. CHEN DATE 3-1-78 CALC. NO. 11406-130 REV. NO. 2
PROJECT _____ CHECKED Bcm DATE 3-28-78
SUBJECT CASK DROP EVALUATION JOB NO. 11406-130
SHEET NO. 21

ESTIMATED f_{cr} FOR HONEYCOMB
FOR 25 TON CASK

$$f_0 = \frac{50000}{\frac{\pi \times (50)^2}{4}} = 25.5 \text{ PSI}$$

$$f_1 = \frac{1061000}{\frac{\pi \times (50)^2}{4}} = 540.4 \text{ PSI}$$

$$f_{cr} = \frac{(25.5 + 540.4)}{2} = 282.95 \text{ PSI}$$

$\therefore$ USE $f_{cr} = 250 \text{ PSI}$

$$t_c = \frac{K.E.}{f_{cr} A 0.7}$$
$$= \frac{\frac{1}{2} \times \frac{50000}{32.2} \times 2 \times 32.2 \times 9}{250 \times 1963.5 \times 0.7}$$

$$= 1.3 \text{ IN.}$$

$\therefore$ USE 2" $f_{cr} = 250 \text{ PSI}$ HONEYCOMB

FOR 100 TON CASK

DIAMETER OF CASK = 6 FT BASED ON CAL. 2.12

$$t_c = \frac{\frac{1}{2} \times \frac{200000}{32.2} \times 2 \times 32.2 \times 9}{250 \times \frac{\pi}{4} (72)^2 \times 0.7}$$

$$= 2.53 \text{ IN.}$$

$\therefore$ USE 3" $f_{cr} = 250 \text{ PSI}$ HONEYCOMB

DATE 3-28-78

DESIGN BY F. CHEN DATE 3-17-78 CHECKED BY BCW SHEET NO. 22
 PROJECT AP 3 L AUXILIARY BLDG JOB NO. 11406-130
 SUBJECT CASK DROP EVALUATION CALCULATION NO. 11406-130 FILE NO. 11406-130

SUMMARY OF STRESSES FOR 25T CASK DROPDATA $f_c' = 6500 \text{ PSI @ 4 YEARS}$ $f_y = 48,300 \text{ PSI FROM MILL CERTIFICATE}$ CRITICAL DROP LOCATION: 7'-0" FROM END SUPPORT
GIVES MAX. FAILURE SHEAR.

(1) ON ED ON 3.00 IN. DROP WITH NO HEXCELL

(a) MAX. SHEAR FORCE AND SAFETY FACTOR

$$E_s = \frac{M_m^2 V_s^2}{2(M_m + M_e)}, \quad V_s^2 = 27 \text{ ft}^2$$

$$\frac{\left(\frac{50}{9}\right)^2 \times 27 \times 300}{2\left(\frac{50}{9} + \frac{50}{9}\right)} = \frac{1}{2} \times (P - 66.15) \times \left(\frac{0.175}{1082.31} P - 0.015\right)$$

$$75 = \frac{0.175}{2164.62} P^2 - \frac{27.81}{2164.62} P + \frac{1073.922}{2164.62}$$

$$0.175 P^2 - 27.81 P - 161272.58 = 0$$

$$P = \frac{27.81}{2 \times 0.175} + \frac{\sqrt{(27.81)^2 + 4 \times 161272.58 \times 0.175}}{2 \times 0.175}$$

$$= 1044.2 \text{ K}$$

V AT 38" FROM FACE OF WALL = MAX. SHARE

$$= \frac{17}{24} \times 1044.20 + \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 - 4.7 \times 10.5 \times 3.5 \times 0.15$$

$$= 779.88 \text{ K}$$

0075



CALCULATION SHEET

0810 (11-76)

DESIGN BY F. CHEN DATE 3-20-78 CHECKED BY BCM SHEET NO. 33
PROJECT A P & L AUXILIARY BLDG UNIT #1 JOB NO. 11406-130
SUBJECT CASK DROP EVALUATION CALCULATION NO. 11406-130 FILE NO. 11406-130

ALLOWABLE COMBINED SHEAR CAPACITY OF CONCRETE
AND WEB REINFORCEMENT

$$= 806.88^k$$

$$\text{SAFETY FACTOR} = \frac{806.88}{779.88} = 1.035$$

(b) MAX. MOMENT AND SAFETY FACTOR

M AT DROP POINT = MAX. MOMENT

$$M = \frac{1044.2 \times 17 \times 7}{24} + \frac{1}{2} \times 10.5 \times 3.5 \times 0.15 \times 17 \times (24 - 17)$$

$$= 5177.49 + 327.99$$

$$= 5505.98^{1-k}$$

$$\text{ALLOWABLE MOMENT CAPACITY} = 6344.71^{1-k}$$

$$\text{SAFETY FACTOR} = \frac{6344.71}{5505.98} = 1.15$$

(c) BOND STRESS

U AT FACE OF WALL = MAX. U

V AT FACE OF WALL

$$= \frac{17}{24} \times 1044.20 + \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 - 1.5 \times 10.5 \times 3.5 \times 0.15$$

$$= 797.52^k$$

$$u = \frac{797.520}{4.43 \times 3 \times 10.5 \times 0.852 \times 38} = 176.50 \text{ PSI}$$

0076



CALCULATION SHEET

0810 (11-74)

DATE 3-28-78DESIGN BY F. CHEN DATE 3-20-78 CHECKED BY BCM SHEET NO. 24PROJECT A P & L AUXILIARY BLDG UNIT #1 JOB NO. 11406-130SUBJECT CASK DROP EVALUATION CALCULATION NO. 11406-130 FILE NO. 11406-130

$$\begin{aligned}\text{ALLOWABLE BOND STRESS} &= \frac{9.5 \sqrt{f_c'}}{D} \\ &= \frac{9.5 \sqrt{6500}}{1.41} \\ &= 543.20 \text{ PSI}\end{aligned}$$

$$\text{SAFTY FACTOR} = \frac{543.20}{176.50} = 3.077$$

0077



CALCULATION SHEET

0510 (11-74)

DESIGN BY F. CHEN DATE 3-20-78 CHECKED BY Bm SHEET NO. 25
 PROJECT A P & L AUXILIARY BLDG UNIT #1 JOB NO. 11406-130
 SUBJECT CASK DROP EVALUATION CALCULATION NO. 11406-130 FILE NO. 11406-130

(2) BASED ON 9" DROP WITH 2 THICK $f_{cr} = 260 \text{ PSI}$ HEXCELLS

$$K.E. = f_{cr} \times A \times 0.7 t_c$$

$$f_{cr} = \frac{K.E.}{A \times 0.7 t_c}$$

$$= \frac{\frac{1}{2} \times \frac{50,000}{32.2} \times 2 \times 32.2 \times 9}{2 \times 1963.5 \times 0.7}$$

$$= 163.7 \text{ PSI} < 260 \text{ PSI}$$

$$P = 2600 \times 1963.5$$

$$= 510510 \text{ #}$$

$$= 510.51 \text{ K}$$

(a) MAX. SHEAR FORCE AND SAFTY FACTOR

V AT 38" FROM FACE OF WALL = MAX. SHARE

$$= \frac{17}{24} \times 510.5 + \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 - 4.7 \times 10.5 \times 3.5 \times 0.15$$

$$= 401.56 \text{ K}$$

CONSERVATIVELY ALLOWABLE COMBINED SHEAR
CAPACITY OF CONCRETE AND WEB REINFORCEMENT

$$= 806.88$$

$$\text{SAFTY FACTOR} = \frac{806.88}{401.56} = 2.009$$

0076



DESIGN BY F. CHEN DATE 3-20-78 CHECKED BY Boull SHEET NO. 26
PROJECT AP & L AUXILIARY BLDG UNIT #1 JOB NO. 11406-150
SUBJECT CASK DROP EVALUATION CALCULATION NO. 11406-130 FILE NO. 11406-130

(b) MAX. MOMENT AND SAFTY FACTOR

M AT DROP POINT = MAX. MOMENT

$$M = \frac{510.51 \times 17 \times 7}{24} + \frac{1}{2} \times 10.5 \times 3.5 \times 0.15 \times 17 \times (24 - 17) \\ = 2531.28 + 327.99 \\ = 2859.27 \text{ 'K}$$

ALLOWABLE MOMENT CAPACITY = 6344.71 'K

$$\text{SAFTY FACTOR} = \frac{6344.71}{2859.27} = 2.219$$

(c) BOND STRESS

U AT FACE OF WALL = MAX. U

V AT FACE OF WALL

$$= \frac{17}{24} \times 510.51 + \frac{1}{2} \times 24 \times 10.5 \times 3.5 \times 0.15 - 1.5 \times 10.5 \times 3.5 \times 0.15 \\ = 419.49 \text{ K}$$

$$u = \frac{419.490}{4.43 \times 3 \times 10.5 \times 0.852 \times 38} = 92.85 \text{ PSI}$$

ALLOWABLE BOND STRESS = 543.20 PSI

$$\text{SAFTY FACTOR} = \frac{543.20}{92.85} = 5.850$$

0079



CALCULATION SHEET

0 0 8 0

ORIGINATOR F. CHEN

DATE 9-17-78

CALC. NO. 11406-130 REV. NO. 2

PROJECT APL AUXILIARY BLDG UNIT #1

CHECKED TX DATE 10/6/78

SUBJECT CASK DROP EVALUATION

JOB NO. 11406-130

SHEET NO. 27

(COMPARISON BTW 1963 & 1971 ACI)

1963 REQUIREMENTS

1. SECTION MOMENTS FOR CALCULATING DEFLECTION ($\S 909(C)$)

$$I_e = I_g \quad \text{WHEN } A_s f_y \leq 500,000$$

$$I_e = I_{cr} \quad \text{WHEN } A_s f_y > 500,000$$

(USED: FORMULA (A-2) OF EC-7.10.2-9)

$$I_a = \frac{1}{2} (I_g + I_{cr})$$

$$2. E_c = 40^{1.5} 33 \sqrt{f'_c} \quad (\S 1102(a))$$

3. EFFECTIVE WIDTH OF BEAM NOT SPECIFIED

4. MOMENT CAPACITY ($\S 1601$)

$$M_u = \phi [A_s f_y (d - \frac{a}{2})]$$

(a) ϕ FOR MOMENT CAPACITY

$$\S 1504(b)$$

$$\phi = 0.90$$

$$(b) a = A_s f_y / 0.85 f'_c b = 12.1 \quad \S 1601(a) \quad \S 1504(b)$$

1971 REQUIREMENTS

1. $\S 9.5.2.2$

$$I_e = \left(\frac{M_k}{M_n} \right)^3 I_g + \left[1 - \left(\frac{M_k}{M_n} \right)^3 \right] I_{cr}$$

DIFF. WHERE

$$M_k = \frac{f_y I_g}{g + 1}, \quad f_y = 75 \sqrt{f'_c}$$

(USED: FORMULA (A-2) OF EC-7.10.2-9)

$$2. E_c = 40^{1.5} 33 \sqrt{f'_c} \quad (\S 8.3.1)$$

3. EFFECTIVE WIDTH OF BEAM NOT SPECIFIED

4. MOMENT CAPACITY

ANY FORMULA RECOGNIZED. THEN-TAKE FORMULA USED IN 1963 ACI CODE. CAN BE USED IN 1971 ACI CODE. ($M_u = \phi [A_s f_y (d - \frac{a}{2})]$)

(a) ϕ FOR MOMENT CAPACITY

$$\S 9.2.1.1$$

$$\phi = 0.90$$

$$(b) a = A_s f_y / 0.85 f'_c b = 10.27 \quad \S 10.2.7$$



CALCULATION SHEET

0081

ORIGINATOR	F. CHEN	DATE	9-19-78	CHECKED	ty	DATE	10/9/78	JOB NO.	11406-130	SHEET NO.	2
PROJECT	AD & S. AUXILIARY BLDG UNIT #1										
SUBJECT	CASK DROP EVALUATION										
(COMPARISON ETW 1963 & 1971 ACI)											

1963 REQUIREMENTS

5. SHEAR CAPACITY

(a) SHEAR CARRIED BY CONCRETE

§ 1701(d)

$$V_c = \phi b d (1.9 \sqrt{f'_c} + 2500 \rho \frac{V_d}{A_g})$$

$$\leq \phi b d 3.5 \sqrt{f'_c}$$

(1) $\phi = 0.85$ (§ 1504(b))

(2) $\rho_w = A_s / b' d$

$b' =$ WIDTH OF WEB IN T AND T SECTION

(3) $V =$ TOTAL SHEAR AT SECTION

(4) $M =$ BENDING MOMENT

(5) $V d \geq M$

(b) SHEAR CARRIED BY WEB REBAR'S OR $A_w \text{ REAR'D}$

(1) $A_w = \frac{V_u S}{\phi f_y d}$ (§ 1703(a))

WHERE $V_u' = \phi (V_u - V_c) b_w d$ AS IN

1971 ACI

(2) WHEN $V_u > 6 \phi \sqrt{f'_c}$, EVERY 45-DEG. LINE SHALL BE CROSSED BY AT LEAST TWO LINES OF WEB REBAR

1971 REQUIREMENTS

5. SHEAR CAPACITY

(a) SHEAR CARRIED BY CONCRETE

§ 11.4.2

$$V_c = \phi b d (1.9 \sqrt{f'_c} + 2500 \frac{\rho V_d}{b_w d})$$

$$\leq \phi b d 5 \sqrt{f'_c}$$

(1) $\phi = 0.85$ (§ 9.2.1.2)

(2) $\rho_w = A_s / b_w d$

$b_w =$ WEB WIDTH

(3) $V_u =$ TOTAL APPLIED DESIGN SHEAR FORCE AT SECTION

(4) $M_u =$ APPLIED DESIGN LOAD MOMENT AT SECTION, IN. LB

(5) $\frac{V_u d}{M_u} \leq 1.0$

(b) SHEAR CARRIED BY WEB REBAR'S OR $A_w \text{ REAR'D}$

(1) $A_w = \frac{(V_u - V_c) b_w s}{f_y}$ (§ 11.6.1)

(2) WHEN $(V_u - V_c) > 4 \sqrt{f'_c}$, s SHALL BE REDUCED BY ONE-HALF (§ 11.6.3)



CALCULATION SHEET

0082

ORIGINATOR	J. CHEN	DATE	9-20-78	CHECKED	—	DATE	10/19/78	11406-130	REV. NO.	2
PROJECT	AP & L AUXILIARY BLDG UNIT #1			JOB NO.	11406-130			29		
SUBJECT	CASK DROP EVALUATION			SHEET NO.						

(COMPARISON BETWEEN 1963 & 1971 ACI)

1963 REQUIREMENTS	1971 REQUIREMENTS
$V_u = \phi V_n$ (IN 1971 ACI)	$V_n = 2\sqrt{f'_c}$ (§ 11.4.1)
$\therefore \{V_u > 6\phi\sqrt{f'_c}\}$ OF 1963 $= \{(V_u - V_n) > 4\sqrt{f'_c}\}$ OF 1971	$V_n = \frac{V_u}{\phi}$ (IN 1963 ACI) (§ 11.2.1)
(3) $V_n \leq 10\sqrt{f'_c}$ (§ 1705)	(3) $(V_u - V_n) \leq 8\sqrt{f'_c}$ (§ 11.6.4)
(4) $A_{vmin} = 0.0015 bs$ (§ 1706(b)) $= 0.0015 \times 46 \times 12$ $= 0.83 in.^2$	(4) $A_{vmin} = 50 \frac{b_w s}{f_y}$ (§ 11.1.2) $= 50 \times \frac{46 \times 12}{48300} = 0.57 in.^2$
6. BOND CAPACITY IN TERM OF BOND STRESS	6. BOND CAPACITY IN TERM OF DEVELOPMENT LENGTH
(a) $u_n = \frac{V_u}{\phi 50 j d}$ (§ 1801 (a))	$l_d = 0.8(0.04 A_b f_y / \sqrt{f'_c})$ $\geq 0.8(0.0004 d_b f_y)$ (§ 12.5 (c) & (d))
(b) $u_n = \frac{M}{\phi j d 20 f_y}$ (§ 1801 (b)) OR $l_d = \frac{f_y d}{4 u_n}$ FOR $f_s = f_y$ FOR BARS OTHER THAN TOP BARS	ACCORDING TO COMMENTARY OF 1971 CODE (CHAPTER 12 GENERAL), l_d OF 1971 CODE IS SUPPOSED SAME AS OF 1963.
$u_n \leq \frac{9.5 \sqrt{f'_c}}{D}$ NOR 800 PSI (§ 1801 (c))	$0.8(0.04 A_b f_y / \sqrt{f'_c})$ $= 0.8 \times (0.04 \times 1.56 \times 48300 \times \frac{1}{\sqrt{6500}})$ $= 29.9 in.$ $0.8(0.0004 d_b f_y) = 0.8 \times 0.0004 \times 1.4 \times 48300$ $= 21.8 in.$ $\therefore l_d = 29.9 in. \approx 31.4 in.$



CALCULATION SHEET

0083

ORIGINATOR F. CHEN DATE 9-21-78 CALC. NO. 11406-130 REV. NO. 2
PROJECT AP & L AUXILIARY BLDG UNIT #1 CHECKED TX DATE 10/9/78
SUBJECT CASK DROP EVALUATION JOB NO. 11406-130
(COMPARISON BTW 1963 & 1971 ACI) SHEET NO. 30

1963 REQUIREMENTS
7. DISTRIBUTION OF FLEXURAL REINF.
(CRACK CONTROL)
NO PROVISION

1971 REQUIREMENTS
7. DISTRIBUTION OF FLEXURAL REINF.
(CRACK CONTROL)

MA.
$$Z = f_s \sqrt[3]{d_c A} \leq 175 \text{ KIPS/IN.}$$

(§10.6.3)
$$f_s = f_y = 48.3 \text{ KSI}$$

CG. OF BARS
$$= 2.21 + \frac{1}{3} \times 2.82$$

$$= 3.15"$$

TOTAL AREA OF CONC.
AROUND BARS
$$= 2 \times 3.15 \times 12$$


$$= 75.6 \text{ IN.}^2$$

$$A = \frac{75.6}{3} = 25.2$$

$$Z = 48.3 \sqrt[3]{2.21 \times 25.2}$$

$$= 184.4$$

$$> 175$$



COMPARISON BETWEEN 1963 AND 1971 ACI CODES

FOR

DROP EVALUATION SUMMARY

FOR

THE 25 TON HANDLING CASK

ELEVATION 404

(Over Control Room)

CAL. NO. 31

JOB # 11406-130

SH. NO. 11406-130

Case I - A drop evaluation for 3" travel height with no hexagonal honeycomb.

Case II - A drop evaluation for 9" travel height with 2 inches of hexagonal honeycomb.

The following results are based on Bechtel BC-TOP-9 (including formula 4-2 for effective moment of inertia for calculation of deflection) and the Ultimate Strength Design Methods:

	CASE I		CASE II	
	1963 Code	1971 Code	1963 Code	1971 Code
Shear Capacity Shear Computed	$\frac{807 \text{ kips}}{780 \text{ kips}} = 1.03;$	$\frac{807 \text{ kips}}{780 \text{ kips}} = 1.03$	$\frac{807 \text{ kips}}{401 \text{ kips}} = 2.01;$	$\frac{807 \text{ kips}}{401 \text{ kips}} = 2.01$
Moment Capacity Moment Computed	$\frac{6345 \text{ kip-ft}}{5506 \text{ kip-ft}} = 1.15;$	$\frac{6345 \text{ kip-ft}}{5506 \text{ kip-ft}} = 1.15$	$\frac{6345 \text{ kip-ft}}{2859 \text{ kip-ft}} = 2.22;$	$\frac{6345 \text{ kip-ft}}{2859 \text{ kip-ft}} = 2.22$
Bond Stress Capacity Bond Stress Computed	$\frac{543 \text{ psi}}{177 \text{ psi}} = 3.07;$	Calculation of peak bond stress not req'd	$\frac{543 \text{ psi}}{93 \text{ psi}} = 5.84;$	Calculation of peak bond stress not req'd
Development Length Provided	$\frac{33 \text{ in.}}{32 \text{ in.}} = 1.03;$	$\frac{33 \text{ in.}}{30 \text{ in.}} = 1.10$	$\frac{33 \text{ in.}}{32 \text{ in.}} = 1.03;$	$\frac{33 \text{ in.}}{30 \text{ in.}} = 1.10$
Development Length Required				