



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 NOV 30 4:22 PM 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-103/0 - Fire
Rated Penetrations Opened
to Implement a Design
Change Package
AECM-83/0754

On October 17, 1983, fire rated penetrations CE 230D, CE 205D, and CE 153D were opened to implement a design change package. A fire watch was established in accordance with Technical Specification 3.7.7 until the penetrations were resealed on November 2, 1983. This condition had no effect on the health and safety of the public and did not constitute a threat to plant safety.

This Special Report is submitted pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation time limit was exceeded.

Yours truly,

8312080033 831123
PDR ADOCK 05000416
S PDR

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

OFFICIAL COPY

FE 22

1/0