

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

7 8 9 80

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

80

W
C
C
P
P
P
P
P



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 28, 1983 23 DEC 5 49:38

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Offgas Pretreatment Monitor
Declared Inoperable
LER 83-177/03 L-0
AECM-83/0758

On October 29, November 2, and November 6, 1983, while placing the steam jet air ejectors in operation, water collected in the offgas pretreatment monitor resulting in improper flow through the monitor. The instrument was declared inoperable and a Limiting Condition for Operation was entered pursuant to Technical Specification 3.3.7.1. This is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-177/03 L-0 which is an interim report.

Yours truly,

L. F. Dale

L. F. Dale

for Manager of Nuclear Services

EBS/SHH:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

OFFICIAL COPY

IE 22
1/1