DEWATERING TOPICAL: CHEM-NUCLEAR SYSTEMS, INC CNSI-DW-11118-01-NP

> 23 December, 1983 Chem-Nuclear Systems, Inc. 240 Stoneridge Drive, Suite 100 Columbia, South Carolina 29210

B312280451 B31223 PDR TOPRP EMVCNSI B PDR

3

٠,

1

### ABSTRACT

Research results have certified dewatering of high integrity containers (HIC), steel liners with Ecodex, Powdex, bead resins, diatomaceous earths, celite 454, and Fibra-Cel. Liners and media specifically tested were PL14-195 (HIC), 76" Pressure Vessel, and L14-195 (steel) with bead resin, PL14-195 (HIC), PL8-120 (HIC), and L14-195 (steel) with Ecodex precoat and L14-195 (Steel) with Powdex precoat. Fiberglass Reinforced Plastic Vessels and 24" Pressure Vessels were also tested.

The largest liners, 14-195's with useable cubic feet interior volumes of 157, 150, 186, and 163, were considered the worst case for dewatering. The test procedure required the vessel to be loaded with the useable volume of precoat or resin and filled with water. The liner dewatering cycle was to pump for a certain time interval, stand for a time interval, and be repeated until dewatering was complete.

Bead moisture before and after road testing, as well as bead temperature, were monitored. Atmospheric data such as temperature, dew point, grains of moisture per pound of air, and relative humidity were analyzed for their impact on dewatering capabilities.

#### SUMMARY

- Chem-Nuclear Systems, Inc. (CNSI) has been providing dewatering processes since 1975. Currently, CNSI provides dewatering of Ecodex, Powdex, bead resins, and diatomaceous earth mixtures Celite 454, and Fibra-Cel. The dewatering process can be accomplished in High Integrity Containers and steel liners.
- 2 The low-level radioactive waste disposal site at Barnwell, South Carolina, requires that free-standing liquids not exceed 0.5% of the volume of waste in containers not designed for stability or 1.0% of the volume of waste in containers that are designed for stability. The Hanford, Washington, site criteria is more restrictive in that it requires no greater than 0.5% or 1 gallon of free-standing liquid, whichever is less.
- 3. This topical report addresses the certification of liners for dewatering. Larger liners, such as 14-195's, were considered the worst case for dewatering. Production liners of smaller diameter and height but with the same internal design and geometry are certified by testing the worst case.
- 4. Dewatering bead resin in steel liners is certified by results of testing given in Appendix 2 of CNSI-DW-11118-01-P. Appendix 1 of CNSI-DW-11118-01-P covers the test instructions and report.

- Dewatering bead resin in high integrity containers is certified by results of testing given in Appendix 3 of CNSI-DW-11118-01-P.
- 6. Appendix 6 of CNSI-DW-11118-01-P covers the test results for dewatering high integrity containers (PL14-195 and PL8-120) and steel liners (PL14-195) with Ecodex and Powdex precoats. Experience has shown Ecodex and Powdex to be the most difficult precoats to dewater. Certifying these worst-case precoats also certify less difficult to dewater precoats such as diatomaceous earths, celite 545, and Fibra-Cel.
- 7. The test procedures required the vessel to be loaded to the useable volume with precoat or resin and filled with water. The liner dewatering cycle was to pump for a certain time interval, stand for a certain time interval, and repeat until the dewatering was complete.
- 8. The dewatering end point was determined to be zero when less than 10 ml was collected over a 24-hour period. At that time, the vessel was loaded on a truck and driven 200 miles over secondary roads. If less than 10 ml was collected following the road test the liner was considered dewatered.

- 9. Testing and evaluation of extracted test resin showed the moisture content to be less than or equal to equilibrium with the static suspending ability of the resin bed and the amount of moisture contained within the bed. At less than or equal to the point of equilibrium, dynamic forces such as those experienced during transportation, would not cause precipitation of interstitial moisture.
- 10. Certification of dewatering bead resin in 76" diameter pressure vessels is found in Appendix 10 of CNSI-DW-11118-01-P. Pressure vessels of 24 inches in diameter containing activated carbon, bead, and macroreticular resins have been tested and recertification is in progress due to changes in internal design. The modification is expected to result in increased efficiency in the dewatering process.

### TABLE OF CONTENTS

## 1.0 INTRODUCTION

- 1.1 10 CFR 61.56
- 1.2 Free-Standing Liquid Criteria
- 1.3 Dewatering History

## 2.0 PROCESS DESCRIPTION

- 2.1 Precoats
- 2.2 Bead Resin
- 2.3 Process Requirements
- 2.4 Dewatering Process
- 2.5 Liquid Removal

# 3.0 EQUIPMENT DESCRIPTION

- 3.1 Filters
- 3.2 Liner Design Specifications
- 3.3 Level 1 Flat Bottom Liners
- 3.4 Level 1 Conical Bottom Liners
- 3.5 Levels 2-4 All Liners
- 3.6 Steel Liners
- 3.7 Polyethylene High Integrity Containers
- 3.8 76" Pressure Vessels
- 3.9 Fiberglass High Integrity Pressure Vessels
- 3.10 24" Steel Pressure Vessels
- 3.11 Weldment
- 3.12 Equipment Summary

i

- 4.G PROCESS OPERATION
  - 4.1 Process Control Program
- 5.0 EQUIPMENT ARRANGEMENT
  - 5.1 ALARA Design
  - 5.2 Maintenance Access
  - 5.3 Utility Requirements
  - 5.4 Typical Layout
- 6.0 REGULATIONS, CODES, AND STANDARDS
  - 6.1 Design and Fabrication
  - 6.2 Operating Equipment
  - 6.3 Operating Procedures
  - 6.4 System Processes
  - 6.5 ALARA

7.0 QUALITY ASSURANCE PROGRAM

- 7.1 Program Design
- 7.2 Responsibilities

# 8.0 ACCIDENT EVALUATION

- 8.1 Postulated Accident Analysis
- 8.2 Fire
- 8.3 Pressure Changes
- 8.4 Equipment Failures
- 8.5 Airborne Release
- 8.6 Liquid Pathway

 $\frac{2}{3}$ 

- 8.7 Incident Scenarios
- 8.8 Accident Evaluation: Case I, Hose Rupture
- 8.9 Accident Evaluation: Case II, Weld Rupture
- 8.10 Information
- 8.11 Notes
- 9.0 OPERATING EXPERIENCE AND RESEARCH RESULTS
  - 9.1 Operating Experience
  - 9.2 Exposure to Personnel
  - 9.3 Waste Characteristics
  - 9.4 Bead Resin Test Material
  - 9.5 Process Control Program
  - 9.6 Testing
  - 9.7 L14-195 BTRC (Steel) Results
  - 9.8 PL14-195 R (HIC) Results
  - 9.9 Precoat Test Instructions
  - 9.10 Precoat Test Results
  - 9.11 76" Diameter Pressure Vessel
  - 9.12 24" Diameter Pressure Vessel
  - 9.13 Atmospheric Results
  - 9.14 Hydrostatic Testing
- 10.0 APPENDICES
  - 10.1 Test Instructions and Report: Bead Resin
  - 10.2 Test Results: L14-195 (Steel) Liners with Bead Resin

1

1

14. 19. 19.

4

10

10.3	Test Results: PL14-195 (HIC) Liners with Bead Resin
10.4	Precoat Test Instruction and Report
10.5	Precoat Test Results
10.6	Description of Test Bead
10.7	Manufacturer Specification of Powdex
10.8	Atmospheric Data
10.9	Hydrostatic Testing
10.10	Test Summary and Results: 76" Pressure Vessel with Bead Resin

iv



## 1.0 INTRODUCTION

- 1.1 On 25 October, 1978 the U.S. Nuclear Regulatory Commission published an Advanced Notice of Proposed Rulemaking (43 FR 49811) regarding the development of specific regulations for the disposal of low-level radioactive wastes (LLW). The regulations affected were 10 CFR Parts 2, 19, 20, 21, 30, 40, 51, 61, 70, 73, and 170. This topical specifically addresses Part 61.56 (a)(3) and (b)(2), Waste Characteristics.
- 1.2 The low-level radioactive waste disposal site at Barnwell, South Carolina, requires that free-standing liquids not exceed 0.5% of the volume of waste in containers not designed for stability or 1.0% of the volume of waste in containers that are designed for stability. The Hanford, Washington, site criteria is more restrictive in that it requires no greater than 0.5% or 1 gallon of free-standing liquid, whichever is less.
- 1.3 Chem-Nuclear Systems, Inc. (CNSI) has been providing dewatering processes since 1975. Currently, CNSI provides dewatering of Ecodex, Powdex, bead resins, macroreticular resin, activated carbon, cartridge filters, and diatomaceous earth mixtures. The dewatering process can be accomplished in High Integrity Containers, and steel liners.

# PROCESS DESCRIPTION

### 2.0 PROCESS DESCRIPTION

Traditionally, precoats such as Powdex, Ecodex, and 2.1 Diatomaceous Earth (DE) are found in light water reactor waste treatment streams. The precoat in solution deposits on an element that then becomes the filter layer. As the molecules within the fluid stream tend ward the direction of desired flow, there is a gradual buildup of the filter layer. As this filter layer builds up the contaminants are trapped farther from the initial layer. Eventually, the collection of contaminants reduces the overall efficiency of the filter media and the system is backflushed with pressure. The precoat is put back in solution and the process begins anew. Ultimately, it becomes necessary to discard and dewater the precoat because of inefficiency. It then becomes necessary that precoats are disposed in accordance with 10 CFR 61.

- 2.2 Bead resins are used to demineralize liquid streams at light water reactors. Resins are usually in the hydrogen or hydroxyl form. The liquid stream flows through the bed and the liquid is deionized. When breakthrough occurs (ionic contaminants appear on the clean side) the feed water is discontinued and the bed is regenerated or replaced. When "loaded" bead is replaced, dewatering of the bed is necessary before ultimate disposal.
- 2.3 The dewatering process uses an air-driven double-diaphram positive displacement pump. For precoat media, there is a 1-1/2" manifold with four 3/4" valved

2 - 1

inlet connections and a 1-1/2" outlet connection. Vacuum gauges are provided at each inlet connection and manifold.

- 2.4 Dewatering occurs when the pump provides a continuous suction on a vessel. This suction removes pumpable liquid to a predetermined quantity or percentage of the waste form. The suction time will vary according to the resin or precoat and container used.
- 2.5 The water removed from a vessel is returned to the plant's waste treatment system.

. .



## 3.0. EQUIPMENT DESCRIPTION

3.1 Filters

The filtration system used by CNCI consists of a shelf-model filter (at varying lengths) a specially engineered CNSI Filter Assembly Type-1, and a special lateral resin filter.

3.1.1 Shelf-Model Filter

- 3.1.1.1 The shelf filters are made of self-bonded polypropylene fiber and they contain no additives such as resin binders, lubricants, or antistatic agents. The fiber matrix and filter width are randomly oriented. There are four to five hundred layers of fibers which are capable of capturing particles larger than 20 microns in size. The filter has greater density near the center, thereby allowing a gradient of trapped particle sizes. This results in a greater holding capacity before fouling.
- 3.1.1.2 Maximum fouling and structural deformation occurs at a differential pressure of 40 psi. There is no loss of integrity at maximum fouling, however.

3.1.1.3 The shelf filters have a crush strength of approximately 60 psi (using parallel plate method - 50% core deflection) when subjected to temperature of 200°F. The addition of solvents tends to reduce the strength of fiber-to-fiber bonding and the overall stiffness of fibers.

3.1.2 CNSI Filter Assembly Type-1

3.1.2.1 The CNSI Filter Assembly Type-1 was designed by Chem-Nuclear for use with Ecodex precoats. The filter is cylindrical and has 2 stages; primary and secondary. The secondary stage is capable of removing particles 40-60 microns in diameter. Permeability, as measured by a Frazier Test, is over 100 CFM/ft<sup>3</sup>. Three different lengths are used according to the physical dimensions of liners. The end caps are metal and are coated to inhibit rust and corrosion.

3.1.3 Lateral Resin Filter

The lateral resin filters used are available in three basic sizes: small, medium, and large.

- 3.2 Liners L14-195, PL14-195, PL14-195R, PL14-170, PL14-170R, PL7-100, and PL7-100R have the same internal design and manufacturing specifications. Precoats such as Powdex, Ecodex, SW-10, Diatomaceous Earth, and Solka Floc can be placed in these liners and dewatered. There are four banks of filters and the number of filters per bank varies according to the physical dimensions of the liner. All the banks are interconnected with PVC piping via a common manifold. Each bank can operate independently or in unison. Each bank is offset 90° from the lower bank and appears cross-hatched when viewed from above. There are intermittent holes over the length of PVC pipes. There are no holes in the PVC pipes that do not run through filters. A float switch or Fava level probe indicates the volume of material in the container.
- 3.3 Internal Equipment description of level 1 of PL14-195 and PL14-170 is proprietary.
- 3.4 Internal Equipment description of conical bottom liners is proprietary.
- 3.5 Levels 2-4 on all the containers have 14 CNSI Type 1 filters.
  - 3.5.1 Powdex. Powdex can be dewatered in PL14-195, PL6-80R, PL8-120R, and L14-195 Model "E" containers.
- 3.6 Steel Liners (See CNSI Drwg. E 334-0200-E01, Rev. G)

- 3.6.1 Steel liners are available in various sizes and are used to dewater bead resins and precoats. Table 3-3 identifies the overall dimensions of the various liners available. The internal design of all the liners is the same except that the length of pipes, laterals, etc. is scaled up or down according to the geometry of the liner.
- 3.6.2 The interior preparation for coating liners consists of an application of two coats of paint (nominally 5 mils DFT per coat). Alternative methods may be used if approved by Quality Assurance. The exterior preparation consists of an application of one coat of paint (nominally 3 mils DFT per coat). Alternative methods may be used if approved by Quality Assurance.

Table 3-4 . Manufacturing Specifications of Steel Liners

Liner	Height (inches)	Diameter (inches)	Empty Wt. (1bs)	Gross Wt. (lbs)	Disposable Volume (ft <sup>3</sup> )	e Used in Cask	Useable Volume (ft <sup>3</sup> )
L-6-80 L7-100 L14-195 L21-300 L18-450 L4-85 L8-120	57 40 78.5 107.5 100 100 74.2	58 74.5 76 82 83.5 44 61	975 1,275 1,650 2,225 2,150 925 1,100	7,500 8,500 16,500 26,000 25,000 7,500 10,000	85 101 230 322 308 88 126	6-807-10014-19521-30018-4504-858-120	66 74 163 273 257 76 100
L14-170	72.5	74.5	1,575	14,000	183	14-1/0	12 /

## Equipment Description

3.7 Polyethylene High Integrity Containers (see CNSI Dwg. B-120-D-0008 Rev. B and 120-D-0009 Rev. A). Polyethylene liners are available in various sizes and are used to dewater bead resins and precoats. Tables 3-6 and 3-7 identify the overall dimensions of the various conical and flat-bottom liners available. The internal design of all the liners is the same except that the length of pipes, laterals, etc. is scaled up or down according to the geometry of the liner.

#### Table 3-5: Manufacturing Specifications of Polyethylene High Integrity Containers (Conical Bottom)

Liner	Height (inches)	Diameter (inches)	Empty wt. (1bs)	Gross wt. (1bs)	Disposable Volume ft <sup>3</sup>	Used in cask	Maximum Internal Volume ft <sup>3</sup>
PI.14-1958	75.5	74	480	12,200	195	14-195	164
PL14-170R	70	72.5	295	10,700	172	14-170	144
PL8-120R	72	60	235	7,500	121	8-120	103
PL7-100R	38	72.5	182	6.250	93	7-100	68
P16-80R	55	57	230	5,000	84	6-80	69
PL4-85R	98	43	232	5,300	88	4-85	75

Table 3-7.

-

Manufacturing Specifications of Polyethylene High Integrity Containers (Flat Bottom)

Liner	Height (inches)	Diameter (inches)	Empty wt. (11/s)	Gross wt. (1bs)	Disposable Volume ft <sup>3</sup>	Used in cask	Maximum Internal Volume ft <sup>3</sup>
PL14-195	75.5	74	395	12,200	195	14-195	171
PL14-170	71	72.5	349	10,800	172	14-170	151
PL8-120	73	60	290	7,500	121	8-120	107
PL7-100	39	72.5	238	6,250	93	7-100	75
PL6-80	56	57	222	5,000	88	6-80	72
PL4-85R	98	43	232	5,300	88	4-85	75

0

- 3.8 76" Pressure Vessel
  - 3.8.1 The 76" Pressure Vessel is so-named because of its diameter. The vessel can be provided to operate at pressures up to 150 psi. The vessel is hydrostatically tested at 1.5 times its rated operating pressure for 30 minutes per ASME Section VIII.
  - 3.8.2 The 76" Pressure Vessels are designed to operate at three purification rates: 50, 100, and 200 gallons per minute. They are referred to as Assembly 1, 2, and 3.
  - 3.8.3 The vessel has 4 outlets on the top. They are: inlet for contaminated water, outlet to remove purified water, dewatering outlet, and a vent used to discharge gas.
  - 3.8.4 Contaminated water flows down through the resin bed and is purified. Purified water is removed via another PVC lateral system called the Lower Sparger Sub-Assembly. This system has the same type and diameter pipe as the distribution laterals.
  - 3.8.5 The purpose of the off-gas vent is to remove gases that may build up during the dewatering processes.

- 3.9 Fiberglass High Integrity Container
  - 3.9.1 The Fiberglass High Integrity Pressure Vessel (FRP), is 79" high, with an maximum outer diameter of 27 inches.
  - 3.9.2 The vessel is designed to operate at a pressure of 100 psi and a temperature of 140°F (200°F maximum). The empty weight is 350 pounds, and the gross weights is 1,600 pounds. Container integrity is hydrostatically tested at 150 psi for 30 minutes as per ASME Section VIII with no visible leakage.
  - 3.9.3 The purpose of the off-gas vent is to remove gases that build up during the demineralization operation and allow air to enter the liner during the dewatering operation.
  - 3.9.4 The vent allows the discharge of gasses that may build up during processing.
  - 3.9.5 The outlet is the dewatering leg. The dewatering flow rate determines pipe diameter.
  - 3.9.6 Flow rate options are 25, 50, and 100 gallons per minute. The laterals are curved according to the geometry of the cylinder bottom. The lateral curvature center point is relative to the vessel center. A series of slots is drilled in each lateral over a five-inch plane.

3.10 24-Inch Steel Pressure Vessel

- 3.10.1 The 24-Inch Steel Pressure Vessel has an outer diameter of 24 inches.
- 3.10.2 The shipping cask configurations determine the height of this vessel. Typically, the vessels are either 78-7/8, 51, or 72 inches high. The vessel is pressure tested at 150 psig. The interior is prepared by commercial sandblasting per specification SSPC-SP-7 and painted. Typically, two coats (4-5 mils each for a total of 8-10 mils) are required.
- 3.10.3 The exterior is prepared for coating by commercial sandblasting as per specification SSPC-SP-6 and painted with one coat of paint.
- 3.10.4 All other 24-Inch Steel Pressure Vessel Specifications are applicable to the 24-Inch Fiberglass High Integrity Container discussed in the previous paragraphs.

#### 3.11 Weldment

- 3.11.1 Welding on liners is accomplished by individuals qualified per ASME, Section IX. Prior to welding, all procedures are approved by Quality Assurance.
- 3.11.2 All sharp edges are deburred and weld spatter is removed. Welds are free from flux and arc strikes. The quality of the weld is inspected in accordance with AWS D1.1-81, Structural Welding Code, Section 9.25.1.

3-9

- 3.12 Dewatering Equipment
  - 3.12.1 Unit Hoses. The pressurized hoses employed in the demineralization system are hydrotested to 225 psig. Hoses that are under continuous pressure are a reinforced non-collapsible type. All hoses are connected to the piping with quick connects.
  - 3.12.2 Accessories. A dewatering skid or an air-driven positive displacement pump is provided with the system. The skid is equipped with positive displacement pumps that are used to dewater spent vessels. Shielding is used to minimize exposure to CNSI personnel.







## 4.0 PROCESS OPERATION

#### 4.1 Process Control Program

4.1.1

The "Final Waste Classification and Waste Form Technical Position Papers," by the NRC dated May 11, 1983, states that the requirement of free-standing water not greater than (1.0% for containers not designed for stability or 0.5% for containers that are) a certain percentage of the waste volume can be measured using the method described in ANS 55.1. This method, found in Appendix 2, ANS 55.1-1979, states that there shall be no free liquid visible flowing or dripping from a one-inch square breach. Based on these guidelines and definitions it is interpreted to mean that no more than 1.0% or 0.5% of the free-standing water can be collected at the time of free-standing water measurement. This precise distinction between what is free-standing water and what is not provides the basis for setting an end-point equal to zero and back calculating to verify that no more than a certain quantity of liquid waste remains in the liner.

4.1.2 Chem-Nuclear has generic process control programs for dewatering bead resin and precoats such as Ecodex, Powdex, and diatomaceous earths. Site specific procedures are generated from the generic procedures. The documents are found in section 4.0 CNSI-DW-11118-01-P.

4-1



#### 5.0 EQUIPMENT ARRANGEMENT

- 5.1 All equipment is located and installed to comply with As Low As Reasonably Achieveable (ALARA) operator dose requirements. Allowances for maintenance access is a critical consideration when arranging equipment. Components are located such that access to lower radiation areas when maintenance must be performed does not require passage through zones of higher radiation. The main control panel, for example, is located outside the waste process areas. To the greatest extent possible, all operations are remotely performed from the control panel.
- 5.2 Skids, pumps, etc. are arranged to allow ease of component inspection and maintenance access. The space required for the resin transfer and dewatering skid (RTDS) is determined by the physical layout of the plant's radwaste area and the type of unit utilized.

### 5.3 Utility Requirements

5.3.1 The following support activities are required due to the nature of a mobile service to simplify relations between the CNSI operator and the utility staff.

- 5.3.2 Telephone communication between the plant operator and the CNSI mobile unit operator must be provided by the utility.
- 5.3.3 The utility shall make prior arrangements for shipping of the dewatered material.
- 5.3.4 The utility must be prepared to accempt component (HIC's, P.V.'s, steel liners, etc.) shipments prior to the arrival of the unit on site.
- 5.3.5 The utility shall issue a Radiation Work Permit (RWP) to the CNSI operator before operations begin (according to its radiation protection procedures).
- 5.3.6 The utility shall provide the CNSI operator with any clothing or equipment for necessary radiation protection.
- 5.3.7 A controlled area must be established around the processing area.
- 5.3.8 The utility will provide crane services, torque wrenches, and other material necessary for loading the disposable liners and preparing the solidified waste for shipment. (Portable units also require crane service for placing fillhead on the liner on the liner during operation).

-

- 5.3.9 The utility will provide a forklift capable of 4,000 pounds at 6 feet moment aim to unload the removable skids and place them in position for full-scale solidification.
- 5.4 Typical Layout









- 6.0 REGULATIONS, CODES, AND STANDARDS
- 6.1 Design, fabrication, operation, and maintenance of CNSI dewatering technology is performed in accordance with the applicable regulations, codes and standards of the nuclear industry.
- 6.2 Operating Equipment is designed to meet the following:
  - 6.2.1 10 CFR 20. Standards for Protection Against Radiation. Occupational exposure and contamination controls were coupled with the ALARA concept in the design phase.

6.2.2 Nuclear Regulatory Commission Regulatory Guides

- 6.2.2.1 Regulatory Guide 8.10. Standing Operating Procedures CN-AD-012, Training and Indoctrination Program; CN-AD-013, Test Control; and CN-AD-019, ALARA Policy; help insure that exposures are kept ALARA. Additional training is provided on the job. Design, operations, and procedures face continual update so that the ALARA philosophy is followed.
- 6.2.2.2 Regulatory Guide 1.143. In the design phases of the dewatering system, CNSI took account of the applicable objectives in Regulatory Guide 1.143 to assure compatibility with utility radioactive waste streams.

6-1


## 6.2.3 American Nuclear Standards Institute

6.2.3.1 ANSI 55.2 (ANSI N199-1976), Liquid Radioactive Waste Processing System for Pressurized Water Reactor Plants. This standard establishes requirements and provides recommendations and guidelines for the design, construction, and performance of pressurized water reactor liquid radioactive waste processing systems. Design requirements and recommendations, as well as quality requirements, are presented. Various process steps and alternate methods of handling and disposing of input quantities of liquid radioactive waste are discussed along with sizing, capacity, arrangement, and redundancy of the system. Instrumentation and control requirements are further provided as well as operating guidance to assure that the performance, safety, and operational objectives of this standard are met. Portions of ANS 55.2 were used to couple equipment design with the operational objectives of this standard.

6.2.3.2 ANS 55.3 (ANSI N197-1976), Boiling Water Reactor Liquid Radioactive Waste Processing System this standard establishes minimum requirements and provides recommendations and guidelines for the design, construction, and

performance with due consideration for operation of boiling water reactor liquid radioactive waste processing systems. Design requirements and recommendations as well as quality requirements are presented. Various process steps and alternate methods of handling and disposing of input quantities of liquid radioactive waste are discussed along with sizing, capacity, arrangement and redundancy of the system. Instrumentation and control requirements are further provided as well as operating

guidance to assure that the performance, safety, and operational objectives of this standard are met. Portions of ANS 55.3 were used to couple equipment design with the operational objectives of this standard.

6.3 Operating procedures were developed to meet the following:

6.3.1 Federal Regulations

6.3.1.1 10 CFR 20. Operator training, system design, and operational procedures were developed with emphasis on protection of personnel and the environment against radiation hazards associated with the receiving and processing of low-level radioactive waste. The training program is an auditable, separate activity from CNSI operating divisions.

6.4

- 6.3.1.2 10 CFR 50. All documents, procedures, and drawings used in the fabrication, testing, operation, and maintenance of this equipment are developed and controlled in accordance with the provisions established in V and VI of Appendix B. Actual operation and processing performed with this equipment is accomplished at a licensed facility and thus is subject to the rules and regulations contained in the utility license.
- 6.3.1.3 10 CFR 71. Provisions are established in the Assembly/Disassembly procedure to ensure that proper precautions and measures are taken to contain potential contamination sources prior to placement into approved shipping containers as required in Section 13 of Appendix E. Actual shipment of LSA material must be accomplished by designated utility staff personnel at the customer's site.

6.3.2 CNSI Standards

11

6.3.2.1 QA-AD-001 Quality Assurance Program. This equipment is fabricated, tested, operated, and maintained under CNSI's Quality Assurance program which meets or exceeds the appropriate requirements of ASME Boiler and Pressure Vessel Code Section VIII, ANSI N45.2-1977, 10 CFR 50,

0

Appendix B, 10 CFR 71 Appendix E and Mil. Q. 9858 A. This program was reviewed by the NRC and has approval Number 0231, Revision 1, assigned.

6.4 System Processes

- 6.4.1 10 CFR 20. All operations performed at a customer's site are subject to the provisions of the utility license. A Radiation Work Permit, or equivalent, issued by that facility is required prior to commencement of any waste transfer or processing evolution. All operators receive training in the standards for protection against radiation prior to being sent to any utility. Satisfactory completion of radiation workers training at any facility is also required.
- 6.4.2 NRC Regulatory Guides 8.10. CNSI provides services to licensed utilities and as such is subject to the rules and regulations enforced at a particular site. The training provided to our operators emphasizes the need to keep operational exposures to radiation as low as reasonably achieveable. This is reinforced by the training programs at various utilities subject to the provisions of this guide.

6.5 Compliance with "ALARA"

6.5.1 The system design and arrangement is in compliance with "ALARA" as specified in the NRC Regulatory Guide 8.10. As shown on the CNSI layout drawings, the system arrangement allows remote operation.

All waste-bearing components and piping are provided with a complete flushing capability to insure that the equipment radioactivity levels have been reduced to the maximum extent possible.

6.5.2 The length of pipe and hose runs are minimized to the shortest possible and practical distance between two points.



e.

- 7.0 QUALITY ASSURANCE PROGRAM
- 7.1 Program Design
  - 7.1.1 CNSI's Quality Assurance Program is designed to ensure that the systems or components developed by CNSI will perform satisfactorily in service. The Quality Assurance Program has been accepted by the NRC and is auditable by customers and regulatory agencies. The Quality Assurance responsibilities outlined below are spectic to Quality Assurance's involvement in the dewatering system. However, they may be extrapolated to other safety-related issues. CNSI's Quality Assurance Program meets the requirements of 10 CFR 50 Appendix B and 10 CFR 71 Appendix E.

## 7.2 Quality Assurance Responsibilities

7.2.1 Inspection Control

The inspection program for the dewatering system verifies that quality-related components of the dewatering system conform to design or process requirements. Scheduled and unannounced inspections or audits of field units are routinely performed by CNSI's Quality Assurance inspectors. (Refer to CNSI Document QA-AD-001, Quality Assurance Program.)

#### 7.2.2 Drawing and Document Control

The Quality Assurance Program confirms the adequacy and completeness of all Dewatering Unit drawings, procedures, and instructions. All changes to drawings or documents are subject to the same confirmation. These controls are detailed in the CNSI Drawing Control and CNSI Document Storage and Control Procedures.

7.2.3 Purchased Material, Equipment of Service Control

Quality Assurance inspectors perform preliminary evaluations of potential vendors and makes procurement recommendations to CNSI's Purchasing, Solidification, Demineralization, and Design groups. Inspectors confirm that the supplied items or services conform to the procurement requirements.

7.2.4 Component & Material Identification and Control

The Quality Assurance Program confirms that the identification and control of purchased components, materials, parts or assemblies used within the dewatering system meet the established requirements. This applies to all phases of fabrication and installation.

7.2.5 Special Process Control

Quality Assurance inspectors confirm that fabrication, installation, and inspection processes associated with the dewatering system are performed in accordance with the applicable CNSI requirements.

#### 7.2.6 Test Control

The Quality Assurance test control program confirms that tests associated with dewatering, fabrication, checkout, operation, and maintenance are performed in accordance with the applicable CNSI requirements.

#### 7.2.7 Measuring and Test Equipment Control

Equipment used for testing of dewatering equipment is calibrated and traceable to NBS standards.

7.2.8 Handling, Storage, and Shipping Control

The Quality Assurance Program confirms that handling, storage, and shipping requirements of any item related to dewatering, including the unit itself, are satisfied.

#### 7.2.9 Nonconformance Control

Quality Assurance inspectors identify and document nonconforming materials, parts, or processes dealing with dewatering operation.

#### 7.2.10 Corrective Action

Quality Assurance inspectors continually monitor materials, processes, and workmanship to ensure that noncomforming items are corrected and the corrective action is documented.

CHEM-NUCLEAR SYSTEMS, INC.

U.S. NUCLEAR REGULATORY COMMISSION 1 APPROVAL NUMBER

FIGURE 7-1

QUALITY ASSURANCE PROGRAM APPROVAL

NRC FORM 311

(12-78)

.



0231

REVISION NUMBER

orders of the Nuclear Re	gulatory Commission now	or hereafte	er in effect and to	any conditions sp	DATE
2. NAME	r Systems, Inc.				
STREET ADDRESS	in Sistema and			January	31, 1985
P.O. Box 18	366	7.5	ZIP CODE	4. DOCKET NUM	ABER .
Bellevue	1	A	98009	71-0231	
S. QUALITY ASSURANCE P	ROGRAM APPLICATION DA	ATE(S)			
September (	5, 1979				
6. CONDITIONS				in a start and a start and a start and a start	2 at the start
Activities	conducted under a	applicab	le criteria	of Appendix	E of 10 CFR
Part 71 to	he executed with	repard	to transpor	tation packad	tes by
Part /1 to	DE EXECUCEU WICH	regard	eo eranspor	cocion pocka	, , , , , , , , , , , , , , , , , , , ,
January 1,	1980.				
	2011 - E. E. E.				
and the second					

Division of Fuel Cycle and MEROPRATERYety, HMSS



## ACCIDENT EVALUATION

- 8.0 ACCIDENT EVALUATION
- 8.1 Postulated Accident Analysis
  - 8.1.1 The design, fabrication, and operation of the CNSI Resin Transfer and Dewatering Skid is in accordance with the appropriate NRC, ASME, ANSI, and IEEE Codes and Standards to ensure the safe and reliable dewatering of the waste. Nonetheless, accidents are statistically plausible and have the potential for the release of radioactivity to the surrounding area. A description of plausible accidents and an analysis of the releases that may occur are summarized in this section.

#### 8.2 Fire

8.2.1 The only source of fire is the electrical power and control system when these components are used. In the event of an electrical fire the fail-safe control system is designed to prevent leakage of radioactive materials or spread of the fire to non-electrical components. When available, fire fighting equipment is provided to the operator to perform the initial fighting of the fire with backup provided by the station fire brigades.

#### 8.3 Pressure Changes

8.3.1 Pressure changes in sealed liners are possible yet are unlikely. Overpressure could result from

media temperature reaching 212°F, thereby causing free water to form steam (experience has shown that media temperature reaching 212° is an unlikely event). The overpressure could then cause a rupture and spill the contents.

8.4 Equipment Failures

8.4.1 Waste Isolation Valve

8.4.1.1 The waste isolation valve is provided with a manual override to enable the opening of the valve should it fail in the closed position. Manual override will allow the completion of the waste fill and flushing cycle so that the dewatering of the current waste batch can proceed and allow repairs to be made between batches under relatively low exposure conditions. Failure of the waste isolation valve in the open position is backed up by the telephone communications with the utility operator, i.e., if the valve does not snut when the correct waste volume has been transferred, waste flow can be stopped by the utility staff.

## 8.5 Airborne Release

8.5.1 Dewatering operations do not normally result in airborne release. Safety precautions such as grab air samples or continuous air monitoring are taken at the discretion of the utility. In some instances, the liner opening may be covered with a fillhead or sealed pan, which may be connected to the utility's off-gas system.

## 8.6 Liquid Pathway

8.6.1 There is no credible liquid pathway offsite due to the double barrier of liner and cask and the coupling to the utility drain systems.

## 8.7 Incident Scenarios

8.7.1 Statistically, a release of radioactive material may occur during the transfer operation or while the radioactive waste is in the container prior to dewatering. In this regard, two scenarios are envisaged: a filling hose rupture and a bottom weld rupture of a full liner.

8.7.2 Case I

A hose rupture during filling activities is seen to be the least serious of the scenarios. This is because the quantity of radioactivity spilled is a function of operator response time and the quantity of radioactivity in the filling hose at any given time. The operator response time is dependent upon observance of the malfunction and the time necessary for physically closing the waste isolation valve. During operation, the operator is positioned near the control station and visually monitors the transfer process. It is estimated that no more than two minutes would elapse between hose rupture and valve closing. Since flow rates of 25, 50, and 100 gallons per minute are expected, the worst-case scenario is a spill of 200 gallons. Table 8-1 shows that if this scenario happens, Cobalt-58 and -60, Cesium-134 and -137, Iodine-131, and Manganese-54 will contribute 27% of MPC at the site boundary (10 CFR 20, Appendix B, Table II, Column 1, Soluable, 1 Dec. 1978).

#### 8.7.3 Case II

A bottom weld rupture of a full liner is seen as the most serious of the incident scenarios but is even less likely than Case I. It is only more serious because the total volume spill is greater. The largest liner dewatered contains a maximum of 1,466 gallons of waste (196 ft<sup>3</sup>) and, depending on the contact radiation readings, are filled either in or out of a cask. If the waste

stream is high activity the liner is inserted into a cask and then filled. Thus, a bottom weld rupture in this operational mode would cause the spill of 1,466 gallons maximum into a cask and the contents would be contained. Therefore, no release to the environment is envisaged.

8.7.3.1 If the waste stream is low activity or the liner is not filled in a cask, then a bottom weld rupture could spill the contents and environmental release is possible. Table 8-1 shows that if this scenario occurred, the listed radionuclides would contribute 36.8% of the MPC allowable under Table II.

8.8 ACCIDENT EVALUATION: CASE I, Hose Rupture

8.1.1 Co-58 MPC

1. release rate:

 $\frac{1.67 \text{ gal}}{\text{sec}} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times \frac{1.2\text{E}-3 \text{ Ci}}{\text{ft}^3} = 2.68 \text{ E}-4 \frac{\text{Ci}}{\text{sec}}$ 

2. partition factor 100,000

2.68 E-4  $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{1} \xrightarrow{\text{E+6}} \frac{\text{uCi}}{\text{Ci}} \times \frac{1}{100,000} = 2.68 \text{ E-3} \frac{\text{uCi}}{\text{sec}}$ 

3. at site boundary

7.75 E-4  $\frac{\sec}{m^3}$  x 2.68 E-3  $\frac{uCi}{\sec}$  x  $\frac{1E-6}{1}$  = 2.1 E-12  $\frac{uCi}{m1}$ 

4. % of MPC

2.1 E-12 <u>uCi</u><u>m1</u> x 100% = 7.0 E-3% of MPC<u>3 E-8 uCi</u><u>m1</u>

8.8.2 Co-60

1. release rate

 $\frac{1.67 \text{ gal}}{\text{sec}} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times \frac{1.4\text{e}-3 \text{ Ci}}{\text{ft}^3} = 3.1 \text{ E}-4 \frac{\text{Ci}}{\text{sec}}$ 

2. partition factor: 100,000

3.1 E-4 
$$\frac{\text{Ci}}{\text{sec}} \times 1$$
 E+6  $\frac{\text{uCi}}{\text{Ci}} \times \frac{1}{100,000} = 3.1$  E-3  $\frac{\text{uCi}}{\text{sec}}$ 

3. at site boundary

7.75 E-4 
$$\frac{\sec}{m^3} \times \frac{3.1 \text{ E-3}}{\sec} \times \frac{1 \text{ E-6 m}^3}{1 \text{ ml}} = \frac{2.4 \text{ E-12 } \text{ uCi}}{\text{ml}}$$

3.50m

4. % of MPC 2.4 E-12 uCi ml x 100 = 2.4 E-2% of MPC 1 E-8 uCi m 1 Cs-134 8.8.3 1. release rate 1.67 gal x  $\frac{1 \text{ ft}^3}{\text{sec}}$  x  $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$  x  $\frac{8.5 \text{ E-3}}{\text{ft}^3}$   $\frac{\text{Ci}}{\text{ft}^3}$  = 1.9 E-3  $\frac{\text{Ci}}{\text{sec}}$ 2. partition factor: 100,000 1.9 E-3  $\frac{Ci}{sec} \times 1$  E+6  $\frac{uCi}{Ci} \times \frac{1}{100,000} = 1.9$  E-2  $\frac{uCi}{sec}$ 3. at site boundary 7.75 E-4  $\frac{\sec}{m^3}$  x 1.9 E-2  $\frac{uCi}{\sec}$  x  $\frac{1 E-6 m^3}{1 m^1}$  = 1.47 E-11  $\frac{uCi}{m^1}$ 4. % of MPC  $\frac{1.47 \text{ E-11 } \text{uCi}}{1 \text{ E-9 } \text{uCi}} \times 100\% = 1.5\% \text{ of MPC}$ 8.8.4 Cs-137 1. release rate 1.67  $\frac{gal}{sec} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times \frac{1.69 \text{ E-2}}{\text{ ft}^3} = 3.77 \text{ E-3} \frac{Ci}{sec}$ 2. partition factor: 100,000  $3.77 \text{ E-3} \frac{\text{Ci}}{\text{sec}} \times \frac{1 \text{ E+6 uCi}}{\text{Ci}} \times \frac{1}{100,000} = 3.77 \text{ E-2} \frac{\text{uCi}}{\text{sec}}$ 3. at site boundary 7.75 E-4 sec x 3.77 E-2 uCi x  $\frac{1 \text{ E-6 m}^3}{\text{m1}}$  = 2.92 E-11 uCi m1

34.7

4. % of MPC

8.8.5 Iodine-131

1. release rate

1.67 gal x  $\frac{1 \text{ ft}^3}{\text{sec}}$  x  $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$  x 1.4 E-3  $\frac{\text{Ci}}{\text{ft}^3}$  = 3.1 E-4  $\frac{\text{Ci}}{\text{sec}}$ 

2. partition factor: 10,000

3.1 E-4  $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{\text{Ci}} = \frac{6}{\text{Ci}} \times \frac{1}{10,000} = 3.1 \text{ E-2} \frac{\text{uCi}}{\text{sec}}$ 

3. at site boundary

7.75 E-4  $\frac{\sec}{m^3}$  x 3.1 E-2  $\frac{uCi}{\sec}$  x  $\frac{1 E-6 m}{1 ml} = \frac{3}{2}.4 E-11 \frac{uCi}{ml}$ 

4. % of MPC

 $\frac{2.4 \text{ E-11 } \text{uCi}}{\text{m1}} \times 100\% = 24\% \text{ of MPC}$   $\frac{1 \text{ E-10 } \text{uCi}}{\text{m1}}$ 

8.8.6 Managnese-54

1. release rate

1.67 gal x 
$$\frac{1 \text{ ft}^3}{\text{sec}}$$
 x  $\frac{6 \text{ E}-4}{7.48 \text{ gal}}$   $\frac{\text{Ci}}{\text{ft}^3}$  = 1.34 E-4  $\frac{\text{Ci}}{\text{sec}}$ 

2. partition factor: 100,000

1.34 E-4 
$$\frac{\text{Ci}}{\text{sec}} \times 1$$
 E+6  $\frac{\text{uCi}}{\text{Ci}} \times \frac{1}{100,000} = 1.34$  E-3  $\frac{\text{uCi}}{\text{sec}}$ 

3. at site boundary

1.34 E-3 <u>uCi</u> x 7.75 E-4 <u>sec</u> x  $\frac{1 \text{ E-6 m}^3}{\text{m}^3}$  = 1.04 E-12 <u>uCi</u> sec <u>m^3</u> 1 m1

4. % of MPC

 $\frac{1.04 \text{ E-12 } \text{uCi}}{1 \text{ E-8 } \text{uCi}} \times 100\% = \frac{1.04 \text{ E-2 \% of MPC}}{1 \text{ m1}}$ 



- 8.9 Case II, Bottom Weld Rupture
- 8.9.1 Cobalt-58
  - 1. release rate:

143.3 gal x  $\frac{1 \text{ ft}^3}{\text{sec}}$  x  $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$  x  $\frac{6 \text{ E-5}}{\text{ft}^3}$   $\frac{\text{Ci}}{\text{ft}^3}$  = 3.63 E-4  $\frac{\text{Ci}}{\text{sec}}$ 

2. partition fraction: 100,000

3.63 E-4  $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{2} \frac{\text{E+6}}{\text{Ci}} \times \frac{1}{100,000} = \frac{3.63 \text{ E-3}}{\text{sec}} \frac{\text{uCi}}{\text{sec}}$ 

3. at site boundary

3.63 E-3 <u>uCi</u> x 7.75 E-4 <u>sec</u> x  $\frac{1 \text{ E-6 m}^3}{\text{m}^3}$  = 2.81 E-12 <u>uCi</u> m1

4. % of MPC

 $\frac{2.81 \text{ E}-12 \text{ uCi}}{\text{m1}} \times 100\% = \frac{9.38 \text{ E}-3\% \text{ of MPC}}{9.38 \text{ E}-3\% \text{ of MPC}}$ 

1. release rate

45.3 <u>gal</u> x  $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$  x 7 E-5  $\frac{\text{Ci}}{\text{ft}^3}$  = 4.23 E-4  $\frac{\text{Ci}}{\text{sec}}$ 

2. partition factor: 100,000

4.23 E-4 
$$\underline{Ci}_{sec}$$
 x 1 E+6  $\underline{uCi}_{ci}$  x  $\frac{1}{100,000}$  = 4.23 E-3  $\underline{uCi}_{sec}$ 

3. at site boundary

4.23 E-3 
$$\underline{uCi}_{sec} \times 7.75$$
 E-4  $\underline{sec}_{m3} \times \frac{1}{m1} = 3.28$  E-12  $\underline{uCi}_{m1}$ 

4. % of MPC  

$$\frac{3.28 \text{ E-12 uCi}}{\frac{\text{m1}}{1 \text{ E-8 uCi}}} \times 100 \% = \frac{3.28 \text{ E-2 \% of MPC}}{3.28 \text{ E-2 \% of MPC}}$$

8.9.3 Cesium-134 1. release rate 45.3 gal x <u>1 ft<sup>3</sup></u> x 4.25 E-4 <u>Ci</u> = 2.57 E-3 <u>Ci</u> sec 7.48 gal ft3 sec partition factor: 100,000 2. 2.57 E-3  $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{1} \frac{\text{E+6 uCi}}{1} \times \frac{1}{100,000} = \frac{2.57 \text{ E-2 uCi}}{\text{sec}}$ 3. at site boundary 2.57 E-2 uCi x 7.75 E-4 sec x 1 E-6 m<sup>3</sup> = 1.99 E-11 uCi m3 m1 m1 sec % of MPC 4. 1.99 E-11 uCi ml x 100 = 1.99 % of MPC E-9 uCi m Cesium-137 8.9.4 1. release rate 45.3 <u>gal</u> x <u>1 ft<sup>3</sup></u> x 8.45 E-4 <u>Ci</u> = 5.12 E-3 <u>Ci</u> sec 7.48 gal ft<sup>3</sup> sec sec 7.48 gal 2. partition factor: 100,000 5.12 E-3  $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{1} \frac{\text{E+6}}{\text{Ci}} \frac{\text{uCi}}{\text{Ci}} \times \frac{1}{100,000} = \frac{5.12 \text{ E-2}}{\frac{\text{uCi}}{\text{sec}}}$ 3. at site boundary 5.12 E-2 uCi x 7.75 E-4 sec x  $1 \text{ E-6 m}^3$  = 3.96 E-11 uCi m<sup>3</sup> 1 m1 m1 sec 4. % of MPC 4.63 E-11 uCi mI x 100 = 1.98 % of MPC 2.0 E-9 uCi ml

8.9.5	Iodine-131	
1.	release rate	
	45.3 <u>gal</u> x $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$ x 7.0 E-5 $\frac{\text{Ci}}{\text{ft}^3}$ = 4.23 E-4 $\frac{\text{Ci}}{\text{sec}}$	
2.	partition factor: 10,000	
	4.23 E-4 $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{\text{E+6}} \frac{\text{uCi}}{\text{Ci}} \times \frac{1}{10,000} = 4.23 \text{ E-2} \frac{\text{uCi}}{\text{sec}}$	
3.	at site boundary	
	4.23 E-2 $\frac{\text{uCi}}{\text{sec}} \times 7.75$ E-4 $\frac{\text{sec}}{\text{m}^3} \times \frac{1 \text{ E-6 m}^3}{1 \text{ ml}} = 3.28$ E-11	uCi ml
4.	% of MPC	
	$\frac{3.83 \text{ E-11 } \text{uCi}}{\frac{\text{m1}}{1 \text{ E-10 } \text{uCi}}} \times 100 \ \text{\%} = 32.8 \ \text{\% of MPC}$	
	I L'IO <u>del</u>	
8.9.6 M	anganese-54	
1.	release rate	
	45.3 gal x $\frac{1 \text{ ft}^3}{\text{sec}}$ x $\frac{1 \text{ ft}^3}{7.48 \text{ gal}}$ x $\frac{3 \text{ E-5}}{\text{ft}^3}$ $\frac{\text{Ci}}{\text{ft}^3}$ = 1.81 E-4 $\frac{\text{Ci}}{\text{sec}}$	
2.	partition factor: 100,000	
	1.81 E-4 $\frac{\text{Ci}}{\text{sec}} \times \frac{1}{1}$ E+6 $\frac{\text{uCi}}{\text{Ci}} \times \frac{1}{100,000} = \frac{1.81}{1.81}$ E-3 $\frac{\text{uCi}}{\text{sec}}$	
3.	at site boundary	
	1.81 E-3 <u>uCi</u> x 7.75 E-4 <u>sec</u> x <u>1 E-6 m<sup>3</sup></u> = 1.40 E-12 sec m <sup>3</sup> m1	uCı ml
4.	% of MPC	
	$\frac{1.40 \text{ E-12 } \text{uCi}}{1 \text{ E-8 } \text{uCi}} \times 100 \ \text{\%} = 1.40 \text{ E-2 \% of MPC}$	

8.10 The following information is presented:

1. Case I.

Maximum spill rate: 100 gallons per minute 1.67 gallons per second

2. Chi/Q:

7.75 E-4 sec (see note 3)

3. Partition factors: (see note 1)

10,000 Iodine-131 100,000 other radionuclides

4. Maximum liner size:

196 ft<sup>3</sup> (approximately 1,466 gallons)

5. Useable liner volume: 186 ft<sup>3</sup> (1,391 gallons)

6. Case I and II

...

No consideration is made for material absorbed on surfaces for the following reasons:

- a. calculated percent of MPC shows a small instantaneous value for all radionuclides
- b. calculated values are considered conservative by a cummulative value of at least 100
- c. these scenarios have a small probability of occurrence
- Case I release is easily corrected and of short-term d. duration

8.11 NOTES

1. Iodine Partitonary Factor = 10,000 (P.F.)

Effluent source terms were conservatively developed by assuming entrainment from liquid phase to vapor phase would occur on the same basis as a system operating on the principle of evaporation. Gray, et al., 1979, BNFP, 1976 reports entrainment factors of 10<sup>-6</sup> for such a system (P.F. = 1,000,000). In the case of evaporation by boiling, a higher rate of release of radionuclides with off-gas vapors occurs than would be expected from routine operation of pumps, valves, and water transfer, and certainly from the case in question. Therefore, assumption of a factor of 10,000 is considered to be extremely conservative for iodine, especially considering the solution will be basic and force the iodine present towards the ionic form. The partitioning factor is also supported in the literature by data presented in WASH 1258, Volume 2, USAEC, July 1973.

2. Partitionary Factor - Other Isotopes = 100,000

For calculation purposes, partitionary factors for isotopes other than iodine (these radionuclides are less volatile than iodine) was chosen as 100,000. Again, this value is conservative (see above) and with industry experience.

# 3. Chi/Q = 7.75 x $10^{-4}$ sec/m<sup>3</sup>

This factor was calculated as an average of worst case Chi/Q values from six typical operating nuclear plants. Since a generic application of site-specific Chi/Q values is necessary for a typical application, an additional conservative factor of 5 was inserted.

## 4. Isotopic Content

Data presented in this document was calculated from data given in +CAEC-007, March 1978. Table 8.3 (p. 251, CAEC-007) was utilized to calculate the percentage of radionuclides in the process waste. Additionally, CAEC-007 was utilized to calculate the isotopic waste content based on reported specific activity of pressurized and boiling water reactors and is reported in Table 8-1 under the waste stream specific activity. A telephone survey of several nuclear plants was conducted to ascertain the validity of the isotopic content used in the evaluation. In all cases sampled, the values used are conservative in relation to actual reported values.

5. Since Case II deals with low activity waste, typical radiation levels of 150-250 mR/hr were scaled down by a factor of 20. These values still remain conservative when compared to actual reported values.

.

6. Total Maximum Permissible Concentration is determined by:

 $\frac{C_a}{MPC_a} + \frac{C_b}{MPC_b} + \frac{C_c}{MPC_c} + \frac{C_n}{MPC_n} = 1 \text{ess than unity}$ 

7. Spill rate calculations are:

 $R = A 2[gh]^{1/2}$  where:

R = volume of liquid discharged per unit time

A = area of orifice  $(2.8 \text{ E-2 m}^2)$ 

g = gravitational constant (9.8  $m/s^2$ )

h = height of liquid above orifice (1.92m)

7.8 E-2 m<sup>2</sup> X 6.13

.17  $\underline{m^3}$  x 264.2 gal  $\underline{m^3}$ 

45.3 gal sec

8.

Time required to empty liner

<u>1390 gal</u> = 30.7 sec 45.3 <u>gal</u> sec





Table 8-1. Case I and II Incident Scenarios and the Resulting Percent Contribution to Table II MPC

	2	C & M-	eta Straam	Ss.A. in	6 Concentratio	on at Site Boundary	Percent	t of MPC
*Radionuclide	"Table II MPC (uCi/ml)	<sup>3</sup> Case 1 (Ci/ft <sup>3</sup> )	<sup>4</sup> Case II (Ci/ft <sup>3</sup> )	20C gal (uCi)	Case I (uCi/ml)	Case Iî (uCi/ml)	Case I	Case II
			(	1.2 F-4	2.1 E-12	2.81 E-12	7.0 E-3	9.38 E-3
Cobalt-58	3 E-8	1.2 E-3	0.0 E-5	175-4	2 4 E-12	3.28 E-12	2.4 E-2	3.28 E-2
Cobalt-60	1 E-8	1.4 E-3	7.0 E-5	3.7 E-4	1 47 E-11	1.99 E-11	1.5	1.99
Cesium-134	1 E-9	8.5 E-3	4.25 E-5	2.3 E-5	1.4/ 6-11	1.05 E 11	1.5	1.98
Cesium-137	2 E-9	1.69 E-2	8.45 E-4	4.5 E-5	2.92 E-11	3.90 E-11	1.5	12.8
Tedine 111	1 E-10	1.4 5-3	7.0 E-5	3.7 E-4	2.4 E-11	3.28 E-11	24	32.0
Manganese-54	1 E-8	6.0 E-4	3.0 E-5	1.6 E-4	1.04 E-12	1.40 E-12	1.04 E-2	1.40 E-2
<sup>7</sup> Percent of M	PC						.270	.368

1 From CAR -007, 1978

<sup>2</sup> 10 CFR 20, Appendix B, Table II, Column I, soluable

<sup>3</sup> calculated from CAEC-007, 1978

<sup>4</sup> scaled down by a factor of 20 to accound for lower level waste (see Note 5)

5 see Note f

<sup>6</sup> see calculations Case I & II

7 see Note 6

.....

OPERATING EXPERIENCE AND RESEARCH RESULTS

55

•

.

## 9.0 OPERATING EXPERIENCE AND RESEARCH RESULTS

- 9.1 Operating Experience
  - 9.1.1 Chem-Nuclear Systems, Inc. has been actively involved in the safe transport and disposal of dewatered/demineralized radioactive waste for the past eight years.
  - 9.1.2 On-site dewatering has been performed at nuclear facilities where experience in the design and operation is used as a basis for continual improvement with regards to safety and operation. Table 9-1 shows the partial experience list to date:
- Table 9-1. A Partial List of Dewatering Operating Experience at Nuclear Power Plants

Arkansas Big Rock Point Brunswick Crystal River Davis-Besse Fitzpatrick H.B. Robinson Hatch

Millstone Mississippi Nine-Mile Point North Anna Oconee Oyster Creek Point Beach Salem



# 9.2 Exposure to Dewatering Operations Personnel

2.3

0

- 9.2.1 Based on design features of the CNSI Dewatering System and temporary shielding in the form of portable shields, personnel dose during normal operation is estimated to be less than four rem per year.
- 9.2.2 Exposure to radiation during system maintenance has been kept as low as practical by separation of process equipment that does not contain radioactive residues from those that have processed waste. Those portions of the system which are required to contain and process radioactive waste have been designed to minimize radioactive material retention. The portable equipment can be moved for maintenance to a low radiation area so that further operator exposure is minimized.
- 9.2.3 CNSI experience with mobile and portable systems for several years with various media has formed the basis for the equipment design. The control panel, when used, is normally located in a non-radiation area and operators receive little or no exposure while processing.
- 9.2.4 Currently, there are two operators involved in purely dewatering projects. Their estimated dose per month, based on TLD's, is 0.356 rem (10.5 months of 1983) and 0.163 rem (7 months of 1983). The total average dose for the dewatering

and demineralization unit where N = 18 persons (based on January - November 17, 1983 operating data) is 0.159 rem. Individual doses range from 0.002 to 0.356 rem per month.

9.3 Waste Characteristics

1

6

9.3.1 Typical PWR and BWR waste types dewatered are mixed resins bed, precoats, and solka floc. Descriptions are:

9.3.1.1 Mixed Bead Resins

Average particle size	0.54 mm
Retained on 50 mesh screen	about 98%
Particle density	
anion	1.1 gm/cc
cation	1.3 gm/cc
Bulk density	45 lbs/ft <sup>3</sup>

9.3.1.2 Cellulose Fibers (Solka Floc)

Solids concentration slurry	1-3% by wt.
Or centrifuged waste	50% water
Average particle size - length	96 micron
- thickness	18 micron
% retained on 100 mesh	45%
Particle density gm/cc	1.58
Bulk density, 1b/ft <sup>3</sup> (solids dry)	18

9.3.1.3 Clean-Up Filter/Demineralizer Sludge (including Fuel Pool Filter/Demineralizer Sludge)

> The sludge comes from the reactor water clean-up filter/demineralizer and the fuel pool filter/demineralizer. The wet solid slurry is primarily powdered demineralizer (Powdex-type) resins, mixed 0.9 Cation (PCH-S) and 0.1 anion (PAO) such as manufactured by Graver Water Conditioning Co.

Solids concentration	0.5% by wt.
Or centrifuged waste	50% water
Particle size	350 mesh
Bulk density, 1b/ft <sup>3</sup>	
(solids dry)	24

Table 9-2 describes the type and volume of wastes normally encountered.

Table 9-2. Summary of Light Water Reactor Waste Streams\*

Туре	Volume Pro <u>PWR</u>	duced (ft <sup>3</sup> )* <u>BWR</u>
Resin Concentrated Liquids Filter Sludges	3,100 4,775 75	3,100 8,600 6,900
TOTALS	7,950 +	18,600 +

\* Untreated wastes delivered to CNSI

+ Experience shows totals are exceptionally high

#### 9.4 Bead Resin Test Material Description

- 9.4.1 Test material in Standard I consists of mixed bed spent anion-cation bead resin. The resin is in poor physical condition as the beads have experienced damage due to forces encountered during centrifugation.
- 9.4.2 The majority of resin is Dowex, ion exchange resin, mixed bed, nuclear grade, Type MR-3. Type MR-3 consists of 58% by weight SBR-OH and 42% by weight of HCR-S. Appendix 6 provides manufacturer specifications of MR-3 bead resin.
- 9.4.3 Category I mixture is considered to be an average example of actual representative bead resin waste as encountered for disposal. The manufacturer states the average new material water retention capacity is 57%. Emperically, CNSI has found that extensive bead handling results in increased moisture-absorbing ability.

## 9.5 Process Control Program

9.5.1 Generally, the PCP states that liners are filled and then pumped for a given time interval. The contents are allowed to stand and the pump cycle is restarted. After a given number of cycles, the liner is considered dewatered and the process stopped.

9.6 Testing

3

- 9.6.1 The test procedures required the vessel to be loaded with the useable volume of precoat or resin and filled with water. The liner dewatering cycle was to pump for a certain time interval, stand for a certain time interval, and repeat until the dewatering was complete.
- 9.6.2 The dewatering end point was determined to be zero when less than 10 ml was collected over a 24-hour period. At that time, the vessel was loaded on a truck and driven 200 miles over secondary roads. If less than 10 ml was collected following the road test the liner was considered dewatered.
- 9.6.3 Larger liners, such as 14-195's, were considered the worst case for dewatering. Production liners of smaller diameter and height but with the same internal design can be certified by testing the worst case.
- 9.6.4 Testing and evaluation of extracted test resin showed the moisture content to be less than or equal to equilibrium with the static suspending ability of the resin bed and the amount of moisture contained within the bed. At less than or equal to the point of equilibrium, dynamic forces, such as those experienced during transportation, would not cause precipitation of interstitial moisture.

- 9.6.5 A typical L14-195 (steel) and PL14-195R (High Integrity Container) were chosen for testing the dewatering capability when filled with resin beads. These containers are five degrees conical in shape at the bottom. The selected liners were chosen from a group that would normally be used for commercial purposes. They were retrofitted to meet the demands of a test liner by the installation of sampling ports. Positioning was the same as that normally expected in commercial operation.
- 9.6.6 CNSI developed specific test instructions and reports that were used to successfully dewater resin to zero free-standing water. All tests were instituted using non-radioactive waste streams. These instructions and report are found in Appendix 1 of CNSI-DW-11118-01-P.

9.7 L14-195 Barrel Top Resin Conical [BTRC (Steel)]

- 9.7.1 Appendix 2 of CNSI-DW-11118-01-P is the test results that certify dewatering of resin beads in L14-195 BTRC (Steel) liners.
- 9.7.2 Tests No. 1 and 2 with the new lateral design show that Barnwell Site Criteria were met after six pump cycles. Hanford criteria was met after 12 pump cycles, while zero free-standing water was obtained after 14. Road testing did not affect bead equilibrium and cause liquid precipitation.
- 9.7.3 Tests No. 1 and 2 with old lateral design show that two pump cycles were necessary to meet the requirements of 10 CFR 61. Five and eight pump cycles were necessary to meet Hanford criteria. Zero free-standing water was obtained after 14 cycles. Road testing did not cause liquid precipitation.
- 9.7.4 The moisture content of the extracted test resin samples indicate an equilbrium has been established between the static suspending ability of the test resin bed and the amount of moisture contained within the bed. The point of equilibrium for the test has been established such that the dynamic forces experienced will not cause liquid precipitation.
- 9.7.5 The Process Control program calls for six and twelve pump cycles to meet 10 CFR 61 and Hanford requirements.

#### 9.8 PL14-195 R (HIC)

- 9.8.1 Appendix 3 of CNSI-DW-11118-01-P is the test results that certify dewatering of PL14-195 R (High Integrity Containers) liners and smaller sized liners.
- 9.8.2 Test No. 1 shows that Barnwell Site Cri 1 was met after the second pump cycle. Hanford criteria was met after the fourth pump cycle. Zero free-standing water was met after 14 pump cycles. Road testing did not affect bead equilibrium and cause liquid precipitation.

- 9.8.3 Test No. 2 shows that 3, 11, and 14 pump cycles were needed to meet 10 CFR 61, Hanford, and zero free-standing water requirements. Road testing did not affect bead equilibrium and cause liquid preciptitation.
- 9.8.4 Test No. 3 shows that 3, 8 and 14 pump cycles were needed to meet 10 CFR 61, Hanford, and zero free-standing water requirements.
- 9.8.5 Road testing was done 14, 17, and 27 days following the completion of 14 pump cycles on Test No. 3. Dynamic forces encountered did not affect bead equilibrium and cause liquid precipitation.
- 9.8.6 The moisture content of the extracted test resin samples indicate an equilibrium has been established between the static suspending ability of the test resin bed and the amount of moisture contained within the bed. The point of equilibrium for the test has been established such that the dynamic forces experienced will not cause liquid precipitation.
- 9.8.7 The Process Control Program calls for three and 11 pump cycles to meet Barnwell Site Criteria and Hanford requirements.
- 9.9 Precoat Test Instructions
  - 9.9.1 Appendix 4 of CNSI-DW-11118-01-P covers the precoat test instructions and report. The liners chosen were L14-195 (Steel), PL14-195 (Poly-Processing),

PL8-120 (Poly-Processing), and PL8-120R (Poly-Processing), and PL14-195R (Crown Rotational). Each container was rigged and the intervals installed as would normally be used during commercial operation. Additionally, each container was converted to a test liner by the installation of sample ports.

- The test procedure is to fill the liner with 9.9.2 slurry. Upon completion of filling, the slurry may stand for a certain interval. After standing, all four banks may be dewatered consecutively or simultaneously. The dewatering ability is measured by a vacuum reading. Generally speaking, the liner is dewatered from the top filter bank downward. When one filter bank is turned off attention is directed toward the remaining banks. The dewatered bank is allowed to stand for a certain time interval and then is rechecked. If the recheck affirms the earlier reading, attention is directed toward the remaining banks. If the recheck is not affirmed, dewatering is begun again until further checks affirm dewatering.
- 9.9.3 After three dewatering cycles the liner is subjected to a 200-mile road test over secondary roads. After the road test low point drains are opened and the volume of water is recorded. Precoat samples for moisture analyses from the port and low point drains were taken. This data is found in Appendix 4, CNSI-DW-11118-01-P.

- 9.9.4 Another dewatering method is to dewater for a certain number of continuous hours. Dewatering is complete at that time.
- 9.9.5 Experience has shown that Ecodex is more difficult to dewater than Powdex, Diatomaceous Earth, Celite 545, and Fibra-Cel (SW 70). For these reasons, Powdex and Ecodex were chosen as representative of difficult-to-dewater media. A description of the test material follows.
  - 9.9.5.1 Ecodex The Ecodex material was obtained from Zimmer Nuclear Station and is representative of an actual waste streeam. The material was depleted and saturated.
  - 9.9.5.2 Powdex The Powdex material was obtained from Graver Chemical and is representative of actual waste streams expected for disposal. The material has contaminants of less than 100 ppm Fe as iron, less than 10 ppm Cu as copper, less than 50 ppm Al as aluminum, and less than 25 ppm Pb as lead (Appendix 7 is the manufacturer's specifications).

- 9.9.5.3 The Ecodex precoat used in these dewatering tests is considered to be the "worst case" for dewatering. It has the greatest potential for suspended solid loading (crud saturation), which results in increased water retention. Since Ecodex has the lowest permeability and the highest water retention of all commercially available precoats, tests with other common precoats should give better dewatering results.
- 9.9.6 The large size precoat internals described by CNSI Drawing No. B-372-E-0001 contains an internal system functionally identical to the small size internals described by Drawing No. B-0372-E-0002. Testing of the largest size liner is considered to be the worst case for a size group. The scientific acceptability of this paragraph is proprietary and is described in paragraphs 9.9.6.1-4 in CNSI-DW-11118-01-P.
- 9.9.7 Three complete and successful full-scale tests were conducted with the large size internals in three different type containers.
- 9.9.8 One test was conducted with the largest container in the category of small liners with the small size internals. The purpose of this test was to demonstrate the small geometry of the internals is functionally equal to the proportionally larger size combination.

- 9.9.9 The moisture content of the extracted test samples indicate an equilibrium has been established between the static suspending ability of the test material and the amount of moisture contained within the container. Dynamic forces experienced during transportation and changing weather conditions will not cause precipitation of suspended moisture.
- 9.9.10 As a precoat material becomes laden with impurities during the normal in-plant cycles, the water retention capability increases. The equilibrium point for saturated precoat waste is higher than new material. If the moisture content of the waste is equal to or less than the moisture content of new material, it is reasonable to assume equilibrium has been more than established. At this point, the matrix of material is capable of absorbing additional moisture without precipitation.
- 9.9.11 If a mixture of precoat materials is received as waste, the relative combination of moisture content is proportional to the combination of the materials. (Example: 50% by weight Ecodex at 70% moisture and 50% Powdex at 60% moisture, new material equilibrium equals 65% moisture.)

9-13

9.9.12 The average moisture content for the Ecodex matrix as dewatered:

L14-195 (01d) L14-195 (New) PL14-195 PL14-195R PL8-120R 67.24% - 2nd Road 59.81% 57.5% 68.5% 1st Powdex = 51.0%

The equilibrium point for new Ecodex, according to the manufacturer, is 65-70% at 100% humidity.

- 9.9.13 Therefore, if the average moisture content for Ecodex matrix is equal to or less than 65% moisture, the matrix is capable of absorbing additional moisture.
- 9.9.14 When dewatering Fibracell, Solka-Flok, diatomaceous earth or Celite, the new model precoat internals perform more efficiently than the old style system. All precoats other than Powdex should be dewatered with Ecodex type filter assemblies.
- 9.9.15 Powdex may be dewatered in an Ecodex liner, resulting in a Powdex matrix with a very low percentage of moisture. Any combined mixtures should be dewatered in an Ecodex liner. The Powdex liner is available for relatively (90%) pure Powdex waste only. (The Powdex liner assembly costs approximately 30% less than the Ecodex liner, at this time).

- 9.9.16 Testing has demonstrated that precoats of the type equal to Ecodex, Fibracell, Solka-Flok, diatomaceous earth, and Celite may be dewatered with "Ecodex" type liners conforming to CNSI Drawing No. B372-E-0001 and B-372-E-0002.
- 9.9.17 Powdex and similar precoats may be dewatered with "Powdex" type liners conforming to CNSI drawing number B-372-E-0001 and B-372-E-0002.
- 9.9.18 When dewatering any precoat with the above-mentioned liners, a three-stage cycle dewatering procedure, or a continuous dewatering method must be used to obtain zero FSW.

#### 9.10 Precoat Test Results

- 9.10.1 Appendix 5 of CNSI-DW-11118-01-P shows the test results for dewatering liners with precoats.
- 9.10.2 Test results indicate that three cycles are adequate to meet zero free-standing water requirements. Alternatively, this criteria may be met by pumping for a certain number of continuous hours.
- 9.10.3 Bead moisture content data indicate an equilibrium has been established between the static suspending ability of the test precoat and the amount of moisture contained within the bed. The point of equilibrium for the test material has been established such that dynamic forces experienced will not cause liquid precipitation.

- 9.10.4 The process control program calls for three pump cycles or a continuous pumping cycle to meet the dewatering requirements.
- 9.11 76" Diameter Pressure Vessel
  - 9.11.1 Appendix 4 of CNSI-DW-11118-01-P, Test Results, covers the test summary and results that certify dewatering of the 76" diameter pressure vessel with bead resin.
  - 9.11.2 The ambient air temeperature recorded for the duration of the three tests ranged from  $29-79^{\circ}F$ . The humidity ranged from 30-100%.
  - 9.11.3 Test results show that 9 ml of water was collected after several pump cycles. Betting this point to zero on a relative scale and adding the area under the curve, it is shown that the Hanford criteria of less than 1 gallon was met in the second pump cycle.
  - 9.11.4 The 0.5% limit of 10 CFR 61 was met during the second pump cycle.
  - 9.11.5 It is interesting to note that the volume collected following the road test was 636 ml (0.168 gal). It can be stated that road testing is unlikely to result in additional free-standing water from that which would have been normally encountered in the first place.

- 9.11.6 In summary, the Hanford Site Criteria and 10 CFR 61 limits were met during the second pump cycle. Currently, additional tests are being conducted that will provide supporting data.
- 9.12 24" Diameter Pressure Vessel
  - 9.12.1 Pressure vessels of 24" in diameter containing activated carbon, bead, or macroreticular resins have been tested at various intervals since 1981. Recertification is in progress due to changes in internal piping design. The modifications are expected to result in increased efficiency of the dewatering process.
  - 9.12.2 Field experience with dewatering over 500 24" pressure vessels indicates that current process control programs are effective in removing free-standing water. The volumes collected from the last two pumping steps have been consistently less than established acceptance criteria.

9.13 Atmospheric Results

9.13.1 A summary of ambient atmospheric data is given in Table 9-8. Analysis indicates that atmospheric data does not appear to significantly affect bead or precoat dewatering capabilities. Complete atmospheric data is found in Appendix 9.

	Aver	age			
	Tempera	cure r	Dew	Grains of Moisture/	Relative
Period	Hi	Lo	Point	Lb of Air	Humidity
11-22 Jun 83	91	59	72	121	54
10-31 Jul 83	97	68	78	150	56
17-29 Aug 83	100	69	77	142	50
7-24 Sep 83	84	59	70	115	64
26-31 Oct 83	68	42	50	55	53
1- 8 Nov 83	67	40	54	65	64

Table 9-8. Atmospheric Data During Test Periods

9.14 Hydrostatic Testing

1.0

9.14.1 Appendix 10 results found in CNSI-DW-11118-01-P, CNSI procedure for Hydrostatic Testing of Field Equipment, indicate the test units are functioning properly and provide accurate readings.







Appendix 10.3 is Proprietary

Appendix 10.4 is Proprietary

20.

ų





4

Ser. Bar

# DESCRIPTION OF TEST BEAD

4

#### THE DOW CHEMICAL COMPANY QUALITY ASSURANCE SALES SPECIFICATION

PAGE: 1

23110

and a

PRODUCT CODE: 23110 EFFECTIVE: 18 OCT 76

NAME: DOWEX (R) MR-3 NUCLEAR GRADE ION EXCHANGE RESIN

DESC: MIXED ION EXCHANGE RESIN APPL GOVT/IND STDS: FDA

-					
	TES	T ITEM	: UNIT :	LIMITS	: TEST METHODS
COL	UMN CAPAC	CITY, MIN.	KGS/CU 12 FT		DOWEX RESIN MD 36
PI:	1693118	SAMPLE	1		
PI:	1693126	1 CU FT FBR I	RUM (NET 45 IR	)	
PI:	2256709	1 CU FT FBR I	RIM/MYL (NET A	5 7 8 1	
PI:	1693134	5 CU FT FRR T	RIM (NET 225 TI		
PI:	1874411	5 CU FT FBR I	RUM/MYL (NET 22	25 LB)	

SALES NOTE:

34

 (1) THE HYDROXIDE FORM SHALL MEET THE REQUIREMENTS OF SPECIFICA-TION 23136.
 (2) THE HYDROGEN FORM SHALL MEET THE REQUIREMENTS OF SPECIFICATION 23087
 (3) CATION AND INVERSE PROPERTY OF SPECIFICATION

(3) CATION AND ANION RESINS SHALL BE MIXED IN A RATIO OF 1 H ION EQUIVALENT TO 1 OH ION EQUIVALENT.

READ PRECAUTIONARY INFORMATION AND MATERIAL SAFETY DATA SHEETS. THIS PRODUCT IS SHIPPED IN COMPLIANCE WITH AP-PLICABLE LAWS AND REGULATIONS REGARDING CLASSIFICATION, PACKAGING, SHIPPING, AND LABELING.

(R) INDICATES A TRADEMARK OF THE DOW CHEMICAL COMPANY LAST PAGE

57% moter retention correction

#### THE DOW CHEMICAL COMPANY QUALITY ASSURANCE SALES SPECIFICATION

PAGE: 1

23087

0

PRODUCT CODE: 23087 EFFECTIVE: 23 MAR 78 SUPERSEDES: 20 OCT 76

NAME: DOWEX (R) HCR-S, NUCLEAR GRADE, H CATION EXCHANGE RESIN

DESC: A STRONG ACID CATION EXCHANGE RESIN IN THE HYDROGEN FORM. APPL GOVT/INT STDS: FDA

TEST ITEM	: UNIT	: LIMITS	: TEST METHODS
TOTAL WET VOLUME CAPACITY,	-:	- :	
MIN	MEQ/ML	1.8	DOWEX RESIN MD. 1
WATER RETENTION CAPACITY	2	50-56	DOWEX RESIN MD. 4
WET SIEVE ANALYSIS:			DOWEX RESIN MD.5
ON NO. 16, MAX.	%	5	DOWEX RESIN MD.5
THRU NO. 40, MAX.	%	5	DOWEX RESIN MD.5
THRU NC. 50, MAX.	%	0.5	DOWEX RESIN MD.5
SPHERICITY, MIN	2	90	DOWEX RESIN MD.6
CONVERSION TO H FORM, MIN.	2	99	DOWEX RESIN MD.1
SOLUBLES, MAX.	PPM	400	BEING DETERMINED
METALS (DRY BASIS)			ATOMIC ABSORPTION
SODIUM, MAX.	PPM	100	ATOMIC ABSORPTION
IRON, MAX.	PPM	200	ATOMIC ABSORPTION
COPPER, MAX.	PPM	50	ATOMIC ABSORITION
ALUMINUM, MAX.	PPM	50	ATOMIC ABSORPTION
HEAVY METALS (AS LEAD).			
MAX.	PPM	50	ATOMIC ABSORPTION

 PI:
 1692961
 SAMPLE

 PI:
 1692979
 1 CU FT FBR DRUM (NET 50 LB)

 PI:
 1692987
 5 CU FT FBR DRUM (NET 250 LB)
 STD CONTAINER

 PI:
 1874387
 5 CU FT FBR DRUM, MYLAR LINED (NET 250 LB)

 PI:
 2393478
 1 CU FT PAPER BAG (NET 50 LB)

 PI:
 2393239
 1 CU FT FBR DRUM, MYLAR LINED (NET 50 LB)

SALES NOTE:

 ANYTHING BUT THE STANDARD CONTAINER LISTED WILL REQUIRE LONG LEAD TIME.

READ PRECAUTIONARY INFORMATION AND MATERIAL SAFETY DATA SHEETS. THIS PRODUCT IS SHIPPED IN COMPLIANCE WITH AP-PLICABLE LAWS AND REGULATIONS REGARDING CLASSIFICATION, PACKAGING, SHIPPING, AND LABELING.

(R) INDICATES A TRADEMARK OF THE DOW CHEMICAL COMPANY LAST PAGE

#### THE DOW CHEMICAL COMPANY QUALITY ASSURANCE SALES SPECIFICATION

PRODUCT CODE: 23136

EFFECTIVE: 20 OCT 76

NAME: DOWEX (R) SBR, NUCLEAR GRADE, OH ANION EXCHANGE RESIN

DESC: STRONG BASE ANION EXCHANGE RESIN - TYPE 1 APPL GOVT/IND STDS: FDA

TEST ITEM	: UNIT	: LIMITS	: TEST METHODS
TOTAL WET VOLUME CAPACITY,			
MIN. WATE: RETENTION CAPACITY,	MEQ/ML	1.1	DOWEX RESIN MD.33C
MAN WET ATEVE ANAL TURIT NO.	2	60	DOWEX RESIN MD. 4
56, MAX	*	0.5	DOWEX RESIN MD. 5
HYDROXIDE, MIN.	EQUIV.	\$ 90	DOWLY RESIN MD. 33C
CALORIDE, MAX.	EQUIV.	% 3	DOWEX RESIN MD. 33C
CAREONATE, MAX.	EQUIV.	2 7	DOWEX RESIN MD. 330

PI: 1761667 SAMPLE PI: 1693399 ' CU FT FBR DRUM (NET 41 LE) PI: 2256642 1 CU FT FBR DRUM, MYLAR LINED (NET 41 LB) PI: 2256634 5 CU FT FBR DRUM (NET 205 LB) PI: 2256626 5 CU FT FBR DRUM, MYLAR LINED (NET 205 LB)

READ PRECAUTIONARY INFORMATION AND MATERIAL SAFETY DATA SHEETS. THIS PRODUCT IS SHIPPED IN COMPLIANCE WITH AP-PLICABLE LAWS AND REGULATIONS REGARDING CLASSIFICATION, PACKAGING, SHIPPING, AND LABELING.

(R) INDICATES A TRADEMARK OF THE DOW CHEMICAL COMPANY LAST PAGE 23136

PAGE: 1

THE DOW CHEMICAL COMPANY

MIDLAND, MICHIGAN 48640

# ANALYTICAL METHOD

This is a file copy. For Outside Distribution Obtain Copies With Liability Clause and Without Dow Reference.

1

May 21, 1969

DOWEX\* Resin Method 4 (Supersedes Method D)

# WATER RETENTION CAPACITY

1. Scope

This method is applicable to the determination of the water retention capacity of Dowex ion exchange resins.

2. Principle

The water retention capacity is determined from the loss in weight of the conditioned resin by drying under vacuum at an elevated temperature or on a moisture balance.

3. Apparatus

(a) Centrifuge, International Clinical Model CL-417, or equivalent, equipped with four-place head (No. 215), 50-ml centrifuge tubes (No. 320) and a Truscon ring (No. 325). The centrifuge is operated at 2,000 rpm. (7a).

(b) Vacuum drying oven, capable of operating at 100 to 105°C and capable of maintaining a pressure equal to about two inches of mercury.

(c) Vacuum pump, capable of maintaining a pressure equal to about two inches of mercury.

(d) Filtering crucible (special), coarse fritted glass Buchner funnel (No. 15C), Corning Glass Works Catalog No. 36060 (cut off 1/4-inch below the frit). See Figure 1.

(e) Cenco Moisture Balance, or equivalent, equipped with a 125-watt infrared lamp and a five-gram torsion wire.

4. Sample Preparation

(a) Cation Resins. Transfer 10 to 15 ml of resin (as received) to a column. Convert completely to the hydrogen form (7b) by passing approximately 500 ml of 5% hydrochloric acid through the column with a minimum

\*Trademark of The Dow Chemical Company.

1 of 3 pages

# 2 of 3 pages

DOWEX\* Resin Method 4 (Supersedes Method D)

3

time of 30 minutes. Wash the column of resin with distilled water until the effluent is above pH of 3.5. Transfer the conditioned resin to the special filtering crucible. Centrifuge at 2,000 rpm for five minutes (7a).

(b) Cation Resins, sodium form. Transfer 10 to 15 ml of resin (as received) to a charging column. Wash with 200 ml of distilled water. Transfer the conditioned resin to the special filtering crucible. Centrifuge at 2000 rpm for five minutes (7a).

(c) Anion Resins, chloride form. Transfer 5 to 10 ml of the resin (as received) to a recharging column and convert completely to the chloride form by passing 150 ml of 5% hydrochloric acid through the column with a minimum time of 20 minutes. When the acid has drained through, wash the resin in the same manner with distilled water until the wash water is neutral to litmus paper. Transfer the conditioned resin to the special filtering crucible. Centrifuge at 2000 rpm for five minutes (7a).

## 5. Procedure

(a) Oven Drying Procedure. Transfer the centrifuged resin to a tared weighing bottle, reweigh, and place in the vacuum oven at 100 to 105°C. Reduce the pressure to about two inches of mercury. After 16 hours, admit air to the oven and remove the crucible. Cool in a dessicator to room temperature

(b) Moisture Balance Procedure. The procedure followed is that described in the operating instructions. Establish the reference point by turning the scale-adjusting knob, which is located on the right side of the unit, until index by turning the pointer adjusting knob, which is located the pointer to the of the unit. Rotate the scale until the 0 percent mark coincides with the index. Raise the lamp housing and distribute the sample, approximately five grams of the centrifuged resin, evenly upon the pan until the pointer coincides with the index. Lower the lamp housing and turn on the infrared lamp. The proper setting of the variable transformer or resistor will vary with the type of resin. Avoid a setting which will cause charring of the resin. The percentage reduction of weight at any instant is determined by rotating the scale adjusting knob, on the right, until the pointer returns to the index. Read the percentage directly from the scale. To assure complete drying, wait until the weight is constant for three minutes. Record this value as the water retention capacity.

# 3 of 3 pages

DOWEX Resin Method 4

6. Calculation

(a) Oven Drying Procedure

 $\frac{(\text{loss of weight})}{(\text{wet resin weight})} \times 100 = \% \text{ Water Retention Capacity}$ 

(b) Moisture Balance Procedure

The reading obtained is numerically the same as the % Water Retention Capacity.

7. Notes

8

(a) If the centrifuge head and tubes used yield an effective radius differing from 3.5 inches, the speed of rotation should be varied to compensate for the difference. Centrifugal force varies directly with radius and with the square of the angular velocity. To find the velocity in rpm needed for a different value of the radius (r), the following expression may be used:

$$rpm = -\sqrt{\frac{3.5 \times (2000)^2}{r}}$$

The effective radius is measured from the center of rotation to the fritted glass in the crucible.

(b) The detailed procedure for conditioning the resin is described in DOWEX Resin Method 1 and 2.

(#50-#16) 01487 D

"The information herein is presented in good faith, but no warranty, expressed or implied, is given nor is freedom from any patent owned by The Dow Chemical Company or by others to be inferred. In the hands of qualified personnel, the procedures are expected to yield results of sufficient accuracy for their intended purposes; but recipients are cautioned to confirm the reliability of their techniques, equipment and standards by appropriate tests. Anyone wishing to reproduce or publish the material in whole or in part should request written permission from The Dow Chemical Company."

vfm



¥.4



# THE DOW CHEMICAL COMPANY

ANALYTICAL METHOD

MIDLAND, MICHIGAN 48640

October 25, 1978

DOWEX\* Resin Method 4-1

#### WATER RETENTION CAPACITY OF HYDROXIDE FORM ANION EXCHANGE RESIN

#### 1. Scope

This method is applicable to the determination of water retention capacity of anion exchange resin in the hydroxide form.

#### 2. Safety

Hydroxide form anion exchange resin may be irritating to the skin and precautions must be taken to avoid eye and skin contact. Methanol and Karl Fischer reagent are flammable solvents and should be used in areas free of ignition sources.

#### 3. Principle

The resin is centrifuged to remove all water except that retained in the resin. The water is then extracted with dry methanol and an aliquot of the methanol is titrated with Karl Fischer reagent to determine the water retention capacity of the resin.

#### 4. Apparatus

(a) Centrifuge with rotor and shield to hold the filtering crucible 4(b) capable of 2000 rpm with an effective radius of 3.5 inches. An acceptable unit is International Clinical Model IEC-428 equipped with four place Rotor (IEC-215), 50 ml shield (IEC-320) and a Trunnion Ring (IEC-325) available from VWR Scientific Inc., Midland, MI 48640.

(b) Filtering crucible (special), course fritted glass Buchner funnel, 15-ml capacity (cut off and modified as shown in Figure 1). Available before modification, Corning No. 36060, from (VWR No. 30295-060) VWR Scientific Inc., Midland, MI 48640.

- (c) Bottle, 2 oz., glass with polyseal cap.
- (d) Pipet, 50-ml volumetric, Class A.

\*Trademark of The Dow Chemical Company

1 of 4 pages

(e) Pipet, 5-ml volumetric, Class A.

(f) Shaker, Reciprocating.

(g) Karl Fischer Titrater, Metrohm Model E547 or equivalent. Available from Brinkmann Instruments, Inc., Westburg, NY 11590.

5. Reagents

(a) Methanol, distilled in glass, dry. Available from Brudick and Jackson Laboratories, Inc., Muskegon, MI 49442.

(b) Karl Fischer Reagent, available from VWR Scientific Inc., Midland, MI 48640.

6. Calibration

(a) Make the following calibration in duplicate each day when performing this analysis.

(b) With methanol in the vessel allow the Karl Fischer apparatus to come to its endpoint using a time delay of 30 seconds.

(c) Place an eyedropper of water in a small test tube and hang on balance and weigh the gross weight to the nearest 0.0001 g.

(d) Add one drop (.04-.10 g) of the water to the Karl Fischer titration vessel and start titration. Reweigh the eyedropper for tare weight. Record net ml Karl Fischer Reagent to the endpoint.

(e) Determine the factor for each of the duplicate runs as follows:

Factor = g of water ml of Karl Fischer

(f) If the duplicate factors agree within 1%, average them. If they do not, repeat the calibration.

7. Procedure

(a) Transfer 10 to 15 ml of resin (as received) to a beaker. Cover the resin with deionized water. Transfer the resin to the special filtering crucible and cover with the rubber stopper. Centrifuge at 2000 rpm for five minutes.

(b) Discard approximately the top quarter of the resin from the crucible.

(c) Weigh 1.0-1.2 g to the nearest 0.001 g of the centrifuged resin into a dry 2-oz. bottle.

(d) With a dry pipet add 50 ml of distilled methanol, cap, and shake for 15 minutes.

(e) Allow the Karl Fischer apparatus to come to its endpoint and with a dry pipet add 5.0 ml of the distilled methanol. Determine the ml of Karl Fischer reagent to bring to the endpoint and record as "Blank ml KF".

(f) Rinse the 5-ml pipet once with the methanol extract of the resin sample and then add 5.0 ml of the extract (avoid getting resin) to the Karl Fischer apparatus which is at endpoint. Determine ml of Karl Fischer reagent to bring to the endpoint and record as "Gross ml KF".

#### 8, Calculation

\* Water Retention Capacity =  $\frac{A - B}{C} \times \frac{50 \text{ ml}}{5 \text{ ml}} \times D \times 100$ Where: A = gross ml of KF reagent B = blank ml of KF reagent C = sample weight in grams D = factor from 6(c)

#### 9. Precision

Data obtained by this procedure indicate a relative standard deviation of 1.42%. The values obtained may be expected to vary from the average by not more than ±2.8% relative at the 95% confidence level. This precision is also improved with sampling identical spots in the centrifuged resin (i.e. middle).

#### 10. Accuracy

A series of five samples were analyzed by this method and DOWEX Resin Method 4 and agreement within the precision of the methods was obtained. Spikes of water were made to samples in addition to the water retained in the resin and recoveries ranged from 99.7 to 100.6%. Accuracy can be expected to be the same as the precision.



#### 11. Note

If the centrifuge head and tubes used to yield an effective radius differing from 3.5 inches, the speed of rotation should be varied to compensate for the difference. Centrifugal force varies directly with radius and with the square of the angular velocity. To find the velocity in rpm needed for a different value of the radius (r), the following expression may be used:

$$rpm = \frac{3.5 \times (2000)^2}{r}$$

The effective radius is measured from the center of rotation to the fritted glass in the crucible.

#### 12. Literature Reference

1973 Annual Book of ASTM Standards Part 23, American Society for Testing and Materials, D2187, "Standard Methods of Test for Physical and Chemical Properties of Particulate Icn-Exchange Resins".

The analytical procedures given herein have been adapted from literature sources or developed upon the basis of experimental data believed to be reliable. In the hands of a qualified analyst, they are expected to yield results of sufficient accuracy for their intended purposes, but recipients are cautioned to confirm the suitability of the methods by appropriate tests. Recipients are also cautioned that The Dow Chemical Company makes no representation or warranty that the practice of the method described herein does not infringe third party patents. Anyone wishing to reproduce or publish the materials in whole or in part should request written permission from The Dow Chemical Company.





October 25, 1978





# DOWEX\* Ion I GENERAL

		10	RESIN	TYPE COPOLYMER PHYSICAL FORM		ICADE	IONIC FORM AS SHIPPED	APPROX- IMATE SHIPPING WEIGHT Ib/cult	STANDARD MESH SIZE-WET MAXIMUM % +16 +20 FINE	PRESSURE DRO AT 25°C APPROXIMATE pei/h at 5 GPM/
	As por		DOWEX SBR	STRONG BASE	201 1 10	S	CI	44	+- 5% 3%-50	0.4
1.2		ŝ		TYPE I	Sec. 5	C/N	140 CT 11-2	- 44	2% 2% 20% 1%-45	0.35
da est				STYRENE-OVB	ICH,	C/N	OH-	41	- 2% 20% 1%-45	6.3
1. 1.				SPHENICAL BEAUS	1 parties a	5	OH	- 41		0.35
AT .			DUWER SBR P	STRONG BASE	N* N*	1 2	10-	43	2%-50	0.4
1. 1. 1.		BEL		STYRENE-DVB	I ACH L	C/N	·E' 0" •	43	2% 20% 1%45	0.35
	19		的人民的共同	SPHERICAL BEADS	A VALAND THE	C/N	. OHA.	40	2% 20% 1%-45	
	ES		DOWEX	DITTO SBR-P UNIQUE POROSITY	DITTO SBR-P	5	0	42	38 2 24-50	04
	NGE R		TOWE CALL	STRONG BASE TYPE II STYRENE-DVB SPHERICAL BEADS	N= CH,CH,O	S	а. 	4	5% 3%-50	04 • • • • •
		-	DOWEX MISA-IS	STRONG BASE TYPE I	Nº SA	s	20	12	1.2% > 3%-50	1 00 045 2
4	ਂ ਹੁ	S		STYRENE DVB	RATE IN AS	1	1.0-	42	194	1
	A <b>M</b> .	RO		SPHERICAL BEADS	Alt -	10	1. M. C. 812		+20 . 14 +	1
2	NON	ACROPO	IDOWE MSA-2	STRONG BASE TYPE II MACROPOROUS S-DVB SPHERICAL BEADS	-N= (CH,CH,O	H S	0	42	2% - ( 3%-50	8.45
Jac 1	A.	W	DOWEX MWA-1	WEAK BASE MACROPOROUS S-DVB SPHERICAL BEADS	N-(CH,),	s	FREE	40	2% 3%-50	a.45 y
		NHa	ODWEX WGR	WEAK BASE EPOXY AMINE HARD PARTICLES	z, —N (R), —NH Y —NH	R S	AMINE	43	10% 5%-40	5 445
	3.	EPI	DOWEOWGR 2	INTERMEDIATE BASE EPOXY AMINE HARD PARTICLES		R S	FREE S	43	1105 5%-40	C.45
1			DOWEX HCR.S	STRONG ACID	Las Pit-	·	Na*	53	1% 5% ····· 1%-50	8.4
3				CATION EXCHANGER	-\$0,-	S N	H*	50	5% 1%-50	0 0.4
1. 1.	19 1 A		32 to 2 to 2	STYRENE-DVB		N	U*	50	05%5	0 0.4
2 × 1	2		ARREST	SPHENILAL BEAUS	ALTERSON, T	5	NH.	51.5		- 04 
1			DOWEY HGR	STRONG ACID	20	5	No	54.0	A 2 5% 1%-50	04 2
1	Ľ.	H	2	STYRENE DVB	-S0,		And States	-F- 810	LE & PERKY	1
2			1.1.1.1	SPHERICAL BEADS	3.22	14 - 185	XINA	1.15	Les Marine Marine	国 法公计 AP
4.5	5		DOWDX HCA-WZ	STRONG ACID	43.747	S. 18"	No.	· SS ·	2% 1%-40	O.2 -
	2			CATION EXCHANGER	12	C/N	H- 14	4 50	2% 3 1440	
1- Sec. 1	5	1	Intro Dia Sug	STYRENE DVB	1. S. A. T.		* No*		1 2% Ang 1%-40	Se 24 . 2
2.00	X		ATTICALL DATE	SPHERICAL BEADS	SA ASOL	C/N	EH' al	51	YSE 2% 54.1%40	1 100 BA de
1. S. a. S.	2	5	DOWEX MSC-1-	STRONG ACID	Part T	5	17 Na***	50	# 8% * 5%-40	D4 Y
10.00 M	ē	80		CATION EXCHANGER	. 02-14	C C	-a Na* det		25 24 HA 1440	1 0.32 Y
7	# F	CNO		MACROPOROUS S-DVB	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	5	A H*49	47		04
1 4	\$ O	3		SPHENILAL BEAUS	12 4 4 1	6	A- H'	47	GITA ACTIVAT	
		CRMIS	DOWEX CCR24	CATION EXCHANGER SPHERICAL BEADS	# FC OH		1.1.1	30	10% Tas 1%-50	U
1	1.0	-	TGRADES TANK	S = STANDARD. C = C	ONDENSATE PO	LISHINC: N =	NUCLEAR	1 . 1 addition	and the second second	A POINT AND AND AND A
				MIXTURE STRONG ACID CATION: STRONG BASE ANION	GRADE	IONIC FORMS C:A	SHIPPING WT.	AL N	COMPONENT IOWEX RESIN ND GRADE ( ) FROM ABOVE	CAPACITY KgrCaCO, PER FT
N2	2	-	MA 3 DE	1:1 EQUIVALENTS	C-N	N:OH	60%	HCR WZ	HC/N SBR OHC/N AT	13.98 - 3
HYDR	5	3		1:1 EQUIVALENTS	8	HOH	. 45 30%	HCR S	H(S) SBR OH(S) <at< td=""><td>44-4 8 - 12</td></at<>	44-4 8 - 12
	2	9	MR-5 2N	1.1 EQUIVALENTS	N	L'OH	: 45	HCR S	I'(N) SBR OH(C/N)	12 Janie 12 (
		NE	TE MR.	1:1 EDUIVALENTS	N	U:OH		HCR-S-	UN SBR OH(C/N)	12
ANT		1	MRJA	1:1 EQUIVALENTS	N	NH. OH		HCR-S-I	NH (N) SBR OH(C/N)	12
	1. A. A. A.		St MR-12 CH	2:1 VOLUME		D #0H1 7		HCR W	HIC/N) SBR P-OH(C/N)	.8:3:
IN SIDE	1.1.1. A. 1.1.1.	1 500		APP		4-9-1-			an an an an an an	

hiles atim

18%

# xchange Resins



BED EXPANSION () AT 25°C APPROXIMATE %. AD. GPM/FC	WATER RETENTION	TOTAL WET VOLUNE ENCHANGE CAPACITY MIDLIMUM EQUIVALENTS / LITER	VOLUME CHANGE % SWELLING	REMARKS	DETAILED DATA SOURCE T.D. INDEX	
80	43-48	. 1.4		Standard, high sphencity resin suite: for water demineralization	220 01	
80 42	43-48	1.4		where organic fouling problems are minimal. Silica, weak acid, and strong, acid, removal. Excellent paidative, stability, "C" Grades	\$30.01	
10 - 3.2	MAX 50%	- 1.1	CI OH = + 15%	primarily designed for high flow rate applications and where		
BO	\$5-65	1.1		maximum oxidenve stability is required. "C" Grade bead strength everages > 350 grams / bead		
10 1 14 19274	53-60			Standard gel resin with porous gel structure to improve resistance	230.01	
	\$0-57	12	CI	to organic fouring and removal of minarar recess during regeneration. Highest regeneration efficiency of Type I resin. "C" Grade is widely used for dean back condensate antishine "C" Grade back towards	100 M	
10 11 11	\$0-70	1.0	· · · · · · ·	averages > 350 grams / bead		
0 1. The 40	55-60	<b>u</b>	CI OH = 20%	Best organic fouling resistance. Recommended for highest punty water production in mixed beds.	240 01 535 01	
80 × 11 × 10	38-45	LA.	CI OH = 14%	High efficiency resin for general deminerations service. Better efficiency than Type I for chlonde and sulfate removal with high physical strength but lower thermal stability.	210 01 \$33 01 \$60.00	
10 10 10 10 12	56-64 56-64	01) 016220	CI OH = 18%	Exceptional physical and esmotic shock stability make this resin most useful in systems using moving bed contactor and where high osmotic forces are involved, such as in chemical processing applications.	250.01 \$36.01	
10 30 10 10 10	\$3.60	10	CI OH = 14%	High capacity, excellent regenerant efficiency and good silica removal in counter current regeneration systems. Umited thermal stability.		
10 - 30 10 - 30	50-60	7 45 10 STOP	FREE AMINE TO HCI = 20%	Highly stable physically, thermally, axidatively, and osmotically least for chemical processing applications and plating waste processing.	320.01	
	= 50%	MINIMUM OPERATING CAPACITY AT	FREE AMINE TO	Wary high operating capacity at near theoretical regeneration efficiency combined with low tasts and odor throw make this resin excellent for potable water deionization.	310.01	
8 2, 14 80	a 50%	S Ib NaOH/Cu Ft = 1.14	HCI FORM a 25%	High capacity, high regenerant utilization efficiancy. Stability to exidation provides long term low nose making resin ideal in three bed systems. Good organic acid removal	330.01	
3 50 7 7.0	44-48	2.0		Standard cation resin with good physical characteristics ideally	**110.01	
1         50         6.5           50         7         6.5           7         50         6.5           4         50         7           50         7         7.0	\$0-56 \$0-56 \$6 MAX 42-46	1.8 1.8 1.8 3.4 20 - +111	No H = 8%	swited for water softening and makeup demineralizers. Nuclear grade and special ionic forms are applicable to radveste demi- neralizers. Also available as components of the mixed resins insted below. Structure based on styrene with 8% divinyIbenzene crosslinkage for optimum cost/property belance.		
	<b>38-43</b>	22	No	10% dwinylbenzene crossinited version of HCR.S. Perocularly applicable to systems requiring somewhat greater resistance to acidative degredation, both softening and deconceton applications.	130.01	
10 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Mat 44-48	1. 18		Premium 8% dimmilibenzene resin. Higher beed strength and purity autable for nuclear applications. Particle size distribution is control- led for optimum operation in deep bed condensate polishers and which had	120.04	
80 32 4 4 8.0 80 - 85	5 39-43 5 <sup>46-49</sup>	20 20	No H a 8%	Premium 10% dwiny/benzene version of the above, offenng im- proved stability to axidebve degradation. Higher density for op- timum separation in emixed bed with DOWEX SBR resin.	140.02	
50 *** 8.4 60 *** 7.8 50 50 6.0 50 7.4	44-50 44-50 50-56 50-56	- 05 > 13 - 15 	Na H <sub>12</sub> 4%	Provides excellent osmolic shock and oxidative degradation resist ance in aqueous chemical processing and water treatment applica- bons, including hot process softeners. Hydrogen form is also recommended for catelyfic applications reguining an acid catelyfig at temperatures to 120°C. Resin suitable for processing non-aqueous solutions.	, 1 <b>48</b> 0.01	
10 Extend 10	85		H	Recommended for desitalization of water for steam flooding or cooling towar applications as well as adjunct to strong acid cation in detonization processes.	171.01 163.01	

Additional Information

REGENERATION: Strong Acid Cation Resins - typically 10-26% NaCl for sodium cycle: 4-10% HCl or 2-8% H2SO, stepwise for hydrogen cycle.

in the state	Wesk Acid Cation Resins - typically 4-10% HCI or 1-5% H,SO, stepwise for hydrogen cycle; stepwise regeneration with sulfuric acid is need to control CaSO, precipitation.
	Strong Base Anion Resins - typically 4% NaOH solution.
	Weak Base Resins - typically 2-4% NaOH solution. Other bases such as NH, OH and Na2CO, can be used at equivalent concentrations.
THERMAL S	TABILITY: Strong Acid Cation Exchange Resins — good to 150°C. Weak Acid Cation Exchange Resins — good to 120° C.
	Strong Base Type I Anion Resin — CI form good to 100 C. OH form to 50 C. Strong Base Type II Anion Resin — CI form good to 77 C. OH form good to 35°C. Weak Base Anion Resins (Epoxy Amine Typa) good to 50 C (mecroporous type) good to 100°C
DOWEX resi	ine listed except DOWEX WGR-2 meet the FDA requirements of Title 21. Sybgart A, 173.25.

ł

0

are under at

· · · · · · · · ·

4

APPENDIX 10.7

# MANUFACTURER SPECIFICATION OF POWDEX

 $\sim$ 

.

GRAVER CHEMICAL Division of The Graver Company

# POWDEX SPECIFICATIONS

## HYDROXIDE FORM ANION

PPPTOUNTION	DE	SI	GN	A	TI	ON	1
-------------	----	----	----	---	----	----	---

RESIN TYPE

TOTAL CAPACITY

IONIC FORM

MOISTURE

AVERAGE SIZE

PARTICLE SIZE

SITE COMPOSITION

CONTAMINANTS (METALS)

PERCENT WHOLE BEADS (maximum) <5%

STRONG BASE ≥4.0 MEQ/DRY GRAM HYDROXIDE 57% (AVERAGE) 35 - 45 MICRONS IRREGULAR >92% OH <sup>-</sup> <2% Cl<sup>-</sup> <5% CO<sub>2</sub> <5% SC<sub>4</sub>

ANION (PAO)

<100	PFm	Fe	as	Fe
<10	PFm	Cu	as	Cu
<50	ppm	Al	as	Al
25	ppm	Pb	as	Pb

/ -

2 2.

1.1

1.7

Division of The Graver Company

GRAVERCHIEMICAL

# POWDEX SPECIFICATIONS

HYDROGEN FORM CATION

DESIGNATION

RESIN TYPE

TOTAL CAPACITY

IONIC FOR

MOISTURE

AVERAGE SIZE

PARTICLE SHAPE

SITE COMPOSITION

CONTAMINANTS (METALS)

CATION (PCH) STRONG ACID

STRONG ACTD

>4.8 MEQ/DRY GRAM

HYDROGEN

60% (AVERAGE)

35-45 MICRONS

IRRE GULAR

>99% H+

<50 ppm Fe as Fe
<10 ppm Cu as Cu
<100 ppm Na as Na
<25 ppm Pb as Pb</pre>

PERCENT SODIUM SITES PERCENT WHOLE BEADS (maximum)

<0.25%

\$%

40.2 182

Division of The Graver Company

GRAVER CHEMICAL

#### ECODEX SPECIFICATIONS

*DESIGNATION	:	ECODEX	
RESIN TYPE		STRONG BASE/STRONG ACID	
IONIC FORM		HYDROGEN/HYDROXIDE OR AMMONIUM/HYDROXIDE	
%MOISTURE		65% (AVERAGE)	
PARTICLE SHAPE		IRREGULAR	
PERCENT WHOLE BEADS (max	(imum)	, 2%	
TURBIDITY		≤3 NTU	
SETTLED VOLUME - V/V15		55-80%	

\*Resins in P grade Ecodex products conform to PAO, PCH, PCN specifications.

The mixed powdered resin/fiber precoat material must be a homogeneous mixture which is applied as a single component precoat. Chemical or material additives for adjustment of precoat floc or supernatant turbidity shall not be required.

9

Graver Water Chemical Division of Ecodyne Products

# TOTAL MOISTURE OF ANION POWDEX .

#### APPLICATION:

This method determines the total (as packaged) moisture of hydroxide form Powdex anion resin.

#### PRINCIPLE:

The hydroxide form Powdex anion is converted to the chloride form by slurrying with a solution of hydrochloric acid. After filtering off the acid and rinse water, the sample is transferred to a microwave oven and dried. The moisture content is determined by calculating the dry weight versus the wet weight.

#### APPARATUS:

1	- beaker, 250 ml	
1	- laboratory balance	
1	- graduated cylinder 200 ml	
1	- magnetic stirrer	
1	- spin bar, 1"	
1	- timer	· · · ·
1	- glass fibered filter paper 15 0	CM Whateas 024 M
1	- buchner funnel, 12.5 CM I.D.	CM Whatman 934 AH
1	vacuum source	
1	microwave oven (CEM Corporation	Model MDS 81)

#### REAGENTS:

1.0 N NH Cl D.I. water

PROCEDURE :

1. Approximately 10 grams of the Powdex anion are weighed into a tared 250 ml. beaker. Record the weight.

2. Add 160 mls. of 1.0 N NH<sub>4</sub>Cl to the beaker.

R.

3. Stir for 10 minutes at a moderate mixing speed. Weigh the filter paper and record the weight.

4. The filter paper is moistened and then placed into the funnel. The edges of the filter paper are molded around the inside circumference of the funnel, so as to form a lip all the way around.

Appendix 10.7.4

-9-
# TOTAL MOISTURE OF ANION POWDEX (CONT'D)

5. The contents of the 250 ml. beaker (excluding the spin bar) are poured into the buchner funnel/vacumm

6. After filtration of the acid, the resin cake is rinsed with 300 mls. of D.I. water.

7. The filter paper holding the resin cake is carefully removed from the funnel and placed on top of another filter paper. The traces of resin left in the funnel are carefully scraped out and transferred to the filter paper.

8. The two filter papers are then transferred to the microwave oven and dried for five minutes at 100% power. After drying, the filter paper holding the resin cake is

CALCULATION: Percent Moisture=1- (.928) ...(C1-RW-FP) Weight of Wet OH Resin X 100

> Cl-SW=Weight of Dry Chloride Resin cake FP=Filter Paper Weight

NOTES:

A. The conversion factor of 0.928 assumes an anion capacity of 4.20 meg./dry gm. OH form.

B. Make sure that all excess rinse water is filtered off before removing the filter paper from the funnel.

C. Do not rinse the traces of resin from the funnel, just scrape these out as quantitatively as possible.

D. Apply vacuum prior to filtering to ensure a good seal.

-10-

----

# TOTAL MOISTURE OF CATION POWDEX

#### APPLICATION:

This method determines the total (as packaged) moisture of hydrogen and ammonium forms of Powdex cation resins.

#### PRINCIPLE:

A sample of the material is transferred to a microwave even and dried. The moisture content is determined by calculating the dry weight versus the wet weight.

#### APPARATUS:

- 1 beaker, 125 ml.
- 1 laboratory balance
- 1 watch glass, 90 mm. diameter
- 1 microwave oven (CEM Corporationn Model MDS 81)

PROCEDURE :

1. Approximatley 8 grams of the Powdex cation are weighed onto the tared watch glass. Record the weight.

\* \*\*

2. The watch glass is transferred to the microwave oven and placed on top of the 125 ml. beaker. Dry for 5 minutes at 100% power.

3. After drying, the dried resin is weighed. Record the weight.

CALCULATION:

Percent Moisture = A - BA X 100

Where A = weight of wet Powdex cation Where B = weight of dry Powdex cation

#### NOTES:

A. Spread the sample over the surface of the watch glass so as to obtain a thin, uniform layer.

-16-

-----

# TOTAL MOISTURE OF ECODEX

# APPLICATION:

1-

7

7

1

3

3.

This method determines the total (as packaged)moisture of all H and N forms of Ecodex.

## PRINCIPLE:

The hydroxide component of the Ecodex is converted to the chloride form after conversion and rinsing. The sample is transferred to a microwave oven and dried. The moisture content is determined by calculating the dry weight versus the wet weight.

# APPARATUS:

1 - beaker, 250 ml. 1 - laboratory balance 1 - graduated cylinder, 200 ml. 1 - magnetic stirrer 1 - spin bar, 1" 1. - timer 1 - glass fibered filter paper, 15.0 CM Whatman No. 934 AH 1 - buchner funnel, 12.5 CM I.D. 1 - vacuum source 1 - vacuum flask, 500 mls. 1 - microwave oven (CEM) Corp. Model MDS 81) REAGENTS: 1. ON HCL 1. ON NH A CL 1. Approximately 10 wet grams of the Ecodex are weighed into a tared 250 ml. beaker. Record the weight. 2. Add 160 mls. of either 1.0N HCl or 1.0N NH 4 Cl to

the beaker. (use HCl for Ecodex hydrogen forms and NH 4

URINEN ALTINU

10.7.7

Stir for 10 minutes at a moderate mixing speed.

4. Weigh the filter paper and record the weight.

-25-

## TOTAL MOISTURE OF ECODEX

(cont'd)

5. The filter paper is moistened then placed into the funcel. The edges of the filter paper are molded around the inside circumference of the funnel so as to form a lip all the way around.

6. The contents of the 250 ml. beaker (excluding the spin bar) are filtered. The resin cake is then rinsed with 300 mls.of D.I. water.

7. The filter paper holding the resin cake is carefully removed from the funnel and placed on top of another filter paper. The traces of resin left in the funnel are carefully scraped out and transferred to the filter paper.

8. The two filter papers are then transferred to the microwave oven and dried for 5 minutes at full power. After drying, the filter paper holding the resin cake is weighed. Record the weight.

1.6.4

#### CALCULATIONS:

#### For 1111 Ratios:

Dry weight Cl form Ecodex = weight of dry resin cake weight of filter paper. Dry weight OH form Ecodex = (0.25) (dry wt. Cl Ecodex) (.928) + (0.75) (dry wt. Cl Ecodex)

#### For 1245 Ratios:

Dry weight Cl form Ecodex = weight of dry resin cake weight of filter paper. Dry weight Powdex component = (dry wt. Cl form Ecodex) (0.67)

Dry weight fiber component = (dry wt. Cl form Ecodex) (0.33)

Dry weight OH anion = (dry wt. Powdex component) (0.56)(0.928)

Dry weight cation = (dry wt. Powdex component) (0.44) Dry weight OH form Ecodex = (dry wt. of fiber) + (dry wt.of cation) + (dry wt. OH anion)

Processing a new

Percent Moisture:

grams of dry OH form Eccdex x 100

min but - at the set in

# Appendix 10.7.8

TOTAL MOISTURE OF ECODEX (cont'd)

-27-

----

NOTES:

. 2 1. One moisture is run for each sample collected. Report the average moisture of the individual samples.

2. The conversion factor of 0.928 assumes an anion capacity of 4.20 meq./dry grams hydrogen form.

3. Make sure that all excess rinse water is filtered off before removing the filter paper from the funnel.

4. Apply vacuum prior to filtering to ensure a good seal.

U.S. DEPARTMENT OF LABOR Occupational Safety and Health Administration Sort Asproved OMB No. 44-R1387

# MATERIAL SAFETY DATA SHEET

Required under USDL Safety and Health Regulations for Ship Repairing, Shipbuilding, and Shipbreaking (29 CFR 1915, 1916, 1917)

SE	CTION I	
Ecodyne - Graver Water Division	- <u>-</u>	EMERGENCY TELEPHONE NO. (201) 964-2400
ADDRESS (Number, Street, City, State, and ZLP Code) 2720 U.S. Highway, Union, New Jersey (	07083	TELEX 230-138215
Powdered Ion Exchange Material		Powdex Anion PAO
CHEMICAL FAMILY Organic Co-Polymer	FORMULA	Styrene - Divinylbenzene

PAINTS, PRESERVA	TIVES. & SOLVENTS	*	(Units)	ALLOYS AND METALLIC COATINGS	*	TLV (Units)
PIGMENTS	None	1		SASE METAL None		
CATALYST	None			ALLOYS None	1	
VEHICLE	None	1		METALLIC COATINGS None	- 1	
SOLVENTS	None	1		FILLER METAL PLUS COATING OR CORE FLUX NONE	1	
ADDITIVES	None			OTHERS None		
THERS	None	1			1	
	SAZARDOUS MIXTURI	ES OF	OTHER LI	QUIDS, SOLIDS, OR GASES	×	TLV (Units
			None			
					1	

	SECT	10N 111 -	PHYSICAL DATA		
BOILING POINT ("F.)		N.A.	SPECIFIC GRAVITY (H20=1)	1.1	
VAPOR PRESSURE (mm Hg.)		0	PERCENT, VOLATILE	55-60	(Water)
VAPOR DENSITY (AIR+1)	1	N.A.	EVAPORATION RATE		0
SOLUSILITY IN WATER	•	0	Density	30-35	lbs/ft <sup>3</sup>
APPEARANCE AND ODOR	Moist Rei	pe Pourter	Amine Odor		

FLASH POINT (Method und)	>500° E (0000	Curl	FLAMMABLE LIMITS	Lei	Uer
	>500 F (Open	cup)		N.A.	A. 6.
EXTINGUISHING MEDIA	H_0; CO2; San	nd			
ECIAL FIRE FIGHTING PR	OCEDURES	lone			
	10.	· · ·	*		
UNUSUAL FIRE AND EXPLO	SION HAZARDS	lone			

(8)

### SECTION V . HEALTH HAZARD DATA

RESHOLD LIMIT VALUE

. .

N.A. May remove essential anions from body fluids (CL, SO4, PO4)

May act as a mild caustic on exposed body tissues.

EMERGENCY AND FIRST AID PROCEDURES

Wash thoroughly with water if skin irritation occurs.

Use Water in eyecup if eye irritation occurs.

			SECTIO	CN VI - REACTIVITY DATA
STABILITY	UNST	TABLE		CONDITIONS TO AVOID
	STABLE		X	Fire or Extreme Heat
INCOMPATABIL	TY Water	(בוסעים כו בובר	Stron	ng Concentrated Oxidizing Agents i.e. HNO
HAZARDOUS DE	COMPOSI	TION PRODU	Tri	imethylamine; Styrene; Nitrogen Oxides
HAZARDOUS MAY OCC		MAY OCCU	R	CONDITIONS TO AVOID
POLYMERIZATI	ON	WILL NOT O	DCCUR	X

### SECTION VII - SPILL OR LEAK PROCEDURES

PS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED

Sweep up or wash away with water.

WASTE DISPOSAL METHOD

Burial

SECTION VIII - SPECIAL PROTECTION INFORMATION

RESPIRATORY PROTECTION (Specify Type)

		Not norm	STIL US	essarv		
VENTILATION	LOCAL EXHAUST	Not requ	ired	SPECIAL	None	
	MECHANICAL (General)	Not requ	ired	. OTHER	None	
PROTECTIVE GLO	Not required	•	EVE PROTI	ECTION Safet	y Goggles	
OTHER PROTECT	IVE EQUIPMENT TE				1	-

If dust is present, use suitable respirator.

SECTION IX - SPECIAL PRECAUTIONS

PRECAUTIONS TO BE TAKEN IN HANDLING AND STORING

woid hand to eve contact while working with material.

CTHER PRECAUTIONS

Spilled material may be slippery; do not walk on.

670 934-110

PAGE (2) Powdex Anion PAO

Appendix 10.7.11



U.S. DEPARTMENT OF LABOR

·.,

10

Form Asproved OMB No. 448:387

Occupational Safety and Health Administration

MATERIAL SAFETY DATA SHEET

Required under USDL Safety and Health Regulations for Ship Repairing, Shipbuilding, and Shipbreaking (29 CFR 1915, 1916, 1917)

SEC	CTION I		
MANUFACTURER'S NAME	1.1.1	EMERGENCY TELEPHONE NO.	
Ecodyne - Graver Water Division	· · · · ·	(201) 964-2400	
ADDRESS (Number, Street, Ciry, State, and ZIP Code) 2720 U.S. Highway 22, Union, New Jersey	07083	TELEX 230-138215	
Powdered Ion Exchange Material		Powdex Cation PCH	
CHEMICAL FAMILY Organic Co-Polymer	FORMUL	Styrene - Divinylbenzene	

	SECTION	· 11 /	HAZAF	RDOUS INGREDIENTS		
PAINTS, PRESERVA	TIVES, & SOLVENTS	1 %	TLV	ALLOYS AND METALLIC COATINGS	1%	TLV (Units)
PIGMENTS	None	1		BASE METAL None		
CATALYST	None	1		ALLOYS NODE	1	
VEHICLE	None	1		METALLIC COATINGS None		
SOLVENTS	None	1		FILLER METAL PLUS SCATING OR CORE FLUX None		
SITIVES	None	1		OTHERS None		
CHERS	None	1			1.	
	HAZARDOUS MIXTUR	ES OF	OTHER LI	QUIDS, SOLIDS, OR GASES	1 %	TLV (Units)
					1	
		Non	e.		.  .	
					1	
					1	1
the second s	A STREET BOARD AND AND AND AND AND AND AND AND AND AN					-

		SECT	TION III -	PHYSICAL DATA	and the second second	
BOILING POINT ("F.)			N.A.	SPECIFIC GRAVITY (H20=1)	1.3	· · · · ·
VAPOR PRESSURE (mm Hg.)			0	PERCENT, VOLATILE BY VOLUME (N)	55-65	(Water)
VAPOR DENSITY (AIR+1)		· .	N.A.	EVAPORATION TATE		1 0
SOLUBILITY IN WATER			0	Density	50-55	lbs/ft <sup>3</sup>
APPEARANCE AND ODOR	Moist	Brown	Powder,	Odorless		

FLASH POINT (Method used)		(0	FLAMMABLE LIMITS	Lei I Uei
	>>00 1	(Uben Cub)		
INGUISHING MEDIA	H20; CO2	; Sand	*	
SPECIAL FIRE FIGHTING PR	OCEDURES			1
		None		

None Appendix 10

-

				SECTI	ON V	- HE.	ALTH H	AZAR	D DAT	A	
THRESHOL	D L:MIT	VALUE		N.A.					1		
May re	DOVE	essenti	al ca	tions	from	body	fluids	. (Ca	a; Mg;	Na;	K.)
May ac	t as	a mild	acid	on exp	posed	body	tissue	s.			
EMERGENC Wash t	Y AND	FIRST AID	eROCE th wa	DURES ter 1	f ski	n irr	itation	occur	rs.		
Use wa	ter i	In eyecu	p if	eye i	rrita	tion	occurs.				· · · · · · · ·

			SECTIO	DN VI - F	REACTIVITY DATA					
STABILITY	UNST	ABLE	1	CONDITIO	NS TO AVOID					
	STAB	LE	X I	X   Fire or Extreme Heat						
INCOMPATABIL	JTY (Mater	213 10 EVOID	Strong	Concentra	ated Oxidizing Agents i.e. ENO,					
MAZARDOUS D	ECOMPOSI	TION PROD	UCTS Sty	rene; Su	lfur Oxides; Nitrogen Oxides.					
HAZARDOUS		MAY OCC	UR	1	CONDITIONS TO AVOID					
POLYMERIZAT	ON	WILL NOT	DCCUR	X						

SECTION VII - SPILL OR LEAK PROCEDURES	
S TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED	
Sweep up or wash away with water.	
*	
WASTE DISPOSAL METHOD	
Burial .	

RESPIRATORY PR	Not normally necess	sery.
VENTILATION	Not required	SPECIAL
	MECHANICAL (General) Not required	OTHER None
PROTECTIVE GLO	Not required	Safety Goggles
OTHER PROTECT	IVE EQUIPMENT If dust is present, use	suitable respirator.
	SECTION IX - SPECIAL PR	ECAUTIONS
PRECAUTIONS TO	D BE TAKEN IN MANDLING AND STORING	
Avoid 1	hand to eve contact while working with	h material.
OTHER PRECAUT	IONS	

Spilled material may be slippery; do not walk on.

PAGE (2) Powdex Cation PCH

\$ 14 E.

Appendix 10.7.13

U.S. DEPARTMENT OF LABOR Occupational Safety and Health Administration CME No. 44-R1367

# MATERIAL SAFETY DATA SHEET

Required under USDL Safety and Health Regulations for Ship Repairing, Shipbuilding, and Shipbreaking (29 CFR 1915, 1916, 1917)

SECTION I						
Ecodyne - Graver Water Division		EMERGENCY TELEPHONE NO. (201) '964-2400				
ACORESS (Number. Street. Ciry. State. and ZIP Code) 2720 U.S. Highway 22, Union, New Jersey	07083	TELEX 230-138215				
Powdered Ion Exchange Filter Material		TRADE NAME AND SYNONYMS Ecodex				
CHEMICAL FAMILY Organic Co-Poymer	FORMUL	A Styrene - Divinylbenzene + Fiber				

PAINTS, PRESERVA	TIVES. & SOLVENTS	3.	TLV (Units)	ALLOYS AND METALLIC C	DATINGS	1 *	TLV (Units)
PIGMENTS	None	1		BASE METAL	None	1	
CATALYST	None	1		ALLOYS	None		
VEHICLE	None			METALLIC COATINGS	None		
SOLVENTS	None .	1		FILLER METAL PLUS COATING OR CORE FLUX	None		
ADDITIVES	None			OTHERS	None		de.
THERS	None			a and the second se			10
	HAZARDOUS MIXTURE	S OF	OTHER LI	CUIDS, SOLIDS, OR GASES		1 *	TLV (Units
			None				_
						1	

	SECT	ION III -	PHYSICAL DATA		1 - P. (
BOILING POINT ("F.)		N.A.	SPECIFIC GRAVITY (H20=1)	1.2	
VAPOR PRESSURE (mm Hg.)		0	PERCENT, VOLATILE	65-70	(Water)
VAPOR DENSITY (AIR=1)	1. ITA 1. ITA 1.	N.A.	EVAPORATION RATE		0
SOLUBILITY IN WATER		0	Density	40-42	lbs/ft <sup>3</sup>
APPEARANCE AND ODOR	Moist, B	eige Powd	ler, Odorless		

cup)			
na			1
None			
	None	None	None

fahis amazon an barrets

In.

Form OSHA-20

S	ECTION V - HEALTH HAZARD DATA
RESHOLD LIMIT VALUE	N.A.
Ion exchange portion may	remove essential cations or anions from body fluids.
Inhalation or eye contac	t may produce irritation.
EMERGENCY AND FIRST AID PROCEDU	URES *
Wash thoroughly with wat	er if skin irritation occurs.
Usa water in eyecup if e	ye irritation occurs.

1.2.18			SECTIC	ON VI - REACTIVITY DATA			
STABILITY	UNST	UNSTABLE		CONDITIONS TO AVOID			
	STA	LE	x	Fire or Extreme Reat			
INCOMPATABIL	TY Mater	ais to svoid)	Strong	Concentrated Oxidizing Agents i.e. ENO,			
HAZARDOUS OF	LC OMPOS	TION PRODUC	TS St	vrene: Sulfur and Nitrogen Oxides; Trimethyla	mine		
HAZARDOUS		MAY OCCUR		CONDITIONS TO AVOID	- 10 M		
POLYMERIZATI	DN	WILL NOT O	CCUR	x			
				and the second se			

•	SECTION VII - SPILL O	A LEAK PROCEDURES	- 12E
PS TO BE TAKEN IN	CASE MATERIAL IS RELEASED OR SP	ILLED	
Sweep up or wa	sh away with water.		
WASTE DISPOSAL METH	405		
Burial			
Star I and			See .

	SECTION VIII - SPECI	IAL PROTECTION INFORMATION
RESPIRATORY PR	OTECTION (Specify type) Not	normally necessary
VENTILATION	Not	required SPECIAL None
Contraction of the	MECHANICAL (General) Not	required None
PROTECTIVE GLO	Not required	Safety Goggles
OTHER PROTECTI	VE EQUIPMENT If dust is	present, use suitable respirator.
1	SECTION IX -	SPECIAL PRECAUTIONS
PRECAUTIONS TO	BE TAKEN IN HANDLING AND STOP	RING

Avoid hand to eve contect while working with material. OTHER PRECAUTIONS

ŧ

Spilled material may be slippery; do not walk on. 6PO \$34.110

PAGE (2) Ecodex

Appendix 10.7.15

Form OSHA-20 REV. 2/83



#### ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager 7mBoly of Date 12-5-83

1

DATE	*F HIGH TEMPERATURE	F LOW TEMPERATURE	WET BULB DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
6-11-83	91.2	49.46	50	54	25%
6-12-83	90	50	64	90.61	42%
6-13-83	91	52	70	109.7	50%
6-14-83	88.86	54.12	70	109.7	55%
<b>9</b> 15-83	92.85	61.37	72	119.5	53%
6-16-83	98	60	77	140	51%
6-17-83	-	-	74	129.4	-
6-18-83	95.89	61.99	· 77	141.8	55%
<b>6-19-83</b>	97.23	66.45	76	139.9	53%
6-20-83	91	67	75	134.9	61%
6-21-83	-		76	137.7	
6-22-83	78.48	67	77	141.6	98%
AVERAGE	91	.59	72	121	54

. . . . .

#### ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

÷.,

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager \_\_\_\_\_ Date \_\_\_\_\_

DATE	°F HIGH TEMPERATURE	°F LOW TEMPERATURE	WET BULB DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
7-19-83	100.4	70.79	79	148.4	51%
7-20-83	102.1	70.89	80	157.1	51%
7-21-83	101.1	74.55	82	168.9	55%
22-83	104.4	72.30	83	173.4	54%
7-23-83	103.4	73.38	86	181.1	56%
7-24-83	102.7	75.39	82	166.3	53%
7-25-83	77.09	70.65	81	161.3	100%
7-26-83	91.82	61.73	74	127.1	58%
7-27-83	97.55	61.00	75	133.4	50%
7-28-83	97.79	64.05	75	134.5	48%
7-29-83	95.43	59.42	72	121.9	48%
7-30-83	90.34	60.21	73	123.8	58%
7-31-83	99.14	.65.92	78	149.1	52%
AVERAGE	97	68	78	150	56

4

. .

## ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager \_\_\_\_

Station .

-27

Date\_\_\_\_\_

-

DATE	°F HIGH TEMPERATURE	°F LOW TEMPERATURE	WET BULB DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
8-17-83	95.15	60.54	72	121.9	47%
8-18-83	98.45	63.39	75	132.5	48%
8-19-83	102.8	67.62	79	151.1	49%
20-83	106.4	71.19	80	157.1	45%
8-21-83	108.4	71.46	79	153.8	42%
8-22-83	106.9	70.95	81	162.4	45%
8-23-83	106.9	76.63	81	161	45%
8-24-83	97.75	70.57	80	157.2	59%
8-25-83	88.4	70.57	79	153.9	75%
8-26-83	92.85	67.52	77	139.4	61%
8-27-83	97.67	67.57	78	145.1	55%
8-28-83	97.23	69.72	59	79.49	30%
8-29-83	96.36	69.91	75	135.1	52%
AVERAGE	100	69	77	142	50



#### ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager From Bolym Date 12-5-83

DATE	HIGH TEMPERATURE	LOW TEMPERATURE	DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
9-7-83	91.42	68	77	141.4	64%
9-8-83	94.61	68.91	77	141.2	58%
9-9-83	93.48	67.57	79	152.3	63%
9-10-83	92.48	67.62	80	157.8	69%
11-83	94.46	66.9	80	158.8	65%
9-12-83	95.96	66.7	75	130.6	52%
9-13-83	74.44	67.36	72	120.6	97%
9-14-83	71.03	57.84	66	96.82	84%
9-15-83	78.81	57.98	65	93.94	62%
9-16-83	80.97	54.46	66	97,4	63%
9-17-83	88.3	54.23	71	117.2	59%
<b>9-</b> 18-83	88.39	60.27	76	137	68%
<b>9-</b> 19-83	87.75	59.56	74	129.3	66%
9-20-83	81.99	69.22	70	111.6	69%
9-21-83	81.99	49.45	73	124.1	78%
9-22-83	70.04	<i>₩ ±</i> 41.13	49	51.53	48%
9-23-83	75.43	44.95	51	56.42	42%
24-83	73.79	44.26	53	60.57	50%
AVERAGE	84	59	70	115	64

.

#### ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager

7

Date 12-5-83

DATE	°F HIGH TEMPERATURE	°F LOW TEMPERATURE	WET BULB DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
10-26-83	67.67	37.13	52	57.98	60%
10-27-83	64.39	33.75	45	44.84	50%
10-28-83	70.76	33.14	50	53.34	49%
10-29-83	76.31	41.63	55	63.5	48%
-30-83	61.78	53.11	47	49.27	49%
10-31-83	67.95	50.72	53	61.31	60%
AVERAGE	68	42	50	55	53

14. 17 - 1

#### ATMOSPHERIC DATA-PAGE 1

The following atmospheric data was gathered from a location approximately five miles Northeast of Aiken, South Carolina.

Barnwell, South Carolina is approximately 30 nautical miles Southeast of Aiken, South Carolina.

The data presented is considered to be accurate and representative of conditions in Barnwell for purpose of evaluation in reference to the dewatering tests conducted.

Project Manager \_\_\_\_\_ Date \_\_\_\_\_

, sh

DATE	°F HIGH TEMPERATURE	°F LOW TEMPERATURE	WET BULB DEW POINT	GRAINS OF MOISTURE/LB.AIR	RELATIVE HUMIDITY
11-1-83	70.46	42.13	60	77.72	70%
11-2-83	69.43	37.75	57	71.77	68%
11-3-83	74.32	38.83	61	80.95	62%
1-4-83	67.49	46.96	62	84.45	82%
11-5-83	59.33	30.57	30	24	31%
11-6-83	62.62	30.59	43	42.19	50%
11-7-83	62.96	39	56	68.98	81%
11-8-83	70.41	53.63	59	73,73	68%
AVERAGE	67	40	54	65	64







1								RE	VISIONS				
1 1 1 1 1 1	R	EV.				DESC	RIPTION	4			DATE		APPROVED
									CON	, 1221	100 57	γ	
CNSI_S BOARD BY DATE NOTE:	AFETY APTRO 4 9 2 THIS	REV VAL	IEN	N IS	CONS	IDER	ED PRO	COP	Y NO.		OT TO BE	RELEA	SED
	OR CO.	PIED	WITHC	UT W	RITTE	N PL	Ma150	ION OF	Chicke-	NULLEA .	a SiSiE	, 110	•
	1	_				REV	ISION S	TATUS		1		1	
		2	3	4	5								
SHEET	1	and the owner water water water			1		1						1
SHEET	<u>1</u>	-			-								
SHEET	r 1	-	-		-			+	+	+		-	
SHEET REV. SHEET REV.	r 1	-			-			_		+			
SHEET REV. SHEET REV. PREPARED					-								
SHEET REV. SHEET REV. PREPARED DELL	DATE S 3-3 3-3 7 3-3		TITLE		-	HE	M -	NUC ATIC 1 EQUIN	CLEA	R SY	STEMS	S, IN	C.

18 Mar

TABLE OF CONTENTS 0 Page 3 1.0 SCOPE 3 REFERENCES 2.0 3 3.0 DETAILED INSTRUCTIONS 4.0 DOCUMENTATION 4 FIGURE 1 5 C 10 . 11 2 DOCUMENT REV. SHEET 2 S20-OP-016 Appendix 10.9.2

#### 1.0 SCOPE

1

#### 1.1 Purpose

The purpose of this instruction is to insure the hydrostatic testing of hoses and piping systems are performed in a safe and satisfactory manner.

#### 1.2 Applicability

This instruction is applicable to the hydrostatic testing of all hoses and piping systems manufactured and assembled in the Field Equipment Maintenance Shop.

#### 2.0 REFERENCES

2.1 CN-AD-003, Procedure For Document Preparation

#### 3.0 DETAILED INSTRUCTIONS

- 3.1 Prerequisites
  - 3.1.1 Hydrostatic test equipment is located in a space designated by the Shop Supervisor/Manager.
  - 3.1.2 All gauges used on test equipment have valid calibration stickers and certification papers.

#### 3.2 Precautions

- CAUTION: HOSES AND OTHER PRESSURE RETAINING COMPONENTS MAY BE PRESSURIZED DURING DISASSEMBLY. FACE SHIELDS AND APPRO-PRIATE PROTECTIVE CLOTHING SHALL BE WORN DURING DISASSEM-BLY OF THIS EQUIPMENT.
  - 3.2.1 All personnel using hydro test equipment shall be qualified by the Shop Supervisor on correct use and shall have a valid copy of this instruction available.
  - 3.2.2 The item to be tested will be placed in a position to avoid injury to personnel and equipment in case of a component rupture during the test.
  - 3.2.3 All personnel who operate the hydro test equipment shall wear either safety glasses, goggles, or face shields and shall remain in back of the test equipment during testing.
  - 3.2.4 During testing, pressure changes should be made in 50 psig increments. The average pressure change should not exceed 10 psig per second.

		REV.	SHEET
S	20-0P-016		3

#### 3.3 Hydrostatic Testing

- 3.3.1 Install a high point bleed-off valve on the equipment to be tested.
- 3.3.2 Elevate the bleed-off valve. This will allow venting of the air in the component during the initial filling.
- 3.3.3 Connect the equipment to the hydro tester and connect the air supply to test equipment.
- 3.3.4 Check to insure the bleed-off valve (B-1) on the hydro tester is closed.
- 3.3.5 Open water supply valve on the hydro tester to allow water flow.
- 3.3.6 Open the air valve (SA-1) slowly to increase water flow until flow is observed out of the bleed valve. Continue venting until all air is forced out, then close the vent valve.
- 3.3.7 Operate the test equipment and raise the component pressure to the required test pressure.

#### CAUTION: THE OFERATOR SHALL OBSERVE THE LIMITS OF SEC-TION 3.2.4 ABOVE.

- 3.3.8 Close the air supply valve SA-1.
- 3.3.9 Inspect the test piece carefully for any visible leaks. Hold test pressure for a full 30 minutes.
  - NOTE: IF HYDROSTATIC PRESSURE CANNOT BE MAINI' NED, LOCATE THE SOURCE OF THE LEAK. BLEED THE PRL.JURE OFF USING SECTION 3.3.10 BELOW. REPAIR THE LEAK AND RETEST STARTING WITH SECTION 3.3.1 ABOVE.
- 3.3.10 When test is completed, open bleed-off valve (B-1) on hydro tester to release pressure. Remove test piece from tester.
- 3.3.11 Open bleed-off valve on the test piece to remove water.

#### 4.0 DOCUMENTATION

- 4.1 Once the test is complete all results must be entered in the Hydro Test Log Book on Form No. MMS-11 (See attached sheet).
- 4.2 The serial number assigned to the test component shall be etched on the item. A metal tag may be used on items where vibroetching is not feasible and/or desired.

DOCUMENT		REV.	SHEET
S20-0P-016		-	4
	Annondix 10-0-1	1	
	Appendix 10101		CNSQ 1002/8-78



-

-

1

ø



## TABLE OF CONTENTS

	이 같은 것은 것은 것은 것은 것은 것은 것이 없는 것이 같이 없다.	Page
1.0	SCOPE	3
2.0	REFERENCES	3
3.0	REQUIREMENTS	3
4.0	PRE-OPERATIONAL CHECKS	3
5.0	ACCEPTANCE CRITERIA	5
6.0	MARKING	5
7.0	POST-OPERATING PROCEDURE	5
8.0	RECORDS	5
FIGUE	RE 1	6
FIEL	D EQUIPMENT MAINTENANCE SHOP TEST RECORD FORM	7

2 **3**: 43

nondi

SHEET

2

SO 1002/8-78

REV.

4

S20-0P-017

DOCUMENT

8

· ·

Ser.

ä

#### 1.0 SCOPE

1.1 This procedure provides guidance for the initial comparison and re-acceptance of pressure gauges and switches using the Portable Live Pressure Tester, Model 3112 manufactured by King Nutronics.

#### 1.2 Applicability

This procedure may be used for mechanical and/or mechanical electrical instruments carrying gas or liquid.

#### 2.0 REFERENCES

2.1 Quality Assurance Program, QA-AD-001

2.2 ASME Code Section V

#### 3.0 REQUIREMENTS

- 3.1 Gauges requiring comparison shall be rechecked every 12 months or sooner if accuracy is in doubt.
- 3.2 Reference gauges shall be calibrated semi-annually by an outside instrument shop. Calibration certification shall be traceable to National Bureau Of Standards
- 3.3 Gauges shall be tested by a qualified operator to maximum system design pressure and/or maximum gauge design pressure, whichever is less.
- 3.4 Gauge comparison may be accomplished either installed or bench tested.
- 3.5 A Gauge Comparison Record Form shall be maintained for each gauge tested and shall have a signature verifying that the test has been completed.

## 4.0 PRE-OPERATIONAL CHECKS

- 4.1 Place the portable pressure tester on a stable level surface.
- 4.2 Depress relief value core on tester case to equalize internal pressure and open case lid.
- 4.3 Check unit to ensure internal nitrogen bottle has adequate pressure to accomplish the desired test. If supply pressure is low, charge tester as described below.

4.3.1. Cha.ging Portable Live Pressure Tester Cylinder

4.3.1.1 Connect test hose to tester fill port coupling, connect opposite end of test hose to external nitrogen supply source.

\$2

DOCUMENT	REV.	SHEET
\$20-0P-017	-	3
Appendix 10.9.7		

- 4.3.1.2 Open vent valve and close pressure control valve.
- 4.3.1.3 Open supply cylinder shut off valve and charge tester internal cylinder to 2250 psig as indicated on the supply pressure gauge.
- 4.3.1.4 When cylinder is fully charged, bleed off pressure from test hose assembly. Disconnect assembly from fill port coupling and external . nitrogen supply source.

#### 4.4 Gauge Comparison

- CAUTION: HOSES AND OTHER PRESSURE RETAINING COMPONENTS MAY BE PRESSURIZED DURING DISASSEMBLY. FACE SHIELDS AND APPRO-PRIATE PROTECTIVE CLOTHING SHALL BE WORN DURING DISASSEM-BLY OF THIS EQUIPMENT.
  - 4.4.1 Close vent pressure control valves.
  - 4.4.2 Connect test hose to <u>Test</u> port opening, connect opposite end to item being tested.
  - 4.4.3 If pressure switch is to be tested, connect electrical test leads between output terminals of the pressure switch and electrical test plugs on tester.
  - 4.4.4 Gradually open pressure control valve and very slowly approach the test point while observing appropriate master gauge.
    - NOTE: THE TESTER IS DESIGNED TO PROTECT THE LOW RANGE GAUGE SO THAT NO DAMAGE WILL OCCUR WHEN IT GOES TO FULL SCALE.
  - 4.4.5 Close pressure control valve when test point has been reached. If desired pressure is exceeded, open vent control valve to bleed off pressure as necessary. Allow time at each test point for gas temperature to stabilize before taking pressure reading.
  - 4.4.6 If pressure switch is being tested, neon indicator lamp will extinguish when pressure switch activates.
  - 4.4.7 Repeat Steps 4.4.4 and 4.4.5 as necessary for higher test pressures.

NOTE: THE GAUGE BEING CALIBRATED MUST BE WITHIN + 10%

4.4.8 To check test points in a descending order, reduce pressure by slightly opening the vent control valve, and very slowly bleeding off pressure until the desired test point is reached.

DOCUMENT			REV.	SHEET
	\$20-0P-017	Appendix 10.9.8	-	. 4

4.4.9 After completion of tests, close pressure control valve and open vent valve to reduce pressure in the tester circuit to zero.

## 5.0 ACCEPTANCE CRITERIA

5.1 If the gauge being calibrated reads greater than + 10% of the master gauge within the normal operating band or at zero, the gauge is not acceptable and shall not be used.

#### 6.0 MARKING

- 6.1 If gauge is within ± 10% of master gauge at 1/2 test pressure in the normal operating band or at zero, proceed as follows:
  - 6.1.1 Fill out gauge acceptance sticker with:
    - 6.1.1.1 Calibration Date
    - 6.1.1.2 Date Due for Re-Calibration
    - 6.1.1.3 Signature of Personnel Performing Calibration
    - 6.1.1.4 QA Inspectors Initial
  - 6.1.2 Ensure gauge serial number is vibro etched on gauge.
  - 6.1.3 Place calibration sticker on an exposed portion of the gauge if possible. On enclosed gauges, place calibration sticker on the panel face directly below associated gauge.

## 7.0 POST-OPERATING PROCEDURE

- 7.1 After completion of tests, perform the following post-operating procedures:
  - 7.1.1 Disconnect test hose and electrical leads and stow in lid of case.
  - 7.1.2 Install dust caps on test and fill port couplings.
  - 7.1.3 Close case lid and place unit in safe storage.

#### 8.0 RECORDS

- 8.1 The Gauge Comparison Record Form shall be filled out and signed.
- 8.2 The Cauge Comparison Record Form shall be filed with the Test/ Acceptance Records package for the unit in which the gauge is installed.

DOCUMENT		REV.	SHEET
S20-0P-017		-	
0.00 0.0	Appendix 10.9.9		



# HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 0 23 Description of Item Being Tested: 10' Hydrolic 5.5. \v| the malk Hydro Test Pressure: 0.S.E. 225 nuration of Test: .... ject Number: Intended Use of Item Being Tested: Waste Serial Number Assigned to Item Tested: 21 Comments: Name of Person Performing Test: KD Sulling Initials

Quality Assurance Signature:

Appendix 10.9.11

Form No. MMS-12

4-28-80

# HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 6 23 83 Description of Item Being Tested: Hudrolic 25' Host S.S. KAMLOUKS Hydro Test Pressure: 225 n.S.T. Duration of Test: 30 MIN ...ject Number: Intended Use of Item Being Tested: Wayie Serial Number Assigned to Item Tested: 2417 Comments: m: 11 3 ' Name of Person Performing Test: DSulli Quality Assurance Signature: Form No. MMS-12 4-28-80 Appendix 10.9.12 62.30

# HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destinations: 6 23 Date of Hydro: 83 Description of Item Being Tested: 25' Hydrolic HOSE remale Kanlock Hydro Test Pressure: 225 n. S.I. Duration of Test: Project Number: Intended Use of Item Being Tested: WASTE . . Serial Number Assigned to Item Tested: 2413 240) 241 Comments:

Name of Person'Performing Test: RoSulla

Quality Assurance Signature: \_

Form No. MMS-12 4-28-80 Appendix 10.9.1352

# HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 6 23 83 Description of Item Being Tested: 3/4 \* 25' Hydrolic 5.5. Have w FEMALE KANJOUR ELE Hydro Test Pressure: 225 D.S.I. nuration of Test: 30 MINV 11119 --ject Number: Intended Use of Item Being Tested: WASTE Serial Number Assigned to Item Tested: 2407 Comments: Name of Person Performing Test: RySulli. Quality Assurance Signature: Form No. MMS-12 4-28-80

Appendix 10.9.14
# HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 23 Description of Item Being Tested: .. FEMPLE ocus Hydro Test Pressure: 225 1.1.2. Duration of Test: ON MIN! .uject Number: Intended Use of Item Being Tested: Value Serial Number Assigned to Item Tested: 2 2406 Comments: · M· 11: Name of Person Performing Test: R.9 Sullis Initials: Quality Assurance Signature: No. MMS-12

Appendix 10.9.15

4-28-80



ES ST

3

10

IMAGE EVALUATION TEST TARGET (MT-3)



in the

-----

12 1 133

8

0





SU



### HYDROSTATIC TEST REPORT FORM

PURPOSE: This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 6 23 83 Description of Item Being Tested: 1/2" & 50' Hydrolic MALE & FEMALE S.S. Hydro Test Pressure: 125 p.(.1 . Duration of Test: 30 Project Number: 11118 Intended Use of Item Being Tested: Waste Serial Number Assigned to Item Tested: Comments: · · · · · · · Name of Person Performing Test: 50 Sullide Initials Quality Assurance Signature: Form No. MMS-12 4-28-80 Appendix 10.9.16 in Es 1212 7 22.2

HYDROSTATIC TEST REPORT FORM

PURPOSE: This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: Date of Hydro: 4 23 83 Description of Item Being Tested: 1/2 VAVOLIC ISE 5.5. W 225 p.S.I. Hydro Test Pressure: Duration of Test: 30 MIN . roject Number: Intended Use of Item Being Tested: Waste Serial Number Assigned to Item Tested: 2404 Comments: 4 Name of Person Performing Test: KD Sulla. Initials: Quality Assurance Signature: Form No. MMS-12 4-28-80 Appendix 10.9.17

A STATES

BRAN

2414 154 H H H H H H H H H H H H H H H H H

### HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destination: 83. 23 Date of Hydro: U 50' Description of Item Being Tested: Hy drolic. S.S. TEMPIE HOSE KAMLOCKS Hydro Test Pressure: 225 D.S.I. Duration of Test: 30 ANIN ... ject Number: Intended Use of Item Being Tested: WRGAC Serial Number Assigned to Item Tested: \_ 2403 Comments: · # · 1. + 1 Name of Person Performing Test: AD Sulli, Initials Quality Assurance Signature: Form No. MMS-12

4-28-80

•	
	CHEM-NUCLEAR SYSTEMS, INC.
	Mobile Maintenance Shop
	HYDROSTATIC TEST REPORT FORM
PURPOSE:	This form shall be used as a first of the state of the st
	test that is not otherwise required on any other
	hose, etc. This form will be retained of equipment,
	period of one (1) year.
Destina	Ter:
Data of u	1100 100
Date of Hy	Yaro: 0 13 83
Descriptio	on of Iten Being Tested: 1/2" x 50 Wulleli
TIOSE	WSSTEMPTE and wold Valor
	FINIC FINIC
Hydro Test	Pressure: 205
Duration	Las p.s.t.
suration o	Trest: <u>SO MIN!</u>
-ject Nu	mber:
Intended U	se of Item Being Tested: WASAL
Serial Num	
	assigned to item Tested:
-	
comments: _	
	· · · · · · · · · · · · · · · · · · ·
	· # · · · · · · · · · · · · · · · · · ·
Name of Pers	son Performing Test: Ro C.112 N.W
Name of Pers Quality Assu	son Performing Test: Ro Sulfing Initials
Name of Pers Quality Assu	son Performing Test: Ro Sulling Initials
Name of Pers Quality Assu	son Performing Test: <u>RO Sullar</u> Initials: brance Signature: Form No. MMS-12

## HYDROSTATIC TEST REPORT FORM

PURPOSE:

This form shall be utilized whenever a hydrostatic test that is not otherwise required on any other form or document is required on a piece of equipment, hose, etc. This form will be retained in file for a period of one (1) year.

Destinations: Date of Hydro: \_ 6 23 83 Description of Item Being Tested: 1/2" x 50 S.S. FEMALE KAMDOCKS USE w Hydro Test Pressure: 225 p.S.I. Duration of Test: 30 MIN .uject Number: Intended Use of Item Being Tested: WAST & Serial Number Assigned to Item Tested: 240 Comments: : #: # 2 : Name of Person Performing Test: Ro Sulla Quality Assurance Signature: Form No. MMS-12 4-28-80 Appendix 10.9.20

TEST GAUGE	INDICAT	TED VALUE
VATUE	INCREASING	DECREASING
20	20	20
40	40	40
60	60	60
80	80	80
100	103	1 102
120	122	124
148	144 .	144
160	NIR	NIA

Gauge Serial Number	BW-160-219
Date Compared	6-23-83
Comparison Due Date	6-23.84
Destination	Eng. 11.11.8
Test Gauge Serial Number	BU-100-037/BUD-2000-036
Test Gauge Calibration Due Date	9.2-83
Test Conducted By	mike Rely
Quality Assurance Representative	CNSI

.

THE CALLER	INDICA	TED VALUE
VALUE	INCREASING	DECREASING
20	18.5	20.0
40	38.0	40.0
60	59.0	40.0
80	80.0	80.0
100	105.0	105.0
120	122.0	124.0
140	138.0	140.0
1 40	N/A*	N/A
	2	
•		
1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1		

BW-160-268 28
1-23-83
6-23-84
Eng - 1118
BW-100-037 180-2000-036
9-2-83
mike Lilis
CNSI



TEST CALLER	INDICATED VALUE		
VALUE	INCREASING	DECREASING	
20	20	20	
40	40	48	
60	59	60	
80	79	68	
100	102	102	
120	123	123	
140	14.3	144	
160	163	163	
AP I			
		T	

Gauge Serial Number	BW-0-160-270
Date Compared	6-24-83
Comparison Due Date	10-24-84
Destination	FRANCE BE En 11118
Test Gauge Serial Number	Bw-100-030 /Bw 1000-036
Test Gauge Calibration Due Data	9-2-83
Test Conducted By	NB tuck l
Quality Assurance Representative	CNSI CNS



(

1

Ø

9

TEST CALLER	INDICATED VALUE			
VALUE	(mg) INC	REASING PSI)	(HI) DECH	(PS)
5	- 6:	5,	- 6.	5.
10	- 11.	10.	- 11.	10.
15	- 16.	15.	- 16	15.
20	- 20.5	20.	-21.	20.
25	- 26.5	25	- 26.	25.
30	- 31.	30	- 31.	30
		1.00		
		1		
		1,		

Gauge Serial Number	80-30-0	30 - 27/
Date Compared	6-24-	83
Comparison Due Date	6-24-8	54
Destination	En. FRA	Ne B IIId
Test Gauge Serial Number	0/338 (H9)	BW. 100 . 037
Test Gauge Calibration Due Date	6-9-84	9-2-83
Test Conducted By	N. K-1	the C
Quality Assurance Representative	CNSI	9
	5	

INDICATED VALUE			
(H9) INCREASING (PS.)		(H9) DECREASING	
- 6	5	- 6	5
- 11	10	- 11,5	10
- 16	1 15	-16	15
- 21	20	- 22	20
- 26	25	1-26	25
- 31	30	- 31	30
	-	1	
· · ·			
1			
	1		
r	BW-	30-0-3	0-272
	6	124183	
e	6	124184	
	Em F	And. B. 1	1118
Number	Bt0-10.	1338 BW	-100-037
tion Due Date	6/9/	84 9	12183
1 8: 11 1	N.	I fich g	-1-2-
51		20-	The Control of the Owner of the
	$\frac{(H_{9})}{INC}$ $\frac{-6}{-11}$ $\frac{-16}{-21}$ $\frac{-26}{-31}$ $\frac{-31}{-26}$ $\frac{-31}{-26}$ $\frac{-31}{-26}$ $\frac{-31}{-26}$ $\frac{-31}{-26}$	$     \begin{array}{c c}             INDICA \\                                    $	$\frac{\text{INDICATED VALUE}}{(H9) \text{ INCREASING} (PSH) (H9) \text{ DECR}}$ $-6 5 - 6$ $-11 10 - 11.5$ $-16 15 - 16$ $-21 20 - 22$ $-26 25 - 26$ $-31 30 - 31$ $-31 30 - 31$ $-31 30 - 31$ $-31 - 30$ $-31 - $

4

		INDICAT	ED VALUE	
VALUE	(HG) INC	REASING (PSI)	(HG) DECRE	ASING (PSI)
5	-6	5	-6.5	5
10	- 11	10	- 11	11
15	- 16.5	15	- 16.5	16
20	-21.5	20	- 22	21
25	- 26.5	26.5	= 26.5	25.5
30	-31.5	31.5	- 31.5	31.5
		•		

- 6/24 6/24 Eng. Fr. nol.	4/83 184 B. 1115
6/24 Eng. Fr. nol.	184 B. 1115
Eng. FR. Anl.	B. 11115/
38 (HG)	BW-100-037
19/84	9/2/83
V.B. Fuch	
CNSI	0
	19/84 AB Frick CNSI 5



TEST GAUGE		INDICAT	ED VALUE	
VALUE	(HG) INCRI	EASING (PSI)	(HG) DECR	EASING (PST)
1-2		5	- '0	5
10		10	- 11	10
t- <u>15</u>	- 16	15	1-16	15
50	-21	20	- 21	20
as	-26	25.5	-26	25
30	- 31	30.5	-31	305
		10	*	
Gauge Serial Number		BW-30-	0-30-2'	74
Date Compared		6	24/83	
Comparison Due Date		6	124/84	
Destination		E.N.S	Franks	3 1110
Test Gauge Serial Number		D/338 (H	6) R()	10 000
Test Gauge Calibrat	ion Due Date	Blalau	al-	102
Test Conducted By	· · · · ·	NR	4.1.	(18)
Quality Assurance P	presentation	CNSI	June	
and ance he	presentative	5	+	

TEST GALGE	INDICATED VALUE			
VALUE	(HG) INCREASING (PST)		(HG) DECREASING (DST)	
5	- 5.5	5	h	5
10	-10,5	10	- 11	10
15	- 15.5	15	-16.5	15
20	- 20.5	20	-205	20
25	- 25.5	25	- 25	25
30	- 30,5	30	-305	30
	1.90.000			
	1			
	· · ·			1. S. S. S. S.

Gauge Serial Number	BW-30-0-30-275
Date Compared	. 6/24/83
Comparison Due Date	6/24/84
Destination	EEnx. Fent. R INV
Test Gauge Serial Number	0/338 (HG) BW-100-037
Test Gauge Calibration Due Date	16/9/84 <b>8</b> 12/92
Test Conducted By	H. B. Fech
Quality Assurance Representative	CNSI
	(3)

....

....

......

TEST GALIGE	INDICATED VALUE		
VALUE	INCREASING	DECREASING	
20	18	20	
40	38	40	
60	58	100	
50	78	VA VA	
00	101	1112	
20	121	12/	
40	141	- 142-	
160	161	161	

BW. 0-160-283
6-24-89
6-24-84
En- Front B. 1110
Bw- 100 and Print
9-2-83
Id. B. Soil 1.
Richt

5

TEST GAUGE	INDICATED VALUE			
VALUE	(1+5) INC	REACING (PSI)	(HS) DECREASING (PS)	
5	- 10.	5,	-65	5
10	-11.5	16.	-11.	10
15	-17.	: 15	-12	15
20	- 22	20	-22,	20
25	-27.5	25	-27.5	25
30	-32.5	30	-32.5	30
•		•		

.

1

Gauge Serial Number	Bw. 30-030 - 264
Date Compared	6-23-83
Companison Due Date	16-23-84
Des ination	FRANK. B.
Test Gauge Serial Number	(H5) (P51) 11 16 - 80 769 BW-100-037
Test ( Calibration Due Date	6-9-84 9-2-83
Test Conducted By	ABtench f.
Quality (ssuri, ce Representative	CNSI

1.4

1

Appendix 10.9.30

.

r

.

TEST GAUGE	GE INDICATED VALUE				
VALUE	(113) INC	(H5) INCREASING (PSI)		(HS) DECREASING (PSI)	
5	- 6.	5,	-55	55	
10	- 110	10.	- 05	10 5	
15	- 16.5	15.5	- 16	15.5	
20	-21.5	20.5	- 21.	20.5	
25	- 26.5	25.5	1= 26,	25.5	
30	- 31.5	30.5	- 31.5	30.5	
		1			
		1			

Gauge Serial Number	80-30-0-30-261	-
Date Compared	10-23.83	
Comparison Due Date	6-23-84	
Destination	FRN.K. B.	
Test Gauge Serial Number	43+3 #16A- 80969 (HS) (PSI) BW-10	0-017
Test Gauge Calibration Due Date	6.9-84 9-2	- 83
Test Conducted By	JAB ficher .	
Quality Assurance Representative	CNSI	

1.4



\*

.

,

T

TEST GAUGE	INDICATED VALUE			
VALUE	(HS) INCREASING		(HS) DECREASING (PSI)	
5	- 5.5	5.5	- 55	15
10	-10.5	10.	- 105	10
15	- 16.	15.5	- 155	155
20	- 21.	20,	- 21	205
25 .	- 26.	25.5	F 25.5	25.5
30	- 31.	29.5	- 31	29.5
		•		
	1.11.1.1.1.1.1.1			

Gauge Serial Number	Bw- 30- 0-30 - 266
Date Compared	6-23-83
Comparison Due Date	6-23-84
Destination	FRAL B.
Test Gauge Serial Number	9/3+3 (HS) PSi) #16A-80769 800-100-037
Test Gauge Calibration Due Date	6-9-84 9-2.83
Test Conducted By	THE South 1.
Quality Assurance Representative	

THE CALLE	(112)	INDICA	TED VALUE	(PCI)	
VALUE	INCREASING		DECREASING		
5	-6.	6.	-6.	5.5	
10	-10.5	11.	-11.	11.	
15	-17.	16.	-16.5	16.5	
20	-22.	21	-22.	21.5	
25.	-27.5	27.	+27.	27	
30.	- 32.5	32	-32.5	32,	
		•			
		1			
	n soletik desi				
				1.	
Gauge Serial Nur	nber	Bw- 30	0- 0- 30-	267	
Date Compared		6.2	6.2389		
Commarison Due Date		6.23	6-23-84		

Gauge Serial Number	BW-30-0-30-267		
Date Compared	6.2383		
Comparison Due Date	6-23-84		
Destination	FRMLE B		
Test Gauge Serial Number	4343 (HS) # 16n - 80767	(BS,) BW- 100-037	
Test Gauge Calibration Due Date	6-9-84	9-2-83	
Test Conducted By	NB tacks f		
Quality Assurance Representative		0	

TEST GAUGE	INDICATED VALUE			
VALUE	(1.3) INC	REASING (P.S.I.)	(49) DECREASING (PS	
5	- 5.	5	- 5	15
10	- 11.	10	- 11	105
15	- 15.5	15.5	- 15	10,5
20	- 21.	20.	-21	13.3
25	- 26.	25.5	1 - 2/2	24
30	- 31,	31,	- 21	01
			1 311	1 31.
			1	1
		-		
and and an excitation of the second state of the			1. S. 1.	

Gauge Serial Number	BW - 30-0-20 - 212		
Date Compared	10-23-88		
Comparison Due Date	6-22-94		
Destination	FRANK, B		
Test Gauge Serial Number	0/32 (H3) (H3) HIGA - 80769		
Test Gauge Calibration Due Date	6-9-84		
Test Conducted By	Id. B Ficher		
Quality Assurance Representative			

