

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)0 1 M A P P S 1 2 0 0 - 1 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CONT

0 1 REPORT SOURCE L 6 0 5 0 - 0 2 9 3 7 1 1 2 9 8 3 8 1 2 2 8 8 3 9
7 8 DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During steady state operation on 11/29/83, an alarm was observed indicating low
0 3 nitrogen pressure in CRD 10-11 Accumulator. After recharging, the alarm was
0 4 again observed. The other rods in the nine-rod square array were verified in
0 5 accordance with T. S. 3.3.D and the Accumulator for CRD 10-11 was declared in-
0 6 operable. This event caused no threat to the public health and safety.

0 7
0 8

0 9 SYSTEM CODE R B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE A C C U M U 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
17 LER/RO REPORT NUMBER 8 3 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 G 0 8 0
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event was a leaking CRD Accumulator gas charging valve seat.
1 1 The #111 valve cartridge was replaced and the Accumulator was successfully
1 2 tested and declared operable on 11/30/83. A previous occurrence was identified
1 3 in LER 82-044/03L-0.
1 4

1 5 FACILITY STATUS Z 28 0 7 7 29 N/A METHOD OF DISCOVERY A 31 Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 Z 38 DESCRIPTION 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
2 0 PUBLICITY ISSUED DESCRIPTION 45 N/A NRC USE ONLY
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER W. J. McCann

PHONE (617) 746-7900

8401160175 831228
PDR ADOCK 05000293
S PDR

BOSTON EDISON COMPANY
800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

WILLIAM D. HARRINGTON
SENIOR VICE PRESIDENT
NUCLEAR

December 28, 1983

BECO. Ltr. #83-303

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Docket Number 50-293
License DPR-35

Dear Sir:

The attached Licensee Event Report, LER 83-060/03L-0 "CRD Accumulator", is hereby submitted in accordance with the requirements of Pilgrim Nuclear Power Station Technical Specification 6.9.B.2.b.

If there are any questions on this subject, please do not hesitate to contact us.

Respectfully submitted,


William D. Harrington

WDH/mg

Enclosure: LER 83-060/03L-0

cc: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Standard BECO. LER distribution

IE22
11