

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D I C I C I 1 0101-101010101-1010 3 4111111 4 1 5

CON'T 01 L 015101010131115 7 1121191813 5 0110131814 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
012 ON 12-19-83, WHILE INVESTIGATING AN 11-25-83 EVENT WHERE THE SAMPLE PUMP FOR THE UNIT
013 VENT EFFLUENT MONITOR (VRS-1500) HAD BEEN FOUND INOPERABLE, IT WAS DISCOVERED THAT THE
014 ACTION REQUIREMENT OF TECHNICAL SPECIFICATION 3.3.3.10 TABLE 3.3-13 ITEMS 3.b AND 3.c
015 HAD NOT BEEN FULFILLED. THE CONTINUOUS CHARCOAL AND PARTICULATE SAMPLES HAD NOT BEEN
016 OBTAINED. DURING THE TIME VRS-1500 WAS INOPERABLE (0248 HOURS ON 11-25-83 TO 1538
017 HOURS ON 11-26-83) NO RADIOACTIVE RELEASES OCCURRED FROM THE UNIT-1 VENT. THE PUBLIC
018 HEALTH AND SAFETY WERE NOT AFFECTED.

019 M I C 11 D 12 Z 13 Z 14 Z 15 Z 16
17 83 1 1211 011 T 0
18 G 13 Z 19 Z 20 Z 21 0101010 N 22 N 23 Z 24 Z 25 Z 26 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
110 THIS EVENT WAS THE RESULT OF INADEQUATE PROCEDURES. THE CONTINUOUS SAMPLING REQUIRE-
111 MENTS, REFERENCED BY ACTION ITEM NO. 32, WERE NOT RECOGNIZED AND INCORPORATED IN APPROVED
112 PROCEDURES. TO PREVENT RECURRENCE, AN AUXILIARY SAMPLE APPARATUS IS NOW AVAILABLE
113 ALLOWING CONTINUOUS PARTICULATE AND CHARCOAL SAMPLING SHOULD THE NORMAL SAMPLE PUMP
114 FAIL FOR VRS-1500. PROCEDURES WERE MODIFIED TO UTILIZE AUXILIARY SAMPLING EQUIPMENT.

115 E 28 01718 23 NA B 31 TECHNICIAN OBSERVATION 32
116 Z 33 Z 34 NA NA 35 NA 36
117 01010 37 Z 38 NA 01010 40 NA 41
118 Z 42 NA 43 NA 44 NA 45 NA 46 NA 47 NA 48 NA 49 NA 50

8401100340 840103
PDR ADDCK 05000315
S PDR

NRC USE ONLY

NAME OF PREPARED J. L. RISCHLING

(616) 465-5901



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

January 3, 1984

Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137


Operating License DPR-58
Docket No. 50-315

Dear Mr. Keppler:

Pursuant to the requirements of the Appendix A Technical Specifications,
the following report/s are submitted:

RO 83-121/01T-0

Sincerely,


W.G. Smith, Jr.
Plant Manager

/clm

cc: J.E. Dolan
M.P. Alexich
R.F. Kroeger
H. Brugger
E. Swanson/N. DuBry RO:III
R.C. Callen MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee
INPO
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE (30 copies)
Dir., MIPC (3 copies)

JAN 5 1984

FE22
11