

**ORIGINAL**

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

---

---

In the matter of:

MEETING BETWEEN STAFF & C. STOKES  
Government Accountability Project

Docket No.

---

---

Location: Bethesda, Maryland

Pages: 1 - 121

Date: Tuesday, April 10, 1984

**TAYLOR ASSOCIATES**

Court Reporters  
925 I Street, N.W. Suite 1006  
Washington, D.C. 20006  
(202) 293-1998

8404180169 840412  
PDR ADOCK 05000275  
T PDR

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION

3 MEETING BETWEEN STAFF AND C. STOKES  
4 (GOVERNMENT ACCOUNTABILITY PROJECT)

5  
6 Public Meeting

7  
8 7735 Old Georgetown Road  
9 Room 6507  
Bethesda, Maryland

10 Tuesday, April 10, 1984

11  
12 The meeting was convened, pursuant to notice,  
13 at 1:20 p.m.

14  
15 NRC STAFF PRESENT:

16 J. KNIGHT

17 H. SCHIERLING

18 R. HEISHMANN

19 B. BOSNAK

20 B. SAFFELL

21 K. MANOLY

22 I. YIN

23 M. HARTZMAN

24 E. SULLIVAN  
25

OTHERS PRESENT:

C. STOKES

J. CLEWETT

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

\* \* \*

11b1

P R O C E E D I N G S

1  
2 MR. SCHIERLING: My name is Hans Schierling.  
3 I'm the Licensing Project Manager with the NRC, for Diablo  
4 Canyon.

5 This is a meeting with Mr. Charles Stokes, who  
6 is represented by Mr. John Clewett of GAP, a meeting between  
7 the NRC and Mr. Stokes.

8 I think it is a follow up meeting on the last  
9 meeting, which we had last Wednesday, April 4th, in  
10 San Luis Obispo. And Mr. Stokes intends to raise certain  
11 concerns -- oh, the meeting was on April 3rd, last Tuesday.  
12 It was Tuesday night, in San Luis Obispo.

13 This meeting is open to the public. The parties  
14 to the Diablo Canyon proceeding have been informed of today's  
15 meeting, although on very short notice.

16 I myself discussed, very briefly, with Mr. Clewett  
17 the possibility of having this meeting open to the public  
18 or not and Mr. Clewett informed me that he personally, and  
19 on behalf of Mr. Stokes, had no objection to having the  
20 meeting open to the public.

21 The meeting is being transcribed and we will  
22 issue a transcript of this meeting to all the parties,  
23 through Board Notification.

24 If there are any handouts being provided at this  
25 meeting, either by the Staff or anyone else, these handouts

1 will be made part of the record, part of the transcript.

2 I will be sending around an attendance sheet for  
3 everyone to please sign in. And also, while we are having  
4 this meeting, everybody should identify himself, at least  
5 the first few times, for ease of the court reporter.

6 I do notice that except for Mr. Stokes and Mr.  
7 Clewett, members of the Staff, we also have -- Chris, would  
8 you please identify yourself for the record?

9 MR. NELSON: Chris Nelson, TERA Corporation.

10 MR. BURNS: Ed Burns, Westinghouse.

11 MR. SCHIERLING: With this introduction, Jim, I  
12 will turn it over to you.

13 MR. KNIGHT: I think it would be useful for the  
14 record to have each of the Staff members identify themselves.

15 MR. SULLIVAN: Ed Sullivan, Division of Engineering.

16 MR. HARTZMAN: Mark Hartzman, Mechanical Engineering  
17 Branch.

18 MR. YIN: Isa Yin, Region III.

19 MR. MANOLY: Kamal Manoly, Region I.

20 MR. SAFFELL: Bernie Saffell, Batelle Columbus  
21 Laboratories.

22 MR. BOSNAK: Bob Bosnak, Mechanical Engineering  
23 Branch.

24 MR. HEISCHMAN: Bob Heishman, IE.

25 MR. KNIGHT: Jim Knight, Division of Engineering.

1 MR. CHERNY: I'm Frank Cherny from Mechanical  
2 Engineering Branch.

3 MR. KNIGHT: Let me ask -- We have Mr. Stokes'  
4 affidavit. Hans, I understand -- I guess there are some  
5 copies available and you're having others made?

6 MR. SCHIERLING: Yes, more copies of the transcript  
7 are right now being made. I think some of them have already  
8 been handed out.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1  
2 MR. KNIGHT: And in a quick runthrough, a very  
3 quick runthrough, my impression is that a lot of these  
4 -- a lot of the items represented in the affidavit are items  
5 that I personally am not familiar with before. Are they  
6 items that have been brought up to members of the Staff,  
7 either in the Region or here before?

8 MR. STOKES: Many of the statements in this  
9 statement of mine, Mr. Knight, are a follow up of previous  
10 comments and replies by PG&E and allegations, which have  
11 been raised in the past by either myself or other parties  
12 interested in the safety concerns at Diablo Canyon.

13 I will not guarantee that every one is a  
14 completely new turn on the past events of that allegation,  
15 but primarily I think they are all -- they all have been  
16 responded to in the past. None, I don't think, are absolutely  
17 new. Some may be new views on an old problem, but I don't  
18 think they're new.

19 MR. KNIGHT: Okay.

20 MR. SCHIERLING: Maybe John Clewett would like  
21 to make some remarks before we get into detailed technical  
22 discussions? John, I'm sorry for overlooking that.

23 MR. CLEWETT: Yes, thank you.

24 I want, first of all, to thank you all for  
25 agreeing to meet with us. I know that Mr. Stokes has, in

11b4

1 particular, been eager to meet again with Mr. Yin, who was  
2 originally assigned to follow up on a number of Mr. Stokes  
3 allegations. And in particular, for the two of them to have  
4 a chance to discuss these issues.

5 I know that at the meeting, before the ACRS, Mr.  
6 Yin was not given a chance to question Mr. Stokes, and he may  
7 have some questions for Mr. Stokes now. Also, I think Mr.  
8 Stokes may have some questions for Mr. Yin about his  
9 specifics and what the Staff plans are for following up on  
10 the 60 percent of Mr. Yin's concerns that I understand  
11 are -- that some compromise has been reached on, as well  
12 as having a chance to review some specific hardware problems,  
13 such as the ones mentioned in this statement that we have  
14 circulated.

15 So with that brief statement, I will turn the  
16 meeting over to the technical people here. I might make  
17 one suggestion. It might be, in terms of facilitating the  
18 focus of Mr. Stokes' presentation, for someone to address  
19 the question of what sort of follow up is being planned  
20 by the Staff on the issues that it does plan to follow up  
21 on. Because it may be that some duplication could be  
22 avoided that way, if we would be focusing on issues that  
23 you all are already planning on going into in great depth.

24 That is really all I have to say, at the moment.

25 MR. SCHIERLING: Jim, do you think it is appropriate



1 at this time, since everything is in a rather fluid stage,  
2 and I don't know to what degree all plans are firm or still  
3 being developed, to address issues as to what steps we plan  
4 to take? And in particular, in light of the Commission  
5 meeting that is probably scheduled for Friday?

6 MR. KNIGHT: In fact, one of the reasons that the  
7 group is assembled here is that we wish to get our own  
8 thinking in the development of programs to follow up the  
9 items that we had given ACRS, as the body of our program to  
10 be conducted during low power operation.

11 I think right now, outside of what they have  
12 already said at the ACRS meeting, there isn't too terribly  
13 much more that we could add. By late in the day Thursday,  
14 we would probably have our program a good deal more fleshed  
15 out, let's put it that way, than it is right now. But  
16 that's the schedule we're working on.

17 MR. CLEWETT: Okay. My understanding, from the  
18 ACRS meeting, was that there were some things that were  
19 definitely planned on. And I'm not sure that the  
20 transcript was that clear on them. Maybe you could just  
21 say if there are certain things that are certain issues  
22 that you are definite about. I don't know if you are or not.

23 MR. KNIGHT: We are definite about all of the  
24 items that we've listed. Unfortunately, I didn't bring my --  
25 I didn't anticipate that aspect of today's meeting.

11b6

1           But just reading now from a copy of the slides, we  
2 would require them to complete their review of the small  
3 bore computer calculations -- these are piping support  
4 calculations. These are the class of calculations that we  
5 perceived as having or determined as having an unacceptably  
6 high error rate as we reported there, or as has been  
7 reported to us, I should say.

8           The utility is in the process of conducting this  
9 review. We have directed them to make it a 100 percent  
10 review.

11           During an earlier part of the program, Mr. Manoly  
12 observed the process being employed to perform the review.  
13 And he may want to comment in a short time, on his overall  
14 impression of that process.

15           MR. MANOLY: Yes. I've reviewed the sample  
16 calculation packages, when I was on site in February. I  
17 was accompanied by Mr. Paul Vesta, from Brookhaven National  
18 Lab, and we looked at approximately 16 design calculation  
19 factors that employed the STRUDL analysis. And we pretty  
20 much liked the quality of the calculation, or the review  
21 process that they went through in these packages, and the  
22 checklist that they had for review.

23           They have a very comprehensive checklist and  
24 there aren't really any comments.

25           MR. STOKES: Concerning that checklist, there are

11b7

1 certain points I raised in those calculation packages.  
2 Were they on that checklist? Such as, how were they  
3 evaluating torsion? The loads calculation sheet, which  
4 is included as a part of the package, how many possible  
5 combinations were running from the possible probability  
6 combinations in the STRUDL, to just five -- the results?  
7 Was it typically a one case type approach with five different  
8 seismic possibilities?

9 MR. MANOLY: I think the number, to just pick one  
10 of those cases that you're talking about, I don't think there  
11 was a code criteria requirement, or any criteria, for how  
12 many of those cases you have to run. I believe that's  
13 a judgment of the engineer, to cover all possible -- well,  
14 whatever he perceives as the combination.

15 One person might pick two. One person might pick  
16 five. It all depends on --

17 MR. STOKES: That is strictly an assumption based  
18 on the ability of each person. There is no criteria  
19 dictating how many combinations.

20 MR. MANOLY: There is not, to my knowledge, and  
21 I don't think I have seen it anywhere.

22 MR. STOKES: Did you review any gang supports?

23 MR. MANOLY: You mean multiple supports?

24 MR. STOKES: Yes, multi-line supports.

25 MR. MANOLY: I'm not sure whether one of them was

1 multiple support, or not. I have copies of these packages.

2 MR. KNIGHT: Yes, I might add, at this point, that  
3 we took a look at this stage to see if we were satisfied  
4 that the process was being carried out by competent people  
5 and in a competent manner. We will be going back and looking  
6 at when we have a broader sample. We will be going back  
7 with another audit, probably a more structured audit, to  
8 look at that work.

9 The next item that we mentioned to ACRS was this  
10 matter of shimming, closely spaced rigid supports. And  
11 that's an issue that the group is considering now, as  
12 refers what criteria would be acceptable, or what methodology  
13 would be acceptable.

14 And over the next couple of days, we'll be forming  
15 a Staff position. We mentioned a program that would require  
16 that they establish a program for monitoring the thermal  
17 gaps. This would be a program that would be in place over  
18 the lifetime of the plant, to assure that the gaps are  
19 maintained.

20 We also cited the need for review of the snubber  
21 lockup motions, used to evaluate the snubber rigid restraint  
22 interactions. Right now, the utility has done an  
23 evaluation based on some average values. We will require them  
24 to justify -- either justify that use, or to use other,  
25 more appropriate values, and carry that evaluation out

1 to the point of determining whether or not those numbers  
2 are functional.

endl

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

y2pbl

1 We also recited the requirement to establish a  
2 so-called quick fix in the Diablo problem review program.  
3 The goal there will be to establish a review program that  
4 would look into questions of both the quick fix and the  
5 Diablo problem review system being used outside of the  
6 bounds that were established by the utility for their use.

7 MR. CLEWETT: Is that going to be a review  
8 program done by the NRC Staff or by the utility?

9 MR. KNIGHT: Primarily I would in general say  
10 that any one of these actions would be accomplished by the  
11 utility and reviewed by the Staff.

12 MR. SCHIERLING: Jim, let me interrupt for a  
13 moment. I think all of this is right now in the developmental  
14 stage. And we will brief the Commission on our plans on  
15 Friday.

16 I think it is number one, premature. And number  
17 two, inappropriate for us to discuss these matters right  
18 now with you, before we brief the Commissioner on these  
19 issues.

20 So I think what regards our plans in the future,  
21 I think the first ones to hear about those would be the  
22 Commission, and not either the licensee or any other party,  
23 or Mr. Stokes, or GAP. So I think we should steer away  
24 from what our plans are, but stick to the facts at hand.  
25 Because I think it would be inappropriate for the Commission

y2pb2

1 to find out about our plans through, for example, through  
2 this transcript.

3 MR. KNIGHT: Yes. Basically all we're doing  
4 here is articulating the same information that was basically  
5 developed before the ACRS. I think you're probably already  
6 aware of the last three, which was the Staff inspection of  
7 the main steam and main feedwater hot walkdown, the  
8 completion of our review of the technical allegation issues,  
9 and the completion of our regional inspection, which is  
10 referring largely to Mr. Yin's inspection.

11 MR. CLEWETT: Thank you, Mr. Knight.

12 MR. STOKES: I guess I have a few questions for  
13 Mr. Yin, basically to start with, if I can, concerning  
14 things that he may not have considered in his analysis of  
15 the problem to date.

16 And by that, primarily all his research has been  
17 into the design aspects of the plant. I mentioned vaguely  
18 the other day, comments concerning his knowledge to the  
19 field construction, QA, QC, pre-inspect, fair training.  
20 I asked him if he knew people were hired right off the  
21 street without any prior experience in QA or QC work. Placed  
22 in the site without any training, and asked to inspect and  
23 QA document structural hangers.

24 He told me roughly I think, and he can deny this  
25 or accept it, that he did not have any knowledge that people

y2pb3

1 were hired under those circumstances and placed in that  
2 kind of position.

3 I also mentioned in passing, under the quick fix  
4 program, it was alluded that the people in the program were  
5 fully aware and knowledgeable of M-9. I asked him if he  
6 was aware of the fact that people were hired right off the  
7 street, given a copy of ESD-223 without ever seeing M-9 and  
8 placed in the quick fix program.

9 He told me he was not aware of that either. I  
10 know both such statements to be absolute truth. Maybe not  
11 for the entire group in quick fix, but at least for several  
12 members of the group on Unit 1. Less for the group on Unit  
13 2. And that many of the people on Unit 2 were taken right  
14 out of the small bore group on-site.

15 But the Unit 1 team, in part, was people hired  
16 from San Francisco office that were brought in off the  
17 street. To my knowledge they didn't spend any appreciable  
18 time in the office, either doing calculations, reviewing  
19 calculations or having any knowledge of M-9 requirements.

20 Those people were sent directly to the field. And  
21 immediately began writing quick fixes. That is a complete  
22 contradiction to what they led you to believe in their  
23 discussion.

24 MR. KNIGHT: I might ask, their discussion? Can  
25 you give me specifics?



y2pb4

1 MR. STOKES: Both on Monday in San Francisco,  
2 and in the discussion which they had in front of the ACRS.  
3 Their comments have been very consistent. They've been so  
4 consistent, even on one point that in reading this statement  
5 -- I believe it was this one --

6 MR. CLEWETT: That's April 2nd.

7 MR. STOKES: Yes. Mr. Shipley. Now I don't know  
8 if this was an intentional thing on his part. But it was  
9 so consistent that I yellowed it in every time he made the  
10 statement. Every time he made the statement that hangers  
11 or supports were acceptable -- he didn't say they were  
12 acceptable. He said they can be proven to be acceptable.

13 I don't believe he made this statement one time  
14 in here that any work has been proven. He said, it can be  
15 demonstrated, or it can be proven.

16 That to me implies that they either haven't done  
17 the work. It is not finished, or the results are not valid.  
18 I don't know which. But if I had finished the work, and  
19 I knew for a fact there was no modifications in that work,  
20 I would have said the work is finished. There have been  
21 no modifications required. There will be none required.  
22 Not that it can be demonstrated.

23 He said that, I think, three times that I'm aware  
24 of in his testimony. It came up so many times that it  
25 really caught my attention.

y2pb5

1           The specific person that I know came down from  
2 San Francisco to write quick fixes without any prior M-9  
3 knowledge came down to work on the night crew as the only  
4 night person originally, and I was placed on the same team  
5 with that person. The person is really a very qualified  
6 person. But I don't feel that anyone is qualified to write  
7 quick fixes without any prior M-9 knowledge.

8           And not only was he brought down, but I know of  
9 at least two other gentlemen who had a minor amount of  
10 M-9 background who came down. They are --

11           MR. HARTZMAN: M-9 is the criteria for the design  
12 of small piping?

13           MR. STOKES: That's right.

14           MR. HARTZMAN: And this person who came down from  
15 San Francisco, was he experienced in the design of small  
16 piping?

17           MR. STOKES: On other jobs, as most of the people  
18 at the plant were.

19           MR. HARTZMAN: But he wasn't a Bechtel person,  
20 right?

21           MR. STOKES: Not Bechtel direct. He was a Bechtel  
22 contract person, just like most of the people at the site.  
23 He ultimately was discontinued\_at Bechtel because he felt  
24 like he had an "in" with one of the vice presidents, and  
25 that he wouldn't be forced to go casual.

y2pb6

1 I should point out something. I don't know if  
2 anyone here has ever been made aware of it. And it's a  
3 series of events that occurred at the plant site.

4 Starting from last November, or November of '82,  
5 when we went at that job, all the contracts from all PG&E  
6 and Bechtel agencies basically read that the job would last  
7 three months to two years. Under those contracts, it is  
8 not an accepted practice for any employer to terminate the  
9 contract and immediately hire the people, right around,  
10 turn-around. There's usually a three-month period which  
11 that person cannot be employed by an engineering firm.

12 In March of '83, before any contracts terminated  
13 by date legally, Bechtel forced all contract agencies and  
14 contract people to go casual. They simply walked in one  
15 day, handed out applications for the people to fill out  
16 for Bechtel employment. They turned those in, whether they  
17 liked it or not. They were notified that if they didn't  
18 accept the change, and roughly a 30 percent decrease in  
19 pay, they would be on the street, unemployed.

20 Some of the people took the unemployment street  
21 on their own. They quit. One such person quit and went  
22 across the United States to Susquehanna to a Bechtel. When  
23 he got there he was told he did not have a job. He had  
24 to return to Diablo Canyon for employment.

25 MR. HARTZMAN: What do you mean by casual?

y2pb7

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. STOKES: The industry is pretty well broken down between direct meaning and contract. Contract is completely temporary employment. They are not shown on the books by the employment company. They are not given vacation time off, sick leave or any other benefit under that kind of a deal.

MR. HARTZMAN: That's direct?

MR. STOKES: Those are shoppers. A direct gets all fringe benefits, vacation, sick leave, holiday leave, the entire scope. He is shown in the internal records as an employee of the company. And it's generally accepted that he will not be terminated unless he is super-flagrant in his work activities.

He can produce one hanger in 30 days to a shopper's 100 in 30 days and he still will not be terminated. That specific case happened at Diablo Canyon by the way.

MR. HARTZMAN: Is casual the same as shopper?

MR. STOKES: No. Casual came up in roughly 1982. Well, the first case I heard of it was at Quadrex. I was employed at Quadrex on Zimmer through Sargent & Lundy. The job ended. They wanted to maintain me on the payroll. I was a very good employee for them, based on what they told me and I was very productive. They valued my technical ability.

You can ask them if this is not true. I'm not

y2pb8

1 trying to stretch any points. In any case, they proposed  
2 that I take a four-week termination without pay, but I was  
3 still employed basically. They put me on leave. And what  
4 they submitted was to Bechtel to put me at Susquehanna under  
5 a deal through them that I would become a casual employee.

6 Now under that deal, they basically agreed to  
7 give me a salary commensurate with the job shoppers salary,  
8 but place me on the records as a permanent employee of  
9 Quadrex. But in doing so, they would not put me in the  
10 records for sick leave, vacation, benefit sharing or any  
11 of the other fringe benefit programs. It was strictly a  
12 way to bypass Bechtel's requirement that only company  
13 personnel, that's direct personnel be used by Quadrex at  
14 Susquehanna as a subcontracting agent.

15 It was a loophole to get around putting shoppers  
16 in for Quadrex people. Since then, I have seen the same  
17 example used. And it was even used at Diablo Canyon by  
18 Bechtel. They forced -- and you can ask the personnel.  
19 Bechtel forced all shopping personnel within their scope to  
20 go casual and take a 30 percent rate pay decrease.

21 In some cases, some of the gentlemen even took  
22 more than that rather than be unemployed. I should note that  
23 they all sent out resumes and they would have all left had  
24 not the market been controlled by Bechtel on the other  
25 job sites.

2pb9

- 1
- end 2. 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

One gentleman did try to leave. He ended up coming back because he couldn't work at the other site.

3pbl

1 Now PG&E didn't do this. There were two agencies  
2 at PG&E at this time. Actually, three. Code 3 was the  
3 one I was working for, owned by Ken Plant. He used to work  
4 for PG&E. He's got some very good inside connections,  
5 undoubtedly.

6 In any case, those three agencies were not forced  
7 to go casual. There was a little bit of discontent by the  
8 Bechtel people who had been forced to go casual, but it was  
9 not toward their fellow workers. It was towards Bechtel  
10 for forcing them to take the decrease in pay.

11 MR. SCHIERLING: You mentioned three agencies.  
12 I don't quite understand that.

13 MR. STOKES: There were two others beside Code  
14 3.

15 MR. SCHIERLING: Code 3? What is that?

16 MR. STOKES: Contractor. Agencies handle contractor  
17 people.

18 MR. HARTZMAN: Were you casual then?

19 MR. STOKES: No, I was a job shopper. I was that  
20 until I was terminated.

21 MR. HARTZMAN: The gentleman that was sent down  
22 from San Francisco was casual.

23 MR. STOKES: He came down as a contract person.  
24 He thought he had a connection and would not be forced under  
25 that switch-over by the Bechtel people to go casual. When

1 he was forced to go casual he quit. He now works for  
2 Pullman. He came back one week later for Pullman. So he  
3 didn't take it lying down, either.

4 MR. HARTZMAN: But he had experience working with  
5 pipe design.

6 MR. STOKES: In other plants. Not at Diablo.

7 MR. HARTZMAN: Not even in San Francisco?

8 MR. STOKES: No, he had done none in San Francisco  
9 before he came to the field. And to my knowledge, he has  
10 never done any design, period, either at the site or in  
11 San Francisco.

12 He has worked in quick fix and he now works as  
13 a Pullman blue hat field engineer. Primarily because he  
14 knew a lot about quick fix.

15 MR. HARTZMAN: But he learned quick fix on the  
16 job, that's what you're saying.

17 MR. STOKES: Quick fix was supposed to be  
18 pre-known knowledge of M-9. He should not have been in  
19 quick fix making design changes without that knowledge in  
20 advance.

21 The fact that he was in the group without prior  
22 knowledge of M-9 completely -- I mean, he may have made --

23 MR. HARTZMAN: Is this written somewhere?

24 MR. STOKES: It was in PG&E's testimony that the  
25 people they filled the quick fix program with were



3pb3

1 pre-design engineers. Previous experienced personnel.

2 That's the reason I'm trying to bring this point  
3 out, that their statement is false. But I'm trying to give  
4 everyone here an atmosphere --

5 MR. SAFFELL: Hold on a minute. There's nothing  
6 to say that this previous experience had to be at Diablo  
7 Canyon. I think small piping design experience, regardless  
8 of what plant it's at, is valid experience.

9 MR. HARTZMAN: Let me say one thing. PG&E has  
10 stated that all engineers hired, at least in the small bore  
11 area, had at least three years experience. Now are you  
12 saying that is not true? That is an incorrect statement.

13 MR. STOKES: If it's in the design trailer itself,  
14 OPEC, it's true. If it's involving field applications from  
15 Pullman or Foley, it's false.

16 There are engineers in the field who do not have  
17 any three years. Many are right out of school, many aren't  
18 even out of school. But I'll get the quote, but I won't  
19 do it right at this minute. It's either in that one on the  
20 quick fix program. I think it was in that on Monday in  
21 San Francisco. It's toward the end, because they discussed  
22 quick fix at the last point.

23 And they specifically state that they had prior  
24 M-9 experience.

25 MR. HARTZMAN: That means that they had prior --

3pb4

1 MR. STOKES: With Diablo Canyon.

2 MR. HARTZMAN: Experience with designing small  
3 bore piping at Diablo Canyon.

4 MR. STOKES: That's right. You will not find  
5 a job shopper, in answer to your question, you won't find  
6 a job shopper that hasn't got at least one to two years in  
7 design experience somewhere in the nuclear industry.

8 It's either at a company -- most of the cases  
9 that they generally have to have more than one year, unless  
10 it was work at Bechtel and they now have a job with Bechtel.

11 In other words, in my case I had five years  
12 experience when I started.

13 MR. SAFFELL: Do you that qualified you to start?

14 MR. STOKES: Let's put it this way. I may not  
15 have felt that it qualified me, but it undoubtedly did,  
16 because I had more job offers than I could take up immediately.  
17 Someone felt that I must have been qualified, okay?

18 MR. SAFFELL: I agree with that.

19 MR. STOKES: I undoubtedly would not feel I was  
20 qualified had I not done what I did, then or now.

21 MR. SAFFELL: That's reasonable.

22 MR. STOKES: Even when I was employed during my  
23 five-year pre-job shopping experience, I didn't typically  
24 take comments by my superiors as being gospel. I went to  
25 school, I was taught, I learned as much as I could and I

3pb5

1 continued to study. I maintain one of the largest technical  
2 libraries in the firm that I worked for during that period  
3 of time. Even surpassing the technical library that they  
4 had for the whole department.

5 The vice president of the floor, in charge of  
6 keeping technical publications frequently came by my desk  
7 and borrowed books. The reason I believe in books is not  
8 that I know everything up front, but I believe that if you  
9 know how to find stuff in books, you can fill out what you  
10 don't know.

11 I also don't believe that you should run around  
12 trying to remember every form and term and phrase that's  
13 in existence in engineering, but at least know how to apply  
14 every one. And know where to find it if you need it. And  
15 be willing to ask the question in the first place is  
16 probably the most predominant point I'd like to make.

17 Anyone who thinks he knows everything without  
18 asking a question is either a fool or he should be a fool.

19 In most of PG&E's replies, I've encountered  
20 numerous additional problems that no question has been asked  
21 by an NRC inspector. Because not only did I question his  
22 solution, but I called the company and asked them what  
23 their comments were concerning it.

24 For instance, one of the allegations in the past  
25 concerned the clamping attachments, which is on page 6.

3ph6

1 MR. YIN: Before we jump to the next subject, let  
2 me just say a few words. It is my position, disregarding  
3 whether the person is qualified or not, should not be  
4 handled the way the quick fix has been handled, because  
5 many of the large bore and small bore hangers involving  
6 major design changes.

7 So there is no way, even a qualified person could  
8 understand fully about the M-9 should handle the kind of  
9 change that we observe. So it's really not a matter of the  
10 person is qualified or unqualified or in between.

11 The matter right now is to check the thousands  
12 and thousands of those TC's, so-called that have been  
13 defectively reviewed by the San Francisco design organization.  
14 So we have already passed the stage of arguing whether or  
15 not the people adequately do a job of implementing the  
16 program. That is not the point.

17 The point is, we want to ensure that the hot water  
18 that has been changed, has received correct evaluation. Okay?

19 MR. STOKES: I wasn't trying to argue with anyone  
20 here on any point. And if it seems that way, I just want  
21 to be heard.

22 MR. YIN: It is part of our program that is put  
23 in front of the ACRS that we are going to discuss with the  
24 licensee and the request for evaluation for all the design  
25 changes.

3pb7

1 MR. STOKES: I only touched on the qualifications  
2 of the people involved in that the statement that was made  
3 by PG&E, I felt, was a falsehood, and should be looked at  
4 by another member of -- I suppose there might be a member of  
5 OI in this group. I'm not sure if there was one mentioned.

6 MR. KNIGHT: Yes, the OI representative isn't  
7 here at the moment. They may be able to break someone loose,  
8 but they are looking forward to seeing the transcript.

9 MR. STOKES: Well, I'll stay away from those  
10 aspects.

11 MR. CLEWETT: To follow up on an earlier point,  
12 I think the reference you wanted was on page 128 of the  
13 April 2nd transcript.

14 MR. STOKES: Yes, page 128 and I quote. "Make  
15 a judgment based on their knowledge of M-9, which is the  
16 guidelines for design of Class I pipe supports and restraints  
17 for the project, the design criteria for pipe supports."

18 MR. HARTZMAN: I had asked where the requirements  
19 of M-9 has to be a prerequisite. And I thought this was  
20 what you were looking up.

21 MR. YIN: The M-9 requirement is stated in the  
22 TC procedure, requires that any deviation from the M-9  
23 requirement has got to be evaluated by a qualified engineer.

24 Now the procedure was intended for minor changes,  
25 such as deviation for certain dimensions, because of the

1 feeling, and so on. But based on my evaluation, in many  
2 cases that I observed, the system has been really abused,  
3 including major changes of structures and face plates and  
4 the whole bit.

5 MR. STOKES: Yes, it was abused primarily because,  
6 not only did they not know of M-9, but the three-page format  
7 which I showed, which was attached to the ACRS testimony  
8 outlining the program guidelines, I was the only member of  
9 that group, to my knowledge, including Unit 1 who had those  
10 three pages. And on those three pages, the only limiting  
11 factor was if it was prior work that had to have a DCN.

12 And if it was new work that had been green tagged,  
13 it was a DR item required. But beyond that, what I trying  
14 to stress, is there were no guidelines. And as Isa said,  
15 if you review those documents, you will see documented  
16 evidence that studs were welded to plates, anchor bolts were  
17 cut off.

18 I ow, because I forced some of that to happen.  
19 In many cases, they didn't want to document it with a DR.  
20 The whole program was that they didn't want DRs to come out  
21 with this kind of information. The only way I got that  
22 kind of information in on even a few of those documents was  
23 through that center page that said a DR had to be originated  
24 before I could fix it.

25 And even then, in many cases, they would not do

3pb9

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

it.

MR. MANOLY: Do we know which ones we're talking about here?

end 3.

MR. STOKES: Yes. Let's see.

(Pause.)

b1

1                   They're in the attachment to the ACRS testimony  
2 that I gave.

3                   MR. MANOLY: Which page?

4                   MR. YIN: Are we still on quick fix?

5                   MR. KNIGHT: I have a couple of questions that  
6 I'd like to pursue, too.

7                   MR. STOKES: I just want to indicate where those  
8 three pages are.

9                   (Pause.)

side 2 10                  MR. STOKES: It is not in here.

11                  MR. SCHIERLING: What are you looking for?

12                  MR. STOKES: There are three pages missing out  
13 of this document.

14                  MR. CLEWETT: Apparently, Exhibit 4 to Mr. Stokes'  
15 testimony to the ACRS is not included in the transcript.

16                  MR. STOKES: Exhibit 4 was the control sheet  
17 for the document. It went to my group lead, which was  
18 Jeff & Klomptenberg when I was in quick fix.

19                  But the program outline is right here. That  
20 and this flow chart.

21                  MR. YIN: Well, again, as far as the program that  
22 we recognized subsequent to that. It provided guidance,  
23 so-called. Again, it is not considered to be an acceptable  
24 format to carry out safety related work.

25                  The procedure should be the avenue to control the



1 work at the site. So I believe all the issues that you have  
2 raised have been really looked at, and perhaps even more.  
3 So we are understanding the problem. We are aware of the  
4 problem. We understand the problem. And we are taking  
5 adequate measures to ensure that everything affected will  
6 be evaluated adequately.

7 So I guess we really couldn't add more to the  
8 issues.

9 MR. KNIGHT: There are just a couple things that  
10 I wanted to follow up on. And just to clarify in my own  
11 mind. Your reference to cut off bolts and welded studs  
12 and such. These were things that you discovered while you  
13 were in the process of performing quick fix work?

14 MR. STOKES: Well, let's say it was things that  
15 the field crews pointed out to me while I was doing that  
16 work.

17 MR. KNIGHT: Well, okay. You became aware of  
18 it. So, just to follow you further. These were situations  
19 that I presume, because of the timing that had gotten  
20 through the previous work that had been done on the IE  
21 bulletins.

22 MR. STOKES: Undoubtedly.

23 MR. KNIGHT: That's what I'm trying to get  
24 straight.

25 MR. STOKES: In regards to IE bulletins, in June

1 of '83 I and another gentleman called up the trailer on-site  
2 and requested all replies from the NRC and PG&E in reply to  
3 79-02, 79-14 and any other guideline bulletin or whatever.

4 The last letter of those letters from the NRC  
5 at that time, stated PG&E had never fully complied with those  
6 bulletins as of that date. Now whether or not they had done  
7 that since the review, or before, I think they were using the  
8 review to do that in part.

9 I find it very difficult to believe they ever  
10 did a 79-14 review at all, before we did the mirror image  
11 review, because the calculations for the hangers, base plates  
12 and everything else were almost nonexistent before we did  
13 that review, and documented what we did.

14 I asked for an old calculation to see if there  
15 was any possibility that I could use any of it in my review,  
16 such as a model.

17 MR. YIN: Wait a minute. I think we've got the  
18 issue all mixed up. He is asking whether or not you have  
19 observed any cut bolts or any hiding of the facts, and  
20 you are talking about 79-14, which has nothing to do with  
21 the bolts.

22 MR. STOKES: Well, he asked me --

23 MR. KNIGHT: The presumption is they would have  
24 been caught.

25 MR. YIN: 79-14 had nothing to do with catching

1 those effects. Probably 79-02. Let's stay on 79-02.

2 MR. STOKES: Well, I was just listing those in  
3 regard to his question. The letter stated they had never  
4 met the full requirements.

5 MR. YIN: Well, even with 79-02 there's no way  
6 to identify that, because it's only asking the licensee to  
7 talk or approve certain bolts, to develop certain confidence  
8 levels. I believe it's 99 percent confidence level, with  
9 less than 5 percent failure.

10 So it's not required to redo 100 percent caulking  
11 or whatever. Now, it's important if you have seen actual  
12 conditions.

13 MR. STOKES: I have.

14 MR. YIN: In certain areas that you pointed out  
15 to us. Then we can go back and take a look. Otherwise,  
16 when we talk about 79-02 and trying to cover whether or not  
17 there were cut bolts and all is irrelevant, because it cannot  
18 be done. The 79-02 is just not the measure.

19 MR. STOKES: I'm just pointing out to him, in  
20 his answer that we found these things, in light of the  
21 fact that both the 79-02 and 79-14 reverification program,  
22 supposedly had pre-taken place.

23 In other words, supposedly we went in in '81 with  
24 those programs behind us. We should have had, I feel, a  
25 much higher level of confidence in what was in the field

1 than what we found.

2 MR. YIN: Yes. But there are two different issues  
3 here. Let's not even talk about 79-14 and 79-02. Let's  
4 just go on the fact that there were some defects that were  
5 written in the plant, and we want to know about it, okay?

6 If you can point out to us the area, the system,  
7 the location we certainly will send people to go out and  
8 take a look.

9 MR. CLEWETT: If I can jump in for a second. I  
10 think this may also illuminate the benefit of another  
11 possibility that I think has been raised by a number of  
12 the individual workers at the plant, who have been meeting  
13 over the past week or so with Region V.

14 I think there are now seven people who have  
15 volunteered to take the NRC out to the plant and actually  
16 point out specific hardware problems. Seven workers, I  
17 think all of them -- well, I'm not sure how many are still  
18 at the plant.

19 MR. STOKES: Three Foley people just recently  
20 came forward.

21 MR. CLEWETT: And my point is that I think that  
22 what would be the best way to do this, I think, would be to  
23 organize some sort of a walkdown of the plant by some of  
24 these individuals. Because I think they could take you and  
25 say all right, let me show you. Here it is. Because there

1 are a number of types of hardware problems.

2 One that has been repeatedly brought up is vendor  
3 welds. And a number of people we've talked to have said  
4 that there's just an epidemic of vendor welds that are really  
5 shoddy. So I think it would be a device calculated to bring  
6 those to the knowledge of the NRC, to take these people on  
7 a plant walkdown.

8 MR. STOKES: I should throw in that the things  
9 I learned, if I could document them, they are documented  
10 in my PSTDCs, or the quick fix formats. Or in a DR or a  
11 DCN someplace.

12 They were written, if I had anything to do with  
13 them. In many cases, I wasn't the primary engineer doing  
14 the quick fix, so I didn't get them documented. But I should  
15 note, those things existed, were corrected if they were  
16 caught.

17 The thing is, many of the plates never came off  
18 the floor. I think that's the biggest point I want to stress.  
19 We only found what we had to take off the floor. And that  
20 was a very minute number of all the hangers in that plant.  
21 And there are 1500 that have never even been looked at, to  
22 my knowledge, at all.

23 MR. MANOLY: How do you propose to do that?

24 MR. STOKES: I'm only pointing out a problem.

25 MR. MANOLY: I'm just asking.

1 MR. STOKES: You're the official. Between you  
2 and PG&E you can come up with a reasonable way of doing it  
3 to ensure that what they've got is right.

4 I know the problems are there. The workers  
5 know they're there. If you'll come out to the site, we'll  
6 put up notices to the workers that everybody who has seen  
7 a bolt welded to the back of a plate, or one cut off to  
8 meet everybody up at the Madonna Inn on a Sunday afternoon.

9 If 2- or 3- or 4,000 people show up, each on  
10 a different hanger, what are you going to say? So they've  
11 caught half of what is in the plant. I'm just telling you  
12 that there's a problem there. I've seen it on more than  
13 one hanger, a lot more. And other people saw them because  
14 they were working on the hangers.

15 You've just got -- you know, how do you get them  
16 to come forward. I'm saying you've got to get them en masse,  
17 where they cannot be fired for doing it. Or either have them  
18 do it, a tour in the plant where nobody is going to say,  
19 oh, John Jones went through this day, and he's going to be  
20 getting on the shit list next week.

21 I'm telling you, those people are still scared.  
22 I don't care how much --

23 MR. MANOLY: I understand. I'm just asking --

24 MR. STOKES: And I'm trying to help you just as  
25 much as I am them. I'm trying to give you the information

1 that they know.

2 Many of the people talk to me. I came public.  
3 I knew if anything came out of this I had to get public  
4 because nobody is going to listen to an anonymous person.  
5 But because I'm public, there are people calling me up saying,  
6 I won't give you my name, I can't, I would only get fired.

7 And I'll tell them, I don't want you fired.  
8 Just tell me what you know, and I'll be your mouth.

9 MR. MANOLY: May you should get more specific  
10 when they talk about it.

11 MR. SCHIERLING: Could we take a break for just  
12 a moment?

13 MR. STOKES: I just want to point out something.  
14 Really, I'm not getting upset. This information in this  
15 pack is under my initials. It was given to me by a QA  
16 inspector who has worked in the plant for 10 years. Many  
17 of th things in this statement I should note are directly  
18 written about this gentleman's papers right here.

19 For instance, I make the statement in here that  
20 I will give these documents to Mr. Yin because the guy's  
21 name is written all over them. He was a QC inspector. If  
22 this document gets to PG&E I'm sure he's going to be up  
23 the wall.

24 Now specifically, the first question, the 325  
25 bolts, the reply to that, this gentleman heard what I had

1 questioned about the bolts and some other gentlemen, and  
2 he supplied me these copies of two documents which show that  
3 some kind of bolt -- there's no number on it, was welded  
4 holding a Class I support.

5 Now, he was the QA inspector. And he gave me the  
6 two documents and I swore I would not give them to anyone  
7 unless they agreed that they would be anonymous, because I  
8 don't want him fired. I mean, he's providing the information.  
9 Any one in this group who will agree to keep those copies  
10 to himself and not give them to PG&E, I'll show them to them.

11 They show that the bolts -- there is no call-out  
12 on top -- have been welded. They show that there was no  
13 weld symbol as to how the joint was prepared. And there's  
14 a comment written by this QA inspector that they could not  
15 be visually inspected by him. That they had been bought  
16 off.

17 MR. YIN: Mr. Stokes, can I interrupt for a  
18 minute?

19 MR. STOKES: Sure, Isa.  
20  
21  
22  
23  
24  
25

end 4.



sy5joy1

1 MR. YIN: The group here is primarily concerned  
2 about design control and technical issues. I don't think  
3 anybody in this group here has been assigned the responsi-  
4 bility for any installation of QC inspection work. At  
5 least I personally have not been involved in any of those  
6 areas.

7 MR. KNIGHT: No, that is a fair characterization.  
8 So it is really important that we best utilize our time to  
9 kind of sort out the areas in design control and design and  
10 technical adequacy, and then maybe perhaps in a second part,  
11 maybe we will have GAP and Region 5 people or whoever  
12 involved in those activities to hear it. It is much better  
13 for them to hear it firsthand than secondhand from us.

14 MR. STOKES: Well, when I came into this meeting,  
15 it seems that I felt all of the decisions as far as your  
16 plans have already been pretty much formalized, but I didn't  
17 know how far the scope of your review has gone and all of  
18 your decisions to do what you have already decided to do when.  
19 Okay? So I came in here to show you technical points of  
20 material elements of hanger problems, material elements of  
21 defective welds, material elements that affect hardware.

22 Now you are telling me that you don't want to hear  
23 hardware.

24 MR. YIN: Right. Not that we don't want to hear  
25 it for NRC. It is the group. You know, it is much better, if

1 possible, that we separate them. Hey, we have design issues  
2 and we have installation and inspection issues, and group  
3 them into two areas and we can handle that in two  
4 separate ways.

5 MR. KNIGHT: If I may, that is one of the reasons  
6 I was asking earlier whether or not these were all new  
7 issues or had you, in fact, already discussed them with the  
8 people in Region 5?

9 MR. STOKES: I haven't discussed them with  
10 Region 5 or anybody else until I raised them myself, following  
11 reading of the reply by PG&E and getting additional informa-  
12 tion to back up the point. I am perfectly willing, though,  
13 to stay with strictly QA things, Isa. I just want everybody  
14 here to know that I have information that goes way beyond  
15 where you are at.

16 I raised the questions that you are now looking at  
17 or support in January, or December, November. I have moved  
18 past that. It has been months in the works since then and  
19 I have a lot of things that I didn't have then.

20 MR. YIN: Well, the issues that you raised and  
21 the additional issues that I personally raised really made  
22 public -- and it is nothing that we are holding back. And  
23 it has been really looked at--by management, by peer review,  
24 whatever. And it has been really taken into consideration  
25 how to improve the overall program and how to initiate  
corrective action.

Sjoy3

1           So believe me, we have taken a lot of actions, as  
2 you know, on your allegations and concerns. So you can be  
3 comforted about that.

4           MR. STOKES: Well, in reading the transcript, I  
5 will say one thing. For the most part, I am very satisfied  
6 with the seven issues as they were listed that the entire  
7 Staff has decided to look at, okay? I realize appreciate  
8 this list. It says a whole hell of a lot, really, to me.  
9 But the follow-up on this still has a lot that I would like,  
10 that, you know, I am interested in.

11           How you do this is very important to me, and if  
12 you decided that these are important from primarily my  
13 raising it in the first place, maybe, and Isa's follow-up,  
14 then I feel like I have an interest in seeing how it was  
15 ultimately determined. Some of these things I am not even  
16 familiar with. I was aware that there should be some kind of  
17 sequencing event between close hangers. I didn't call it  
18 hot shimming. I just knew that it should be applied.

19           I also proposed a similar proposal to a permanent  
20 life monitoring of thermal gaps if they want to use them.  
21 I guess the open areas that I have are concerning the fact  
22 that you are looking only at the past 400 computer runs  
23 and how they are looked at, and then the fact that there has  
24 been a statement made that roughly 63 percent of the hangers  
25 they looked at had some kind of change to them; but why have

Sjoy4

1 they not looked at the other 1500 in the system?

2 MR. YIN: Well, let me say, between the seven points  
3 or eight points that we are talking about, it is the NRC's  
4 prerogative to control the Licensee's program upgrades, the  
5 corrective action that is needed, and also reinspection  
6 required. Certainly we operate under the public scrutiny.  
7 You are welcome to look at what we have done and we will  
8 address any particular concerns, but you must understand that  
9 we do not require, by local body government or any public  
10 individuals' concerns to carry out our work.

11 So again, I can assure you that any program that  
12 is carried out is going to be sufficient and is going to be  
13 adequate as well as effective; otherwise, I can tell you  
14 right here, I am the one who will never recommend a full  
15 power operation license, and I will put that in writing. So  
16 that is the way it is going to be.

17 MR. STOKES: I am glad to hear that, Isa, because  
18 after the other day, I was more or less in doubt as to that  
19 point.

20 MR. KNIGHT: I think it is probably useful at this  
21 point to take a short break. Let's keep it short.

22  
23 MR. SCHIERLING: Before we take the break, anyone  
24 who is not NRC employed and you have to leave the office,  
25 let me know because we have to let you back in again, and

Sjoy5

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

don't wander around the offices here, okay?

[Recess]

6pb1

1 MR. KNIGHT: Back on the record. During the  
2 break we've been discussing ways in which we can structure  
3 the remainder of the meeting to make the most optimum use  
4 of this particular group's time. And to establish as sound  
5 as record as we can.

6 In particular, we've discussed, that is Mr. Stokes,  
7 Mr. Clewett, and myself have discussed searching out those  
8 areas where Mr. Stokes is free or feels free to specifically  
9 indicate an item in the plant or a portion of the plant where  
10 there are problems that he believes should be looked at.  
11 To characterize that problem as best he can, so that we can  
12 use that as a shopping list, if you will, to continue with  
13 our review of Diablo Canyon.

14 And to the extent that any of the members of the  
15 group have specific questions then, either related to some  
16 of Mr. Stokes' past information or to anything that has  
17 come up today, I'd like to take them one at a time around  
18 the table and see if we have any particular questions.

19 Mr. Stokes, can you -- can you give use some  
20 particulars that we could work with?

21 MR. STOKES: I believe this is an area that has  
22 been looked into. I'm not sure. I know you have looked  
23 into U-bolts. Have you looked into how the loads are  
24 transferred to the piping? The bearing stress section of  
25 ASME B31.1 and 31.7. Has any calculations been done by

6pb2

1 PG&E for the interface requirements per the codes?

2 Not just for U-bolts, for any of the attaching  
3 hardware. For the anchors. Supposedly on every plant I  
4 have ever worked we had another group beyond the hangers  
5 who were responsible for those attachments, integral  
6 attachment. Not only integral attachments, but any  
7 attachment, clamps. It is true for lugs, it's true for  
8 anchors. It's also equally true for clamps. It's true for  
9 any method of restraining a pipe.

10 The original design is deficient if no one has  
11 ever looked at how the loads are transferred to the pipe  
12 from the supporting member.

13 MR. MANOLY: Let me ask you a question. When  
14 you talk about non-integral attachments. If you are using  
15 a U-bolt that's qualified for a certain load on a certain  
16 size pipe, if one guide does it -- if it meets in one case,  
17 why doesn't it meet it for other supports?

18 MR. STOKES: But has it been done for one case?  
19 I'll make the statement that in conversations with ITT  
20 Grinnell personnel, they did not make the statement that they  
21 have ever qualified a U-bolt.

22 MR. BOSNAK: They don't do that. It is incumbent  
23 upon the piping designer to do that. And that's the kind  
24 of question that I asked at the Monday meeting in San  
25 Francisco. I asked them about the group that has overall

6pb3

1 responsibility. And that's one of the things that the  
2 piping people have to do.

3 Now whether they did it or not --

4 MR. STOKES: Well, typically I agree with you.  
5 It's the piping people. Every plant I've ever worked on,  
6 that's the way it was. The reason why I made this statement  
7 is in regard to his comment in the Grinnell catalog it states  
8 that the load ratings have been established to the  
9 requirements of ASME NF sections.

10 I specifically recall Grinnell concerning that  
11 point on whether they did or did not, and would or would not.  
12 They told me that if it is included in their contract, they  
13 themselves will do that interface calculation as an extra.  
14 But typically they don't do it.

15 The lug ratings are only as to the component  
16 ability, not what it will do to the pipe.

17 MR. HARTZMAN: What do you mean by interface  
18 here?

19 MR. BOSNAK: The interface between the supports  
20 and the pipe. In other words, you have two groups and  
21 somebody then has to be responsible for putting the thing  
22 together.

23 MR. HARTZMAN: Well, if you take specifically  
24 a U-bolt, you're talking about the pipe. The U-bolt is  
25 attached, or goes around the pipe and is attached to the



6pb4

1 angle frame, or to a frame.

2 Which is the interface there?

3 MR. STOKES: The interface is the contact area  
4 between the U-bolt and the pipe. How it transfers the load  
5 to the pipe in a restraint condition. Or the pipe transfers  
6 the load to the U-bolt if it's acting on the U-bolt.

7 MR. HARTZMAN: You're talking about the very  
8 local deformation between U-bolt and pipe and U-bolt and  
9 beam?

10 MR. STOKES: Well, the specific sections --

11 MR. BOSNAK: There is a section in the code that  
12 requires you to take a look at the effective clamp or  
13 whatever on the pipe to make sure that you haven't exceeded --

14 MR. HARTZMAN: In other words, crimping the pipe?

15 MR. STOKES: Specifically bearing stresses on  
16 the pipe, on the U-bolt. Either one. They are both going  
17 to be similar under that contact zone.

18 MR. HARTZMAN: This is like preloading of the  
19 U-bolt?

20 MR. YIN: Well, there's a lot of things to that.

21 MR. STOKES: Well, there are other sections that  
22 come into this point other than the bearing stress. Things  
23 like vibration analysis.

24 MR. YIN: Stiff cram and soft cram.

25 MR. STOKES: Fracture because of the kind of

6pb5

1 attachment could be a problem. There are several sections  
2 in the code that go into these.

3 It is not just the bearing aspect of it only.  
4 But the bearing stress calculation is the most simple, first  
5 run calculation for seeing how an attachment transfers loads  
6 to the pipe, or vice versa. To see how it affects locally.

7 MR. HARTZMAN: We have a board over there.

8 MR. STOKES: Well, I've got the codes with me.  
9 And on top of the codes, I will draw a sketch.

10 Typically, like I said, typically any job I work  
11 on I am always told in the hanger group that there is a  
12 member of a stress group someplace who specifically is  
13 researching out this aspect of the job.

14 In some cases I am told, you know, nobody is  
15 doing it. It's due to an oversight. And that is something  
16 that I guess I'm trying to question.

17 MR. SULLIVAN: Have you ever worked on a job where  
18 they did it?

19 MR. STOKES: I have, yes.

20 MR. SULLIVAN. Did you ever find out whether or  
21 not --

22 MR. STOKES: Because I was allowed to do it myself.

23 MR. SULLIVAN: Were there ever any cases where  
24 the design had to be changed because the pipe was overstressed?

25 MR. STOKES: In the case of U-bolts, specifically.

6pb6

1 MR. SULLIVAN: Yes, that's what we're talking  
2 about.

3 MR. STOKES: Yes. At ITT. No, not ITT. Well,  
4 at ITT Grinnell 2, back in 1979, I think we raised the  
5 question because in their catalog they show predominantly  
6 saddle type swings. A lot of clamps.

7 If you read the code section in NF, it states  
8 that things like clevises, slings -- it doesn't mention  
9 U-bolts at all in the section under attachments to piping.

10 I specifically researched that in answering my  
11 rebuttal to PG&E's comments. It says component standards  
12 are typically cataloged and mass-produced. I went back to  
13 what they call -- they have a bunch of things shown here,  
14 component standards. They do show a U-bolt in NF.

15 MR. SCHIERLING: Charlie, what are you reading  
16 from right now, for the record?

17 MR. STOKES: ASME, subsection NF, component  
18 supports.

19 MR. SCHIERLING: It's a 1980 edition, Section 3.

20 MR. STOKES: Yes, Section 3. They have a very  
21 simplistic approach to this interface here. It's a little  
22 block diagram of maybe a piece of pipe and a little block  
23 diagram out of a piece of support. But they do include the  
24 jurisdictional interface requirements.

25 The specific section on bearings -- I went back

6pb7

1 and checked these by the way because I checked ASME B31.1  
2 and 31.7.

3 MR. KNIGHT: Why look in there? To follow up on  
4 a question that Ed Sullivan asked, is it your position, I  
5 guess one might say, that at Diablo Canyon they should have  
6 specifically considered load transfers?

7 MR. STOKES: Load transfer in every support.  
8 Someone should evaluate how that load was transferred to the  
9 pipe and the effects it has on the pipe.

10 MR. MANOLY: There are two cases. Integral  
11 and non-integral.

12 MR. STOKES: Both cases.

13 MR. MANOLY: So the integral, you say they don't  
14 do it?

15 MR. STOKES: I'm saying in the non-integral they  
16 don't. And I am not aware of any program for integral. I'm  
17 only aware that in integral there was a table that said, for  
18 a load up to so much you needed two lugs fully welded, and  
19 the size was dictated.

20 They didn't get full penetration welds in many  
21 cases, and that is documented in the DR.

22 MR. MANOLY: Maybe that's based on some parametric  
23 study. Do you know that? -

24 MR. STOKES: I have never seen --

25 MR. MANOLY: They might not be sure of the design

6pb8

1 but --

2 MR. STOKES: Well, it's a good point for you to  
3 ask because they won't even talk to me at all anymore. But  
4 under Section 3182.2, non-integral attachments, paragraph  
5 (a) non-integral attachments include clamps, slings, cradles,  
6 saddles, straps and clevises. Absolutely no comment of  
7 U-bolts. None.

8 Right under that it says, it mentions sheer  
9 lugs for slippage.

10 MR. MANOLY: The question Ted asked you was  
11 about what did you see -- how you saw it evaluated --

12  
13 MR. STOKES: On one job I didn't take management's  
14 statement that someone was evaluating it, and my project  
15 engineer of hangers agreed that I could do the calculation  
16 for U-bolts, and another gentleman in the group could  
17 evaluate my calculation by checking it. That gentleman  
18 works at Diablo Canyon by the way, and he is aware that  
19 U-bolts, due to the fact that they have no bearing area,  
20 so to speak, exceed the bearing allowables under any code,  
21 if there is any load applied to them.

22 The thing is, U-bolts should not -- I don't  
23 believe ITT ever felt that U-bolts should be used without  
24 shim material. They include various type shims, saddles.  
25 I even noted down to half-inch pipe. They've got a little

6pb9

1 saddle protection type thing. And that really caught me  
2 off guard because I didn't expect it. I've never seen it  
3 used on pipe below maybe four inches.

4 MR. KNIGHT: I am going to try to move us along,  
5 and I'm not trying to restrict in any way what you want to  
6 bring up. But for our purposes, today at least, the message  
7 I get is that, although it may be not only Diablo Canyon,  
8 it may be other places as well.

9 MR. STOKES: I don't have that knowledge. I've  
10 been told they did do it on other plants. But whether or  
11 not they did, I don't want to push. I'm just saying, that  
12 I don't believe it was done here. And I know I have done  
13 it in the past.

14 MR. KNIGHT: But for non-integral attachments,  
15 there was no adequate consideration for want of a better  
16 word, of load transfer.

17 MR. STOKES: Well, they didn't include the code  
18 sections that pertained to non-integral attachments.

19 MR. MANOLY: But you just said they don't say  
20 U-bolts.

21 MR. STOKES: Yes. But let me point out right  
22 here. Under NF 3226.1, bearing loads, the average bearing  
23 stress for resistance to crushing under the maximum load  
24 experienced as a result of design loads, test loads or any  
25 service loads.

6pb10

1           Now the reason I looked this up is because they  
2           were using a test program on the U-bolts. And I was very  
3           concerned as to whether or not they included this in the  
4           test load evaluation. But under test loads or any service  
5           loads except those for which level D limits are designated --  
6           which is ultimate failure, the plant shuts down -- shall be  
7           limited to SY at temperature, except when the distance to  
8           a free edge is larger than the distance over which the  
9           bearing load is applied. A stress of 1.5 SY at temperature  
10          is permitted.

11           Now I completely forgot about evaluating that  
12          distance statement, and just taken the stress at 1.5 SY.  
13          And not only U-bolts but some clamps don't have enough width  
14          for the loads that they transmit to the pipe.

15           If PG&E wants to sharpen their pencil --

16          MR. HARTZMAN: Are you basically saying that they  
17          should not use U-bolts at all? Do I understand that?

18          MR. STOKES: Not in seismic category systems. I  
19          don't believe that ITT Grinnell designed -- you have to take  
20          into account, ITT Grinnell is a fire protection sprinkler  
21          design company. And fire protection systems you use all  
22          the U-bolts you want.

23           But they do not comply with the code. And I'm  
24          not saying that they're not acceptable under some procedure.  
25          I'm just saying that they didn't evaluate the component,

6pb11

1 much less any other component to comply with the code.

2 MR. MANOLY: What was the section you just read?

3 MR. STOKES: 3226.1, NF, bearing loads. It is  
4 just in front 3226.1. It is on the back side of the flip  
5 section under design by load rating, 3226.0, which is where  
6 PG&E got their load rating criteria.

7 There are some other sections concerning vibrations  
8 and things like that that can affect the reduction in stress  
9 levels. I'm not even going to get in on those others. I  
10 just took the simplistic approach.

11 The reason, I guess, that I bring this up is I  
12 started out in structural engineering before I got to pipe  
13 supports. Primarily doing structural steel and concrete.  
14 That's where I really got my basis. And I've not only  
15 designed concrete slabs bigger than they needed to be,  
16 because of bearing. But I have designed base plates bigger  
17 than I thought they should have been because of bearing.

18 I have even looked at things like washers under  
19 a net that is high strength steel on the A-36 steel to see  
20 if I had enough bearing area to comply with the section.

21 You say, well, nobody does that. This guy's  
22 crazy. But I look at -- unless -- I want to avoid a code  
23 section when I'm told that a code applies. I will evaluate  
24 any part of a structure to the full requirements of the  
25 code.

end 6. 25



1 MR. KNIGHT: I think we have covered U-bolts  
2 enough to get the message across.

3 MR. MANOLY: One more question. Are these U-bolts  
4 pre-tensioned, because it makes a difference if they are  
5 pre-tensioned or not. I mean, is there a requirement for  
6 pre-tension of U-bolts?

7 MR. STOKES: Pre-tension? I'm familiar with  
8 pre-tension of concrete rebar members. But a U-bolt, they  
9 simply nut two nuts up loose. It's a loose fit.

10 MR. MANOLY: I'm just asking if there's pre-  
11 tension --

12 MR. STOKES: It includes however you calculate  
13 those stresses, interface stresses.

14 MR. MANOLY: It was a simple question. Yes or no.

15 MR. STOKES: Yes.

16 MR. MANOLY: This precribes pre-tension -- this  
17 prescribes pre-tension --

18 MR. STOKES: I'm saying somebody should have  
19 evaluated the effects from the pipe to get that load on  
20 the U-bolt.

21 MR. MANOLY: My question is, is there a requirement  
22 for pre-tensioning U-bolts.

23 MR. SULLIVAN: Let me ask the question another  
24 way. Did you design or did anyone design pre-tensioning  
25 into the U-bolts?

1 MR. STOKES: At Diablo Canyon, no.

2 MR. SULLIVAN: Okay. I think that's the answer.

3 MR. STOKES: No pre-tension.

4 MR. KNIGHT: Just for my own information, is there  
5 any restriction in pipe size for which U-bolts are used at  
6 Diablo at all?

7 MR. STOKES: None. There are none. There are some  
8 really big U-bolts that were bent out of a rod on some  
9 20-inch lines in the turbine building. Maybe even some  
10 bigger than that. I do know that they custom made them at  
11 the site. Like I said, I don't think they evaluated the  
12 codes as to how that interface --

13 MR. KNIGHT: Let's see, a 20-inch line in the  
14 turbine building, would that be a safety-related line?

15 MR. STOKES: I'm pretty sure there are some safety-  
16 related lines, even inside the containment. They've got  
17 U-bolt rod restraints on the main steam lines, I think,  
18 going up beside the --

19 MR. KNIGHT: Those are pipe whip restraints.

20 MR. STOKES: Some of them I think are actual  
21 restraints.

22 MR. KNIGHT: The ones I'm familiar with --

23 MR. STOKES: I know there are some whip restraints  
24 that are -- right. Now, that is different.

25 MR. YIN: Those stress bars -- they're provided,

1 they're in service to make sure there is no crimping on  
2 the pipe when you reach that restraint. That was not the  
3 worry or concern you have, though.

4 MR. STOKES: The what, now?

5 MR. YIN: We're talking about the pipe whip  
6 restraint where you have stretch bars. You are?

7 MR. STOKES: Well, if they're governed under this  
8 same code section. But the thing, whip restraints only  
9 come into play when you have a failure. That's the  
10 Class D --

11 MR. BOSNAK: Class D is not failure; it does not  
12 indicate a failure.

13 MR. YIN: No, the pipe whip restraint is not  
14 governed by the ASME code, you know.

15 MR. STOKES. No.

16 MR. BOSNAK: Pipe whip restraints are not part of  
17 the code; they are outside the scope of the code.

18 MR. STOKES: But they're usually designed --

19 MR. BOSNAK: They are designed to some criteria,  
20 but they are not --

21 MR. YIN: They are not governed by ASME code.

22 MR. STOKES: But to have one come into play  
23 typically it's after a rupture. In other words, there's  
24 already been a failure. You don't have to protect the line  
25 after a failure.

1 MR. BOSNAK: That line has failed.

2 MR. STOKES: You see what I'm saying? That's why  
3 I say I don't think it matters on whip restraints.

4 MR. BOSNAK: But you've got earlier that Level D  
5 indicates failure, and it doesn't.

6 MR. KNIGHT: I didn't hear that. I think what  
7 Charlies was saying was that the restraint comes into  
8 play only after failure.

9 MR. STOKES: That's what I was saying, but --

10 MR. BOSNAK: But we were talking, before we got  
11 into whip restraints, about Level D.

12 MR. STOKES: That's what I was saying on whip  
13 restraints, they do not come into effect unless there's  
14 been a break in the line.

15 MR. KNIGHT: I think we've treated that issue  
16 pretty well. Just looking at my own notes here, there's  
17 an area in the original affidavit that you passed out today,  
18 and you note here that there are two specific -- and this  
19 is going back to the question of welded bolts. You note  
20 that there are two specific cases in which you can provide  
21 support numbers. Are those the instances that you related  
22 earlier where you're concerned that the -- giving the  
23 support numbers would be a way of perhaps compromising  
24 someone's confidence?

25 MR. STOKES: Well, this is a Unit 1 support.

1 It's an angle frame connected to a wide flange piece of  
2 steel, 14-inch wide flange. The number is 2181-2. It is  
3 mainly a vertical restraint, and it does have bolts on it.  
4 It says stud; it doesn't say if they are studs, what grade  
5 steel. And there is no weld call-out.

6 It does show that they are inaccessible for visual  
7 inspection, on the drawing. It has been as-built reviewed  
8 and approved 12/30/83, Rev 4. It's got a PG&E deviation  
9 number 253 stamped on it. And there's another one --

10 (Pause.)

11 This one has four studs. They don't call out any  
12 grade or weld symbol. It's 2181.13 and it is Unit 1. It  
13 does state on here it's bore or code Class 1. And the  
14 other hanger also says it's Class 1, system 4, area F at  
15 115 elevation. Both are at 115 elevation, area F.

16 Those two -- and I can give you the numbers. There  
17 may be something else here that I can provide you.

18 There's a preliminary DR written against several --  
19 I should explain this statement. I don't know if I put it  
20 in here, because I didn't put all the things the guy told  
21 me in here.

22 There was a DR out against Unit 2. Quite a few  
23 stanchions were welded to the pipe, and the welds were  
24 supposed to be full penetration welds on the stanchions.  
25 They were anchors. And the Unit 2 DR had already been

1 written up. They were not qualified. They were not approved  
2 as being full pins, and they had been written up to be  
3 removed.

4 They were removed, but when they removed them and  
5 they ran the pipe down, they did not have a UT-examined  
6 pipe wall to justify whether they damaged the pipe. And  
7 according to the QA inspector, they were supposed to have  
8 it at the time they did the work.

9 It was done on Unit 2 seven months later. Now,  
10 someone at the plant saw the Unit 2 DR and originated a  
11 preliminary DR against Unit 1; after doing some investigation  
12 he found I think about seven similar stanchions on pipes  
13 in Unit 1.

14 I was trying to come up with a name on that  
15 preliminary DR.

16 MR. KNIGHT: These are all situations where  
17 there's been a restraint or a stanchion removed and the  
18 pipe ground before --

19 MR. STOKES: Yes.

20 MR. HEISCHMAN: Your concern is that they have  
21 encroached on the pipe wall? Is that correct?

22 MR. STOKES: Well, yes. They didn't follow the  
23 procedures. The procedures, according to the QA, was  
24 they should have UT'd the wall. They didn't UT it, and  
25 when they did UT it they had already rewelded the stanchion,

1 and the results are erroneous, following that test on  
2 Unit 2.

3 Unit 1, I don't think they've ever done any.  
4 I'm not even sure they've done any work on these stanchions  
5 on Unit 1 because it was a preliminary DR.

6 (Pause.)

7 The DR on the welded integral pipe attachments,  
8 there's 34.37 is Unit 1, and then there is a 34.66 in  
9 Unit 1, and the 35.38, Unit 2; and 34.65, Unit 2; and  
10 44.99, both units. And it says, this DR shows that some  
11 piping attachment welds have not been identified and fixed.  
12 I will take it as 44.99, the last one, concerning both  
13 units.

14 35.38 DR identifies 250 improperly installed  
15 pipe attachments. A large number of these are for large  
16 bore anchors, and he says, see DR. 35.37 and 34.66. He  
17 didn't have a copy of those.

18 MR. KNIGHT: I'm sorry, could you give me the  
19 subject of that again?

20 MR. STOKES: Roughly 250 improperly installed pipe  
21 attachments. A large number of these are large bore  
22 anchors. It's a DR that is out.

23 MR. KNIGHT: Let's see, should I construe -- if  
24 the DR has been written --

25 MR. STOKES: Well, there's one that's preliminary

1 written against Unit 1, and that one doesn't have a control  
2 number on it. It's just like my DR's were; until they come  
3 back with a number for it, it's basically in limbo.

4 I do have a copy I think of that.

5 MR. SAFFELL: What was the number of that one?

6 MR. STOKES: 35.38. He references several other  
7 DR's -- 35.37, 34.66 --

8 MR. KNIGHT: Should I construe from that that this  
9 is work in progress? That the DR has been written?

10 MR. STOKES: Well, it was written by someone who  
11 was not sure it is going to --

12 MR. KNIGHT: Or they perhaps got filed somewhere  
13 and not acted upon? Is that the basic concern?

14 MR. STOKES: Yes, exactly.

15 MR. CLEWETT: A number of people at the plant  
16 that we have talked to have said that almost always, the  
17 response to anything like this is "accept as is." Some of  
18 them have joked that it should be "accept, as usual."

19 MR. STOKES: There's a copy of the preliminary  
20 DR. It was written by a guy named Dougherty. I would try  
21 to keep his name quiet because --

22 MR. HARTZMAN: Well, it's on the record now.

23 MR. STOKES: I know that. Well, he didn't give it  
24 to me anyway, so. From that standpoint, he shouldn't get  
25 into too much heat. You can't say anything around here



1 without getting someone into trouble somehow. I've gotten  
2 friends in trouble just because I had copies of their  
3 calculations some way or another. At least we're still  
4 friends, for some ungodly reason, I don't know why, although  
5 I have gotten a few comments like --

6 MR. KNIGHT: Okay. Just looking at this one,  
7 the recommended disposition is "accept as is," based upon  
8 acceptable UT's being performed on the surrounding areas.

9 Should I construe that, in fact, that UT's have  
10 been performed? Well, somebody --

11 MR. CLEWETT: No. If I could jump in for a second.  
12 As I understand it, when a person writes a discrepancy  
13 report they give several possible dispositions, and the  
14 person who eventually dispositions it will circle the one  
15 that they want.

16 So it appears, from looking over your shoulder  
17 here, that number 1 and number 3 are inconsistent recommended  
18 dispositions. One is to accept as is, and number 3 is to  
19 issue process sheets to rework.

20 MR. KNIGHT: And number 2 is, PG&E to disposition.

21 MR. STOKES: Yes. Somebody else makes the decision.  
22 All I'm trying to point out is that the problem has been  
23 raised, it has been attempted to be raised in that someone  
24 wrote up a form. Now, whether it is followed through on and  
25 how PG&E -- you know, they will more than likely accept it

1 on an as-is basis because that's generally the way everybody  
2 tells us everything is done at the plant. It's just do an  
3 as-built of it, and accept it on an as-built basis.

4 MR. KNIGHT: Well, if that's carried out in an  
5 appropriate way, is there anything wrong with that?  
6 I mean, that mean seem a naive question.

7 MR. CLEWETT: It probably depends on --

8 MR. STOKES: -- how appropriate is it. I'm not  
9 going to make a conclusion. Personally, I wouldn't think  
10 that that's an acceptable engineering procedure to do that.  
11 But if it's fine with you gentlemen, --

12 MR. SULLIVAN: Can you give me a typical example  
13 of why a DR was written up?

14 MR. STOKES: Why? To get some kind of action taken  
15 on it, hopefully.

16 MR. SULLIVAN: I realize that. I'm looking for a  
17 typical example of what kind of problem you would write up  
18 in a DR.

19 MR. STOKES: It's a problem which you cannot  
20 correct by yourself. It's something you have to get  
21 management's directives on, like I wrote -- primarily, the  
22 one I wrote up was concerning all the welding problems  
23 from the symbolism controls, all the way out to the field,  
24 and the weld specs didn't interpret how the symbols would  
25 be applied. The prep angle was not what I was calling out

1 in the office.

2 In other words, it was a problem that we discussed  
3 between us and everyone accepted as a problem. But we  
4 were not in control enough, or high enough up in management  
5 to get an overall directive on it to solve it.

6 MR. SULLIVAN: But it sounds like you wrote up  
7 some what I would call generic DR's.

8 MR. STOKES: True, I did.

9 MR. SULLIVAN: But in this conversation that was  
10 going on before about "accept as usual" or "accept as is",  
11 they must have been specific DR's.

12 MR. STOKES: Yes.

13 MR. SULLIVAN: Can you give me an example or two  
14 of a specific DR?

15 MR. STOKES: This one was written against seven  
16 pipe supports, basically anchors.

17 MR. SULLIVAN: What was the problem?

18 MR. STOKES: They had reworked the stanchion  
19 welds and when they took off the old stanchions, they didn't  
20 do a UT exam under a process sheet inspection, and they  
21 rewelded the new stanchions and someone found out about it.

22 MR. SULLIVAN: Okay. Any other examples you can  
23 give us?

24 MR. STOKES: I don't happen to have a copy of some  
25 that another friend of mine wrote. But other type things --

1 well typically, a DR -- just for your information, a DCN  
2 was required at Diablo Canyon for in-work process. In  
3 other words, if it's being built right this minute and  
4 there's a problem encountered you can write a design change  
5 notice to get it changed.

6 But a DR was required if the work had previously  
7 been done and green-tagged by a QC/QA inspector as approved.  
8 Undoubtedly, in this particular case a DR was the viable  
9 mechanism by which he would bring up concerns which had in  
10 the past been already accepted by a QA inspector. And which  
11 were not correct.

12 It could have been on anchor bolts, it could be --  
13 for instance, we have this problem happening because the  
14 QA inspectors have not been told in the ESD that they  
15 specifically were to check the hole orientation as it existed  
16 in the concrete for the 10d diameters. What they had been  
17 told in their instructions was wait until you do the final  
18 check of the hanger and you measure the bolts where they  
19 stick out of the plate. That tells you where the holes for  
20 the plate are and where the bolts are, and you get all of  
21 it down there real quick.

22 Now the problem with that was in quick fix, by the  
23 time we got to quick fix we've got a hanger that's been  
24 green tagged, and the problem should have been caught day one  
25 when the holes were drilled in the concrete. And I enforced

1 the fact that a DR should be issued because it had already  
2 gone through the mill and was accepted.

3 They didn't want to do that; they wanted a DCN on  
4 it because it was in-work process. There's a question there  
5 as to which one applies. The DCN definitely applies, it  
6 was in work, and DR if has already been green tagged, maybe.

7 But there was a DR issued against a concrete pour  
8 in the containment because, for instance, I was doing the  
9 quick fixes for the intake which was all Unit 1 and Unit 2  
10 structure. The drawings came down from San Francisco to  
11 put in 10-inch -- actually, it was 12-inch Hiltite stud  
12 bolts and a 12-inch concrete wall. Undoubtedly, they hadn't  
13 reviewed the concrete drawings in San Francisco and they  
14 asked for a 10-inch embedment.

15 Now, what happened was they drilled the holes  
16 10 inches without going through the wall, but when they went  
17 to set the studs they typically hit one-inch studs with a  
18 five-pound sledgehammer to set them good. That's okay if  
19 the slab is four foot thick. In this case, it just went  
20 right out the back side of the wall.

21 Now, the problem was this wall happened to be one  
22 of the pump seal rooms down there. That has to be a water-  
23 tight room. So I got called, Foley got called, the lead  
24 engineer got called from the site mechanical engineer for  
25 all hangers that night. His name was Torstrum. Because I was

1 quick fix, I had the final say-so on how we fixed the  
2 problem. The concrete was very, very granular, very sandy  
3 looking. You could just rub it with your finger and flake  
4 it off. It didn't look like it had enough concrete mix in  
5 it, to satisfy me, consistent with the typical plant  
6 layout. I required a DR on that to get a fix on it.  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

8joy1

1           If they had reviewed the drawing in San Francisco,  
2 they would have put something besides 10-inch bolt in the wall  
3 if they had reviewed the installation procedures, anyway, for  
4 sure. Not only that, one time when they were drilling the holes  
5 for a plate, we hit a drain line. We had to patch the drain  
6 line. That required a DR. The drain line wasn't where it was  
7 supposed to be according to the drawings. It was too close  
8 to the surface of the concrete. The slab was 3 foot thick.  
9 It was supposed to be more in the middle. That is minor.

10           I felt I needed to document the fact that I didn't  
11 think the concrete was adequate. And another thing was that  
12 during the drilling of those bolts, not only did we not go  
13 through the wall, but we found a chunk of wood in it,  
14 actually two pieces of wood. I wanted the wood documented,  
15 so I had a DR written up on it.

16           MR. YIN: Let me interrupt a minute. Those  
17 specifics I think you mentioned a couple of times before.  
18 My concern is over the use of DCN, design change notices, and  
19 also deficiency reports, the control aspects of the two  
20 systems. Maybe you can address that. Maybe you know a lot  
21 better than I do what was the practice at Diablo Canyon site.

22           Now, the DR involves perhaps as-built, accept as is,  
23 modify or maybe rework, either change something or accept as  
24 is, right?

25           MR. STOKES: Uh-huh.

8joy2

1 MR. YIN: Now, the DCN is directly telling you to  
2 change it, or what? I am trying to assess the effect of the  
3 two systems.

4 MR. STOKES: Well, they can both be used basically  
5 to do identical things. The only difference was the time  
6 frame as far as what we were instructed. If the hanger had  
7 been green tagged from a previous inspection QA program,  
8 which almost every hanger in the plant was, we were told it  
9 would have to be a DR if it was reworked, other than under  
10 the review program. I suppose there was a DR written against  
11 all supports redone under the review program. I don't know.

12 MR. YIN. Okay. Now, I understand perhaps there  
13 was some mishandling of a prior or subsequent use of certain  
14 documents. I understand that. I am more concerned about  
15 the safety impact of such measures. Now, everything is built,  
16 installed. It sounds like we are beating a dead horse.

17 Now, you tell me. Is there any safety implications  
18 that maybe we should follow up? Otherwise, what is the need  
19 for following it?

20 MR. STOKES: The DCNs very definitely could in  
21 many cases, and I am sure they do, say "accept as is" the work  
22 that has been done no matter how incorrect it is.

23 MR. SULLIVAN: I think that's a point, though, that  
24 needs to be looked at. If it was accepted as is, was there  
25 a basis and is it documented? Does it even need to be



8joy3

1 documented?

2 MR. STOKES: It is documented in the DCN or DR.

3 MR. SULLIVAN: The reason, the justification.

4 MR. STOKES: That's probably not there. In many  
5 cases all you will see is that there is a problem, and there  
6 will be a statement that it is okay as it is or it needs to  
7 go back to the home office. You won't see -- if it's okay as  
8 is, you won't see any statement as to why. We didn't have to  
9 write down why we made our decisions.

10 MR. SULLIVAN: Was it written down somewhere else  
11 as part of the hanger package or as an attachment to a hanger  
12 package?

13 MR. STOKES: No.

14 MR. YIN: Let me address this a little bit.  
15 Basically, during the construction stage it is sometimes to  
16 the benefit of a licensee, at least cosmetically, to indicate  
17 that -- well, maybe there are not that many problems, so if  
18 you trend those problems, gave the public a more favorable  
19 impression, that really we're just asking for changes.  
20 We didn't have that many construction problems. That was  
21 frequently what we encountered. But as far as the actual  
22 correction of the problem and fixing the defects, there was  
23 no attempt, based on my experience, to try to shortchange  
24 the system. It was just to give the people -- you know --  
25 MR. STOKES: It was a camouflage in many respects.

8joy4

1 Writing a DCN was better than a DR.

2 MR. YIN: So at least in this particular case here,  
3 besides the point I just made, you don't see any safety  
4 impact on the system or operations or functional aspects.  
5 Can you maybe address it more specifically in that area?

6 MR. STOKES: Well, I have seen an awful lot of DRs  
7 that were accepted on an as is basis that I personally  
8 felt --

9 MR. YIN: Well, that was the management's decision  
10 to make. Unless you have any specifics to concur your  
11 belief that those sections were not correct and so on, then  
12 perhaps there is really no basis for us to pursue it.

13 [Pause]

14 MR. STOKES: Concerning that point, now this is  
15 from another gentleman. The PG&E letter on this one was  
16 17 -- that is the one I was keeping on steel bolts.

18 I do have reason to believe that some of the  
19 follow-ups on those documents were not handled by people  
20 qualified to handle them. For instance, the lead engineer  
21 for Pullman was not an engineer. The gentleman, I think --  
22 I have been informed by Pullman people that he is 26, he came  
23 up from a designer to an engineer. If he is reviewing  
24 documents, which I have been led to believe he is, there is  
25 no basis for him doing that work. If he puts down "as built,"  
almost any engineer would probably question his ability to

5

1 do that or accept "as is." Typically these documents stop at  
2 some point in management. How they are ultimately reviewed,  
3 I think, should be reviewed by QC or QA, but any one of  
4 these items -- like this one is signed by Virgin Tenneson,  
5 but it was superseded -- in this particular case it got up  
6 to a certain point and the document was told by the guy  
7 who was handling it that it should be put on another form  
8 other than a DR, and it was put on an inspection report, not  
9 a DR.

10 Now, in solving the inspection report, it was  
11 handled by L-a-t-h-r-o-m, it looks like. It ended up that  
12 part of it was put right back on a DR. I mean what I am saying  
13 is unless someone, an outside party, reviews most of these  
14 things, you don't know who really ended up solving it even  
15 though the guy signed it. In many cases the signature is  
16 shown on the documents before there is ever an answer. I  
17 don't happen to have a copy of one of those, I don't think,  
18 at the moment.

19 MR. YIN: Well, let me ask you this. Are you  
20 going to give us some specific DR numbers or DCN numbers to  
21 follow up, or would you like us to perhaps select some  
22 samples for you?

23 MR. STOKES: Well, this thing started on a non-  
24 conformance report, number 8802-667.

25 MR. YIN: You are too fast for me.

6

1 MR. STOKES: 8802-667 was the nonconformance report  
2 number.

3 MR. YIN: This is Foley's?

4 MR. STOKES: Foley's. Then it went to an inspec-  
5 tion report number 8802-120. Then, believe it or not, it  
6 went to this, a little memo that says, "Virgil, all  
7 dispositions are acceptable with the exception of number 2.  
8 Disposition of number 2 should be to transfer to NCR. Howard."  
9 This is where a lot of it is handled.

10 In any case, then it comes back. There is part of  
11 it that has been put back on --

12 MR. YIN: Wait a minute. Let's get the issue  
13 straight here. Are you questioning the process that is  
14 really cumbersome and unacceptable? Are you questioning the  
15 disposition of -- the disposition of the NCR is questionable.  
16 If that is the case, then tell us why you believe that the  
17 disposition is not a settlement.

18 MR. STOKES: Well, the way a nonconformance typically  
19 is handled is management person decides it is an NCR item.  
20 In this case he decided it was, and it went to PG&E to be  
21 solved. That group makes a statement that it shouldn't have  
22 been put on one and that it could be handled differently so  
23 it wouldn't be on a nonconformance report.

24 It says basically that it occurred due to an  
25 oversight of Howard -- the whole reason for this thing is that

7

1 it was an oversight of a Howard P. Foley, Project Engineer,  
2 Project Manager, and a PG&E resident engineer. Then I should  
3 point out that this all involves the brazing of certain  
4 joints and the way the work was handled. They had omitted  
5 a vertical up direction in the test program, but the specs  
6 read "all directions."

7 MR. YIN: Again let me remind you that we are  
8 mostly concerned about the design control and all that. You  
9 are talking about, again, construction, installation,  
10 QC inspection. Are there any DRs or DCNs that really  
11 affected the overall design adequacy, overall adequacy in  
12 design control, or maybe design change control? That I  
13 really want to know.

14 As far as the installation inspection, the use  
15 of DRs, DCNs, NCRs, FCRs -- we have got a whole bowlful.

16 [Laughter]

17 MR. STOKES: In my judgment it should have been  
18 left on a DR or an NR, and the item is subject to review of  
19 all the work. All the work was never reviewed. That was  
20 covered in this. It was all finally just written off on an  
21 "accept as is" basis.

22 Now, if that is not answering your question, I am  
23 not, maybe, real clear -- but to me it looks like --

24 MR. YIN: Well, normally the DCNs, DRs and so on  
25 are really kind of case specific, a unique situation. It never

8

1 has been really intended for a generic application. If they do,  
2 it is in violation of the procedure anyway, so unless --

3 MR. STOKES: It is?

4 MR. YIN: It is. Is there any specific case --

5 MR. STOKES: All of my DRs were generic, written  
6 against Unit 1 and Unit 2. If they were against procedures --  
7 there are DRs like mine that are generic.

8 MR. YIN: Okay. Well, since you wrote some of the  
9 DRs in a generic nature, perhaps you can provide us some  
10 information on that and maybe we can pursue that because if  
11 there are any specific deviations --

12 MR. STOKES: Okay, I will try to get you some more  
13 DRs that are generic in nature.

14 MR. HARTZMAN: Well, the U-bolt is generic in  
15 nature.

16 MR. STOKES: The U-bolts, the welding, the anchor  
17 bolt locations for studs were all written up and went through  
18 management's approval. I should note, if it was against  
19 procedure, it looks to me like management should have raised  
20 it.

21 Now, beyond the three that I wrote, I am aware  
22 of others that I have seen in other people's possession that  
23 were generic and had just as much scope. I will have to get  
24 those because I don't have copies of that stuff with me.

25 MR. YIN: Generic information should carry on

9

1 joint specs, DCNs, all that control documents because the  
2 DRs may be familiar by certain individuals but definitely it  
3 is not intended for everybody to read or understand it  
4 because DRs and DCNs are all really unique problems. So if  
5 you have any specific cases like that, I believe it is  
6 worthwhile to look into it.

7 The reason I said that is because there is a  
8 possibility that somebody was aware of the specific DRs but  
9 some other people may not be aware of it, and as a result,  
10 they may do something contrary to what is dispositioned in  
11 the DRs.

12 MR. STOKES: There is a memo being used in the  
13 same way. In regard to the stanchions a while ago, there  
14 is a memo number 411 that is basically a generic type  
15 memorandum, but if you are not aware of -- and it does go  
16 to design. It's specifically for QA people, and it involves  
17 quite a bit of old work, from what I have been told. And  
18 that is a memo. It is not a DR. But DRs -- boy, there's  
19 a bunch of DRs that are generic in nature. They have got a  
20 few out now that they don't even have all the things closed  
21 on. It's just an open-ended item.

22 MR. HARTZMAN: Such as what?

23 [Pause]

24 MR. HARTZMAN: These are all construction-related  
25 DRs?

10

1 MR. STOKES: Well, the memo -- well, the two  
2 drawings also came from this gentleman on the studs.

3 MR. CLEWETT: While he is looking at that, I have  
4 a question, Mr. Yin. I'm not sure I understood why a DR  
5 shouldn't raise generic issues. Maybe I just misunderstood  
6 what you are saying.

7 MR. YIN: As I mentioned earlier, the generic  
8 requirement should be prescribed, documented in drawings, in  
9 specifications, in procedures, in instructions that has been  
10 really reviewed, approved and issued, controlled for generic  
11 application. Now the DR and NCRs and whatnot really address  
12 a portion of the system or any specific items that need to  
13 be --

14 MR. CLEWETT: But if a person in the field should  
15 discover that there is a generic problem that they are  
16 welding bolts that they shouldn't be or that there is a  
17 generic problem, that there is inadequate design control or  
18 something --

19 MR. YIN: It could start out as a DR, but when you  
20 want to apply it generically across the board, then you  
21 should issue --

22 MR. STOKES: It should be a change notice.

23 MR. CLEWETT: Right. I see what you are saying.

24 MR. STOKES: Well, that's a point that I hadn't  
25 really thought about. There is a memo 411. It concerns



11

1 welds.

2 MR. YIN: Again, there could be a generic issue  
3 raised in the DR, and subsequently the management  
4 incorporates it in some kind of a notice. That is perfectly  
5 acceptable, too. So unless you are absolutely sure that  
6 there was no follow-up action on the generic issue  
7 identified in those DRs, then I think we may have a problem.

8 So if you have that, then give us the specifics so  
9 we can follow up on. We would be more than happy to look  
10 into it.

11 MR. STOKES: I don't know how this is going. The  
12 memo 411 applies to how welds are interpreted. This is how  
13 I was told this by QA. Pullman interpreted the meaning of  
14 this memo to be everything could be as-built on a drawing.  
15 Rather than indicate it through a DR or a discrepancy report  
16 or some kind of other documentation, it is QA. They  
17 interpret this memo 411 as meaning that anything wrong with  
18 a hanger can be as built rather than DR.

19 MR. YIN: Are we talking about DR or are we talking  
20 about a memo?

21 MR. STOKES: Well, this memo is used almost like a  
22 design change notice.

23 MR. YIN: Yes, but that's not the DR we are talk-  
24 ing about. Do you know of any specific DRs that talk about  
25 generic change of the systems?

1 MR. STOKES: I don't happen to have one handy.

2 MR. YIN: Could you go back and maybe refresh your  
3 memory and provide us with something?

4 MR. STOKES: I will do more than that. I said I  
5 will go back and talk to the guy I was talking to and tell him  
6 I need copies of all that stuff that I didn't think I needed.

7 MR. YIN: Okay. I guess we cannot proceed any  
8 further, and you may want to take a look and go back to  
9 check with your folks and see if you can provide any  
10 specific information.

11 MR. SULLIVAN: Charlie, how many different people  
12 are you in touch with on this thing?

13 MR. STOKES: How many? Oh, boy.

14 MR. SULLIVAN: Can you tell us that?

15 MR. STOKES: All together, 25 or 30. Maybe 50.  
16 I get people calling all the time and they don't ever give me  
17 their names, so I don't know if they called before or not.  
18 but I have got probably in the neighborhood of 25 people that  
19 I know I'm talking to, and I not only talk to them but I  
20 call them up every now and then and say, look, I've heard  
21 about this document and I need a copy of it.

22 MR. SULLIVAN: Out of how many support engineers  
23 all together?

24 MR. STOKES: I can't tell you that.

25 MR. SULLIVAN: No, I mean how many are employed at

1 the site?

2 MR. STOKES: How many are still there? I will tell  
3 you that.

4 MR. SULLIVAN: Oh, some of these people you talk to  
5 don't work there anymore? Is that what you mean?

6 MR. STOKES: No, they work there. That's who I'm  
7 talking about. Twenty-five people I now work there in one  
8 form or another.

9 MR. SULLIVAN: Oh, they are not all support  
10 engineers?

11 MR. STOKES: No. I've got support engineers, which  
12 is a limited group, and the number has decreased quite a  
13 bit, and that is putting really a lot of pressure on those  
14 people if PG&E reads it; but I have friends in Pre-Inspection,  
15 QC, QA, welders, bidders. There's almost no -- for Foley,  
16 Pullman, both groups, PG&E personnel, QA, QC. There's  
17 somebody in almost every group, one department or another,  
18 for the entire scope of the plant. Somebody is calling me.

19 MR. SULLIVAN: Okay. I didn't want to take a bunch  
20 of your time with that.

21 MR. YIN: I have about six or seven specific  
22 questions for clarification regarding your summary of  
23 remarks before the ACRS on April 6, 1984. If you don't have  
24 any other things to talk about, let me address that; okay?

25 MR. STOKES: Okay.

14

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

MR. YIN: On page 2 of that summary, second paragraph, you mention another incident: it was because we make erroneous, wildly optimistic assumptions about the quality of construction. And before that, you mentioned people working blindly due to missing information and drawings.

END 8

1           Are there any specific instances or cases which  
2 you can identify?

3           MR. STOKES: I don't happen to have the drawing  
4 or a specific drawing in mind at the moment, Isa. Due to  
5 the lack of documentation which I kept and notes, I am  
6 aware that in some cases the welding call-outs were  
7 insufficient. And due to the fact we could not physically  
8 go the plant during that time, to visual the drawing or  
9 as-built ourselves.

10           In many cases, the designer simply took what  
11 appeared to be as accurate as he could, figured out as  
12 best he could from the dimensions, and then put out a  
13 calculation package on the item, including all the welds  
14 per his own requirements.

15           MR. HARTZMAN: These were supports in existence?

16           MR. STOKES: Yes. I should point out, when we went  
17 to the site, we were supposed there because we had field  
18 access. We went through the psychological review program  
19 only to find that the thorn for us taking it was at somebody's  
20 desk. And the results stayed in somebody's desk, rather  
21 than us getting our own badges for access. And we had to  
22 resort to guides which were supplied by Wall-Tech for like  
23 five gentlemen.

24           We had to go through the security screen, all five  
25 people had to follow around with one person. If one guy

91b2

1 went to the bathroom, they all had to.

2 In any case, people completely stopped going to  
3 look. It was such a difficulty to produce, under those  
4 requirements, that if you had to put out one and a half a  
5 day, the guys just would not go look. Their attitude was  
6 if they are going to be asbuilt inspected, per these  
7 drawings, QC/QA bought off, hell, I won't waste my time going  
8 to look. I'm just going to take the drawing as best it is.  
9 And I'm going to put out a calculation package as best I  
10 can. And the results will be drawn up the way I want it.

11 MR. HARTZMAN: But weren't you required to look?  
12 I mean, to go actually in the fields and look at these  
13 supports?

14 MR. STOKES: No.

15 MR. SULLIVAN: How long does it take to go out  
16 and do something like that?

17 MR. STOKES: With full security on, typically  
18 there was a craft line at the plant every morning until  
19 10 o'clock. You had to get in line to go after the crafts.  
20 You had to have your paperwork up front. It generally took  
21 over an hour just to get in the security building.

22 It typically wasted a half a day for a group to go  
23 out and look at pipehangers.

24 MR. YIN: Let's go back to the subject matter here.  
25 Is it your suspicion --

1 MR. STOKES: It's not suspicion. This is based  
2 on my personal knowledge.

3 MR. YIN: Can you point out what area, what  
4 hanger? Maybe you want to go back and talk to your  
5 friends and see if they can provide something in that area,  
6 because we're talking specifics. Without specifics there's  
7 not really much we can do on.

8 MR. STOKES: I understand. But that's the way the  
9 review program was conducted, though. I can't help that.

10 MR. YIN: Can I go on to the second question, while  
11 you make a note? The second question is on the third  
12 paragraph, the last sentence. It was done to avoid a  
13 failure rate of greater than five percent, which would have  
14 forced expansion of sample from 20 percent to a comprehensive  
15 review of all small bore supports.

16 Was that written anywhere in the procedure, that  
17 anytime you so-called failed five percent, then you had to--

18 MR. STOKES: No, to my knowledge, I never saw  
19 it in writing. That statement, the 20 percent, comes from  
20 the sample. That's the relative size of the sample, in  
21 return for the entire scope. And this was in return for  
22 all Class I. This whole comment came from Leo Mangoba  
23 Alex Schustrom, my group lead.

24 It was a verbal transmittal of the way the  
25 program was written up. They expressed that there was a

1 specific number listed of supports, which had been given to  
2 the NRC, that would be reviewed, sampled, and that this  
3 sample comprised roughly five percent -- or not five percent  
4 but 20 percent of the hole.

5 And that if we failed more than five percent out  
6 of that sample, as it was originally specified, we would  
7 have to redo all the calcs for all the supports, Class I  
8 supports.

9 Now what happened was, now I've gotten this from  
10 PG&E responses to how they got around this. I know how  
11 they tried to get around it, first, but how they finally  
12 got around it was they changed the supports which failed  
13 out of that first 20 percent sample to generic problems.

14 MR. YIN: Well, wait a minute. The 20 percent,  
15 again, is not a document number, documented number. It's  
16 just really hearsay, so there's really -- it's not worth  
17 anything.

18 MR. STOKES: It's not hearsay anymore, Isa:

19 MR. YIN: Well, the second point is, right now  
20 we are pushing them to really evaluate 100 percent of those  
21 STRUDL calcs. Would this problem go away?

22 MR. STOKES: No.

23 MR. YIN: What is the significance of the 20 percent,  
24 or five percent, or whatever?

25 MR. STOKES: The 20 percent represents 5,000 linear



1 feet.

check

2 MR. YIN:

3 MR. STOKES: The 20 percent represents 5,000  
4 linear feet of 25,000 linear feet total Class I systems,  
5 to which PG&E has -- no, let me make sure.

6 PG&E's comment was 15,000 feet they have not  
7 looked at and they have looked at 25,000.

8 MR. YIN: So you're talking about the piping  
9 sampling, not the support failures, right?

10 MR. STOKES: Yes. Well, no. We had a five  
11 percent failure rate out of the hangers on the sample  
12 systems.

13 MR. YIN: Well, you're mixing two things together.  
14 You're talking about 5,000 feet of pipe that was used as  
15 a sample basis. And now you're talking about failure of  
16 supports. I mean, you can't mix those two things together.  
17 What does 20 percent and five percent really apply to?

18 Does this apply to additional hanger review or  
19 applied to additional linear feet of pipe needs to be reviewed?

20 MR. STOKES: The way I've always heard this  
21 written was against linear footage analysis of pipe, which  
22 included a certain number of hangers on that linear footage  
23 of pipe. If there was one program for the pipelines and  
24 another program for the hangers, then I'm a little bit mixed  
25 up myself. But the fact is, I was told that whatever the

1 original sample was, and I never saw the original sample, that  
2 if five percent of that sample failed out of the hangers,  
3 they would have to redo not only those hangers but the  
4 entire hangers on all Class I systems.

5 Now I don't know if that's different than looking  
6 at the linear footage of pipe under the sample program  
7 because I have been told, at the plant, that the hangers  
8 were randomly selected out of all the piping. But the sample  
9 is on a limited span footage.

10 Now from that aspect, I guess they are different.

11 MR. HARTZMAN: Would exhibit one be of some help  
12 to you? Because that's the small bore review program.

13 MR. STOKES: Well, yes. It may even say what I  
14 just said there, I don't know.

15 MR. HARTZMAN: At least it is a small bore program,  
16 as it was installed.

17 (Pause.)

18 MR. STOKES: They're talking about pipelines in  
19 (1) and (2), pipelines in (3). Then a sample of 75 supports  
20 operating at 350 --

21 MR. YIN: Is it possible for you to go back and  
22 clarify this sentence, because right now it's kind of foggy?

23 MR. STOKES: Well, it's foggy to me in that I don't  
24 know how big the sample was, to start with, for hangers. I  
25 never saw the list. I do have a list of what PG&E --

91b7

1 MR. HARTZMAN: According to what you say here,  
2 this sample pertains to all small bore supports. I mean,  
3 it's 25 percent of all small bore supports, the way you have  
4 it written here.

5 MR. STOKES: Well, I took the 20 percent from --  
6 I did that calculation myself, for the 20 percent and that  
7 may be incorrect. I took it based on linear footage of  
8 pipe. The review program basically, as they have stated,  
9 for the pipe was 25,000 linear feet, we justified in doing  
10 analysis on 15,000 and there is 10,000 left.

11 And so there was an original sample of 5,000 for  
12 the 25,000 which is 20 feet of the linear sample.

13 It was in a PG&E document someplace.

14 MR. YIN: Well, we'll look into that, but I think  
15 it's a different issue.

16 MR. STOKES: Well, if you find a different sample  
17 than -- I would like to see a sample list. The only samples  
18 that I'm aware of is there's a thermal list of hangers that  
19 were reviewed. There is a seismic sample and a SAM and a  
20 TAM sample.

21 MR. HARTZMAN: But this was all at the beginning.  
22 This, after a while, became moot.

23 MR. STOKES: The people working there never knew  
24 it became moot. I'm trying to point that out. If it became  
25 moot, we didn't know it. The sample, to our understanding,

1 never changed.

2 MR. HARTZMAN: Yes, but we know that they worked  
3 on a lot more than just those supports, that were under  
4 those three lists. We know that.

5 MR. STOKES: Yes, and the way that I explained this  
6 in that statement, and I'll try to explain it now, is from  
7 PG&E's comments they took problems that came out of that  
8 original sample beyond that.

9 MR. HARTZMAN: Beyond what?

10 MR. STOKES: For example, you have seen the thermal  
11 sample list and SAM & TAM at the field?

12 MR. HARTZMAN: Yes.

13 MR. STOKES: From what I gather, other hangers  
14 were looked at and they didn't think they had failed. They  
15 didn't think they would have a five percent failure, but  
16 they did. And what management did was they scoped all of  
17 these into some kind of category.

18 Now I have never been told what kind of category  
19 it was, if it was hot thermal lines, or something to that  
20 effect. But we did have a lot of hangers failing on hot  
21 lines.

22 So that could be one area they made generic, that  
23 we had hangers failing on lines that were not hot.

24 Now if they didn't put them in a generic category  
25 of hot thermal lines, I'm not aware of another category that

1 would cover those.

2 MR. HARTZMAN: Yes, but you don't know that, do you?

3 MR. STOKES: I'm saying -- no, I don't.

4 MR. HARTZMAN: So it is possible that they would,  
5 and we know that they didn't put them into another category  
6 because we have the whole list of all the supports that  
7 they reanalyzed.

8 MR. STOKES: Yes, they said they put them in  
9 another category.

10 MR. HARTZMAN: Presumably, about 1800 supports.

11 MR. STOKES: But do they put all the ones that  
12 were falling into those categories, or do they just put  
13 what was in the specific scope? What I'm saying is the  
14 program that originally I was aware of, or was told about,  
15 had problems with it and I have made this point clear in many  
16 of the other meetings.

17 That I was aware that they were trying to cut out  
18 supports out of that sample because they were failing.  
19 Now I never did find out how they finally solved that  
20 problem. All I know is finally, we ended up where we are,  
21 I suppose. And what they said, in the comments that I have  
22 read to you, is they have moved problem areas to generic  
23 areas and that the sample didn't change.

24 They specifically told us they have two programs,  
25 one for generic, which if you look at the top of the small

1 bore program sheet, Exhibit 1 --

2 MR. YIN: Well, we understand that. We are  
3 looking into sample programs, generic --

4 MR. HARTZMAN: You read Mr. Yin's last report, I  
5 assume?

6 MR. STOKES: I have read everything that I've  
7 gotten my hands on, but I won't guarantee I've read his last  
8 one.

9 MR. YIN: That's okay. We have some concern in  
10 that area. It may not be exactly dealing with what you  
11 have, but I guess the issue has been looked into. And we  
12 haven't finished our inspection yet, so this is one of the  
13 items that Dr. Hartzman and myself will be looking into  
14 during our future follow up inspections.

15 Let me quickly jump to the third item, page 6,  
16 in the middle of the page. You talk about the placement of  
17 struts, spring cans, and snubbers on the wrong side of rigid  
18 restraints. This could cause actual lock up of lines due  
19 to thermal movement. Now you drew me a little sketch here.  
20 Perhaps maybe you can explain it a little bit better on the  
21 large paper board over there.

22 MR. STOKES: All right. It may have been caught  
23 in relation to the 3 and 5d. But the way the 3 and 5d  
24 discussion went on had to do with lateral gap requirements  
25 for snubbers. But when I was in quick fix, I believe it was

1 in RCP 1-2 -- I won't guarantee that because I am relying  
2 on memory. But there was either a three-quarter or a one  
3 inch line that came off the bottom fo the numo. It came out,  
4 made an elbow, came over and made an elbow vertically, like  
5 so.

6 (Indicating.)

7 This would represent this line and this represents  
8 what happens up here. Now this distance was in the  
9 neighborhood of three to four feet, if I remember correctly,  
10 and it was very short here. Typically the same distance,  
11 three to four feet. There were two new supports going in  
12 on this line.

13 There was a rigid Y restraint with completely  
14 open -- I mean, it could move four feet in one side. It  
15 was supposed to go in.

16 MR. YIN: What do you mean by can move four feet on  
17 one side?

18 MR. STOKES: Well, it had an angle support with two  
19 angles cantilevered off and it was completely open on one  
20 side so the pipe could move completely out of the support.  
21 But it had quite a bit of throw on it, so it was completely  
22 guided, I would expect.

23 Now the problem was the original installation --  
24 this was a five --

25 MR. YIN: Is it possible to draw an isometric, so

1b12

1 we can see the relationship better?

2 MR. STOKES: I'm a good drawer, but, well -- let's  
3 just try settlement elevations. That's if the view looking  
4 in, this is down on it, that is plan right here. Median  
5 isometric -- something like this. It comes out, comes  
6 across and comes vertical.

7 In any case, this was a 5d radius right here.  
8 There was a bend. It was more than just an elbow.

9 MR. YIN: It was tubing, right?

10 MR. STOKES: Yes, bent tubing. Anyway --

11 MR. SCHIERLING: What size pipe is that?

12 MR. STOKES: I think it's about three-quarters,  
13 one inch to three-quarters. In any case, there was proposed  
14 rigid Y to go in six inches, I believe, roughly from this  
15 elbow. Now the elbow wasn't accounted for because of the  
16 radius. And putting it in barely came into contact with  
17 the transition from the flat to the curve.

18 Now at the same time, there was a lateral snubber  
19 that was supposed to go in at this point.

20 MR. YIN: A snubber for three-quarter inch, right?

21 MR. STOKES: There's a lot of snubbers on this line,  
22 Isa. In fact, this entire vertical rim has snubbers in  
23 two directions for about 20 to 25 feet. There were no  
24 supports on this rigid, other than snubbers, until this rigid  
25 Y went in. Now what happened was there was a beam steel



1 under here that sort of ran diagonally. It didn't run  
2 straight with the beam and to get the grading out of the  
3 way and cut a hole in it and get the angle attaching to the  
4 beam, they slid the support right up to the flat part, curved  
5 section of the elbow.

6 Now that was within ESD tolerances. There was no  
7 problem by itself. Now I got into this because one of the  
8 field engineers called me when they started putting in the  
9 snubber. Because the snubber and the rigid Y had not been  
10 ruled to go together -- in other words, typically in the  
11 industry you will see them both attached together or a note  
12 that they should be worked together by the same crew.

13 But what happened is when they started to put the  
14 snubber in, the rigid Y was already here, welded in place,  
15 QC/QA and everything, green tagged.

16 Well, if the engineer hadn't questioned all the  
17 snubbers on this thing, he wouldn't have called me. But what  
18 he did was he called me because they were fixing to weld  
19 the snubber in on this side, within a half inch of the  
20 support, so it wouldn't hit cold and put up the steel.  
21 And they called me and said I think you should come down  
22 here and look at this. This doesn't look like it's right.

23 Well, I went down and looked and I know there's a  
24 lot of movement off these pumps. And I also looked at it  
25 in the line spec, and the line temperature for this line,

91b14

1 I believe, was something like 512 degrees. I looked at  
2 what was already there, off a lot of snubbers, and I  
3 realized that this snubber if anything probably was going to  
4 move into this support, if they put it where they were  
5 planning.

6 I put the thing on hold, and I went into the  
7 stress group --

8 MR. YIN: Well, you mentioned it's a very short  
9 piece of pipe, three to four feet. How much do you expect  
10 will be removed?

end9

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

10joy1

1 MR. STOKES: According to the pipe stress calculations  
2 between the thermal load, the seismic movement,  
3 this vertical line moved about two inches at the bottom.

4 MR. YIN: Okay. It's moving upwards, right?

5 MR. STOKES: No. The snubbers on this thing are  
6 lateral.

7 MR. YIN: Okay. That's no problem, then; right?

8 MR. STOKES: Well, it says that this pipe, since it  
9 didn't have a restraint, was moving in two directions at the  
10 bottom, and it was. It was moving roughly laterally, in a  
11 lateral direction, about an inch and a half, and it was  
12 moving axially, I guess, due to the pump maybe twisting. I'm  
13 not sure. But I just know the movement specified where the  
14 snubber went in, in the neighborhood of two inches in all  
15 directions. That is laterally at this point (indicating).

16 Now, I knew that the rigid Y was going to limit  
17 the Y to about 0, but I know that they had enough distance  
18 in here to take out the Y directional movements. But had they  
19 put that snubber in front of this support, it would have only  
20 moved a half-inch before it started hitting the angle iron  
21 and it would have locked the pipe up.

22 Now, I believe I fixed this particular support  
23 where it will not lock up, but if you go back and review the  
24 calcs, I may be wrong. I didn't have enough information on the  
25 snubber drawing to accurately design this mechanism, nor did

10joy2

1 the original engineers who did it. In some cases there is  
2 so much movement when you have a snubber shown where a rigid  
3 goes that the snubber can displace, even if it is placed at  
4 the same point, completely out of the vertical guide.

5 MR. YIN: Well, let me ask you before you go any  
6 further: the pump is anchored on the floor, right, or some  
7 kind of a structure?

8 MR. STOKES: It is bolted down. I will agree with  
9 that.

10 MR. YIN: It is bolted down. And there you have a  
11 short piece of tubing going down and turning.

12 MR. STOKES: Well, it is actually coming out.

13 MR. YIN: Okay. It doesn't matter. So the total  
14 displacement from either direction may be not more than four  
15 or five feet, as you mentioned. How is it possible to have  
16 two inches of movement?

17 MR. STOKES: I didn't do the analysis. This is  
18 temperature, line pump movement -- the annulus steel --  
19 It was sitting on the annulus steel, on top of that.

20 MR. YIN: It's physically impossible.

21 MR. STOKES: If it is physically impossible for a  
22 problem to occur from a high temperature line on annulus  
23 steel, then forget what I said. If you don't even want to  
24 look at it, if you don't think there is absolutely any way  
25 that could be a problem, forget what I said. But with a

3

1 half-inch gap between supports, even if you had a one-inch  
2 movement, you will have lock-up if the thing is not designed  
3 correctly, and I know for --

4 MR. YIN: Wait a minute. Have you done the  
5 analysis yourself or are you saying just because you are  
6 looking at the drawing it shows two-inch --

7 MR. STOKES: I didn't see it on the drawing. They  
8 don't put movements on drawings.

9 MR. YIN: Well, where did you get the two inches  
10 from?

11 MR. STOKES: I got it from the Stress Group, but  
12 they don't put any of that information on the drawings  
13 any more. We did initially put the movements, the thermal  
14 temperature changes. We put the normal operating temperature,  
15 the design accident temperature. We put the movements. We  
16 put all of that. And I could have used it.

17 MR. YIN: Let me ask you. The two inches or  
18 directional movement, is that a verbal information,  
19 or is that a document that is written, instructions that  
20 certain movement that will be used.

21 MR. STOKES: Written instructions? It wasn't  
22 written instructions.

23 MR. YIN: It's just a verbal type --

24 MR. STOKES: It came from my own -- to my memory,  
25 I went to the Stress Group and actually pulled the stress

4

1 printout showing the displacements on that line. There was  
2 no transmittal of information, no -- as a matter of fact, had  
3 I not even looked at it -- well, you say there couldn't have  
4 been a problem, and possibly there couldn't be, but they  
5 didn't put snubbers on that line for 20 feet because there  
6 was no thermal growth on it, or no displacement that they  
7 could handle with the rigid.

8 MR. YIN: Yes. Well, you mentioned position of  
9 struts, spring cans and snubbers. So far you've mentioned  
10 snubbers. Do you see instructions on struts and spring  
11 cans?

12 MR. STOKES: Spring cans are just as likely, and  
13 struts, in particular, are handled -- I have never seen so  
14 many uses of struts at a plant as I have seen at Diablo  
15 Canyon for rigid restraint. Typically you have to have  
16 two-direction restraints for a snubber to interplay without  
17 folding down, and then the line has to hold it up in one  
18 direction. They use snubbers at the plant, or struts.

19 MR. YIN: Okay. On page 8 it says, on the upper  
20 page here, "It did not seem reasonable to have a mixture of  
21 20 hertz and 33 hertz support on a single pipeline,  
22 but management required us to design it that way." Is that  
23 a procedural requirement or is it a verbal requirement?

24 MR. STOKES: That was written down in the early  
25 M-9s. I don't know if it is still written down in the M-9.

5

1 MR. YIN: Well, when you say early, do you remember  
2 what revision?

3 MR. STOKES: Probably -- I haven't seen it lately.  
4 Probably around Revision 3.

5 MR. YIN: Actually, safety implication is really  
6 minimum, isn't it, because right now the criteria calls for  
7 20 hertz, so you have got 33 hertz. It won't bother you,  
8 right, because 20 hertz could be 25, could be 30 or whatever  
9 because the minimum acceptance deflection is .025. So  
10 really --

11 MR. STOKES: True. But there is another number  
12 being used besides the .025 inch displacement; this .009 has  
13 been used.

14 MR. YIN: Where does the .009 come from?

15 MR. STOKES: 33 hertz.

16 MR. YIN: Okay.

17 MR. MANOLY: Do you feel that 20 hertz is not  
18 adequate? Let's get down to the bottom of this. Is that the  
19 concern?

20 MR. STOKES: The concern is that they have two  
21 different procedures for doing the same work. If 20 was  
22 valid for one support, why was it not valid for the other  
23 one?

24 MR. YIN: Again, if you look at the scenario of the  
25 thing here, you originally designed 20 hertz, and then later

6

1 on you determined a 33 hertz requirement. Now, definitely  
2 there is a problem. But the reverse is true. Before you  
3 used 33 hertz, and now you back off to 20 hertz. So every-  
4 thing you have done before is still acceptable.

5 MR. STOKES: If it's 33, it's better than 20, but  
6 at one time there was a split system.

7 MR. YIN: Well, the intent is to make sure that you  
8 have a rigid structure to hold up the pipe. That's about it,  
9 right?

10 MR. HARTZMAN: Your answer to his question was that  
11 you have no objection to the 20 hertz; is that correct?

12 MR. MANOLY: Yes, that was my question. If they  
13 can meet 20 hertz, is there a safety concern there? I don't  
14 see it; do you?

15 MR. STOKES: Not just to the stiffness, no.

16 MR. MANOLY: Well, you know what it's for, the  
17 number of hertz?

18 MR. STOKES: Frequency correlates to the seismic  
19 accelerations. Fits it within a dampening mode.

20 MR. MANOLY: Well you know what it means that it  
21 tries to get as much close to the stiffness of a support.  
22 They assume the stiffness in the piping analysis --  
23 So the 20 hertz can give you there a close proximity to  
24 the assumed stiffness, then you are set. If you go more,  
25 then you are incorrect, right? So I'm asking, is there



1 a safety concern there?

2 MR. YIN: I think he addressed that already. He  
3 is not concerned with the 20 hertz. I guess -- let's jump  
4 to the next one. It's getting late. I'm getting hungry.

5 MR. STOKES: Me, too.

6 MR. YIN: On page 9, the first paragraph, last  
7 sentence. Now the drawings have been stripped of the  
8 minimum information. Instead, we got tardy telephone --  
9 suspicious accuracy? Is this related to what I was talking  
10 about in my draft report where there was lack of control  
11 for telephone-provided information? Or something --

12 MR. STOKES: No. It has to do with the practice  
13 of including the information concerning snubbers on the  
14 drawing, movements -- that typically would flag a problem  
15 if it's placed in too close conjunction to a rigid.

16 Not only does it include that kind of information,  
17 but it also would include information which -- like loads.  
18 Spring cans typically had load data, the old ones did.  
19 They completely took that off of the drawing.

20 Anytime you had a question down in the field as to  
21 some change in the support, you didn't have the data to do  
22 a rough hand calc or -- for instance, if you wanted to put a  
23  
24  
25

1 spring can on a cantilever, it hadn't been on a cantilever.  
2 That would be a minor calc if you knew the load.

3 MR. YIN: Well, legally there is no requirement to  
4 put down on the thermal movements and so on on the installa-  
5 tion joints, as long as it is provided in some other design  
6 document.

7 MR. STOKES: Legally, you are right. I said  
8 industry practice.

9 MR. YIN: I think the issue is whether or not there  
10 is somewhere that those documents exist.

11 MR. STOKES: Computer printouts.

12 MR. YIN: Have you given a copy of that for your  
13 work?

14 MR. STOKES: No, we were never given that.

15 MR. YIN: You were not?

16 MR. STOKES: No.

17 MR. HARTZMAN: In none of the analysis that you  
18 did you were never given any thermal movements for the  
19 supports?

20 MR. STOKES: We were given the loads in the  
21 thermal movements for the support, but not in the field.  
22 There was no correlation for the drawings for field use on  
23 that same point. It did come to the design trailer, sometimes  
24 on a torn-off sheet of paper without anybody's name on it.

25 MR. KNIGHT: Do you have any idea where that

1 torn-off piece of paper came from? I mean do they come from  
2 random places or was it the same place?

3 MR. STOKES: Yes, they came from quite random  
4 places. Sometimes they came from a stress engineer in the  
5 stress trailer. Occasionally it came from a group lead.  
6 There's just no way --

7 MR. KNIGHT: Let me ask something else. What was  
8 the motivation to send the torn-off piece of paper? The  
9 intimation is that there was some sort of system, and I am  
10 just trying to get some sort of feel for what it was.

11 MR. STOKES: You would think that they had inter-  
12 office memos in use, but believe it or not, I didn't ever  
13 see any forms for that. So there was no actual form that  
14 could be used, such as an inter-office memorandum or something  
15 that you would put on. Typically, after a while some of it  
16 did come over with a cover sheet on it and Xerox copies  
17 attached under a file number, but more times than not, it  
18 was just a random bit of information without any substantia-  
19 tion.

20 MR. SAFFELL: I guess another question is that you  
21 obviously had to document this in your analysis, and I would  
22 have thought that the checker would have requested the source.

23 MR. STOKES: Many times they don't request the  
24 loads. You could show them that torn-off piece of paper  
25 and he'd buy it just as well as you did the first time.

1 MR. SAFFELL: It doesn't bother me that that  
2 information is not on those drawings. That doesn't bother me  
3 at all.

4 MR. YIN: It helps to be on the drawing.

5 MR. STOKES: If it was on the drawings, it would  
6 have cut down on problems of interferences and so forth in  
7 the installation.

8 MR. SAFFELL: Or it could be looked at as a means  
9 of them controlling who and how used that information.

10 MR. STOKES: Well, as an industry practice, it  
11 is typically put on there when they go to do a walkdown  
12 on the line. They don't come out with a calculation program.  
13 They come out with the drawings because it has them on it,  
14 okay? I mean I see where you are coming from, but there is  
15 a hell of a basis for putting it on there in the first  
16 place, and we did start out doing it at the plant. To tell  
17 you the truth, everybody questioned why it was finally  
18 taken off.

19 MR. YIN: My last question, page 10, first paragraph.  
20 It talks about key plans, and I guess you are talking about  
21 orientation, and I think it's very important because if the  
22 orientation is wrong, then everything is wrong. All the  
23 moments and the forces and so on would be all incorrect.

24 Now, before we determine that that was the fact,  
25 can you give us more indication on what makes your concern

1 that there is some problem in that area?

2 MR. STOKES: Well, as I stated the other day, it  
3 primarily revolves around that little key plan, which is an  
4 attachment to Exhibit 8. I have not worked at the plant  
5 since last October 14th, and as of a year working on that  
6 site, based on what I was told by my group leads and super-  
7 iors, this key plan is contradictory to what I was told as  
8 a basis for the loads on the pipe, the hangers, the plant,  
9 everything in relation to Unit 2, as is stated in that  
10 little write-up.

11 MR. YIN: But again, from what I understand, the  
12 pocket guide is used for a quick reference on what the  
13 design versus installation requirements are. It is not really  
14 used for design per se, right?

15 MR. STOKES: It wasn't ever used in the design  
16 group. They never had a document like that document right  
17 there. That's what I'm trying to say. When I worked in the  
18 design trailer, we didn't have absolutely any written  
19 documentation as to what the mirror image problem had been  
20 and what it should be for Unit 2. We were only told, and  
21 based on that knowledge, what I'm telling you here today is  
22 I was told something different than what that drawing  
23 represents.

24 Now, PG&E admitted in the ACRS that this drawing  
25 is correct, and over six months after I quit working at the

1 plant, just looking at that document brought a problem for  
2 Unit 2 up in that I had a question from what I was told and  
3 what I was told as knowledge and what I used versus what the  
4 drawing represented.

5 The whole question, then, that came up was, even  
6 though Unit 1 is the one that is being licensed, is there a  
7 problem presently with what we have been doing on Unit 2?  
8 And as far as I know -- and I will stretch that -- to my  
9 knowledge no one at the site has been informed of this in  
10 the Design Group because this is the only place I have ever  
11 seen this little document shown, was in that little black  
12 book.

13 MR. YIN: Okay. So you have no concern as far as  
14 Unit 1, the mirror image or whatever the problem, design  
15 problem, Unit 1 is okay, but you have some concern with  
16 whether or not it was applied correctly on Unit 2 so you have  
17 asked us to maybe look into the Unit 2 design.

18 MR. STOKES: Yes, someday.

19 MR. YIN: In the future. All right.

20 MR. STOKES: I'm really interested in that in the  
21 future. But I was using that as an example. If this thing  
22 had ever come out, it would have been a good thing for  
23 management because it is the only-written thing I ever saw  
24 with that on it, and they didn't do it.

25 MR. YIN: Before I wrap up my questions, let me

13

1 ask you: This affidavit that you provided to the Staff today,  
2 is there anything involving safety-related design control  
3 and design issues? It looks to me like it is all construc-  
4 tion and QC-related.

5 MR. STOKES: Well, yes. I've been trying to get  
6 away from QA because that is one area that you have been  
7 looking at, and I am trying to get you into QA and the field  
8 aspects. So from that standpoint I suppose it probably  
9 does relate predominantly with field practices.

10 MR. KNIGHT: I have been looking this over while  
11 you have been talking. On page 10, you note that there is  
12 no angle limitations for skewed T-joints. Now,  
13 that would seem to be an area that would affect the designer's  
14 approach.

15 MR. STOKES: Well, it does, yes. It was raised,  
16 I should note, by a gentleman in the field.  
17  
18  
19  
20  
21  
22  
23  
24  
25

END 10

11pbl

1 Well, you can see a Xeroxed portion of this book  
2 in the back of this attachment. Specifically, page 75 on  
3 attachment 1. It's the second from the back pages in the  
4 right. This table was taken from this little black book,  
5 but I believe it is identical to what is in ESD-223.

6 I had this question in my DR. And a pre-inspect  
7 engineer has been reraising this same issue and he's drawn up  
8 a lot of these little sketches at various angles. But I  
9 have never seen an explanation as to how you really use this  
10 table. And from my determination of it, it appears that for  
11 a 15 degree angle, if S is  $3/16$ ths required, then you should  
12 have -- or a W is  $3/16$ ths. You need an S of  $3/16$ ths, and.  
13 I would allude that at 15 degrees you need at least  $1/4$ th  
14 inch over that due to the throat deduction.

15 Either I am not reading this table right, and the  
16 pre-inspect engineer who works in the field is not, because  
17 he has to use this table on interior angles, to determine  
18 if the weld has indeed been installed.

19 It seems to him and to me that at 30 degrees, if  
20 you need  $3/16$ ths throat, which would be W, you would have to  
21 have an S of  $1/4$ th plus  $3/16$ ths in this table to give you  
22 that measurement.

23 Now I would really like to have some clarification  
24 on this. Not only for myself, but if this table is what  
25 is being installed and does account for the throat deductions



11pb2

1 in the installation, then the welds as installed are not  
2 in compliance with the design requirements for the effective  
3 throat. And they do impinge on the designs.

4 They also affect installation. This is one  
5 typical area that has been, I guess, a thorn to me. It's  
6 the way they handled welding at that plant.

7 I should note that this information on welding  
8 which is shown on this same attachment and the next page is --  
9 there's actually four pages on symbolism. That would have  
10 been the most useful information that they could have put  
11 out on that plant site. Because the reason that I got  
12 put into quick fix was on partial penetration welds I was  
13 showing S and E in angle preparation and 60 at 45.

14 The field couldn't read those dimensions, and  
15 quick fix was having to remove them. My lead engineer when  
16 I left the trailer said, straighten out the weld problems.  
17 And that's primarily why I went to quick fix. Because either  
18 he had something to do with it, or somebody did.

19 But had they put out this little book, they would  
20 have cleared up many of the problems from our drawings,  
21 because they would have been able to read them. And they  
22 really needed a few more pages of these examples.

23 But they didn't need to do the kind of program  
24 that they had. I mean, this little table for the inspectors  
25 really didn't look right to me. But maybe I'm just not

11pb3

1 understanding how you use it. But I wish somebody would  
2 tell me so I can forget about it someday.

3 MR. HARTZMAN: Let me ask you something. Again,  
4 let's go back to this little book. You said that you were  
5 told about bolts, both orientation being by right-hand rule.  
6 Was this verbally or was this written down somewhere?

7 MR. STOKES: No. I already stated, there was  
8 no other drawing. This is the only written document that  
9 I've ever seen of the plant right here.

10 When I went to the plant site, it was all verbal.  
11 We continually had a question as to which way zero azimuth  
12 was in the Unit 1 building.

13 MR. HARTZMAN: Why? In other words, where does  
14 this information come in in the checking of the supports?

15 MR. STOKES: Well, depending on which way is  
16 what, when the stress gives you the loads, the positive  
17 side would go one way and the negative a different way. And  
18 we wanted to know that the way we were applying it was the  
19 way stress intended it to be applied to the structure. As  
20 all the seismic accelerations were applied to the structure.

21 And if we didn't follow through the way they  
22 wanted it placed, you could possibly have the positive going  
23 in the opposite direction from the way it should have been.  
24 And the magnitudes varied in many cases.

25 MR. HARTZMAN: So what you're really implying her

11bp4

1 is that there may have been some kind of a deficiency in the  
2 loads from the pipe stress group being transmitted to the  
3 support group.

4 Why would there not be now in Unit 1 and only in  
5 Unit 2?

6 MR. STOKES: Based on what I was told, Unit 1  
7 follows the rule.

8 MR. HARTZMAN: And are you comforted that in  
9 Unit 1 the loads were transmitted correctly? That's what  
10 you're saying.

11 MR. STOKES: No, not what you just said. When  
12 you put it to me that way --

13 MR. YIN: It's not an immediate concern. He  
14 just wants us to go back, check the Unit 2 in the future,  
15 right?

16 MR. STOKES: Well -- but what he is raising is  
17 am I absolutely sure that we transferred the loads in the  
18 Unit 1 from stress to the hangers correctly.

19 MR. HARTZMAN: I'm trying to see if that's what  
20 you're stating.

21 MR. YIN: We have no concern with Unit 1.

22 MR. HARTZMAN: Let me ask you a broader question.  
23 You said that in this problem over here, they told you that  
24 the displacements were two inches. This was the pipe stress  
25 group.

llpb5

1 MR. STOKES: They had a specific system for that,  
2 yes.

3 MR. HARTZMAN: Well, before that, last week when  
4 we spoke to each other, there was a question about the  
5 1,000 degree rise. That also came from the pipe stress  
6 group.

7 It seems, you know, I'm beginning to wonder just  
8 what kind of information they were giving you.

9 MR. STOKES: Well, there has been a other statement  
10 along those lines that's been raised concerning how many  
11 procedure books are in what trailers. And for the longest  
12 time, there was only one control book in the stress trailer,  
13 one set of documents.

14 I'd be very interested to know how many control  
15 books are still in that trailer.

16 MR. HARTZMAN: What has this got to do with  
17 control books?

18 MR. STOKES: It has to do with whether the people  
19 were aware of the system that they were supposed to be  
20 using.

21 MR. HARTZMAN: Yes. But the point of this is,  
22 when they told you that these things expanded two inches.  
23 That's what you said, expand two inches. How much of the  
24 thermal --

25 MR. STOKES: I said it moved, from expansion,

llpb6

1 whatever. Anchor movement, from the pump movement. That  
2 was total movement at that point. It was listed as two  
3 inches in two directions.

4 MR. HARTZMAN: Yet we heard here that it's almost  
5 a physical impossibility for something like that to happen.

6 MR. STOKES: I didn't perform that analysis.

7 MR. KNIGHT: First of all, we're never going to  
8 know until we go look. And secondly, maybe it's anchor  
9 movement. That strikes me as a big number.

10 MR. HARTZMAN: All right. Let me just finish my  
11 last question. When we spoke about the 1,000 degrees last  
12 week, did you ever go back and really try to determine  
13 where that came from, by any chance? I know that we left  
14 it -- we didn't pursue it any further. But I just wondered  
15 if perhaps your curiosity was -- was aroused.

16 MR. STOKES: Initially there were two numbers  
17 provided to us. That was an accident condition and an  
18 operating condition. Now the numbers originally came out,  
19 I was told off of that list I showed you last week.

20 MR. HARTZMAN: That showed up to 688 degrees.

21 MR. STOKES: Yes. Now there was a time when  
22 that list was not used. And I don't know who derived the  
23 numbers, but during that time we saw a lot of temperatures  
24 higher than what was on that list.

25 And a Mr. Lepke was in charge of that, if you

11pb7

1 want to know who to ask.

2 MR. HARTZMAN: Okay.

3 MR. STOKES: I can only tell you, we were supplied  
4 the data and told to do the calcs, and it varied in a lot  
5 of cases. And I guess that's the reason I'm sitting here.  
6 It was never written down.

7 Had they given us -- we had a copy of that line  
8 list, by the way, when we were doing these calculations.  
9 And I questioned some of the temperatures then.

10 MR. HARTZMAN: But you didn't see anywhere that  
11 there was 1,000 degrees.

12 MR. STOKES: No. Except what was supplied to us.  
13 You know, I've got two things to base it on. Documents  
14 that I saw and then things that people told me to do. And  
15 that's where I'm coming from.

16 MR. HARTZMAN: Okay. Thanks.

17 MR. YIN: I have no further questions.

18 MR. KNIGHT: Anybody?

19 (No response.)

20 MR. KNIGHT: Charles, is there anything -- I will  
21 admit to almost hesitating to ask.

22 MR. STOKES: The only thing I want to mention is  
23 basically I'm interested in having -- torsion is ultimately  
24 decided on. Technically they've resolved that, I won't say more.

25 I am also concerned with how you ultimately

llpb8

1 decide toward the Australian Paper on Angles. I have  
2 reviewed the document partially. There are several load  
3 case combinations and Pullman is in the back of that  
4 document, which to me implies that there is much more work  
5 in the design calculation to justify the use of their  
6 program than we did.

7 I hope you would at least consider those formulas  
8 in the back and how they are applied to the calcs. I also  
9 am concerned about the admission, by PG&E, the other day  
10 of finding one and a half T tube steel in the plant. And  
11 in an earlier statement by PG&E that implies that there  
12 is foreign steel in the plant, due to American standards  
13 being of 2T requirement. I'd like to know what material  
14 specs the steel conforms to, how it would affect the  
15 safety of whatever it is installed on and beyond that, before  
16 any major amount of functional testing or whatever is  
17 performed, I would really appreciate everyone looking at  
18 the asbuilt drawings in regards to welding specifically.  
19 And maybe do their own walkdown of a few, just to see if  
20 they can have any confidence in the drawings for later rework  
21 or rereview program.

22 I don't. And the people that work in the plant  
23 now don't. And I really think those drawings are very  
24 important if we're going to allow --

25 MR. KNIGHT: Just to be sure I understand what

1 you're saying, do you feel that there is a likelihood that  
2 you will find that the asbuilt drawings do not, in fact,  
3 reflect the geometry?

4 MR. BOSNAK: Particularly the welds, the type of  
5 welds.

6 MR. STOKES: Particularly -- well, on fillet welds  
7 most every guy in the field can call out a fillet. He's  
8 given a fillet gauge call-out or measuring device, little  
9 gauges. I've even got a set. But specifically, anytime  
10 there was a preparation type joint, whether or not the  
11 joint was ever prepped should be documented somewhere,  
12 having been a QA approved on the original prep of the  
13 joint.

14 Without that documentation, you shouldn't take  
15 face blank that that weld exists there, without doing a  
16 very, very in depth look at the joint yourself. Scratch  
17 the point off. Try to see if it was cut, look at the heat  
18 effects. Maybe it still shows the temperature that was  
19 applied to it.

20 There are ways to get an idea of whether that  
21 joint was prepped, even if you don't know how much or  
22 what angle. I can tell you what the old angles were  
23 uniformly, and that was  $37\frac{1}{2}$  because that's what was in  
24 Pullman's weld specs up until June of '83, when I raised  
25 the question.



1 I can give you a specific date on when the  
2 transition took place, because I have a copy of the original  
3 document right here. It was made on 6/23/83. Before that,  
4 there was absolutely no use of 45 or 60, to my knowledge, by  
5 Pullman. Anything designed, built, installed, per them, was  
6 at 37 1/2.

7 Now in the calculations, I would expect that that  
8 be reflected accurately and that the final analysis document  
9 that the affected throat is indeed acceptable by some  
10 procedure. If they only used AWS D11, Bechtel should  
11 issue their own standards for what the effectiveness is at that  
12 angle, I would think.

13 MR. BOSNAK: You are mostly concerned about the  
14 work done by Pullman, or anybody else?

15 MR. STOKES: No, Pullman, in relation to piping.  
16 I am also very concerned in Foley's work, in that one of  
17 the comments from Foley people that I am getting is that  
18 the way they applied the crisscrossing of the safety and  
19 non-safety cable tray systems, the way it was worked out for  
20 small bore, was if a non-safety related line crosses a  
21 Class I line, it will be evaluated to upgrade the system to  
22 Class I in this area of concern.

end11

23

24

25

1           Some of the people have stated that if the trays  
2 did not cross Class I trays that they did not look at them.  
3 Only when they directly crossed the trays --

4           MR. BOSNAK: Do you think they may have  
5 misinterpreted the interaction or the two over one criteria?

6           MR. STOKES: The way we handled small bore when  
7 it crossed, was roughly at two over one or three spans,  
8 two on each side, three supports.

9           In the cable trays, I've been told, their runs  
10 were for 25 feet or so. A Class II tray will sit roughly  
11 nine inches above Class I. And because it physically never  
12 crossed, it was never looked at. That is a very literal  
13 interpretation of the word "cross" and the word shouldn't  
14 have been "cross." It should have been "supported above."

15           But that's because the people in the plant  
16 typically do not or haven't had prior experience. The  
17 people working inside the plant, other than job shoppers --  
18 they have never seen that process applied before. And they  
19 take literally every word as someone on the street would.  
20 And you have to look at it from that aspect.

21           And I believe, as far as I'm concerned, the only  
22 other point I'd like to stress is we really -- and I'm  
23 talking for me and all the whistly blowers, all the people  
24 that have fed me information and probably will continue to  
25 would like to take everyone here on a field trip.

1                   It's something I've been asking for for months.  
2                   And don't expect that I'll continue to ask for it, but I'm  
3                   getting a lot of support from the people in the field, now.  
4                   They are willing to say well, I'm anonymous, but if they'll  
5                   do that, I'll go with you.

6                   And that is something that, to me, is unbelievable  
7                   because these people don't want to lose their jobs, but  
8                   other than that, that's all I have to say.

9                   MR. KNIGHT: Thank you very much.

10                  In my judgment, from looking around the table,  
11                  it has been a busy afternoon. I see a lot of tired people.

12                  Thank you.

13                  (Whereupon, at 4:52 p.m., the meeting was adjourned.)  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE OF PROCEEDINGS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

This is to certify that the attached proceedings before the  
NRC COMMISSION

In the matter of: Meeting between Staff and C. Stokes  
(Government Accountability Project)


Date of Proceeding: Tuesday, April 10, 1984

Place of Proceeding: Bethesda, Maryland

were held as herein appears, and that this is the original  
transcript for the file of the Commission.

Suzanne Young

Official Reporter - Typed



Official Reporter - Signature

11 pages with  
7 page document

NRC Meeting with C. Stokes  
April 10, 1984  
Bethesda Md

Affidavit

My name is Charles Stokes. I am submitting this affidavit to the Nuclear Regulatory Commission (NRC) to inform them of material false statements and other evidence of activities which could compromise the quality of the Diablo Canyon nuclear power plant, if it should be turned on. The misconduct involves welding, procedure qualification tests, and plant modifications during the hot functional tests. In my professional judgment, if these issues alone are confirmed as examples of general practices, the plant could not possibly be licensed to go critical under the NRC's legal requirements in 10 C.F.R.

In fact, the practices revealed below and others I have disclosed would even flunk Bechtel's own standards. I am enclosing as Exhibit 1 portions of Bechtel's "Field Engineer Pocket Hanger Reference," Diablo Canyon Project, Bechtel Power Corporation. Bechtel's booklet is not a bad document. Although there are a few minor errors, it describes a reasonable design control and quality assurance (QA) program.

Unfortunately it was not issued on-site before I left. I obtained a copy before distribution was stopped. I can understand why Bechtel didn't want the booklet released. The plant wasn't built at all like the system described in Bechtel's own handbook. The handbook will be discussed in more detail below.

(1) In reply to PG&E's letters no. DCL-84-067 and no. DCL-84-078 concerning welding of A-325 bolts. PG&E contends that "10 supports were identified which used welded A-325 bolt design." That is highly misleading. In reality, there are many more cases where bolts have been used.

Because of inadequate documentation, welded bolts have been used and it is impossible to say whether they are A-325 or A-307 or anything else. Even QA Personnel concedes not knowing. In two specific cases, for which I can provide the support numbers, undocumented bolts were used to connect support members to structural steel.

In my opinion, PG&E's reply is so far from complete that it does not provide accurate information to the NRC concerning the use of A-325, A-307 or other bolts. The two specific supports do not even have a weld symbol describing how they were welded on the drawings. The QA inspector was not able to visually inspect the connection.

(2) A second illustration of deficient documentation for welding bolts is inadequate material traceability. Material was not stamped for traceability back to the Certificates of Compliance as required. The significance of stamping for traceability is that without this traceability there existed no methodology to ensure that the material used in many hangers, or other seismic class one structures, complied with the requirements (e.g., proper metallurgical properties).

In ANSI B31.7 chapter 10723, entitled "Materials," it is stated that "all material shall be clearly identified" by "the applicable material specification and grade, heat number, or heat code of the material, and any additional markings required to facilitate traceability of the reports of the results of all tests and examinations performed on the material." ANSI B31.7 also states that "Certificate of Compliance with the material specifications may be provided in lieu of Certified Material Test Reports unless otherwise required by the design specification." (Emphasis added)

Material traceability is only one aspect of the required traceability. In ANSI B31.7 Para. 1-727.5.3 and Para. 1-727.6, weld traceability is also required. "The welder or welding operator shall identify it as his work by applying his assigned symbol for permanent record in a manner specified by his employer. As an alternative, the employer shall keep a record of the joints and of the welders working the joints." This is also true under ASME Section IX QW-301.3, entitled "Identification of Welders and Welding Operations," which states: "Each qualified welder and welding operator shall be assigned an identifying number, letter, or symbol by the manufacturer or contractor, which shall be used to identify the work of that welder or welding operator."

In discussions with Pre-inspection Engineers, QC and QA inspectors, some of whom have worked for as long as ten years at Diablo, it is obvious that neither material nor welder traceability was maintained. All that was required was that the "Certificate of Compliance" be provided. This superficial attempt to comply with the requirements of ANSI B31.7 and ASME Section IX does not satisfy the code requirements. This is evidenced by past and present industry practice at other plants across the United States. The abuse of traceability destroys the foundation of a valid Quality Control Program -- accountability and traceability.

Since many of the pre-inspection engineers and QC, QA personnel have never before Diablo worked at a nuclear plant nor other heavy industry construction site nor read ANSI B31.1, B31.7 or ASME Section IX, they worked at Diablo under the false assumption that the work was being performed correctly, and that management was implementing all the necessary directives for them to do their work. Management did not train personnel, nor did they correct this misconception.

Having worked on other nuclear plants, I know the importance of these sections in ANSI B31.7 and ASME Section IX. At other plants almost everything in Class I systems was stamped and logged, and records were kept to insure that traceability was maintained. Per B31.7, "The marking or marking code shall be transferred to all pieces when material is cut to make more than one piece." In my experience at other plants, this was required for all Class I material except miscellaneous material, such as "gaskets, packing, seals, springs, bearings, retaining rings, washers, fluids for hangers, etc." This was not done at Diablo Canyon. The practice of using "non traceable" steel was widespread throughout the plant. At other plants shim stock was not required to be stamped, and I suppose shim stock was considered to be "etc."

B31.7 states in the case of miscellaneous items that "A list of such materials shall be furnished, and such materials do not require certified materials test reports or certificates of compliance as defined in 1-723.1.2." (Emphasis added) Management at Diablo Canyon have failed to provide the chain of documentation which is necessary under 10 C.F.R. 50 before the plant can be operational. Not only did they fail to provide an "up-to-date heat number log," but also failed to publish a list of material that did not have to meet the scrutiny of ANSI B31.7.

(3) Deficient training reinforced the problems, and perpetuated them. QA inspectors told me that their training consisted of reading ESD 223 for one week and being given a list of suggested reading. This list contained B31.7, B-31.1 and other codes. In one conversation, when I asked if the QC inspectors were required to read the suggested readings, his reply was "no, we only had to know what B31.7 was, not what it says." "I and others thought that these codes had been incorporated into ESD 223 by management." This was, and remains, a wrong assumption. The inspectors undoubtedly performed to the best of their




ability. However, the instruction, training, and practices necessary to adequately perform their functions were deficient. The inspectors only discovered their "wrong beliefs" through discussions with better trained, more experienced inspectors from companies other than PG&E.


(4) In letter no. DCL-84-094, PG&E states, "Pipe support number 100-111, identified for NRC review by Mr. C. Stokes, resulted in a minor modification . . . This change was made for consistency with Project Standard Practices even though analysis showed the change was not necessary to meet acceptance criteria."

I don't know if PG&E reported other modifications performed during the hot functional testing to the NRC. I do know of at least one other support which was modified during hot functional testing. I can not give the support number here. My informant would be immediately on the "firing" line. I will supply the support number to NRC inspector Isa Yin, if the NRC supplies a list of supports to me for which they know modifications have been performed.

(5) In PG&E's answer to the intervenor's motion to reopen licensing issues on Construction Quality Assurance, "Affidavit of D.A. Rockwell, L.R. Wilson," Paragraph 3 states in part: "Since this contact is provided by the plate of the clamp to the Unistrut, the plate is not necessarily horizontal and may appear 'cockeyed.'" This statement is too incomplete to be meaningful. The use of the term "cockeyed" is not explained or supported nearly enough to support any conclusion that the clamping plates were correctly installed. If incorrectly installed, the clamp will tend to slip off the structural steel to which it is attached. See sketches below of correct installation compared to incorrect installation.



Correct. Notice Line contact at toe and heel of plate. When bolt is torqued properly, clamp should not be easily displaced.



Incorrect. Line contact but not at toe. When torqued, this tends to slip off the steel marker.

In both the examples above, the plate is "cockeyed." One is correct, and if installed correctly, should not be easily moved. On the other hand, the incorrect installation could slip easily. This fact can be checked by consulting engineering manuals from either Unistrut, Superstrut, or other brand names.

(6) In paragraph 5 as a remedy for possible slipping, PG&E states, "For support type S221, U-bolts were torqued and U-bolt nuts tack welded. For other support types, the Unistrut channel was directly welded to the beam flange." (Emphasis added) Based on my experience in the nuclear industry, the proposed fix by PG&E/Foley would do more damage than good. To my knowledge, there are no engineering documents presently available or in use that support the practice of welding Unistrut or similar material. In fact, the material type used in making "Superstrut" and similar products should not be welded. In a phone call on 3/27/84 with a Superstrut Product Engineer, I was told that Superstrut is coated with an electro-plated galvanized chromate coating (an epoxy paint) which burns when welded, giving off toxic gases. Two problems result from welding it. (1) Air quality problems for the welder and (2) the joint corrodes. The Product Engineer said he would never

advise that Superstrut be welded when used as Class I supports in a nuclear plant near the ocean. He said that the material could be destroyed in one year if exposed to adverse conditions.

(7) In reply to intervenor's Petition to reopen Construction Quality Assurance, Affidavit of H.R. Arnold, F.C. Breismesiter and R.K. Rhodes Paragraph 6. "During a planned review of existing brazing procedures for copper and stainless steel by Foley QA Personnel in September 1981, it could not be verified that stainless steel tubing PBS number MD045 had been qualified in all braze flow positions (vertical-up, vertical-down, horizontal and flat) since the procedure qualification tests performed in 1977 did not include the vertical-up flow position. This variation was properly documented on Foley Non-Conformance Report (NCR) #8802-675 in accordance with approved procedures." (Emphasis added) The statement quoted above is in direct contradiction to the first line in Para. 1 and line, Page 1. "This allegation is completely false. The procedures in question were qualified prior to their use." (Emphasis added) To correct this problem, one worker was tested. Under ANSI B31.7 and ASME Section IX, each welder must be qualified to perform the work to which he is assigned. Foley's solution does not correct the use of the procedure from 1977 to 1981 for brazing a vertical-up joint as was originally stated in the procedure. Nor does it resolve the issue as to whether the brazers before 1977 were qualified to perform work. The test of one worker does not satisfy ASME requirements that each worker be qualified unless the worker tested was the only person on-site who was assigned the brazing work. Nor do the present tests qualify old work, since past work could be considered training thus not qualifying as acceptable work. ASME Section IX requires that the welder be qualified first before work is performed. There is a reason for this,

which is to ensure that the work is performed correctly. The other point not sufficiently covered in Foley's reply is that "Neither the ASME Code nor Foley procedures require documentation of these inspections. Therefore none were documented." Nor in the statement that "ASME Section IX recognizes the function of independent mechanical test contractors such as Central Coast Lab, and does not require them to witness the actual brazing." (Paragraph 3, page 6 and 7) This is an example of Management's near-sightedness. Can they say that this documentation is not required in B31.1, B31.7, ASME Section IX, AWS D1.1-79 or 10 C.F.R? From my previous experience in the nuclear industry, it has been the practice to test and document results therefrom for welders. This would certify that the weld was made by the specific welder and that the test results were for the welds performed by that individual. These logs and records were controlled and monitored by the QA. The policies at Diablo by PG&E, Pullman, and Foley are at the opposite end of the scale from what has been typical industry practice. Where documentation was in question, other plant owners considered it good engineering practice and a good policy to go ahead and provide documentation to prevent the problem of a future question. At Diablo, just the opposite is true.

(8) In a discussion with a friend, I was shown a Discrepancy Report written against Unit #2. This document listed many anchor and smaller supports which did not have acceptable full penetration welds at the stantion to pipe and were to be reworked. The problem with this work was that there had been no process sheets issued for the removal nor had the pipe been ultrasonically tested to ensure that the minimum wall remained after grinding away the old material. The new stanchions were installed without an ultrasonic test (UT) being performed. The tests were performed seven months later. Per ASME Section IX and ANSI B31.7, the ultrasonic testing should have been conducted

at the time after removal and before new stanshions were welded in place. When ultrasonically testing this type of joint, incorrect readings are possible.

A worker who was familiar with this Discrepancy Report (DR) on Unit 2 realized the same problem might have occurred on Unit 1. I was shown a copy of a Preliminary Discrepancy Report listing about 15 supports in Unit 1 which the worker had determined had the same problem as the Unit 2 problem narrated above. I can supply the DR number on Unit 2 and the author of the Unit 1 DR. This will be suppld under similar conditions listed on a previous issue to Isa Yin.

(9) In closing and as the only exhibit to this affidavit, I have a copy of a document which was scheduled to be issued to all field engineers to aid them in their work at Diablo. It was prepared by Bechtel Power Corporation. The title of this document is Field Engineer Pocket Hanger Reference. This document was sent to the field for issuing, but was recalled under the excuse that it contained errors which needed to be corrected. I and other engineers at Diablo had copies of this document. It contains valuable information to which an engineer could refer and rely upon during his work. In truth, this document represents Bechtel policy at previous jobs. Much of it is in direct contradiction to the procedures used to build Diablo. Had it been issued many problems would have surfaced in a relatively short time. Why is this true? The document puts at finger tip location contradictory guides, providing typical industry practice in many areas, to the procedures and management directives issued at Diablo. There are minor errors in this document. However, I have reviewed it and have found it to be a valuable and handy document to have when working in the field. It should have been checked, corrected, issued and used.

Enclosed are pages 1-10 and 1-11, "Notes: Pipe Insulation Chart." In reading these two pages several points are evident which were not complied with at Diablo: (1) vapor barrier requirements; and (2) the application of a double layer of insulation on high thermal lines. In PG&E's answers to the staff concerning stress walkdown, they tried to explain away interferences by local crushing of calcium silicate. Note, this is not acceptable on Page 1-10.

Also enclosed is a copy of page 1-13, "Insulation Removal Request Flow Chart" and page 1-14, "Request for Insulation Removal." I am not aware of either of these procedures being followed at Diablo.

Also enclosed is a copy of Section 7, "Welding Instruction." On page 7-2, item 15, it is stated that there are no dihedral angle limitations for skewed T-joints. I feel this policy will cause problems by design personnel failing to consider welds shown as fillet as partial penetration groove welds unless a note specifically stated that it should be considered otherwise. I personally know many engineers will assume a fully effective throat for any weld indicated as a fillet. I suggest a test at site on this point before a decision is made on how to represent a skewed T-joint.

Also on page 7-5, see "attachment I." Either I don't understand this table or no allowance was added for the throat deduction for inadequate penetration. This last conclusion was also that of a pre-inspect engineer at Diablo Canyon.

Lastly, on pages 7-7 thru 7-10, I would like to point out the concise clarification of weld symbol terminology. Had this part of the book been in effect at Diablo, many questions would have been resolved (although many

other questionable practices would have become evident to many field personnel).

I have read the above 11-page statement and it is true and correct to the best of my knowledge and belief.

---

Charles Stokes

# CCS


## Field Engineer Pocket Hanger Reference

Diablo Canyon Project

Bechtel Power Corporation

1983

*BEAM*



### KEY PLAN ELEVATION

TURBINE BUILDING EL.	AUXILIARY BUILDING EL.	CONTAINMENT BUILDING EL.
GROUND LEVEL ACCESS 88'-0"	GROUND LEVEL ACCESS 88'-0"	LOWER LEVEL FLOOR 81'-0"
104'-0"	100'-0"	ANNULUS STEEL 101'-0"
118'-0"	115'-0"	ANNULUS STEEL 108'-0"
TURBINE DECK 140'-0"	FUEL ROD CLEANING ROOM 129'-0"	117'-0"
	CONTROL ROOM 140'-0"	CONTAINMENT ACCESS 140'-0"

### COLUMN LINE SCHEDULE

LINE	DIST. (PL. #)	TOT. (PL. #)	LINE (PL. #)	DIST. (PL. #)	TOT. (PL. #)	LINE (PL. #)	DIST. (PL. #)	SM/TOT. (PL. #)	TOT. (PL. #)
A	0	0	1	0	0	10	0	0	371.00
B	24-10	24-10	2	10-00	10-00	10	27-20	27-20	380-4
C	15-0	39-10	2	15-0	35-00	20	27-20	34-00	425-70
D	30-0	69-4	4	10-0	51-00	20	4-00	55-0	430-00
E	20-0	89-10	5	25-0	76-00	21	22-00	81-00	462-100
F	21-0	110-10	6	21-0	107-00	22	27-20	100-1	480-10
G	10-10	120-0	6 <sup>1</sup>	12-0	120-00	22	3-0	110-0	477-00
H	0-2	142-10	7	15-0	135-00	20	20-2	105-7	513-70
J	17-0	160-0	8	13-0	162-100	20	11-7	150-2	529-20
K	25-0	185-0	9	27-20	190-2	20	0-0	190-0	521-00
L	27-0	212-10	9 <sup>1</sup>	7-100	190-00	20	10-10	190-4	551-00
M	25-0	237-10	10	2-0	190-00	20	3-0	193-0	561-00
N	30-0	267-4	10 <sup>1</sup>	10-10	210-00	27	7-100	196-100	581-170
O	30-0	297-4	11	0-0	210-100	20	27-20	210-2	600-20
T	30-0	310-4	12	11-7	220-00	20	17-0	230-0	600-00
V	30-0	340-4	13	20-2	250-70	20	10-0	251-0	627-00
V	30-0	370-4	14	3-0	267-110	20	13-0	260-0	650-00
			15	27-20	290-3	21	21-0	290-0	680-00
			16 <sup>1</sup>	22-00	312-00	27	25-0	310-0	680-00
			16	4-00	310-00	20	10-0	320-0	700-00
			17	27-20	342-00	24	10-0	352-0	723-00
			18	27-20	371-00	20	10-100	371-00	742-0



① LINE NUMBER	② LINE DESIGNATION	③ LINE SIZE (IN)	④ LINE WEIGHT (LB)	⑤ LINE MATERIAL	⑥ LINE SCHEDULE	⑦ LINE TYPE	⑧ DESIGN CLASS		⑨ SERVICE	
							PG&E	ASME	CLASS	GROUP
101	H-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
102	H-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
103	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
104	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
105	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
106	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
107	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
108	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
109	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0
110	B-101 - NEW MAIN TO B-101	24	43.0	SA-312	10S	100	A	0	100	0

SPECIFICATION/PIPE SCHEDULE CONVERSION

NOMINAL PIPE SIZE	CLASS 100 SCHED 40	CLASS 150 SCHED 40	CLASS 100 SCHED 40			CLASS 150 SCHED 40			CLASS 100 SCHED 40	CLASS 150 SCHED 40	CLASS 200 SCHED 40
			10S	10S	10S	10S	10S	10S			
8											
9											
10											
12											
14											
16											
18											
20											
24											
30											
36											
42											
48											
54											
60											
72											
84											
96											
108											
120											
144											
168											
192											
216											
240											
288											
336											
384											
432											
480											
528											
576											
624											
672											
720											

PG&E DESIGN CLASS SYMBOLS

- A - DESIGN TO ANSI B31.1-1967; MATERIAL, N.D.E., FABRICATION AND ERECTION TO ANSI B31.7 CLASS I-1968 EDITION PLUS 1970 ADD., PG&E DESIGN CLASS I
- B - ANSI B31.7 CLASS II, 1968 EDITION PLUS 1970 ADD., PG&E DESIGN CLASS I
- C - ANSI B31.7 CLASS III, 1968 EDITION PLUS 1970 ADD., PG&E DESIGN CLASS I
- E - ANSI B31.1-1967, PG&E DESIGN CLASS II
- E1 - CLASS E, MODIFIED TO REQUIRE "FILE-44" - DESIGN EARTHQUAKE ANALYSIS
- 6 - NFPA; ALSO COMPLIES WITH ANSI B31.1
- 61 - NFPA STANDARDS, PG&E DESIGN CLASS II (19 CFR 50 APPENDIX B QUALITY ASSURANCE PROVISION APPLIES TO THIS PG&E DESIGN CLASS II SYSTEM)
- 6 - DESIGN TO ANSI B31.1-1967, FABRICATION, ERECTION AND INSPECTION TO ASME BOILER AND PRESSURE VESSEL CODE SECTION I, 1968 EDITION, PG&E DESIGN CLASS I. (EXCEPTION: LINES No. 1 THROUGH No. 12 AND No. 18 ARE DESIGNED TO THE 1955 EDITION OF ANSI B31.1 AND APPLICABLE NUCLEAR CODE CASES.)

① LINE NUMBER: 01-1000, 02-1000, 03-1000, 04-1000, 05-1000, 06-1000, 07-1000, 08-1000, 09-1000, 10-1000, 11-1000, 12-1000, 13-1000, 14-1000, 15-1000, 16-1000, 17-1000, 18-1000, 19-1000, 20-1000, 21-1000, 22-1000, 23-1000, 24-1000, 25-1000, 26-1000, 27-1000, 28-1000, 29-1000, 30-1000, 31-1000, 32-1000, 33-1000, 34-1000, 35-1000, 36-1000, 37-1000, 38-1000, 39-1000, 40-1000, 41-1000, 42-1000, 43-1000, 44-1000, 45-1000, 46-1000, 47-1000, 48-1000, 49-1000, 50-1000, 51-1000, 52-1000, 53-1000, 54-1000, 55-1000, 56-1000, 57-1000, 58-1000, 59-1000, 60-1000, 61-1000, 62-1000, 63-1000, 64-1000, 65-1000, 66-1000, 67-1000, 68-1000, 69-1000, 70-1000, 71-1000, 72-1000, 73-1000, 74-1000, 75-1000, 76-1000, 77-1000, 78-1000, 79-1000, 80-1000, 81-1000, 82-1000, 83-1000, 84-1000, 85-1000, 86-1000, 87-1000, 88-1000, 89-1000, 90-1000, 91-1000, 92-1000, 93-1000, 94-1000, 95-1000, 96-1000, 97-1000, 98-1000, 99-1000, 100-1000.

NOTES: PIPE INSULATION CHART

Fittings and valves are normally insulated with pre-formed sections of the same material as used on the pipe. However segmental blocks are sometimes used by wiring them on the fitting or valve and filling the gaps with asbestos cement.

Many and varied types of jackets for insulation are available. Some of these are: canvas, asphalt-saturated asbestos felt, plastic-impregnated asbestos felt, thin gage sections of galvanized steel, and integral or separate jackets of aluminum alloy or stainless steel.

The selection of the type of jacket to be used should be made with due consideration given to the following: amount of abrasion and mechanical abuse to be encountered, weather protection for outdoor installations, fire proofing, vapor barrier requirements, cost of application, and last but not least the finished appearance.

Most insulation failures are caused by water entering through breaks in the finish, such as expansion cracks, or un-flashed openings, therefore, particular attention should be given to complete detailed specifications in regard to weatherproofing.

The usual insulating materials and jackets for heated piping and equipment allow the moisture to escape in the form of vapor. However in the medium temperature range, and where shut-downs are frequent, moisture in the insulation is not driven off and water damage is most likely to occur. For these conditions, the insulation should be thoroughly dry before applying the jacket, the surface of the pipe should be primed and painted, and corrosion-restraint wire or bands used for securing the insulation. If possible, insulation should be applied to high temperature piping while heated to insure the complete dryness of the completed installation.

The layout of insulated piping and equipment should provide adequate clearances for proper application of the insulation and also safeguard against mechanical damage during normal operation and maintenance.

Thicknesses, as shown are nominal. Actual thicknesses, which are based on "simplified thicknesses," will vary slightly from nominal in that the outer diameters of the insulation approximate the diameters of iron pipe sizes in order to obtain nesting of layers.

Weights, as shown, are for actual thicknesses and are based on densities of 11 pounds per cubic foot for 85% magnesia and calcium silicate, and 21 pounds per cubic foot for diatomaceous earth (calcined diatomaceous silica and asbestos fiber). Weights for materials with different densities may be proportioned accordingly.

At temperatures above 600°F, pipe expansion is a significant factor. For best results pipe insulation should be applied in double layers with staggered joints for all operating temperatures above 600°F. This construction prevents excessive heat losses and surface temperatures at the joints, opened by pipe expansion, thus eliminating scorched or burned jackets. This construction also eliminates the potential fire hazard of exposing jackets to higher temperatures at the joint. Double-layer, staggered-joint construction also minimizes thermal stresses in the insulation by reducing the temperature differential across each layer.

The recommended thicknesses in the above table are calculated on an economic basis for heat conservation under average operating conditions for steam generation and process piping, and assure adequate temperature control. To determine the most economical thickness for any particular installation the cost of fuel, fixed charges, need for definite temperature control, or other special conditions must be considered. If necessary, insulation thickness can be increased.

Generally, pipe insulation is furnished in 3-foot half sections for pipe sizes up to 24-inch in calcium silicate and up to 14-inch pipe size for 85 percent magnesia and diatomaceous earth. Insulation for pipe sizes larger than those mentioned is usually furnished in 3-foot long segments or curved blocks.

LINE DESIGNATIONS (NOTES 1 THROUGH 10)

- ① 1/2" DIA. - 1000 FT. LONG
- ② 1/2" DIA. - 1000 FT. LONG
- ③ 1/2" DIA. - 1000 FT. LONG
- ④ 1/2" DIA. - 1000 FT. LONG
- ⑤ 1/2" DIA. - 1000 FT. LONG
- ⑥ 1/2" DIA. - 1000 FT. LONG
- ⑦ 1/2" DIA. - 1000 FT. LONG
- ⑧ 1/2" DIA. - 1000 FT. LONG
- ⑨ 1/2" DIA. - 1000 FT. LONG
- ⑩ 1/2" DIA. - 1000 FT. LONG



LINE DESIGNATIONS (ADDITIONAL NOTES)

- 1. INSULATION TYPE - 85% MAGNESIA AND CALCIUM SILICATE
- 2. INSULATION TYPE - DIATOMACEOUS EARTH
- 3. INSULATION TYPE - ASPHALT-SATURATED ASBESTOS FELT
- 4. INSULATION TYPE - CANVAS
- 5. INSULATION TYPE - GALVANIZED STEEL
- 6. INSULATION TYPE - STAINLESS STEEL
- 7. INSULATION TYPE - ALUMINUM ALLOY
- 8. INSULATION TYPE - ASPHALT CEMENT
- 9. INSULATION TYPE - ASPHALT CEMENT AND ASPHALT CEMENT
- 10. INSULATION TYPE - ASPHALT CEMENT AND ASPHALT CEMENT

APPENDIX E OF DCM 888


TYPE OF INSULATION		APPROVAL		
CLASS	NO.	BY	DATE	NO.
1	...	...	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...
8	...	...	...	...
9	...	...	...	...
10	...	...	...	...
11	...	...	...	...
12	...	...	...	...

CLASS 1 MECH INSUL  
CLASS 2 MECH INSUL  
CLASS 3 MECH INSUL  
CLASS 4 MECH INSUL  
CLASS 5 MECH INSUL  
CLASS 6 MECH INSUL  
CLASS 7 MECH INSUL  
CLASS 8 MECH INSUL  
CLASS 9 MECH INSUL  
CLASS 10 MECH INSUL  
CLASS 11 MECH INSUL  
CLASS 12 MECH INSUL

1 THE CLASS 1, 2 AND 3 INSULATION REMOVAL SHALL BE MADE FOR CLASSIFICATION TO BE MADE BY THE INSULATION WORKER.  
2 THE CLASS 4, 5 AND 6 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
3 THE CLASS 7, 8 AND 9 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
4 THE CLASS 10, 11 AND 12 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
5 THE CLASS 13 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
6 THE CLASS 14 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
7 THE CLASS 15 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
8 THE CLASS 16 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
9 THE CLASS 17 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
10 THE CLASS 18 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
11 THE CLASS 19 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.  
12 THE CLASS 20 INSULATION REMOVAL SHALL BE MADE BY THE INSULATION WORKER.

1-12

INSULATION REMOVAL REQUEST FLOW CHART



REQUEST FOR INSULATION REMOVAL

REQUEST NO. \_\_\_\_\_

CLASS \_\_\_\_\_ LINE NO. \_\_\_\_\_

DATE \_\_\_\_\_

BY \_\_\_\_\_

CLASS 1 MECH INSUL \_\_\_\_\_

CLASS 2 MECH INSUL \_\_\_\_\_

CLASS 3 MECH INSUL \_\_\_\_\_

CLASS 4 MECH INSUL \_\_\_\_\_

CLASS 5 MECH INSUL \_\_\_\_\_

CLASS 6 MECH INSUL \_\_\_\_\_

CLASS 7 MECH INSUL \_\_\_\_\_

CLASS 8 MECH INSUL \_\_\_\_\_


CLASS 9 MECH INSUL \_\_\_\_\_

CLASS 10 MECH INSUL \_\_\_\_\_

CLASS 11 MECH INSUL \_\_\_\_\_

CLASS 12 MECH INSUL \_\_\_\_\_

1-13



CLASS \_\_\_\_\_

LINE NO. \_\_\_\_\_

DATE \_\_\_\_\_

BY \_\_\_\_\_

CLASS 1 MECH INSUL \_\_\_\_\_

CLASS 2 MECH INSUL \_\_\_\_\_

CLASS 3 MECH INSUL \_\_\_\_\_

CLASS 4 MECH INSUL \_\_\_\_\_

CLASS 5 MECH INSUL \_\_\_\_\_

CLASS 6 MECH INSUL \_\_\_\_\_

CLASS 7 MECH INSUL \_\_\_\_\_

CLASS 8 MECH INSUL \_\_\_\_\_

CLASS 9 MECH INSUL \_\_\_\_\_

CLASS 10 MECH INSUL \_\_\_\_\_

CLASS 11 MECH INSUL \_\_\_\_\_

CLASS 12 MECH INSUL \_\_\_\_\_

RELEASED FOR REMOVAL & LOGGED \_\_\_\_\_ DATE \_\_\_\_\_ BY \_\_\_\_\_

ELECTRICAL HEAT TRACE INSPECTOR \_\_\_\_\_ DATE \_\_\_\_\_ BY \_\_\_\_\_

MECHANICAL INSULATION INSPECTOR \_\_\_\_\_ DATE \_\_\_\_\_ BY \_\_\_\_\_

MECHANICAL INSULATION INSPECTOR \_\_\_\_\_ DATE \_\_\_\_\_ BY \_\_\_\_\_

INSULATION FOREMAN COMPLETED \_\_\_\_\_ DATE \_\_\_\_\_ BY \_\_\_\_\_

8-8-88 1-13-88

WELDING INSTRUCTIONS  
(EXCEPTED FROM ESD-223 REV. 7)

- 1 WELDS SHALL NOT BE PEENED.
- 2 FULL PENETRATION WELDS SHALL BE FIT IN ACCORDANCE WITH THE WELD PROCEDURES DESIGNATED BY THE FIELD ENGINEER. ROOT OPENINGS USING BACKING STRAPS SHOULD BE  $1/4"$  PLUS OR MINUS  $1/16"$ . ROOT OPENING REQUIREMENTS FOR STAIN WELD PROCEDURES ARE  $1/8"$  PLUS OR MINUS  $1/32"$ .
- 3 PARTIAL PENETRATION GROOVE WELDS SHALL BE FIT IN ACCORDANCE WITH THE WELD PROCEDURE DESIGNATED BY THE FIELD ENGINEER. THE JOINT SHALL BE BROUGHT INTO AS CLOSE CONTACT AS POSSIBLE. THE GAP BETWEEN PARTS SHALL NOT EXCEED  $3/16"$ .
- 4 SQUARE GROOVE WELDS SHALL BE FIT IN ACCORDANCE WITH THE WELD PROCEDURE DESIGNATED BY THE FIELD ENGINEER. ROOT OPENING SHALL BE  $0"$  TO  $1/16"$  MAXIMUM.
- 5 FILLET WELDS SHALL BE FIT IN ACCORDANCE WITH THE WELD PROCEDURE DESIGNATED BY THE FIELD ENGINEER. PARTS TO BE JOINED SHALL BE BROUGHT INTO AS CLOSE CONTACT AS POSSIBLE. NO PACKING, SHIMMING, OR WELDING WILL BE PERMITTED TO CORRECT POOR FIT-UP OF JOINTS. IF THE SEPARATION IS  $1/16"$  OR GREATER, THE LEG OF THE FILLET SHALL BE INCREASED BY THE AMOUNT OF THE SEPARATION. THE GAP SHALL NOT EXCEED  $3/32"$ .
- 6 ALL MEMBERS SHALL BE VISUALLY PLUMB, TRUE TO LINE, AND SUBSTANTIALLY FREE FROM BENDS, TWISTS, OR EXCESSIVE GAPS.
- 7 ALL WELD PREPARATION SURFACES SHALL BE FREE FROM FOUNDRY OR MILL SCALE, OIL, RUST, SAND, SLAG, PAINT, AND ANY TYPE OF SURFACE OXIDE OR DIRT.
- 8 WELD PREPARATION SHALL BE SMOOTH AND UNIFORM. IF WELD PREPARATIONS ARE FORMED BY FLAME CUTTING, THEY SHALL BE GROUND AND DRESSED BEFORE WELDING.
- 9 UNDERCUT, EXTENDING THE LENGTH OF THE WELD, SHALL NOT EXCEED  $1/32"$  IN DEPTH. LOCAL UNDERCUT SHALL NOT EXCEED  $1/16"$  WHEN THE LENGTH OF A LOCAL UNDERCUT AREA DOES NOT EXCEED  $1/2"$  IN ANY  $6"$  LENGTH OF WELD.
- 10 FOR GROOVE AND FILLET WELDS, THE SUM OF THE DIAMETERS OF POROSITY SHALL NOT EXCEED  $3/8"$  IN ANY LINEAR INCH OF WELD AND SHALL NOT EXCEED  $3/4"$  IN ANY  $12"$  LENGTH OF WELD.
- 11 WINDOR ARC STRIKES ON SUPPORT MEMBERS SHALL BE MINORIZED. SERIOUS ARC STRIKES ON SUPPORT MEMBERS SHALL BE REMOVED AND/OR REPAIRED PRIOR TO QC ACCEPTANCE. NO ARC STRIKES ON PIPE SHALL BE PERMITTED. ARC STRIKES ON PIPE AND SEISMIC LIMITERS SHALL BE REPORTED ON A DEFICIENT CONDITION NOTICE FOR DISPOSITION PER ESD-260.
- 12 THE FILLET WELD SIZE SHALL BE AS SPECIFIED ON THE DRAWING. WHERE THE SIZE IS NOT SPECIFIED, THE FILLET SHALL BE OF THE SAME SIZE AS THE THICKNESS OF THE THINNER OF THE TWO MEMBERS BEING JOINED. AS-BUILT IS REQUIRED TO SHOW WELD SIZE.

- 13 OVERWELD: FOR EXISTING WELDS ANY AMOUNT OF OVERWELD IS ACCEPTABLE, PROVIDED DISTORTION IS NOT EXCESSIVE. FOR NEW WELDS THE MAXIMUM OVERWELD SHALL BE 50 PERCENT OR  $1/8"$ , WHICHEVER IS GREATER, PROVIDED THAT DISTORTION IS NOT EXCESSIVE. (SEE PARAGRAPH 9.8.2.4.A.) AS-BUILT IS NOT REQUIRED.
  - 14 UNDERWELD: FOR EXISTING WELDS, ANY UNDERWELD IS ACCEPTABLE PROVIDED THAT THE AISC RECOMMENDED MINIMUM WELD SIZE FOR THE MATERIAL BEING WELDED IS MET. A NEW FILLET WELD IN ANY SIMILAR CONTINUOUS WELD SHALL BE PERMITTED TO UNDERWELD THE NOMINAL FILLET WELD SIZE REQUIRED BY  $1/16"$  WITHOUT CORRECTION, PROVIDED THAT THE UNDERSIZED PORTION OF THE WELD DOES NOT EXCEED 10% OF THE LENGTH OF THE WELD.
- AS-BUILT IS REQUIRED TO SHOW EXISTING WELDS WHICH ARE MORE THAN 25 PERCENT UNDERSIZED AND/OR OVERSIZED FOR MORE THAN 25 PERCENT OF THE TOTAL LENGTH OF THE WELD.

FILLET WELD SIZE TABLE

MATERIAL THICKNESS OF THINNER PART JOINED	MINIMUM SIZE OF FILLET WELD
UP TO AND INCLUDING $1/4"$	$1/8"$
OVER $1/4"$ THROUGH $1/2"$	$3/16"$
OVER $1/2"$ THROUGH $3/4"$	$1/4"$
OVER $3/4"$ THROUGH $1-1/2"$	$5/16"$
OVER $1-1/2"$ THROUGH $2-1/4"$	$3/8"$
OVER $2-1/4"$ THROUGH $6"$	$1/2"$
OVER $6"$	$5/8"$

15 FILLET WELDS ON SKEWED T-JOINTS

- THERE ARE NO BIDIAGONAL ANGLE LIMITATIONS
- THE SIZE OF FILLET WELDS ON SKEWED T-JOINTS SHALL BE DETERMINED BY MEASURING THE NOMINAL LEG, AS FOLLOWS:




V = NOMINAL WELD LEG

WELD SURFACES MUST BE FLAT OR CONVEY.

16 PARTIAL PENETRATION WELDS

- WHEN VERIFYING THE SIZE OF PARTIAL PENETRATION BEVEL WELDS, THE FACE MUST BE AT LEAST FLUSH WITH THE FACE OF THE BEVELED PIECE.
- BE FIT-UP INSPECTION IS REQUIRED ON PARTIAL PENETRATION GROOVE WELDS DESIGNED AT SKEWED T-JOINTS. THE SIZE OF PARTIAL PENETRATION GROOVE WELDS, WHICH HAVE BEEN DESIGNED TO BE INSTALLED AT SKEWED T-JOINTS, SHALL BE DETERMINED BY MEASURING THE FACE OF THE WELD, AS FOLLOWS:



V = NOMINAL WELD LEG

S = SPECIFIED SIZE

USE V MINIMUM IN DETERMINING WELD SIZE.

THE ACCEPTABILITY OF THE WELD SIZE SHALL BE DETERMINED BY USING THE CHART IN ATTACHMENT I.

17 FLARE-BEVEL WELDS WHICH ARE FORMED BY AT LEAST ONE PIECE OF TUBE STEEL SHALL HAVE THE SIZE DETERMINED AS FOLLOWS:

- WHEN NO SIZE IS SPECIFIED ON THE DRAWING, THE FACE OF THE WELD SHALL BE AT LEAST FLUSH WITH THE FACE OF THE TUBE STEEL BEING WELDED
- WHEN THE SIZE OF THE WELD IS SPECIFIED ON THE DRAWING, THE SIZE OF THE WELD SHALL BE DETERMINED BY MEASURING THE FACE OF THE WELD AS FOLLOWS:



V = NOMINAL WELD FACE

S = SPECIFIED SIZE

THE ACCEPTABILITY OF THE WELD SIZE SHALL BE DETERMINED BY USING THE CHART IN ATTACHMENT J.



PLATE NO. 1011 - WELDED STEEL	PLATE NO. 1012 - WELDED STEEL	PLATE NO. 1013 - WELDED STEEL	PLATE NO. 1014 - WELDED STEEL
<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>

7-10

PLATE NO. 1015 - WELDED STEEL	PLATE NO. 1016 - WELDED STEEL	PLATE NO. 1017 - WELDED STEEL	PLATE NO. 1018 - WELDED STEEL
<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>

7-8

PLATE NO. 1019 - WELDED STEEL	PLATE NO. 1020 - WELDED STEEL	PLATE NO. 1021 - WELDED STEEL	PLATE NO. 1022 - WELDED STEEL
<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>	<p><b>WELDED STEEL JOINTS - GENERAL INFORMATION</b></p> <p>Welding process: Shielded metal arc welding (SMAW)</p> <p>Electrode: E6010</p> <p>Shielding gas: None</p> <p>Preheat: None</p> <p>Post-weld heat treatment: None</p>

7-8

Meeting April 10, 1987  
NRC / C. Stokes

H. Schierling  
C. STOKES  
J. CLEWETT  
J. P. KNIGHT  
R. F. STEISHMAN  
J. BOSNAK  
B. F. SAFFELL  
K. A. MANDLY  
J. T. Yin  
M. HARTZMAN  
E. Sullivan, Jr  
C. Nelson  
F. C. Cherny  
E. M. Burns  
T. Rehm  
G. C. Ginn  
S. Ward

NRC Licensing Project Manager?  
former Diablo Canyon engineer  
GAP  
NRC/DE  
NRC IE  
NRC/DE/NEB  
Battelle Columbus Laboratories  
NRC - REGION I, Div. of Eng & Tech. programs  
NRC - R III  
NRC - DE - MEB  
NRC - DE  
TERA  
NRC/DE/MEB  
WESTINGHOUSE  
NRC  
BRETT Gaithe  
Bechtel