

# WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard  
Vice President Plant Operations

May 15, 1995

WO 95-0084

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D. C. 20555

Subject: Docket No. 50-482: April, 1995, Monthly  
Operating Report

Gentlemen:

Attached is the April, 1995, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a  
D. F. Kirsch (NRC), w/a  
J. F. Ringwald (NRC), w/a  
J. C. Stone (NRC), w/a

100006

9505190386 950430  
PDR ADDCK 05000482  
R PDR

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HC/VET

IE24  
11

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: April YEAR: 1995

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 122

## SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of April, 1995. This report is being provided pursuant to Technical Specification 6.9.1.8.

### I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power in Mode 1 for the month of April, 1995.

### II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

NONE

OPERATING DATA REPORT  
DOCKET NO. 50-482  
WOLF CREEK GENERATING STATION  
WOLF CREEK NUCLEAR OPERATING CORPORATION  
DATE 5-10-95  
TELEPHONE 316-364-8831

## OPERATING STATUS

1. Reporting Period: April, 1995 Gross Hours in Reporting Period: 719
2. Currently Authorized Power Level (Mwt): 3565 Max. Depend. Capacity (MWe-Net): 1160  
Design Electrical Rating (MWe-Net): 1170
3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
4. Reasons for Restriction (If Any): N/A

	This Month	Yr. to Date	Cumulative
5. Number of Hours Reactor was Critical	<u>719</u>	<u>2767.7</u>	<u>68,735.8</u>
6. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>339.8</u>
7. Hours Generator on Line	<u>719</u>	<u>2,744.1</u>	<u>67,898.7</u>
8. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
9. Gross Thermal Energy Generated (MWh)	<u>2,543,603</u>	<u>9,588,002</u>	<u>224,620,320</u>
10. Gross Electrical Energy Generated (MWh)	<u>885,431</u>	<u>3,328,573</u>	<u>78,092,788</u>
11. Net Electrical Energy Generated (MWh)	<u>849,034</u>	<u>3,190,443</u>	<u>74,565,117</u>
12. Reactor Service Factor	<u>100.0%</u>	<u>96.1%</u>	<u>81.2%</u>
13. Reactor Availability Factor	<u>100.0%</u>	<u>96.1%</u>	<u>81.6%</u>
14. Unit Service Factor	<u>100.0%</u>	<u>95.3%</u>	<u>80.2%</u>
15. Unit Availability Factor	<u>100.0%</u>	<u>95.3%</u>	<u>80.2%</u>
16. Unit Capacity Factor (Using MDC)	<u>101.8%</u>	<u>95.5%</u>	<u>77.7%</u>
17. Unit Capacity Factor (Using Design MWe)	<u>100.0%</u>	<u>94.7%</u>	<u>75.3%</u>
18. Unit Forced Outage Rate	<u>0.0%</u>	<u>4.7%</u>	<u>5.1%</u>
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):	<u>No outages are scheduled at this time.</u>		

20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

Wolf Creek Generating Station  
Monthly Operating Report  
April, 1995  
Page 2 of 5

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 5-10-95TELEPHONE 316-364-8831MONTH April, 1995DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1	1182
2	1182
3	1182
4	1182
5	1182
6	1173
7	1182
8	1182
9	1181
10	1182
11	1182
12	1182
13	1169
14	1180
15	1182
16	1182

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17	1182
18	1181
19	1182
20	1174
21	1181
22	1183
23	1184
24	1184
25	1183
26	1182
27	1176
28	1179
29	1183
30	1183
31	NA

## UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482  
 WOLF CREEK GENERATING STATION  
 WOLF CREEK NUCLEAR OPERATING CORPORATION  
 DATE 5-10-95  
 TELEPHONE 316-364-8831

No	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
NA	NA	NA	NA	NA	NA	NA

## SUMMARY:

The unit operated at or near 100% in Mode 1 for the month of April, 1995.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL  
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM  
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM  
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED  
 5. REDUCED LOAD  
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH April, 1995

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
NA	NA	NA