

Appendix

NOTICE OF VIOLATION

Consumers Power Company

Docket No. 50-255

As a result of the inspection conducted on December 14-17, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specification 3.9.4 requires that the liquid radioactive waste discharge monitor be in operation during any release unless the monitor (RIA-1049) is down for maintenance. If the monitor is down for maintenance, samples of the discharge water are required to be taken every four hours and each sample analyzed.

Contrary to the above, the provision for sampling every four hours has been used routinely, in lieu of maintaining the discharge monitor (RIA-1049) operable, to monitor and control liquid releases even though the discharge monitor was not down for maintenance.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

JAN 14 1983

Dated _____

Original Signed by J. R. Miller

J. R. Miller, Chief
Technical Programs Branch