



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

APR 05 1984


MEMORANDUM FOR: Darrell Eisenhut, Director  
Division of Licensing

FROM: Roger Mattson, Director  
Division of Systems Integration

SUBJECT: BOARD NOTIFICATION

The purpose of this memorandum is to request that you notify the Commission in connection with the Indian Point Hearing and any other licensing boards associated with severe accident considerations in PWRs of new and possibly relevant information which has recently come to our attention. A description of this information is provided in the enclosure.

The staff is evaluating this information to determine its safety significance and relevance. In particular, we are evaluating how the new information affects our assessments of risk associated with core melt and early containment failure. We anticipate completing our evaluation within several months, depending on the extent of analysis necessary.

  
Roger J. Mattson, Director  
Division of Systems Integration

Enclosure:  
As stated

cc:

H. Denton  
J. Stolz  
D. Eisenhut  
R. Vollmer  
R. Minogue, RES  
O. Bassett, RES  
D. Ross, RES  
F. Rowsome  
J. Moore, ELD

8404190213 840416  
PDR COMMS NRCC  
CORRESPONDENCE PDR

## ENCLOSURE

### BACKGROUND


Under some conditions, a core melt accident may proceed with the primary system at high pressure. In such cases, the melt material might be dispersed into the containment due to high pressure ejection of the melt from the reactor vessel. The sequence is typified by Figure 1.

The range of possible containment response in terms of melt location, chemical reaction, particle size, and atmospheric heating has not been well established. An experimental investigation is ongoing at the Sandia National Laboratories to study molten core debris interaction with reactor cavity configurations. The program objectives include confirmation of debris dispersal mechanisms; assessment of melt jet geometry, gas solubility and aerosol generation; assessment of melt-concrete water interaction and synergistic effects.

The staff was recently informed of test results by Sandia which indicate that the conditional probability of early containment failure following a core melt accident at high primary system pressure due to the rapid heating of the containment atmosphere may be higher than previously determined. The applicability of the test information has not been determined.

FIGURE 1

## HIGH PRESSURE EJECTION ACCIDENT SEQUENCE



## PROBLEM

The new test information is related to accidents in which core meltdown and vessel breach occur with the Reactor Coolant System (RCS) pressure above several hundred pounds per square inch. It has been previously hypothesized that, for this event, there would be insufficient material participating in direct heating of the containment atmosphere to seriously jeopardize a large PWR containment. In the test, a large proportion of the simulated melt was blown out of the reactor vessel cavity in a dispersed form. Rapid chemical reaction with the atmosphere occurred, which was estimated to increase the immediately available thermal energy in a nuclear melt down event by about a factor of three over what would be anticipated from sensible heat of the melt alone. The large proportion of dispersed melt caused rapid energy transfer to the atmosphere. If the test behavior were to occur in a large dry PWR containment, containment failure could potentially occur shortly after vessel failure due to short term overpressure, with the potential for an increase in predicted early health consequences as compared to what has been reported in plant PRAs and recent staff assessments. The magnitude of the health consequences would be a strong function of the specific site and evacuation model.

The test geometry was intended to simulate the vessel cavity of a W NSSS design. There was no attempt to simulate other regions of containment. The test melt, which consisted of a hot thermite mixture to simulate the molten fuel-steel-zirconium mixture, was not impeded in passing out of the vessel cavity. There are many questions related to applicability of

test information to response of a PWR containment atmosphere. These include concerns with influence of cavity scaling, influence of structure to impede flow and limit air for chemical reaction, and proto-typicality of thermite as a molten fuel simulator. Consequently, test results are not directly applicable to PWR and NSSS containment response, and conclusions must await further test evaluation, which is in progress.

Additional information is provided below in the slide copies taken from two Containment Loads Working Group meetings; the first is a Sandia presentation at EPRI, Palo Alto, CA., February 2, 1984; and the second is a Brookhaven presentation at Rockville, MD., March 13-14, 1984. The important point in the first presentation is that if most of the melt is ejected from the vessel cavity directly into the containment of a large "dry containment" PWR, the resulting chemical reaction with the containment atmosphere may lead to pressures which could fail the containment. The point of the second presentation is that the geometry of the PWR containment will probably prevent full ejection and will limit mixing of dispersed melt with the containment atmosphere, thus alleviating the concerns raised in the first presentation.


The staff is evaluating information pertinent to these phenomena and how it affects assessment of risk associated with core melt and early containment failure. This evaluation is anticipated to take several months, depending on the extent of analysis necessary.

CLWG Standard Problem  
Calculations with CONTAIN  
Surry and Zion PWR's



K. D. Bergeron  
Containment Modeling Division  
Sandia National Laboratories  
Albuquerque, NM  
February 2, 1984

# Energy Balance for Dispersed Debris Scenarios



## Issues for Direct Heating Containment Response Modeling

1. How much melt exits cavity?
2. How much mass is fragmented to a small size? ("Small" meaning that residence time exceeds time to cool.)
3. How much additional energy from chemical reactions is added?
4. Of the energy lost from fragmented material, how much goes into
  - (a) radiation to heat sinks and condensate films?
  - (b) direct heating of gas?



There is a different dependence of containment load for thermal and chemical energy heat transfer.

- Each unit of thermal energy added to direct heating reduces energy to steam generation.
- Each unit of chemical energy added to direct heating does not reduce steam generation.



# Zion Direct Heating Study

Case 7. No direct heating.  
Fast water quench

Case 9. 20% direct heating, oxidize  
only 10% of Zr, but not  
Fe or  $\text{UO}_2$

Case 11. 90% ejection; complete  
oxidation of all Zr,  
Fe,  $\text{UO}_2$



# Zion Direct Heating CONTAIN Results

Case	Peak Press <sup>a</sup> (bar)	Peak Temp °K	Thermal Energy to steam J	Energy to gas J	Chemical Energy to gas J
7	6.40	430	2.0E11	0.0	0.0
9	6.83	502	1.6E11	4.0E10	6.0E9
11	13.9	1342	1.6E10	5.9E10	2.4E11

<sup>a</sup>Pressure at vessel failure is 3.0 bar (nonadiabatic calculation)



# Surry Standard Problem

Case 12. No direct heating, but 90% ejection and water quench.

Case 13. 20% ejection and direct heating, oxidize ~~UO<sub>2</sub>~~ Zr only.

Case 14. 90% ejection; oxidize all Zr and Fe, but only 42% of UO<sub>2</sub> because of oxygen starvation.







# Preliminary Summary TALB Results (High)

Case	Peak Press. (bar)	Peak Temp (°K)	Therm Energy to Steam	Therm Energy to Gas	Chem. Energy (to Gas)	Description
12	5.6	500	1.2E11	0.0	0.0	Steam spike
13	4.8	769	1.2E10	2.4E10	2.8E10	20% ejection. Zr only
14	13.3	2114	1.2E10	1.3E10	2.1E11	90% ejected oxidized everything

Direct Heating Cases

ON DIRECT HEATING IN ZION CONTAINMENT

T. GINSBERG

BROOKHAVEN NATIONAL LABORATORY  
DEPARTMENT OF NUCLEAR ENERGY  
EXPERIMENTAL MODELING GROUP  
UPTON, NEW YORK 11973

CONTAINMENT LOADS WORKING GROUP MEETING  
ROCKVILLE, MD  
MARCH 13-14, 1984

- PERSPECTIVE
- FLOW PATHS IN ZION CONTAINMENT
- KEYWAY JET STAGNATION AND DROPLET DEPOSITION
- FLOW WITHIN STEAM GENERATOR COMPARTMENT
- SUMMARY
- RECOMMENDATIONS

## PERSPECTIVE

- CAVITY SWEEPOUT POTENTIAL UNDER HIGH-PRESSURE EJECTION HAS BEEN DEMONSTRATED BY SNL/ANL TESTS
  
- CONSERVATIVE BOUNDING CALCULATION PREDICTS EARLY ZION CONTAINMENT FAILURE
  
- MITIGATION ARGUMENTS
  - FUEL MASS EJECTED FROM VESSEL
  
  - DEPOSITION/FALLOUT DURING TRANSPORT TO CONTAINMENT DOME
  
  - RATE-LIMITED CHEMICAL REACTIONS

# FLOW PATHS IN ZION




Figure 1-1. Schematic Illustration of Zion Reactor Containment Building.




FIGURE L2-9  
 AMENDMENT 3  
 OCTOBER '72

GENERAL ARRANGEMENT  
 SECTIONS A-A & B-B  
 ZION STATION UNIT NO. 1  
 COMMONWEALTH EDISON CO.  
 CHICAGO, ILLINOIS

SARGENT & LUNDY  
 ENGINEERS  
 CHICAGO, ILLINOIS  
 DRAWING NO.  
 M-9

NO.	DATE	DESCRIPTION
1	11/15/71	ISSUED FOR CONSTRUCTION
2	1/10/72	REVISIONS
3	3/15/72	REVISIONS
4	5/15/72	REVISIONS
5	7/15/72	REVISIONS
6	9/15/72	REVISIONS
7	11/15/72	REVISIONS
8	1/15/73	REVISIONS
9	3/15/73	REVISIONS
10	5/15/73	REVISIONS
11	7/15/73	REVISIONS
12	9/15/73	REVISIONS
13	11/15/73	REVISIONS
14	1/15/74	REVISIONS
15	3/15/74	REVISIONS
16	5/15/74	REVISIONS
17	7/15/74	REVISIONS
18	9/15/74	REVISIONS
19	11/15/74	REVISIONS
20	1/15/75	REVISIONS
21	3/15/75	REVISIONS
22	5/15/75	REVISIONS
23	7/15/75	REVISIONS
24	9/15/75	REVISIONS
25	11/15/75	REVISIONS
26	1/15/76	REVISIONS
27	3/15/76	REVISIONS
28	5/15/76	REVISIONS
29	7/15/76	REVISIONS
30	9/15/76	REVISIONS
31	11/15/76	REVISIONS
32	1/15/77	REVISIONS
33	3/15/77	REVISIONS
34	5/15/77	REVISIONS
35	7/15/77	REVISIONS
36	9/15/77	REVISIONS
37	11/15/77	REVISIONS
38	1/15/78	REVISIONS
39	3/15/78	REVISIONS
40	5/15/78	REVISIONS
41	7/15/78	REVISIONS
42	9/15/78	REVISIONS
43	11/15/78	REVISIONS
44	1/15/79	REVISIONS
45	3/15/79	REVISIONS
46	5/15/79	REVISIONS
47	7/15/79	REVISIONS
48	9/15/79	REVISIONS
49	11/15/79	REVISIONS
50	1/15/80	REVISIONS
51	3/15/80	REVISIONS
52	5/15/80	REVISIONS
53	7/15/80	REVISIONS
54	9/15/80	REVISIONS
55	11/15/80	REVISIONS
56	1/15/81	REVISIONS
57	3/15/81	REVISIONS
58	5/15/81	REVISIONS
59	7/15/81	REVISIONS
60	9/15/81	REVISIONS
61	11/15/81	REVISIONS
62	1/15/82	REVISIONS
63	3/15/82	REVISIONS
64	5/15/82	REVISIONS
65	7/15/82	REVISIONS
66	9/15/82	REVISIONS
67	11/15/82	REVISIONS
68	1/15/83	REVISIONS
69	3/15/83	REVISIONS
70	5/15/83	REVISIONS
71	7/15/83	REVISIONS
72	9/15/83	REVISIONS
73	11/15/83	REVISIONS
74	1/15/84	REVISIONS
75	3/15/84	REVISIONS
76	5/15/84	REVISIONS
77	7/15/84	REVISIONS
78	9/15/84	REVISIONS
79	11/15/84	REVISIONS
80	1/15/85	REVISIONS
81	3/15/85	REVISIONS
82	5/15/85	REVISIONS
83	7/15/85	REVISIONS
84	9/15/85	REVISIONS
85	11/15/85	REVISIONS
86	1/15/86	REVISIONS
87	3/15/86	REVISIONS
88	5/15/86	REVISIONS
89	7/15/86	REVISIONS
90	9/15/86	REVISIONS
91	11/15/86	REVISIONS
92	1/15/87	REVISIONS
93	3/15/87	REVISIONS
94	5/15/87	REVISIONS
95	7/15/87	REVISIONS
96	9/15/87	REVISIONS
97	11/15/87	REVISIONS
98	1/15/88	REVISIONS
99	3/15/88	REVISIONS
100	5/15/88	REVISIONS




FIGURE I.2-6  
 AMENDMENT 23  
 OCTOBER '72



<b>GENERAL ARRANGEMENT</b> <b>PLAN BASEMENT FLOOR EL. 56'-0"</b> <b>ZION STATION UNIT NO. 1</b> <b>COMMONWEALTH EDISON CO.</b> <b>CHICAGO, ILLINOIS</b>	
PROJECT NO. 1177-1222 SHEET NO. 4-6	<b>SARGENT &amp; LUNDY</b> ENGINEERS CHICAGO, ILLINOIS




FIGURE 1.2-5  
 AMENDMENT 23  
 OCTOBER 77

GENERAL ARRANGEMENT  
 PLAN GROUND FLOOR EL. 582-0'  
 ZION STATION UNIT NO. 1  
 COMMONWEALTH EDISON CO.  
 CHICAGO, ILLINOIS

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	10/1/77
2	ISSUED FOR PERMIT	10/1/77
3	ISSUED FOR PERMIT	10/1/77
4	ISSUED FOR PERMIT	10/1/77
5	ISSUED FOR PERMIT	10/1/77
6	ISSUED FOR PERMIT	10/1/77
7	ISSUED FOR PERMIT	10/1/77
8	ISSUED FOR PERMIT	10/1/77
9	ISSUED FOR PERMIT	10/1/77
10	ISSUED FOR PERMIT	10/1/77
11	ISSUED FOR PERMIT	10/1/77
12	ISSUED FOR PERMIT	10/1/77
13	ISSUED FOR PERMIT	10/1/77
14	ISSUED FOR PERMIT	10/1/77
15	ISSUED FOR PERMIT	10/1/77
16	ISSUED FOR PERMIT	10/1/77
17	ISSUED FOR PERMIT	10/1/77
18	ISSUED FOR PERMIT	10/1/77
19	ISSUED FOR PERMIT	10/1/77
20	ISSUED FOR PERMIT	10/1/77
21	ISSUED FOR PERMIT	10/1/77
22	ISSUED FOR PERMIT	10/1/77
23	ISSUED FOR PERMIT	10/1/77
24	ISSUED FOR PERMIT	10/1/77
25	ISSUED FOR PERMIT	10/1/77
26	ISSUED FOR PERMIT	10/1/77
27	ISSUED FOR PERMIT	10/1/77
28	ISSUED FOR PERMIT	10/1/77
29	ISSUED FOR PERMIT	10/1/77
30	ISSUED FOR PERMIT	10/1/77
31	ISSUED FOR PERMIT	10/1/77
32	ISSUED FOR PERMIT	10/1/77
33	ISSUED FOR PERMIT	10/1/77
34	ISSUED FOR PERMIT	10/1/77
35	ISSUED FOR PERMIT	10/1/77
36	ISSUED FOR PERMIT	10/1/77
37	ISSUED FOR PERMIT	10/1/77
38	ISSUED FOR PERMIT	10/1/77
39	ISSUED FOR PERMIT	10/1/77
40	ISSUED FOR PERMIT	10/1/77
41	ISSUED FOR PERMIT	10/1/77
42	ISSUED FOR PERMIT	10/1/77
43	ISSUED FOR PERMIT	10/1/77
44	ISSUED FOR PERMIT	10/1/77
45	ISSUED FOR PERMIT	10/1/77

**SARGENT & LUNDY**  
 ENGINEERS  
 CHICAGO, ILLINOIS  
 DRAWING NO.  
 M-5




FIGURE 1.2-4  
 AMENDMENT 23  
 OCTOBER '72


GENERAL ARRANGEMENT  
 PLAN MEZZ. FLOOR EL. 817'-0"  
 ON STATION UNIT NO. 1  
 COMMONWEALTH EDISON CO.  
 CHICAGO, ILLINOIS

NO.	DESCRIPTION	DATE
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		
62		
63		
64		
65		
66		
67		
68		
69		
70		
71		
72		
73		
74		
75		
76		
77		
78		
79		
80		
81		
82		
83		
84		
85		
86		
87		
88		
89		
90		
91		
92		
93		
94		
95		
96		
97		
98		
99		
100		

ARGENT & LUNDY  
 ENGINEERS  
 CHICAGO, ILLINOIS  
 M-4



6. Level  
560'



L.C. 69  
0



ZION FLOW PATHS: KEYWAY JET STAGNATION AND REFLECTION

- FLOW DIRECTED UP KEYWAY TOWARDS CRANE WALL
- EXPECTED SMALL FLOW UP SEAL TABLE SHAFT
- FLOW STAGNATION AND SHARP DIRECTIONAL CHANGE NEAR ENTRY TO SEAL TABLE SHAFT
- EXTENSIVE TURBULENCE AND MIXING INDICATED
- PLUME RISE AND STRATIFICATION






Figure 1-1. Schematic Illustration of Zion Reactor Containment Building.

SCHEMATIC OF FLOW DIRECTION CHANGE



# MAXIMUM DIAMETER OF PARTICLE MAKING TURN



FLOW DIRECTION CHANGE: SUMMARY

- DROPS WITH  $d_p > 10$ 'S OF MICRONS MAY NOT MAKE THE TURN
- DEPOSITION OF EJECTED DEBRIS ON WALLS INDICATED FOR ALL BUT "SPIT" AEROSOLS
- DROP SIZE DISTRIBUTION WILL BE ALTERED DUE TO DEPOSITION
- EXPERIMENTS SHOULD SIMULATE DETAILS OF KEYWAY, CRANE WALL, SEAL TABLE SHAFT

## FLOW WITHIN STEAM GENERATOR COMPARTMENT

- PATHS TO CONTAINMENT DOME
  - JET/PLUME RISE TO STEAM GENERATOR PENETRATIONS
  - FLOW OUT CRANE WALL PENETRATIONS TO OUTER ANNULUS AND THROUGH GRATINGS
  
- DEPLETION MECHANISMS
  - MIXING
  - FALLOUT
  - DEPOSITION

# PLUME RISE AND STRATIFICATION







Figure 1-1. Schematic Illustration of Zion Reactor Containment Building.

# SPIT-19 DEBRIS DISTRIBUTION




# INERTIAL DEPOSITION




$$St = \frac{\rho_p d^2 U}{18\mu a}$$

Fig. 4-9 Collection efficiency for cylinders in an inviscid flow with point particles (Brun et al., 1955). The rate of deposition, particles per unit time per unit length of cylinder, is  $2\eta_R n_m Ua$  where  $n_m$  is the particle concentration in the mainstream.



Diameter of Obstacle,  $m$

Collection Efficiency,  $\%$



DIAMETER OF OBSTACLE, M

Collection Efficiency,  $\eta_p$

DEPOSITION: SUMMARY

- POTENTIAL FOR DEPOSITION ON STRUCTURES EXISTS FOR  $d_p > 100$  MICRONS WITHIN STEAM GENERATOR COMPARTMENT
- MORE DETAILED FLOW MAPPING, PARTICLE TRAJECTORIES NEEDED FOR QUANTITATIVE ASSESSMENT

## SUMMARY

- NO DIRECT PATHWAY FROM KEYWAY TO UPPER CONTAINMENT IDENTIFIED
- KEYWAY JET IMPACTS CRANE WALL AT SEAL SHAFT ENTRANCE. SIGNIFICANT MELT DEPOSITION EXPECTED. RE-ENTRAINMENT IS KEY ISSUE. DETAILS OF GEOMETRY IMPORTANT.
- JET/PLUME RISE AND STRATIFICATION EXPECTED IN STEAM GENERATOR COMPARTMENT (SGC). MUCH OF VERTICAL MOMENTUM MAY BE DISSIPATED.
- FLOW TO OUTER CONTAINMENT WITH NO SIGNIFICANT DEPOSITION/FALLOUT UNLIKELY. CANNOT QUANTIZE DEFINITELY WITHOUT DETAILED FLOW MODELING AND, PERHAPS EXPERIMENTS.

## RECOMMENDATIONS

- EXPERIMENTS MUST MODEL STRUCTURE ADEQUATELY TO PROPERLY SIMULATE JET INTERACTION WITH CRANE WALL/SEAL SHAFT REGION.
  
- PROPOSED MINIMUM METALLIC OXIDATION REACTION:
  - CONSUME OXYGEN IN LOWER COMPARTMENT
  
  - REACT AEROSOL ONLY (LESS THAN 100 MICRONS) IN UPPER CONTAINMENT
  
- ON UPPER BOUND:
  - CERTAINLY LESS THAN .90%
  
  - BUT ??????