

ATTACHMENT 1

Updates Included In This Submittal

DIABLO CANYON EMERGENCY PLAN  
IMPLEMENTING PROCEDURES

Volume 3A

EP OP-3A, Revision 5  
EP OP-8, Revision 8  
EP OP-13, Revision 3  
EP OP-25, Revision 2  
EP M-1, Revision 11  
EP R-1, Revision 11  
EP R-7, Revision 4

Volume 3B

EP EF-5, Revision 4  
EP RB-2, On-The-Spot Change

CORPORATE EMERGENCY RESPONSE PLAN  
IMPLEMENTING PROCEDURES

CERP 2.2, Revision 1

ATTACHMENT 2

Location of Proprietary/Privacy Information

Procedure:

R-1, pages 2, 11 and 16 of 16; Attachment "Safety, Health, and Claims Personnel to be Contacted for Reporting of Injuries at Diablo Canyon" - pages 1 and 2 of 2.

R-7, pages 9 and 10 of 10.

M-1, pages 1-3 of 5; Attachment - "Company Panel of Physicians, Ambulances and Hospitals" - pages 1 and 2 of 2; Attachment - "Panel of Physicians, Ambulances and Hospitals, Coast Valleys Division" - pages 2.1-2.6 of 6; Attachment - "Safety, Health and Claims Personnel to be Contacted for Reporting of Injuries at Diablo Canyon" - pages 1 and 2 of 2; Attachment 10 - Appendix Z - page 1 of 1.

EF-5, page 11 of 38; pages 26, 27, 28, 29, 30, 31 and 32 of 38; Attachment - "Emergency Facility Phone Numbers" - page 1 of 1; Attachment - "Technical Support Center Check List" - pages 2 and 3 of 3; Attachment - "Emergency Operating Facility Equipment Function Checklist" - pages 1-3 of 3.

CURRENT  
EMERGENCY PLAN  
IMPLEMENTING PROCEDURES

TABLE OF CONTENTS

Volume 3A


	<u>TITLE</u>	<u>REV</u>
OP-0	Reactor Trip With Safety Injection	5
OP-1	Loss of Coolant Accident	7
OP-2	Loss of Secondary Coolant	2
OP-3A	Steam Gen Tube Failure	5
OP-3B	Minor Steam Gen Tube Failure	1
OP-4A	Loss of Electrical Power	1
OP-4B	Loss of All AC Power	0
OP-5	Reactor Trip Without Safety Injection	5
OP-6	Emergency Boration	6
OP-7	Loss of Condenser Vacuum	2
OP-8	Control Room Inaccessibility	8
OP-9	Loss of Reactor Coolant Pump	4
OP-10	Loss of Auxiliary Salt Water	2
OP-11	Loss of Component Cooling Water	3
OP-12	Malfunction of Auto Reactor Control System	1
OP-12A	Failure of a Control Bk to Move in Auto	2
OP-12B	Cont Withdrawl of a Control Rod Bank	3
OP-12C	Cont Insertion of a Control Rod Bank	2
OP-12D	Control Rod Pos Indication Sys Malfunc	3
OP-12E	Control Rod Misalignment	2
OP-12F	Dropped Control Rod	2
OP-13	Malfunction of Reactor Press Control System	3
OP-14	High Activity in Reactor Coolant	2
OP-15	Loss of Feedwater	4
OP-16	Nuclear Instrumentation Malfunctions	3
OP-17	Malfunction of RHR System	2
OP-18A	Loss of Charging	0
OP-18B	Loss of Normal Letdown	0
OP-19	Malfunction of Reactor Makeup Control	2
OP-20	Excessive Reactor Coolant System Leakage	2

03/26/84

0502d/0005K

	<u>TITLE</u>	<u>REV</u>
OP-21	Loss of A Coolant Loop RTD	2
OP-22	Emergency Shutdown	1
OP-23	Natural Circulation of Reactor Coolant	3
OP-24	Loss of Containment Integrity	1
OP-25	Tank Ruptures	2
OP-26	Excessive Feedwater Flow	1
OP-27	Irradiated Fuel Damage	1
OP-28	Startup of an Inactive Reactive Coolant Loop	1
OP-29	Excessive Load Increase	1
OP-30	Inadvertent Load Fuel Assly Improper Pos	1
OP-31	System Under Frequency	1
OP-32	Rod Ejection	1
OP-33	Loss of Instrument Air	1
OP-34	Generator Trip - Full Load Rejection	1
OP-35	Loss of Vital or Non-Vital Instr AC Sys	1
OP-36	Turbine Trip	1
OP-37	Loss of Protection System Channel	1
OP-38	Anticipated Transient Without Trip (ATWT)	5
OP-39	RCP Locked Rotor Accident	1
OP-40	Accidental Depressurization of MS System	1
OP-41	Hydrogen "Explosion" Inside Containment	1
OP-44	Gaseous Voids in the RCS	2
R-1	Per Injury (Rad Related) And/Or Overexp	11
R-2	Rel of Airborne Radioactive Materials	4
R-3	Rel of Radioactive Liquids	3
R-4	High Radiation (In Plant)	3
R-5	Radioactive Liquid Spill	3
R-6	Radiological Fire	6
R-7	Offsite Transportation Accidents	4
M-1	Employee Injury of Illness (Nonradiological)	11
M-2	Nonemployee Injury or Illness (Third Party)	9
M-3	Chlorine Release	5
M-4	Earthquake	7
M-5	Tsunami Warning	5
M-6	Nonradiological Fire	8
M-7	Oil Spill ISO and Clean Up Procedure	6
M-8	Containment Emergency Personnel Hatch	0
M-9	Hazardous Waste Management Contingency Plan	1
G-1	Emergency Classification and Emergency Plan Activation	3
G-2	Establishment of the On-Site Emergency Organization	3
G-3	Notification of Off-Site Organizations	2
G-4	Personnel Accountability and Assembly	3
G-5	Evacuation of Nonessential Site Personnel	0

03/26/84



Pacific Gas and Electric Company

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 1 OF 23



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

TITLE EMERGENCY PROCEDURE  
STEAM GENERATOR TUBE RUPTURE

IMPORTANT  
TO  
SAFETY

APPROVED: R. C. Thompson 2-27-84  
PLANT MANAGER DATE

SCOPE

This procedure covers the operating steps to be taken in the event of a steam generator tube rupture. It is assumed that reactor trip and safety injection actuations have occurred. The operator should have already performed Emergency Operating Procedure OP-0, "Reactor Trip with Safety Injection". This procedure and changes thereto requires PSRC review.

SYMPTOMS

(See OP-0 symptoms)

AUTOMATIC ACTIONS

(See OP-0 Automatic Actions)

OBJECTIVES

1. To minimize the release of radioactive material by identifying and isolating the faulted steam generator and by reducing reactor coolant system pressure below the steam generator valve setting (1065 psig).
2. To establish the capability to supply feedwater to all steam generators and to isolate feedwater to the faulted steam generator.
3. To maintain the ability to remove the necessary residual heat from the reactor through the intact steam generators via the steam dump valves to the condenser or the atmosphere.
4. To maintain the reactor coolant system in a subcooled state during the recovery.
5. To prevent overflowing of the faulty steam generator.

IMMEDIATE OPERATOR ACTIONS

(See OP-0 Immediate Operator Actions)

SUBSEQUENT OPERATOR ACTIONS

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 2 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

1. Sound the site emergency alarm.
  2. Contact Chemistry & Radiation Department to sample containment atmosphere and all steam generators for abnormal radiation.
  3. Identify the faulted steam generator by one of the following methods.
    - a. Observe steam generator water levels. The faulted steam generator should experience an unexpected rise in level. If required, momentarily reduce auxiliary feedwater flow to the steam generators and attempt to identify the faulted steam generator by level indications.
    - b. Reset Containment Isolation Phase A, Train A and Train B.
      - 1) If a high blowdown radiation signal is NOT present, open or check open the inside containment SG blowdown isolation valves and open the sample valves FCV 250, 248, 246 and 244 one at a time to identify the faulted steam generator. Allow time between opening to allow sample flow to contact the radiation element. The steam generator blowdown with high radiation identifies the faulted steam generator.
2. The steam generator samples are essential for subsequent recovery actions.
  3. While attempting to identify and isolate the faulted steam generator, continue with this procedure up to step 17.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 3 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- 2) If high radiation level on steam generator blowdown liquid monitor has isolated steam generator blowdown and blowdown samples, determine the faulted steam generator as follows. First, check open or open the IC blowdown isolation valves, then cut in the S/G blowdown Hi Rad switch on VB-3 to override the high radiation trip signal and open FCV's 250, 248, 246 and 244 steam generators 1 through 4 blowdown sample valves, one at a time as necessary to compare radiation levels on each. The SG with the high radiation in the sample is the faulted SG.
- 3) From the steam generator samples, identify the faulted Steam Generator by observation of abnormally high radiation in any one steam generator.
4. When the faulted steam generator has been positively identified, ISOLATE THE FAULTED STEAM GENERATOR.
  - a. Stop all AFW flow to the faulted steam generator.
  - a. Monitor the water level in the faulted steam generator throughout this procedure.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 4 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- b. Close or verify closed, the following valves associated with the faulted steam generator. (VB3).

- b. The steam generator safety valves on the faulted steam generator may lift during this operation.

Main Steam Isolation Valve,  
Main Steam Isolation Valve Bypass Valve,  
IC and OC Blowdown Valve,  
Blowdown Sample Valve,  
10% Atmospheric Relief Valve.

5. If the main steam isolation valves or the main steam isolation valve bypass valve on the faulted steam generator will not close, then close the main steam isolation valves and bypass valves on ALL nonfaulted steam generators and verify the nonfaulted steam generators 10% atmospheric relief valves maintaining steam generator pressure approximately 1035 psig.

6. Verify closed and place in manual the 10% atmospheric relief valve on the faulted steam generator.

7. If steam generator No. 2 is the faulted steam generator, close the aux. feedwater pump steam supply FCV 37. If steam generator No. 3 is the faulted steam generator, close FCV 38.

7. This will terminate the activity release from the faulted steam generator via the steam driven aux. feed pump.

8. Verify all pressurizer PORV's are closed.

8. Verify by position lights and discharge line temperature indication.

Verify by lit position lights that power is available to the pressurizer power operated relief valve backup isolation valves.



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 5 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

9. Monitor the core exit thermocouple temperature for indications of inadequate core cooling. If indications of inadequate core cooling exist, perform Appendix C of this procedure.
9. Indications of inadequate core cooling are given in Appendix C of this procedure.
10. If RCS wide range pressure continues to decay below 1220 psig or is below 1220 psig and stable.
10. NOTE: The conditions for stopping RCP must be continuously monitored through step 18.
- a. Again verify a minimum of one charging pump delivering flow and one SI pump delivering flow to the RCS.
- b. THEN, STOP all four reactor coolant pumps. Maintain seal water flow to the RCPseals by manually adjusting the reciprocating charging pump speed or FCV 128.
- c. Close the Centrifugal Charging pump recirculation valves (8105 and 8106)
- c. NOTE: If the W.R. RCS pressure is increased above 2000 psig, reopen valves 8105 and 8106 to prevent pump damage.
- d. If component cooling water to the RCP's is isolated due to a containment Phase B isolation, stop all RCP's within 5 minutes and maintain seal flow as above.
11. If the faulted steam generator was isolated by closure of its MSIV (per step 4 of this procedure) perform steps a. & b. below. If it was isolated as per step 5, go to step 12.
11. If the faulted steam generator has been identified, do not dump steam from the faulted steam generator. Maintain containment Phase A isolation until necessary to reset for system operations.

DIABLO CANYON POWER PLANT UNIT NO(S)	1 AND 2	NUMBER	EP OP-3A
		REVISION	5
		DATE	2/8/84
		PAGE	6 OF 23
TITLE	STEAM GENERATOR TUBE RUPTURE		

<u>ACTIONS</u>	<u>COMMENTS</u>
<p>a. If the condenser is available, open or verify open the nonfaulted steam generators main steam isolation valves and establish steam dump to the condenser. Transfer the steam dump control to the pressure control mode and verify set pressure at NO load pressure.</p> <p>b. If the condenser is not available, verify the 10% atmospheric relief valves holding steam pressure below the safety valve setpoint.</p>	
<p>12. Verify or establish power on the 480 volt vital buses, F, G and H.</p>	<p>12. This power, plus the normal and backup bottled air supply, will assure power sources available for at least one PZR PORV, steam generator PORV's and charging and letdown flowpaths. If loss of offsite power occurs, the letdown path will be to the PRT via the relief valve downstream of the orifice valves.</p>
<p>13. Verify RCS <math>T_{avg}</math> is at or approaching <math>T_{no\ load}</math> under the influence of condenser or atmospheric relief valves from the nonfaulted steam generators. Adjust steam dump if required to achieve <math>T_{no\ load}</math>.</p>	
<p>14. Maintain maximum AFW flow until the steam generator water levels are in the narrow range. When the SG water levels approach 33% NR, verify automatic steam generator level control.</p>	<p>14. Observe the water levels closely for unexplained changes in one steam generator which may identify the faulted steam generator.</p>

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONSCOMMENTS

15. Monitor the condensate storage tank and upon reaching approximately 10% level, perform a. or b. below.

15. If the CST-10 10 level alarm occurs, the operator has approximately 25 minutes to perform Steps a. or b.

a. Verify a level in the raw water storage reservoir; then open FCV-436 and FCV-437 (Reservoir supply to AFW pumps). Allow the AFW pumps to run during the transfer. Monitor the AFW flow closely. If AFW flow is lost, trip all 3 AFW pumps until the transfer is complete, then restart the pumps.

b. If the raw water storage reservoir is not available, go to Appendix A (AFW Pump Suction Supply from Fire Water Tank Procedure). Allow the AFW pumps to run during the transfer. Monitor the AFW flow closely. If AFW flow is lost, trip all 3 AFW pumps until the transfer is complete, then restart the pumps.

16. If the RCS pressure is above the shutoff head of the RHR pumps,

16. CAUTION:1)If the RCS pressure falls below the shutoff head of the RHR pumps, restart the pumps to deliver water to the RCS

RESET SAFETY INJECTION

and stop both RHR pumps.

CAUTION:2)Automatic reinitiation of safety injection will not occur after this step since the reactor trip breakers are open. If the operator has indication that an SI is required after this step, he must initiate it manually.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 8 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

16. (Cont)

CAUTION:3) If loss of offsite power occurs after resetting safety injection, it will be necessary to load the safeguards equipment onto the vital buses manually. If safety injection is reinitiated manually after the loss of offsite power, the vital buses will automatically sequentially load the safeguard equipment. If loss of offsite power occurs, go to Appendix B (Blackout With SI Emerg. Loading of Vital Buses).

17. DO NOT PROCEED BEYOND THIS STEP UNTIL THE FAULTED STEAM GENERATOR IS IDENTIFIED AND ISOLATED.

18. Begin a Rapid cooldown of the RCS to 500 degrees F using only the nonfaulted steam generators.

a. If the faulted steam generator was isolated by closure of the main steam isolation valves associated with the nonfaulted steam generators, dump steam only from the nonfaulted steam generators through the 10% atmospheric relief valves. If isolated per step 4, use step b. or c. below.

b. Use the condenser steam dumps if the condenser is available. Go to steam pressure control mode if not already in this mode. Place the steam pressure controller in MANUAL and increase the demand as necessary cooldown.

b. This is the preferred method. When P-12 is reached, select Bypass Interlock on the Steam Dump Interlock Selector switches to permit the

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 9 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- c. If the condenser is not available, use the 10% atmospheric relief valves from the nonfaulted steam generators.
19. Continue to monitor containment conditions, if containment sump level rises abnormally or if a containment sample (if available) indicates high activity in containment, go to OP-1 for further accident recovery.
20. After the RCS has been cooled to 500 degrees F, if required, depressurize the RCS to the value equal to the faulted steam generator pressure. If pressurizer level has been off scale low, the level will probably return during this operation. Maintain minimum 35 degrees F subcooling during this operation.
- a. If RCP's are in service, use pressurizer spray to reduce RCS pressure.
- b. If normal spray is not available, open one pressurizer Power Operated Relief Valve (PORV) to reduce RCS pressure. Verify closure of the valve by observing position indication and discharge line temperature decreasing, and if required, close the backup isolation valve.
20. During subsequent controlled RCS depressurization, the criteria for tripping RCP's on low pressure no longer applies.
- b. NOTE: It may take 2-3 minutes for PORV discharge line temperature to start decreasing

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 10 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

21. As RCS pressurize decreases, due to PZR spray or the PZR PORV being open, monitor PZR level and stop the depressurization when:
- a. PZR level exceeds 85%,
  - b. OR RCS pressure decreases to the pressure of the faulted steam generator.

Verify closure of the PORV by position indication and discharge line temperature. Verify closure of the spray valve by position indication.

22. Continue to monitor RCS pressure and pressurizer water level.

- a. If pressurizer level continues to rise or is stable with continued RCS pressure decreasing after the depressurization is terminated, suspect leakage from the pressurizer steam space. If this condition persists and the PRT rupture disc is ruptured go to OP-1, "Loss of Coolant Accident".
- b. If the pressurizer level continues to rise with rising RCS pressure,

- a. Monitor PRT conditions and relief line temperatures to detect a possible stuck open valve. Close the appropriate PORV isolation valve if leakage is suspected.

AND PRT conditions are stable, the SI Flow is greater than the tube rupture flow.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 11 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- c. DO NOT continue in this procedure until the conditions of b. above are observed.
23. When RCS pressure has increased by 200 psig after the termination of the depressurization,
- a. AND Pressurizer water level is greater than 22%
- b. AND indicated subcooling from the nonfaulted steam generator loops is greater than 35 degrees F
- c. THEN allow one centrifugal charging pump to operate for normal charging and RCP seals and shutdown the remaining charging, and SI pumps while maintaining operable safety injection flowpaths.
24. Establish normal charging.
- a. Reset containment Phase A isolation if required.
- b. Check open or open normal charging valve 8146.
- c. Check closed or close charging to aux. spray valve 8145 and alt. spray bypass valve 8148 and alternate charging valve 8147.
- d. Open charging line isolation valves 8107 and 8108.
- e. Close the BIT inlet and outlet valves 8803A and B and 8801A and B.
24. Continue monitoring PZR level. If PZR level cannot be maintained above 22%, or indicated subcooling from the nonfaulted steam generator loops cannot be maintained greater than 35 degrees F, manually reinitiate SI and return to step 20 and continue.
- When the charging and SI pumps are shutdown the RCS pressure should decrease to the value of the faulted steam generator.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 12 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- f. Adjust HCV-142 and FCV-128 or reciprocal charging pump speed to achieve RCP seal flow and charging flow as required to maintain pressurizer level greater than 22%.
  - g. Open RCP seal return valves, 8100 and 8112. Check seal flow normal.
  - h. Open RCP No. 1 seal bypass valve (8142) if RCS pressure is less than 1500 psig.
25. Establish normal letdown.
- a. Check open or open letdown valves LCV-459 and 460.
  - b. Open letdown isolation valve 8152.
  - c. Open one 75 gpm letdown orifice valve.
  - d. Verify PCV-135 opening by observing letdown flow.
26. Establish VCT makeup and transfer charging pumps suction to VCT.
- a. Adjust VCT makeup blend to the cold Xe free concentration.
  - b. Open VCT outlet valves LCV-112B&C.
  - c. Close RWST to charging pump suction valves 8805 A&B.
  - d. Verify divert valve LCV-112A in AUTO.
27. Reestablish the use of the pressurizer heaters to control pressure. If required, transfer the pressurizer backup heaters groups 2 and 3 to the vital 480 volt buses G&H.



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 13 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- |   |   |
|---|---|
| 28. If possible, establish conditions for starting No. 1 and No. 2 RCP's if the pumps have been shutdown.<br><br>a. When conditions are established, start both RCP's.  | 28. The low pressure pump trip criteria no longer applies.<br><br>a. Start both pumps to deliver spray regardless of whether these pumps are associated with a faulted steam generator.   |
| 29. If No. 1 and/or No. 2 RCP is running, shutdown No. 3 and and No. 4 RCP's.   | 29. This step will reduce the primary heat load.  |
| 30. With the plant in a stabilized condition, determine if the condenser will be available to receive steam dump during the subsequent cooldown.<br><br>a. If the condenser is available, perform steps 31, 32 and 33 SIMULTANEOUSLY.<br><br>b. If the condenser is not available, notify the Chemistry and Radiation Protection Department that a controlled activity release will be occurring. If time permits, verify that all faulted steam generator samples have been taken, then perform steps 31, 32, and 33 SIMULTANEOUSLY. | a. Failure to perform steps 31, 32 and 33 simultaneously may result in a loss of PZR level control.<br><br>b. Consult the Vol. 9 curves to determine how long the plant can remain at hot standby before proceeding to cold shutdown. |
| 31. Begin a controlled cooldown of the RCS using steam dump from the <u>NONFAULTED</u> steam generators only. Verify as steam dump begins that AFW system is maintaining ALL steam generator levels in automatic.   |   |

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 14 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

Place the LCV for the faulted steam generator in automatic and verify normal AFW response to the faulted steam generator existing level. If the faulted steam generator level is low, verify feedwater flow to the steam generator; if level is high, NO feedwater flow to the steam generator.

- a. Maintain an RCS cooldown rate of about 50 degrees F/HR.
- b. Use the condenser dump valves by reducing the pressure setpoint. If the condenser is not available, use the 10% atmospheric relief valves.

If the faulted steam generator was isolated as per step 5 of this procedure, use the 10% atmospheric relief valves.

- 32. Simultaneous with the cooldown, dump steam from the faulted steam generator to the condenser.

- a. Bleed steam to the condenser using the Main Steam Isolation Valve BYPASS VALVE.
- b. If the condenser is not available, use the 10% atmospheric steam relief valves.

a. THIS IS THE PREFERRED METHOD.

b. THIS IS NOT THE PREFERRED METHOD.

- 33. Simultaneous with the faulted steam generator pressure decay, control RCS pressure approximately the same as the faulted steam generator pressure.

33. This will minimize the mass RCS and the faulted steam generator. Stay within the limits on the Tech. Spec. cooldown curves during this operation.

- a. Use PZR heaters and one of the following:
- b. Use normal PZR spray if possible

OR

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 15 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTIONS

COMMENTS

- c. Use auxiliary spray if letdown is in service

OR

- d. Use PZR PORV intermittently if required. If the PZR PORV is used, continuously monitor PRT pressure, temperature, and level and take appropriate actions to maintain PRT integrity. Verify PORV closure by position indication and PRT conditions. If a RCS leak to the PRT is identified, close the PORV isolation valve.

34. Determine the cold Xe Free Shutdown margin and borate if required to that concentration.

35. At approximately 800 psig RCS pressure close all 4 accumulator injection isolation valves.

36. When the RCS hot leg temperatures are reduced to less than 350 degrees F and RCS pressure is less than 400 psig, place the RHR in service using Operating Procedure B-2. (Residual Heat Removal System).

36. Do not collapse the PZR bubble.

37. Continue the cooldown in this mode until the RCP is stopped, then continue to control RCS and faulted steam generator pressures until the RCS hot leg temperatures are below 200 degrees F, then use auxiliary spray until the RCS pressure and faulted steam generator pressures equilibrate.

37. Use Operating Procedure L-5 (Plant Cooldown From Minimum Load to Cold Shutdown) in conjunction with this procedure during the cooldown. Enter L-5 at the point where RHR is to be put into service.

38. Continue operation of the RHR, letdown and charging as required.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 16 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

APPENDIX A

AUXILIARY FEED PUMP SUCTION SUPPLY FROM FIRE WATER TANK

The operator has 20 minutes to perform this operation after the low level alarm on the condensate storage tank and before the AFW pumps lose suction. This provides sufficient time; however, the operator must not delay and must carry out the valve line up in order as written.

If the AFW pumps are being supplied from the raw water reservoir and a seismic event occurs with resultant loss of AFW suction and auxiliary feedwater flow to the steam generators, the steam generators will boil dry in about 30 minutes. Under these conditions, it is especially important to expedite this procedure and reestablish AFW flow to the steam generators prior to the reactor losing its heat sink.

ACTIONS


COMMENTS

Using the attached drawing, proceed to supply the AFW pumps suction from the fire water tank.

1. Close or verify closed MU-0-284 and MU-0-286.
2. Close or check closed MU-1-298.
3. Close or check closed MU-0-325.
4. Close or check closed MU-0-427.
5. Open FP-0-306 and FP-0-307.
6. Notify the control room that the suction for the AFW pumps is now available from the fire water tank.
7. From the control room open FCV-436 and 437.
8. Proceed to the auxiliary feedwater pumps and vent the pump casings if required to remove air.

1. Closing these valves prevents losing fire water out a possible break in the reservoir supply line.

DC0003 171



APPENDIX A (Cont'd)

TITLE	DIABLO CANYON POWER PLANT UNIT NO. 1 AND 2
STEAM GENERATOR TUBE RUPTURE	
NUMBER	EP 0P-3A
REVISION	5
DATE	2/8/84
PAGE	17 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

## APPENDIX B

BLACKOUT WITH SAFETY INJECTION EMERGENCY LOADING OF VITAL BUSES

1. If the vital buses lose voltage prior to resetting the safety injection signal, the vital buses will automatically load the vital equipment given below. Verify the equipment has been loaded by observing breaker lights on the control board.
2. If the vital buses lose voltage after the safety injection signal has been reset, load or verify loaded the equipment given below onto the vital buses manually. Allow approximately 4 seconds between loading of each piece of equipment onto a given vital bus. Load or verify that the CFCU's are running in Low Speed.

<u>VITAL BUS</u> <u>F</u>	<u>VITAL BUS</u> <u>G</u>	<u>VITAL BUS</u> <u>H</u>
D/G 1-3	D/G 1-2	D/G 1-1
MCC 1-F	MCC 1-G	FCC 1-H
CC Pp 1-1	CC Pp 1-2	SI Pp 1-2
SI Pp 1-1		
CFCU 1-2	RHR Pp 1-1	RHR Pp 1-2
CFCU 1-1	CFCU 1-3	CFCU 1-4
CCW Pp 1-1	CFCU 1-5	CCW Pp 1-3
ASW Pp 1-1	CCW Pp 1-2	AFW Pp 1-2
AFW Pp 1-1	ASW Pp 1-2	

3. Load the containment spray Pumps only if they were running prior to the blackout.

<u>VITAL BUS</u> <u>G</u>	<u>VITAL BUS</u> <u>H</u>
Cont Spray Pp 1-1	Cont Spray Pp 1-2

TITLE STEAM GENERATOR TUBE RUPTURE

## APPENDIX C

## DETERMINATION OF ADEQUATE CORE COOLING

This appendix provides the guidance to determine adequate core cooling if inadequate core cooling is suspected. Further, the instructions for regaining adequate core cooling is presented.

ACTIONCOMMENTS

1. Monitor the core exit thermocouple temperatures.
  - a. If the P-250 is available go to step 2.
  - b. If the P-250 is not available go to step 3.
  
2. If 5 or more P-250 thermocouple readings exceed 1200 degrees F, notify the Shift Foreman that inadequate core cooling exists and go to step 5.
 

If there are not 5 or more that exceed 1200 degrees F, discontinue this appendix but continue to monitor the thermocouple readings.
  
3. Monitor the thermocouple readout on PAMS 3 and 4. If 5 or more thermocouple readings exceed 1200°F notify the Shift Foreman that inadequate core cooling exists and go to step 5.
 

If there are not 5 or more readings that exceed 1200°F, discontinue this appendix but continue to monitor the thermocouple readings.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/64  
PAGE 20 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

ACTION

COMMENTS

4. The Shift Foreman will verify if inadequate core cooling exists using the appropriate steps above. If inadequate core cooling exists the Shift Foreman will direct operations as follows:

- a. Declare a General Emergency. Implement the instructions given in Emergency Procedure G-1 regarding on and offsite protective actions.
- b. Attempt to establish SI flow to the RCS and AFW flow to the steam generators.
- c. Continue monitoring core outlet temperature to determine the effectiveness of the remaining actions.
- d. DEPRESSURIZE THE RCS by method 1 or 2 below.

1) Dump steam to the condenser or atmosphere if the steam generator levels are in the narrow range and AFW flow is evident.

1) THIS IS THE PREFERRED METHOD.

2) Verify the SIS or charging pumps are running and available to deliver water to the RCS

2) Opening the PORV's will provide a drop in RCS pressure sufficient to allow the SI flow required to cool the core.

THEN

Open the pressurizer PORV's.

This method is to be used only if 1) (above) is ineffective.



DIABLO CANYON POWER PLANT UNIT NO(S)      1 AND 2  TITLE      STEAM GENERATOR TUBE RUPTURE	NUMBER      EP OP-3A REVISION      5 DATE      2/8/84 PAGE      21 OF 23
--	---

ACTIONS

e. If no means of depressurization are available, or if the depressurization did not result in decreasing core thermocouple temperatures,

THEN


START one RCP if possible.

If the RCP fails after starting, replace the lost RCP with any remaining RCP.

COMMENTS

e. Attempt to establish CCW and seal water flow to the pump; however, if CCW and/or seal water exit flow cannot be established, proceed to start a RCP. The pump must be started to move coolant through the core.

TITLE STEAM GENERATOR TUBE RUPTURE



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2


NUMBER EP OP-3A  
REVISION 5  
DATE 2/8/84  
PAGE 23 OF 23

TITLE STEAM GENERATOR TUBE RUPTURE

APPENDIX Z

EMERGENCY PROCEDURE NOTIFICATION

1. When this emergency procedure has been activated and upon direction from the Shift Foreman proceed as follows:
  - a. Designate this event an Alert. Notify plant staff and response organizations required for this classification by Emergency Procedure G-2 "Establishment of On-Site Organization" and Emergency Procedure G-3 "Notification of Off-Site Organization" in accordance with Emergency Procedure G-1 "Accident Classification and Emergency Plan Activation."
  - b. Designate this event a Site Area Emergency if steam generator tube leakage coincides with a loss of off-site power indicated by Appendix B of this procedure and inability to restore power to the non-vital 12KV and 4K busses (D and E). Notify plant staff and response organizations required by EP G-2 and EP G-3 in accordance with EP G-1.
  - c. In the event inadequate core cooling is verified per Appendix C, reclassify this event as a General Emergency. Notify plant staff and response organizations required by EP G-2 and EP G-3 in accordance with EP G-1.



Pacific Gas and Electric Company

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 1 OF 56



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

TITLE: EMERGENCY OPERATING PROCEDURE  
CONTROL ROOM INACCESSIBILITY

IMPORTANT  
TO  
SAFETY

APPROVED: R. C. Thompson 3-5-84  
PLANT MANAGER DATE

SCOPE

These instructions are provided to cover those conditions prevailing when operation from the Control Room is no longer possible due to fire, smoke, heat, chlorine, high radioactivity or other occurrences which make the Control Room uninhabitable.

- Section A TO MAINTAIN THE PLANT IN HOT STANDBY - pg. 4
- Section B TO TAKE THE PLANT FROM HOT STANDBY TO COLD SHUTDOWN - pg. 12
- Appendix A TO RE-ESTABLISH LTDN AFTER A LTDN ISOLATION - pg. 32
- Appendix B TO USE NORMAL PZR SPRAY VALVES - pg. 33
- Appendix C ENERGIZING NON-VITAL 480V BUSES WITH THE EMERGENCY DIESEL GENERATOR - pg. 34
- Appendix D TO TAKE THE PLANT FROM HOT STANDBY TO COLD SHUTDOWN USING NATURAL CIRCULATION - pg. 40
- Appendix E AUXILIARY FEED PUMPS SUCTION SUPPLY FROM FIRE WATER TANK - pg. 53
- Appendix Z NOTIFICATION INSTRUCTIONS - pg. 56

This procedure and changes thereto requires PSRC review.

SYMPTOMS

Possible Annunciator Alarms:

1. HIGH RADIATION (PK 11-21)
  - a. Rad Mon Cont Rm Area
  - b. Process Monitor Hi-Rad

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 2 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

2. CONTROL ROOM VENT (PK 15-06)
  - a. Cont Rm Chlorine & Rad Monitor
3. FIRE/SMOKE DETECTOR (PK 10-10)

OBJECTIVES

1. Establish stable Hot Standby conditions from the Hot Shutdown Panel.
2. To provide instructions to allow the plant to be taken to Cold Shutdown condition from Hot Standby from outside the Control Room if conditions require it.

AUTOMATIC ACTIONS

1. Possible transfer to Control Room ventilation to Mode 3 (high Chlorine) or Mode 4 (Pressurization).
2. Possible start of the Emergency Diesel Generators (if offsite power is lost).

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

IMMEDIATE ACTIONS

- |  |  |
|--|--|
| <ol style="list-style-type: none"><li>1. Manually TRIP the reactor <u>BEFORE</u> leaving the Control Room.<ol style="list-style-type: none"><li>a. Verify the Reactor Trip<ol style="list-style-type: none"><li>1) All Control Rod Bottom Lights <u>ON</u> (DRPI)</li><li>2) Reactor Power NIS-DECREASING</li></ol></li></ol></li><li>2. Verify tripped or manually TRIP the Turbine <u>BEFORE</u> leaving the Control Room.<ol style="list-style-type: none"><li>a. Verify all four STOP valves CLOSED on turbine EH panel.</li></ol></li></ol> | <ol style="list-style-type: none"><li>1. TRIP the Reactor locally at the Reactor Trip Breakers.</li><li>2. TRIP the Turbine locally at the Governor Pedestal.<ol style="list-style-type: none"><li>a. Verify turbine STOP valves CLOSED by observing actual valve position at the turbine.</li></ol></li></ol> |
|--|--|

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 3 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

3. Proceed to the Hot Shutdown Panel.

SUBSEQUENT ACTIONS

4. STOP any dilution in progress.
4. Manually operate valves locally as necessary.
5. If condenser vacuum decreasing consider:
- a. Restarting a circulating water pump OR
  - b. Securing Air Ejectors on the inactive half of the main condenser.

NOTE: Certain loads (ASW and CFCU) auto start on auto transfer to startup power. Normally these loads cannot be shutdown until AUTO transfer is RESET but if the DC control power is removed from the ASW pump breaker after the breaker is opened locally it can be shutdown. The CFCU breakers must be opened locally to shut them down.

NOTE: The following list of equipment should have their Control Switches placed in the position described below BEFORE transferring to local control to insure a BUMPLESS transfer:

- a. PZR HTR GRPS 12 and 14 to the NEUTRAL position.
- b. The in-service LTDN Orifice Isolation valve CVCS-8149 A, B or C to the OPEN position.
- c. The NOT in-service LTDN Orifice Isolation valve CVCS-8149 A, B or C to the CLOSED position.
- d. Boric Acid Transfer Pumps 11 and 12 to Low Speed.

**CAUTION:** Transfer of Boric Acid Pumps and PZR HTRS to local control removes them from their AUTO control schemes.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/2/84  
PAGE 4 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

A. TO MAINTAIN THE PLANT IN HOT STANDBY

1. The following equipment is available for transfer to local control if Manual control is desired:
  - \*a. Boric acid transfer pump 11
  - \*b. Containment fan coolers 11, 13 and 14.
  - \*c. 8149A&C (letdown orifice valves).
    - d. HCV 142
    - e. FCV 128
    - f. 10% steam dump valves.
    - g. LCV 110, 111, 115 and 113.
    - h. CCW pump 11 and 13
    - i. ASW pump 12
  - \*k. Pzr. Heater group 14
    - l. AFW pump 13
  - \*m. LCV 108
  - \*n. LCV 109
2. The following equipment must have their control transfer cutout switch CUT IN prior to transferring to local control:
  - a. Located inside the 480V Bus F AUX relay panel:
    - \*1. Containment fan cooler 12
    - \*2. 8149B (letdown orifice valve)

\*These items must have their control transfer relays hand reset when transferring control back to Control Room (in addition to being in remote position on transfer switch).

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

- b. Located inside the 480V  
Bus G AUX relay panel:
- \*1. FCV 95 (AFW pump 11)
  - \*2. MOV 8104 (Emerg.  
Borate Valve)
  - \*3. LCV 106
  - \*4. LCV 107
  - \*5. BA XFER pump 12
  - \*6. CONTAINMENT fan  
cooler 15
- c. Located at 4 KV Bus G
- 1. CCW pump 12
  - 2. ASW pump 11
  - 3. Cent. Chg. pump 12
- d. Located at 4 KV Bus H  
AFW pump 12
- e. LOCATED INSIDE 480V Bus  
13D cutout switch panel.
- \*PZR heater group 12
3. Trip the Main Feedwater Pump  
Turbines and ensure that they  
go on Turning Gear once zero  
speed is reached.

\*These items must have their control transfer relays hand reset when transferring control back to Control Room (in addition to being in remote position on transfer switch).



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 6 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

4. Ensure that the Bearing Oil Pump, HP Seal Oil Backup Pump and the Bearing Lift Oil Pumps are running; and that the Main Unit Turbine goes on Turning Gear once zero speed is reached.
5. Maintain the Reactor at Hot Standby condition by:
  - a. Controlling narrow range Steam Generators in the normal operating band (approximately 80% actual level W.R.) with the Auxiliary Feedwater controls in AUTO.
    - 1) STOP turbine driven Auxiliary Feedwater Pump if not needed for level control.

RESPONSE NOT OBTAINED

4. If required contact the Electrical Maintenance Department for starting loads locally.
  - a. Control Steam Generator NR level manually.

NOTE: Refer to Figure #5 for determining Actual vs Indicated Steam Generator Level (attempt to maintain and actual SG level of 78% - 85% on the Wide Range indicator.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 7 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

- b. Verify PZR level being maintained in AUTO by a Charging Pump.

- c. Control RCS pressure at 2235 PSIG by use of the Backup HTRS as needed.

- d. Verify Steam Generator pressure is being maintained at approximately 1005 psig by use of the Condenser Steam Dump. This will be an automatic function unless vacuum is lost in the condenser.

RESPONSE NOT OBTAINED

- b. START a Centrifugal Charging Pump at the Hot Shutdown Panel.

1) STOP the Reciprocating Charging Pump using the control switch at the 4160V Bkr.

2) Manually adjust charging flow to control PZR level and Seal Injection using HIC-128 and HIC-142.

3) Maintain PZR level >20% to insure against a LTDN Isolation.

4) If LTDN Isolation does occur, restore LTDN per Appendix A.

- c. Transfer PZR HTR GRPS 12 and 13 to the Emergency Power Supply, 480V Vital Bkrs 52-1G-72, 52-1H-74.

- d. Control Steam Generator pressure at 1005 psig by Manually operating the 10% Steam Dumps.

NOTE: PZR HTR GRPS 12 and 13 on Emergency Power Supply can ONLY be controlled (when outside the Control Room) by locally closing or opening their breakers for pressure control.

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

- e. Calculate the SDM for Hot and Cold XE Free conditions.
6. Establish or verify communications between the Hot Shutdown Panel [(x1431 Unit 1, x2432 Unit 2)]
- a. Technical Support Center:  
[(x3199 for operator)]  
1) Outside telephone exchange  
2) ERFDS for additional plant monitoring capability.
- b. Dedicated Shutdown Panel [(x1355 Unit 1, x2246 Unit 2)] as necessary.
- c. 480V vital switchgear area [(x1372 Unit 1, x2497 Unit 2)]
- d. 4 KV vital switchgear [(x1747 Unit 1, x2404 x2778 x2706 Unit 2)] area.
7. Maintain SDM using method a. or b. below (method a. is the preferred method):
- a. OPEN Emergency Borate valve, CVCS-8104 from the Hot Shutdown Panel.
- 1) Verify Boric Acid flow on FI-113B at Hot Shutdown Panel.
- a. OPEN Manual Borate valve, CVCS-8471 and shift Boric Acid Pump to fast speed.
- 1) Boric Acid concentration may be determined by either:

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OF-8  
REVISION 6  
DATE 2/3/84  
PAGE 9 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- a. Observing the Boron concentration monitor near the secondary Sample Panel 85 e1 (this monitor is only valid if letdown is in service) OR
- b. By sampling the RCS.
- b. Boration to Hot Xe Free Condition using the BIT.
- 1) CLOSE and verify locally SI-8870 A & B and SI-8911 (BAST to BIT Recirc valves) by securing air to the valve operator at Mech Pnl 74.
  - 2) Manually OPEN MOV 8803 A or B.
  - 3) Manually OPEN MOV 8301 A or B.
  - 4) Manually CLOSE HCV-142 to bypass maximum flow through BIT.
- NOTE: Seal injection to RCPs still required or verify CCW to RCP thermal barriers heat exchangers.
- 5) Based on a BIT flow rate of 120 gpm flush the BIT for 15 min.
  - 6) If additional boron is required, swap charging pump suction to the RWST (open MOV 8805 A and B).

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

- |   |   |
|---|---|
| <p>c. Keep the PZR HTRS energized during the boration.</p> <p>d. Use PZR spray to maintain RCS pressure and permote RCS/PZR Boric Acid mixing. See Appendix B for operation of Normal PZR spray valves.</p> | <p>d. Control Auxiliary PZR Spray by OPENING CVCS-8145 at the Dedicated Shutdown Panel.</p> |
|---|---|

NOTE: Table 5.7-1 of Section 5 of the Technical Specifications limits the number of unheated auxiliary spray cycles if the spray water temperature and pressurizer water temperature differential is  $>320^{\circ}\text{F}$ .

- e. Verify Boron Concentration and good mixing of boron in RCS by sampling:
- 1) RCS Hot Leg
  - 2) PZR liquid
  - 3) LTDN line

NOTE: Satisfactory mixing of boron throughout the RCS should be accomplished after 3-4 RCS Loop Samples which should take about 1 hour.

8. Place Emergency Diesel Generator control selector switch on excitation cubicle to LOCAL position.
  - a. Verify the AUTO/TEST selector switch on local panel in the AUTO position locally in each Diesel Generator room.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 11 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- 9. Place SU FDR breaker transfer switches to LOCAL position on cubicles.
- 10. If there was a loss of OFFSITE power the Emergency Diesel Generator should start automatically and assume the vital bus loads.
  - a. Verify the Emergency Diesel Generators STARTED Automatically and are supplying the 4KV vital buses.
    - 1) 4KV Bus F, G and H voltage indication at the Hot Shutdown Panel.
  - b. Shutdown unnecessary equip. not needed for current plant status.

- a. START the Emergency Diesel Generators locally and energize the 4KV vital buses. (Requires operator locally at bus to parallel). If the diesel generator output breaker does not close due to a fire induced fault at the Control Room, open the switchgear door with a dedicated wrench provided for this purpose, and follow the instructions posted on the inside of the door to mechanically close the breaker.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 12 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

c. Verify that equipment with controls located at Hot Shutdown Panel have restarted after transfer of power to Emergency Diesel Generators.

d. Transfer PZR HTR GRPS 12 and 13 to the Emergency Power Supply, 480V Vital Bkrs 52-1G-72, 52-1H-74. (Refer to OP A-4A).

NOTE: PZR HTR GRPS 12 and 13 on Emergency Power Supply can ONLY be controlled (when outside the Control Room) by locally closing and opening their emergency power breakers for pressure control.

11. Maintain HOT STANDBY until Control Room access is restored and control has been returned to the Control Room.

NOTE: If Control Room access is not restored rapidly, a decision must be reached on HOW LONG to remain in HOT STANDBY and when to start cooling down to COLD SHUTDOWN. The basis for this decision is CST inventory. Refer to Figures IB-1 and 2 in volume 9 of the plant manual for guidance in making this decision. The copies of these figures at the end of the procedure are for information only.

8. TO TAKE THE PLANT FROM HOT STANDBY TO COLD SHUTDOWN FROM OUTSIDE THE CONTROL ROOM

1. Containment entry may be required to accomplish various evolutions in this procedure.

RESPONSE NOT OBTAINED

c. Restart equipment locally if necessary. If the 4KV pump loads cannot be started due to a fire induced fault at the Control Room, open the switchgear with a dedicated wrench provided for this purpose, and follow the instructions posted on the inside of the door to mechanically close the breakers

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 13 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- a. Notify the Rad/Chem Dept. for assistance as necessary in the containment entry.
2. Notify the I&C Dept. for assistance to execute certain steps in the procedure.
3. Calculate the SDM for Cold XE Free Conditions if not previously calculated and borate as necessary.
  - a. Refer to Section A, Step 7 of the procedure for preferred method of Boration
4. Sample the RCS & PZR to ensure boron concentrations are equalized and adequate for cold shutdown.
5. During the cooldown maintain RCS temperature and pressure within the operating bands of Figure 6 at the end of the procedure.
6. Maintain Cold XE Free Boron Concentration by closely monitoring RCS Boron Concentration.
  - a. Remote readout of the boron analyzer is available at the secondary sample panel area 85' E1. (this monitor is only valid if letdown is in service).



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 14 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

7. De-energize all PZR HTRS.
- a. OPEN and RACK OUT Bkrs.
    - 1) Proportional Htrs (52-13D-5)
    - 2) Group 13 (52-13E-2)
    - 3) Group 12 and 14 control switch to OFF.
  - b. If htr groups 12 and 13 are on Backup Supply, OPEN 52-1G-72 and 52-1H-74.
8. Verify that all Control Rod Drive Mechanism cooling fans are in operation.

8. START all fans.
- a. If CRDM cooling fans are NOT in operation due to Loss of Non-vital power GO to Appendix C to Re-energize the Non-Vital Buses.

**CAUTION:** Appendix C will not be carried out without the approval of the Plant Superintendent.

- b. If CRDM cooling fans can not be operated continue with the procedure. This condition is significant during the Natural Circulation cooldown and shall be addressed in Appendix D.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 15 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

9. START RCS cooldown.

a. With forced Reactor Coolant flow do NOT exceed a 75°F/HR cooldown rate. A 50°F/HR cooldown rate is recommended.

b. Slowly increase pressurizer level and maintain pressurizer level  $\approx$  50%.

a. If in a Natural Circulation Mode GO TO APPENDIX D for cooldown instructions.

b. If pressurizer level decreases to <22% STOP cooldown until pressurizer level is recovered.

NOTE: During cooldown, actual PZR level can be determined by using Figure 4 at the end of the procedure. Indicated level at the Dedicated Shutdown Panel (LI-406).

CAUTION: When using the steam generator 10% dumps for cooldown, maintain steam generator pressures balanced to avoid an SI on steam generator differential pressure.

c. To start the cooldown SLOWLY increase the rate of steam flow through the 10% Steam Dumps.

d. Verify Auxiliary Feedwater System is automatically maintaining Steam Generator Narrow Range level at 33%.

e. Monitor the Condensate Storage Tank.

1) If CST level is low, and condensate pumps are available restore CST level by pumping down the condenser hotwell.

c. As an alternate means of cooldown (if condenser available) use handjack on 40% steam dump valve.

d. Manually throttle auxiliary feedwater flow, as necessary.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 16 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- 2) At 10% in the CST refer to Appendix E to shift CST suction to an alternate source.
- f. Reduce RCS pressure using PZR Spray, See Appendix B for Using Normal PZR Spray.

- f. If Auxiliary PZR Spray is preferred OPEN CVCS 8145 at the Dedicated Shutdown Panel.

NOTE: If it is desired to secure normal charging to the RCS, CLOSE CVCS-8146 by installing a pneumatic jumper around SV 200 in PM 45 in Containment.

- g. Maintain sub-cooling margin  $>35^{\circ}\text{F}$  as determined by the following:
  - 1) STEAM TABLES
  - 2) PI-406 RCS Wide Range Pressure (Dedicated Shutdown Panel.)
  - 3) TI-406 RCS Wide Range Loop 1 Hot Leg Temperature (Dedicated Shutdown Panel.)
  - 4) TSC (ERFDS)
- h. During Pressure Reduction OPEN additional orifices as necessary to maintain desired letdown flow.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 17 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

**CAUTION:** AUTO and Manual SI is NOT available with PY 1115 and PY 1418  
**OPEN.** Station an operator at these breakers in communication with the Hot Shutdown Panel. Deactivation is a violation of the Technical Specification and must be approved by a Senior Reactor Operator. This action requires immediate notification of the NRC.

10. When RCS temperature has been reduced below 543°F (as indicated at the Dedicated Shutdown Panel) OPEN the following instrument AC breakers to inhibit HI steam line flow and Low PZR pressure SI.
  - a. PY 1115 Train A Output Cab.
  - b. PY 1418 Train B Output Cab.
11. Reduce primary heat load by reducing the number of RCPs in service.
  - a. As a minimum RCP should remain No. 2 in service to provide Normal PZR Spray Control.
  - b. TRIP the RCPs to be removed from service locally at the 12KV Bkr. cubicle.
  - c. Local indication of RCP vibration and RCP seal injection flows should be observed periodically during cooldown.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 18 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: Maintain  $<25^{\circ}\text{F}$   $\Delta\text{T}$  between loops. The selectable Cold Leg or Hot Leg temperature of RCS loop 1 is directly indicated at the Dedicated Shutdown Panel. The cold leg temperature for loops 2, 3 and 4 can be determined as a function of steam generator pressure and the steam tables.

12. When RCS pressure decreases below 1000 psig close the accumulator outlet valves (one at a time) by performing the following for each of the following breakers:

MOV 8808A 52-1F-46  
MOV 8808B 52-1G-07  
MOV 8808C 52-1H-14  
MOV 8808D 52-1G-05

- a. Lay down close contactor seal-in wire on terminal #4 (inside bkr cubicle).
- b. Close breaker.
- c. Depress close contactor.
- d. When close contactor drops out, immediately re-open breaker. If open contactor picks up before breaker is opened, close valve fully using local handwheel.
- e. Re-lift and tape seal in wire on terminal #4.
- f. Closure of these valves can be verified locally depending on ALARA considerations.

12. If a containment entry is required the accumulator valves may be manually closed locally.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 19 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

13. Continue to cool RCS until the temperature is less than 350°F and pressure is below 390 psig. Maintain pressure by reducing spray flow and energizing PZR heaters.
14. While preparing RHR system for service contact I&C Department to perform the following to expedite RHR operation.
  - a. Install signal simulator units to PM 135 and FM 133 (located in PM 87 on 85' el. of Aux. Bldg.).
  - b. Install pressure gauge upstream of PCV 135 to monitor letdown press.
15. Place RHR system in service on Recirc.
  - a. Manually CLOSE MOV 8809 A & B (RHR to CL 1, 2, 3, & 4).
  - b. Cut in control transfer relays cutout switches on the RHR pump brk. cubicles.
  - c. START RHR pumps locally at their switchgear cubicles.
    - 1) Observe recirc flow established on FIs located outside RHR pump rooms.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 20 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

NOTE: DO NOT allow RHR pumps to run longer than 30 minutes on Recirc.

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

16. Sample RHR recirc line and analyze for Boron Concentration.

17. Verify RHR Boron Conc. equal to or greater than RCS Boron Conc.

17. Recirc RHR system on the RWST.

a. OPEN RHR-8741

b. Resample RHR recirc and reanalyze for Boron Conc.

c. When RHR Boron Conc. is equal to or greater than RCS Boron Conc. CLOSE RHR-8741.

18. Shutdown BOTH RHR pumps.

19. CLOSE MOV-8980 using handwheel.

20. Close the breakers for MOV-8701 (52-1G-25) & 8702 (52-1H-19).

21. OPEN MOV-8702 and 8701.

a. Open by momentarily pushing the open contactor, located inside the breaker panel.

TITLE CONTROL ROOM INACCESSIBILITY

NOTE: The valve is full open when the open contactor drops out. This should take about 100 seconds.

ACTIONS/EXPECTED RESPONSERESPONSE NOT OBTAINED

- b. OPEN the valve breaker when the valve is full open.
  - c. Observe local pump suction pressure indication (which should increase to RCS pressure).
22. OPEN FCV-364 and FCV-365, RHR HX CCW outlet vlvs.
- a. Open by closing air supply valves at air manifold P-85G-01. (FCVs are ATC/FO).
  - b. Observe CCW flow thru HX's local FI's (100' E1 Aux. Bldg.).
23. Start #1 RHR pump on recirc.
- a. Monitor recirc flow locally.
24. Slowly open MOV an increase in observed. Th the RHR syst
- a. Observe indicator of RHR HX (located in RHR HX room).



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 22 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

25. Start #2 RHR pump as per steps 23 and 24 above (except using MOV-8809B).
26. Slowly open MOV-8809A & B to commence further cooldown of RCS.
27. Open RHR Hx Manual Crosstie Valves RHR 8734A & B and establish RHR to letdown by fully opening hCV 133.
28. Regulate letdown flow by controlling PCV 135.
29. When condenser vacuum can no longer be maintained, proceed as follows:
  - a. Condenser vacuum can be observed at the main unit turbine pedestal on PI 256, or on local indicator in PM 177 on 104' El. (near PY 17).
  - b. Terminate condenser steam dump (if in use).
  - c. Break condenser vacuum.
  - d. Shutdown the air ejectors and secure shaft seal system on the main feed pumps and main unit turbine.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 23 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

30. Open DC Control power to SI pumps at breakers 52-HH-15 and 52-HF-15 and manually shut valve MOV-8835. (SI to C.L. 1, 2, 3 and 4).
31. Reduce letdown flow less than charging flow to begin increasing PZR level to approx. 90%.
32. When RCS cold leg temperature has been reduced to 323°F perform the following:
  - a. Verify only one charging pump operable.
  - b. Verify both SI pumps inoperable.
  - c. Verify MOV5 8701 and 8702 are CPEN.
  - d. Rack out the valves and inoperable pump.
  - e. Notify the NRC that pressurizer PORV LOW PRESSURE protection is not available until access to the control room is re-established.
33. When RCS temp. is reduced below 200°F, fill the steam generators all the way and place in wet layup.

TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSERESPONSE NOT OBTAINED

34. Ensure shutdown margin remains greater than 1.0%  $\Delta$  K/K.

35. Fill the PZR.

NOTE: While filling and cooling down the PZR with auxiliary spray, ensure the PZR cooldown rate does not exceed 200°F/HR.

36. Shutdown remaining RCP's when the RCS temp. is below 160°F.

37. Continue to cooldown the PZR until the PZR temp. is below 150°F.

CAUTION: Depressurizing the RCS before the entire RCS is below 200°F may result in void formation in the system.

38. Continue Cooldown of Inactive Portion of RCS:

a. Upper head region - ALL CRDM FANS RUNNING.

b. Steam Generator U-Tubes - CONTINUE DUMPING STEAM from all steam generators until it is VERIFIED that they have stopped steaming.

a. IF fans NOT running, THEN DO NOT depressurize RCS until upper head cools to less than 200°F (approximately 27 hours after RHR system is placed in service).

b. DO NOT depressurize RCS until steam generators have stopped steaming.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 25 OF 56


TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

39. Reduce the system pressure to approx. 50 psi by reducing charging flow and increasing RHR letdown flow.
40. Shutdown the charging pump.
41. Stop any spray flow in progress and close the RHR letdown valve HCV 133.
42. Leave the RHR system in service recirculating from hot leg 4 to the cold legs.
43. After approximately 72 hours of cooling, one RHR train and related auxiliary systems may be shut down. The remaining RHR train must remain in service.

FIGURE IF-1  
REQUIRED CONDENSATE STORAGE CAPACITY AS A FUNCTION  
OF STANDBY TIME AND COOLDOWN TIME (RATED  $Mw_t = 3423$ )




ORNL - McDonough Letter Pd 101 (December 7, 1975)

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 27 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

REQUIRED CONDENSATE LEVEL TO MAINTAIN  
A GIVEN HOT STANDBY TIME (RATED  $MW_t = 3423$ )




HOT STANDBY TIME (HOURS) FIGURE IB-2

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 28 OF 56

TITLE CONTROL ROOM INACCESSIBILITY


### REQUIRED LEVEL OF CONDENSATE TO COOLDOWN TO 350F



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 29 OF 56


TITLE CONTROL ROOM INACCESSIBILITY



LI-406  
PRESSURIZER LEVEL CORRECTION CURVES FOR PRESSURIZER PRESSURES (PSIG)  
(CONTAINMENT TEMPERATURE=100°F EXCEPT AT : 0 PSIG, 70°F)  
FIGURE 4



TITLE CONTROL ROOM INACCESSIBILITY



INDICATED LEVEL (% OF SPAN)  
STEAM GENERATOR LEVEL (WIDE RANGE) CORRECTION CURVES  
FOR STEAM GENERATOR PRESSURE (PSIG)  
(CONTAINMENT TEMPERATURE-100°F)  
FIGURE 5

TITLE CONTROL ROOM INACCESSIBILITY




FIGURE 6

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 32 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

APPENDIX A

LETDOWN ISOLATION

Should letdown isolation occur due to low PZR level, proceed as follows:

1. Place control switch(s) for LTDN orifice valve(s) in CLOSED position.
2. Re-establish PZR level via charging flow control.
3. At nuclear auxiliary relay rack "B", depress and hold in energized position relays 33aoX / LCV 459 and 33aoX / LCV 460 for approx. 10 seconds.

NOTE: Relays 33aoX / LCV 459 and 33aoX / LCV 460 are located in the top right hand corner of RNARB (cable spreading rm. 128' el.) and are appropriately labeled.

4. Open letdown orifice isolation valve(s) as required from the hot shutdown panel.
5. Check letdown flow re-established.
6. Restore Group I Pressurizer Heaters by reclosing 52-13D-05 locally.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 33 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

APPENDIX B

PRESSURIZER SPRAY ACTUATION

1. This method uses a normal pressurizer spray valve and requires a RCP associated with its respective spray valve to be in operation.
  - a. To use PCV 455A (Loop 1):
    - 1) Contact the I&C Dept. and have them disconnect the output of PC 455G in Hagan Rack 19 at TB H leads #9 and #10, and install a 4-20 ma current source (Transmation model 1040 or equivalent) to the disconnected leads. This will allow for modulation of PCV 455A.
    - 2) Establish phone communications between the Hot Shutdown Panel and Hagan rack area.
    - 3) Increasing current to the valve will cause increased opening of the valve.
    - 4) When the valve is closed and operation of the valve is not required, turn off transmation unit.
  - b. To use PCV 455B (Loop 2)
    - 1) Contact the I&C Dept. and have them disconnect the output of PC 455F in Hagan Rack 19 at TB H leads #5 and #6, and install a 4-20 ma current source (Trasmation model 1040 or equiv.) to the disconnected leads. This will allow for modulation of PCV 455B.
    - 2) Establish phone communications between the Hot Shutdown Panel and Hagan rack area.
    - 3) Increasing current to the valve will cause increased opening of the valve.
    - 4) When the valve is closed and operation of the valve is not required, turn off transmation unit.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP UP-8  
REVISION 8  
DATE 2/3/84  
PAGE 34 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

APPENDIX C  
ENERGIZING NON-VITAL 480V BUSES WITH DIESEL GENERATOR

DISCUSSION

This procedure is written using the 12 diesel generator as the source of power for the non vital bus. This does not preclude the use of 11 or 13 diesel generator in which case the buses and breakers unique to the 11 or 13 diesel generator would be substituted for the respective diesel generator buses and breakers.

PROCEDURE

1. At 4KV Bus G Switchgear Room, remove the non-essential loads from 4KV Bus G.
  2. At 4KV Bus G Switchgear Room:
    - a. Open S.U. power to vital buses F, G, H 52-HG-15.
    - b. Verify cut in all 1-2 D.G. Protection service.
  3. At the 12KV Switchgear room perform the following:
    - a. Open or check open 52-VU-14, S.U. Transformer 1-2 Feeder ACB. Then open the DC control power.
1. Leave the 480V M.C.C. connected, transfer to redundant pumps on 4KV busses F or H if possible.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 35 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

b. For the following ACB's on 4KV Bus E OPEN or check OPEN the ACB THEN OPEN the DC Control power.

- 1) 52-HE-2 AUX. Feeder to 4KV Bus E.
- 2) 52-HE-3 S.U. Feeder to 4KV Bus E.
- 3) 52-HE-6 No. 2 Heater Drip Pump ACB.
- 4) 52-HE-11, Condensate and Booster Pump 12 ACB.
- 5) 52-HE-9, Condensate and Booster Pump 13 ACB.
- 6) 52-HE-12, 480V Bus 15E Feeder ACB.
- 7) 52-HE-4, 480V Bus 13E Feeder ACB.
- 8) 52-HE-5, 480V Bus 12E Feeder ACB.
- 9) 52-HE-8, 480V Bus 11E Feeder ACB.
- 10) 52-HE-7, Station Service Feeder to 500 KV Swyd.

c. For the following ACB's on 4KV Bus D OPEN or check OPEN the ACB THEN OPEN the DC Control power.

- 1) 52-HD-14 S.U. Feeder to 4KV Bus D

TITLE CONTROL ROOM INACCESSIBILITY

- 2) 52-HD-15, Aux. Feeder to 4KV Bus D
  - 3) 52-HD-7, Condenser Vacuum Pump ACB
  - 4) 52-HD-9, Condensate and Booster Pump 1-1 ACB
  - 5) 52-HD-11, Station Service Feeder to 230KV Swyd.
  - 6) 52-HD-8, 480V Bus 14D Feeder ACB
4. At 480V Bus 11D, open all 480V breakers except 52-11D-02. Verify tie breaker 52-11DE is open.
  5. At 480V bus 15D, open all 480V breakers except 52-15D-02, verify tie breaker 52-15DE is open.
  6. At 480V bus 12D, open all breakers except 52-12D-02, 52-12DM and 52-12DJ. Verify tie breaker 52-12DE is open.
  7. At 480V bus 12J, open all 480V breakers.
  8. At 480V bus 13D, open all 480V breakers except 52-13D-02. Verify tie breaker 52-13DE is open. Cut out DC control to pressurizer heater ACB's 52-13D-05, 52-13D-06.
  9. At 480V Bus 12M, open all 480V breakers except 52-12MD. Verify tie breaker 52-12MN is open.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 37 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

10. At 4KV Bus G, manually close 52-HG-14, start-up feeder to Bus G.
11. At 4KV Bus D, manually close 52-HD-14, start-up feeder to Bus D.
12. At 4KV Bus E, manually close 52-HE-3, start-up feeder to Bus E.
13. Locally close 52-HG-15 to energize 4KV Bus D from 1-2 diesel generator. Closely watch diesel generator during this operation for any sign of instability.

NOTE: There will be a short load surge on the Diesel Generator as the startup transformer 12 is energized.

CAUTION: If the diesel generator appears unstable during this step or at any time beyond this point in the procedure, immediately open 52-HG-15 to separate the diesel from the nonvital system.

14. Locally at the switchgear energize the 480V buses by the following actions:
  - a. Close 52-HD-10 to energize 480V Bus 11D.
  - b. Close 52-HD-12 to energize 480V Busses 12D, 12M, 12J.
  - c. Close 52-HD-13 to energize 480V Bus 13D.
  - d. Close 52-HD-6 to energize 480V Bus 15D.



TITLE CONTROL ROOM INACCESSIBILITY

15. Make available, rack in the breakers and start the following equipment, if necessary.
  - a. Plant air compressors.
  - b. Control rod drive shroud coolers.
  - c. Service cooling water pump.
  - d. Turbine-generator lift pump, turning gear drive. Place turbine on gear if possible.
  
16. If the 500KV and 230KV Swyd compressed air systems need returned to service perform the following:
  - a. Locally at 4KV Bus E manually close 52-HE-7.
  - b. Dispatch an operator to the 500KV Switchyard to verify closed or CLOSE the local 4KV bus feeder breaker in the 500KV switchyard.
  - c. Operator should also verify 480V bus is energized and 500KV switchgear compressed air system is available.
  - d. Operator should verify 230KV yard 4KV bus is energized via the emergency tie cable and its compressed air system is available.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 39 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

17. Additional equipment deemed necessary may be started at the discretion of the Shift Foreman. During any new operations close attention should be paid to diesel generator conditions.

TITLE CONTROL ROOM INACCESSIBILITY

## APPENDIX D

TO TAKE THE PLANT FROM HOT STANDBY TO COLD SHUTDOWN FROM OUTSIDE THE CONTROL ROOM USING NATURAL CIRCULATION.

PREREQUISITE

This Appendix procedure assumes all conditions up to and including Section B, Step 8 of the Operator Actions of EP OP-8 Control Room Inaccessibility have been met.

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

1. START RCS Cooldown.
  - a. Maintain cooldown rate less than 25°F/HR.
  - b. Slowly increase pressurizer level and maintain pressurizer level ~50%.
  - b. If pressurizer level decreases to <22% STOP cooldown until

NOTE: During cooldown, actual PZR level can be determined by using Figure 4 at the end of the procedure and indicated level at the Dedicated Shutdown Panel (LI-406).

CAUTION: When using the steam generator 10% dumps for cooldown, maintain steam generator pressures balanced to avoid an SI on steam generator differential pressure.

- c. To start the cooldown SLOWLY increase the rate of steam flow through the 10% Steam Dumps.
- d. Verify Auxiliary Feedwater System is automatically maintaining Steam Generator Narrow Range level at 33%.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 41 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

e. Monitor the Condensate Storage Tank.

1) If CST level is low, and condensate pumps are available restore CST level by pumping down the condenser hotwell.

2) At 10% in the CST refer to Appendix E of this procedure to shift CST suction to an alternate source.

2. Check RCS Hot Leg Temperature:

a. RCS Hot Leg temperature - LESS THAN 550°F (as indicated at the Dedicated Shutdown Panel).

a. DO NOT proceed until RCS Hot Leg temperature is less than 550°F.

**CAUTION:** AUTO and MANUAL SI is NOT available with PY 1115 and PY 1418 OPEN. Station an operator at these breakers in communication with the Hot Shutdown Panel. Deactivation is a violation of the Technical Specification and must be approved by a Senior Reactor Operator. This action requires immediate notification of the NRC.

3. When RCS temperature has been reduced below 543°F ( as indicated at the Dedicated Shutdown Panel) OPEN the following instrument AC breakers to inhibit HI steam line flow and Low Pzr pressure SI.

DIABLO CANYON POWER PLANT UNIT NO(S): 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 42 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- a. PY 1115 Train A Output Cab.
- b. PY 1418 Train B Output Cab.
4. Commence depressurizing the RCS to approximately 1865 psig.
  - a. Depressurize RCS using pressurizer auxiliary spray, CVCS-8145 (Dedicated Shutdown Panel).

NOTE: Table 5.7-1 of Section 5 of the Technical Specifications limits the number of unheated auxiliary spray cycles if the spray water temperature and pressurizer water temperature differential is  $>320^{\circ}\text{F}$ .

5. Maintain the following RCS conditions:
  - a. RCS pressure - about 1865 psig.
  - b. Pressurizer level - about 50%.
  - c. RCS cooldown rate - Less than  $25^{\circ}\text{F/hr}$ .
  - d. Less than  $25^{\circ}\text{F } \Delta\text{T}$  between loops as determined by TI-406 and Steam Generator pressure for selected to Loop 1 Cold Leg and loops 2, 3 and 4.

DIABLO CANYON POWER PLANT UNIT NOIS: 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 43 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

6. Verify RCS cooldown:

- a. Wide Range Loop 1 Hot Leg RTD temperature-trending down (TI-406 at Dedicated Shutdown Panel).
- b. RCS subcooling - increasing (minimum of 50°F) as determined by:
  - 1) STEAM TABLES
  - 2) PI-406 RCS Wide Range Pressure (Dedicated Shutdown Panel).
  - 3) TI-406 (selected to Loop 1 Hot Leg).

7. Depressurize RCS as follows:

- a. If all CRDM fans are running maintain 50°F subcooling.
- b. Depressurize using auxiliary spray, CVCS-8145 (Dedicated Shutdown Panel).

- a. If all CRDM cooling fans are NOT available for operation:

- 1) Maintain 200°F subcooling until RCS pressure is 1200 psig.
- 2) Maintain RCS pressure at 1865 psig until RCS temperature is cooled down to 430°F.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 44 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

8. Continued RCS cooldown AND depressurization:

a. Maintain cooldown rate - LESS THAN 25°F/hr.

b. Maintain subcooling requirements of step 5.

c. Maintain the reactor coolant system pressure-temperature relationship within the boundaries of the Plant Cooldown Curve. Figure 6 at the end of the main procedure.

9. Verify NO voiding in Reactor Vessel Head Area.

a. Pressurizer level RESPONSE NORMAL.

10. If all CRDM fans are NOT in operation:

a. Maintain RCS at 1200 psig while continuing to cooldown to 350°F.

b. If the required subcooling cannot be maintained, STOP the depressurization and re-establish the required subcooling.

9. If voiding is suspected due to large variations in pressurizer level THEN repressurize the RCS to collapse the void in the head area.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 45 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- b. In Technical Support Center use ERFDS channel, observe TT-25 thermocouple in Reactor Vessel Head.
- 1) Do not depressurize to <1200 psig until upperhead area is less than saturation temperature for 400 psig (445°F).
11. Check if SI system should be disabled:
- a. RCS pressure - Less than 1000 psig but greater than 700 psig.
- b. Average RCS temperature - LESS 350°F but RCS cold leg temperature greater than 323°F.
- c. Isolate SI accumulators.
- b. Maintain 1200 psig for approximately 8 hours to allow the upperhead to cool off to a temperature less than saturation for 400 psig (445°F) before continuing with the depressurization.
- a. DO NOT disable any SI system equipment if greater than 1000 psig.
- b. DO NOT disable any SI system equipment if Average RCS temperature is greater than 350°F.
- c. If NO ALARA considerations required and containment entry is necessary, SI accumulators may be isolated manually.



DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 46 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- 1) Close each isolation valve (one at a time) by performing the following for each of the following breakers:

MOV 8808A 52-1F-46  
MOV 8808B 52-1G-07  
MOV 8808C 52-1H-14  
MOV 8808D 52-1G-05

- a) Lay down close contactor seal-in wire on terminal #4 (inside bkr cubicle).
- b) Close breaker.
- c) Depress close contactor.
- d) When close contactor drops out, immediately re-open breaker. If open contactor picks up before breaker is opened, close valve fully using local handwheel.
- e) Re-lift and tape seal in wire on terminal #4.

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- f) Closure of these valves can be verified locally depending on ALARA considerations.
- 2) Rack out each isolation valve breaker.
- d. Disable the safety injection pumps by opening the DC control power to the pump breaker.
- e. Disable the non-operating centrifugal charging pump by opening the DC control power to the pump breaker.
- 12. Open additional letdown orifices if necessary to maintain normal letdown flow.
- 13. Maintain adequate RCP Seal Injection Flow.
  - a. Adjust HCV-142, as necessary.
- 14. When system pressure has been reduced to approximately 400 psig, hold it constant at this value by reducing auxiliary spray flow and energizing the PZR heaters as necessary.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 48 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

15. When RCS hot leg temperature has been reduced to less than 350°F and pressure is between 380-420 psig, place the RHR system in service recirculating from hot leg 4 to the cold legs as follows:

- a. While preparing RHR System for service contact I&C Department to perform the following:
  - 1) Install signal simulator units to PM 135 and FM 133 (located in PM 87 on 85' el. of Aux. Bldg.).
  - 2) Install pressure gauge upstream of PCV 135 to monitor letdown press.
- b. Manually CLOSE MOV 8809A & B (RHR to CL 1,2,3&4).
- c. CUT IN control transfer relays cutout switches on the RHR pump bkr. cubicles.
- d. START RHR pumps locally at their switchgear cubicles.
  - 1) Observe recirc flow established on FI's located outside RHR pump rooms.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 49 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

NOTE: DO NOT allow RHR pumps to run longer than 30 minutes on Recirc.

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- e. Sample RHR recirc line and analyze for Boron Conc.
- f. Verify RHR Boron Conc. equal to or greater than RCS Boron Conc.
- g. Shutdown BOTH RHR pumps. CLOSE MOV-8980 using handwheel.
- h. Close the breakers for MOV-8701 (52-1G-25) & 8702 (52-1H-19).
- i. OPEN MOV-8702 and 8701.
  - 1) Open by momentarily pushing the open contactor, located inside the breaker panel.

- f. Recirc RHR system on the RWST.
  - 1) OPEN RHR-8741
  - 2) Resample RHR recirc and reanalyze for Boron Conc.
  - 3) When RHR Boron Conc. is equal to or greater than RCS Boron Conc. CLOSE RHR-8741.

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

NOTE: The valve is full open when the open contactor drops out. This should take about 100 seconds.

- 2) OPEN the valve breaker when the valve is full open.
  - 3) Rack out motor breakers for MOV 8701 and 8702.
  - 4) Observe local pump suction pressure indication (which should increase to RCS pressure).
- j. OPEN FCV-364 and FCV-365, RHR Hx CCW outlet vlv's.
- 1) Open by closing air supply valves at air manifold P-85G-01. (FCV's are ATC/FO)
  - 2) Observe CCW flow thru HX's local FI's (100' E1 Aux. Bldg.)
- k. Start #1 RHR pump on recirc.
- 1) Monitor recirc. flow locally.
- l. Slowly open MOV-8809A until an increase in flow is observed. This is to allow the RHR system to heat up.

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSERESPONSE NOT OBTAINED

- 1) Observe local temperature indicator on RCS outlet of RHR HX (located in RHR HX room).
- m. Start #2 RHR pump as per steps k and l above (except using MOV-8809B).
- n. Slowly open MOV-8809A & B to commence further cooldown of RCS.
16. Open RHR HX Manual crosstie valves RHR-8734A & B and establish RHR to letdown by fully opening HCV 133.
17. Regulate letdown flow by controlling PCV 135.
18. When RCS cold leg temperature reduces to <math>323^{\circ}\text{F}</math> notify the NRC that Pressurizer PORV Low Pressure Protection will not be available, until the control room accessibility is re-established.
19. Reduce letdown flow less than charging flow to begin increasing PZR level to approx. 90%.
20. When RCS temp. is reduced below  $200^{\circ}\text{F}$ , fill the steam generators all the way and place in wet layup.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 52 OF 66

TITLE CONTROL ROOM INACCESSIBILITY

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

21. Ensure shutdown margin  
remains greater than 1.0%  $\Delta$   
K/K.

22. Fill the PZR.

NOTE: While filling and cooling down the PZR with auxiliary spray,  
ensure the PZR cooldown rate does not exceed 200°F/HR.

23. Return to Section 8 Step 37  
of Main Procedure.

TITLE CONTROL ROOM INACCESSIBILITY

## APPENDIX E

AUXILIARY FEED PUMP SUCTION SUPPLY FROM FIRE WATER TANK

The operator has 20 minutes to perform this operation after the 10 10 level alarm on the condensate storage tank and before the AFW pumps lose suction. This provides sufficient time; however, the operator must not delay and must carry out the valve line up in order as written.

If the AFW pumps are being supplied from the raw water reservoir and a seismic event occurs with resultant loss of AFW suction and auxiliary feedwater flow to the steam generators, the steam generators will boil dry in about 30 minutes. Under these conditions, it is especially important to expedite this procedure and re-establish AFW flow to the steam generators prior to the reactor losing its heat sink.

ACTIONSCOMMENTS

Using the attached drawing, proceed to supply the AFW pumps suction from the fire water tank.

1. Close or verify closed MU-0-284 and MU-0-286.
2. Close or check closed MU-1-298.
3. Close or check closed MU-0-325.
4. Close or check closed MU-0-427.
5. Open FP-0-306 and FP-0-307.
6. Notify the control room that the suction for the AFW pumps is now available from the fire water tank.
7. Locally open FCV-436 and 437.

1. Closing these valves prevents losing fire water out a possible break in the reservoir supply line.



DIABLO CANYON POWER PLANT (UNIT NO. S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 54 OF 56


TITLE CONTROL ROOM INACCESSIBILITY

ACTIONS

COMMENTS

8. Proceed to the auxiliary feedwater pumps and vent the pump casings if required to remove air.

APPENDIX E



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-8  
REVISION 8  
DATE 2/3/84  
PAGE 56 OF 56

TITLE CONTROL ROOM INACCESSIBILITY

APPENDIX Z

NOTIFICATION INSTRUCTIONS

1. When this procedure has been activated and upon direction from the Shift Foreman, proceed as follows:
  - a. Designate this event an Alert. Notify plant staff and response organizations required for this classification by implementing Emergency Procedure G-2 "Establishment of the Onsite Emergency Organization" and G-3 Emergency Procedure "Notification of Offsite Organizations" in accordance with Emergency Procedure G-1 "Accident Classification and Emergency Plan Activation."
  - b. If, after evacuation of the Control Room, control of shutdown systems cannot be established within 15 minutes, redesignate this event as a Site Area Emergency. Notify plant staff and response organizations required by EP G-2 and EP G-3 in accordance with EP G-1.

NOTE: Notification requirement must be carried out either at the Technical Support Center or Administration Building communication equipment.



Pacific Gas and Electric Company

NUMBER EP OP-13



DEPARTMENT OF NUCLEAR PLANT OPERATIONS

REVISION 3

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

DATE 2/1/84

TITLE EMERGENCY OPERATING PROCEDURE  
MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

PAGE 1 OF 9

APPROVED

R. C. Thompson  
PLANT MANAGER

2-27-84

DATE

IMPORTANT  
TO  
SAFETY

### SCOPE

The purpose of this procedure is to provide instructions to be followed in the event of a malfunction of the reactor pressure control system. For simplicity, this procedure is subdivided into four parts as follows:

- PART A: Pressurizer Pressure Channel fails high.
- PART B: Stuck open spray valve.
- PART C: Pressurizer heater malfunction.
- PART D: Stuck open or leaking power operated relief valve.

This procedure and changes thereto requires PSRC review.

### PART A: PRESSURIZER CHANNEL FAILS HIGH

#### SYMPTOMS

1. Failed channel will indicate high pressure. Give the high pressurizer pressure alarm (PK05-16) and trip the associated reactor trip bystable (PK05-6).
2. Other pressure channels show actual pressure is decreasing and gives low pressure alarm (PK05-17).
3. PRT pressure, level and temperature indicators on VB-2 show abnormally high indication.
4. "Pressurizer PORV Temperature High" annunciator alarms (PK05-23).

#### AUTOMATIC ACTIONS

1. If the controlling channel fails high.
  - a. Both spray valves open.
  - b. All pressurizer heaters de-energized.
  - c. PCV-455C opens (closes again when pressure decreases to 2185 psig).

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-13  
REVISION 3  
DATE 2/1/84  
PAGE 2 OF 9

TITLE: MANFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

2. If the selected protection channel fails high, PCV-474 and PCV-456 will open (but close when actual pressure decreases to 2185 psig).
3. Possible reactor trip on low pressure.
4. Possible safety injection signal on low pressure.

#### OBJECTIVES

1. To regain pressure control by selecting the alternate control channel to terminate event without a reactor trip.
2. To restore pressurizer pressure and level to reference values.
3. To trip all the bistables associated with the failed channel within one hour.

#### IMMEDIATE OPERATOR ACTIONS

##### ACTION

##### COMMENTS

1. Select alternate channel for pressure control on selector switch P/455A.
  2. Verify spray valves closed, PORV's closed and heaters energized.
  3. If step 2 does not occur, place the master pressure controller (HC-455K) in manual and return pressure to normal.
  4. Stop any unit load changes in progress.
  5. If a reactor trip occurs, refer to Emergency Operating Procedure No. OP-5
  6. If a safety injection occurs, refer to Emergency Operating Procedure No. OP-0.
1. Insure that the position selected does not utilize the defective channel.

#### SUBSEQUENT OPERATOR ACTIONS

##### ACTION

##### COMMENTS

1. Select the pressurizer pressure recorder to record a valid pressure channel (P/455B).

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-13  
REVISION 3  
DATE 2/1/84  
PAGE 3 OF 9

TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

ACTION

COMMENTS

2. If a reactor trip does not occur:

a. Ensure pressurizer level and pressure return to their normal value.

b. Within one hour trip, all the by-stables associated with the failed pressurizer pressure channel.

b. See Table III A-1 in Volume 9 of DCPD Plant Manual.

3. Refer to Operating Procedure No. A-48 to return the PRT to normal.

PART B: STUCK OPEN SPRAY VALVE

SYMPTOMS

1. All pressurizer pressure channels show decreasing pressure.
2. Low pressurizer pressure alarm (PK05-17).
3. Pressurizer heaters and spray on at the same time.
4. Pressurizer surge line temperature is lower than normal due to upsurge and will give an alarm.

AUTOMATIC ACTIONS

1. Backup heater energize.
2. Possible reactor trip on low pressure.
3. Possible safety injection signal.

OBJECTIVES

1. To terminate spray valve action.
2. To restore pressure control.

## TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

IMMEDIATE OPERATOR ACTIONACTIONCOMMENTS

1. Place affected spray valve controller to manual and close the spray valve.
2. If spray valve does not completely close, ensure all heater groups are energized.
3. Quickly drop load, if necessary, to reduce the power level to about 20%. Then trip the reactor coolant pump of the loop associated with the defective spray valve.

3. If the RCP is tripped at a power level much greater than 20%, the reactor will probably trip on low steam generator level. If the RCP is tripped above 35% power, the reactor will trip.

NOTE: Loop No. 1 feeds PCV-455A and Loop No. 2 feeds PCV-455B.

4. If step 3, above, results in a reactor trip, then:
  - a. Trip the reactor coolant pump of the loop associated with the affected spray valve.
  - b. Proceed to Emergency Operating Procedure No. OP-5.
5. If a safety injection occurs, proceed to Emergency Operating Procedure No. OP-0.

SUBSEQUENT OPERATOR ACTIONSACTIONCOMMENTS

1. If system pressure was maintained without a reactor trip.
  - a. Return system to normal pressure by manual heater operation.
  - a. Use the minimum number of heater banks to maintain pressure.

## TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

<u>ACTION</u>	<u>COMMENTS</u>
b. If normal spray is not useable or ineffective when system pressure is restored, use auxiliary spray or use a pressurizer relief. Follow step No. 1C or 1D below.	
c. If auxiliary spray is needed.	
1) Ensure letdown is not isolated.	1) If letdown is isolated or becomes isolated, auxiliary spray cannot be used due to the $\Delta T$ limit (Tech Spec 3.4.9.2).
2) Close the normal charging path to the reactor coolant loop.	
3) Monitor and maintain adequate RCP seal injection.	
4) Open auxiliary spray valve to control pressure.	
d. If a pressurizer relief is needed for pressure control,	
1) Close one pressurizer relief isolation valve.	
2) When the isolation valve is closed, open its' associated PORV.	
3) The motor operated isolation valve can now be jogged for pressure control.	
e. If a spray valve is stuck open, evaluate the conditions necessary for containment entry to repair or isolate the defective valve.	
f. If the defective valve was closed, repair if possible or evaluate plant conditions to determine the feasibility of continued power operation in such a mode.	



TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

PART C: PRESSURIZER HEATER MALFUNCTION

SYMPTOMS

The following are symptoms for 3 possible failures:

1. If controlling pressurizer heater channel fails low.
  - a. Low pressurizer pressure and alarm (PK05-17) on defective channel.
  - b. High pressurizer pressure and alarm (PK05-16) on other channels.
  - c. Pressurizer high temperature alarm (PK05-18).
  - d. No automatic initiation of sprays.
2. If heaters fail to de-energize.
  - a. Pressurizer sprays and heater operating simultaneously.
3. Loss of pressurizer heaters.
  - a. Low pressurizer pressure on all channels and alarm (PK05-17).
  - b. No automatic initiation of pressurizer heaters.

AUTOMATIC ACTIONS

1. If controlling channel fails low, backup heaters will energize and soon pressurizer power operated relief valves will open when actual pressurizer pressure reaches 2335 psig.
2. If the heaters fail to deenergize automatically, pressurizer sprays will actuate to maintain pressure.

OBJECTIVES

1. To maintain pressure with manual control of heaters if it is determined that the pressurizer heaters are malfunctioning.
2. To reestablish automatic pressure control by selecting the alternate pressurizer control channel.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-13  
REVISION 3  
DATE 2/1/84  
PAGE 7 OF 9

TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

IMMEDIATE OPERATOR ACTIONS

ACTION

COMMENTS

1. Take manual control of heaters and restore pressure to normal setpoint value.
2. If the controlling pressurizer pressure channel failed low, select the alternate control channel and reestablish normal auto pressure control
3. Stop any unit load change in progress

SUBSEQUENT OPERATOR ACTIONS

ACTION

COMMENTS

1. With a failed pressurizer pressure channel, within one hour trip all the bistables associated with the failed pressurizer pressure channel.

PART D: STUCK OPEN OR LEAKING POWER OPERATED RELIEF VALVE

SYMPTOMS

1. Low pressurizer pressure indication and alarm.
2. Pressurizer relief tank pressure, level and temperature indicators read high (VB-2).
3. Pressurizer relief valve discharge temperature indicator reads high (VB-2).
4. Pressurizer PORV high temperature alarm (PK05-23).

AUTOMATIC ACTIONS

1. Backup heaters energize.
2. Reactor trip on low pressurizer pressure.
3. Safety injection on low pressurizer pressure.

TITLE: MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

IMMEDIATE OPERATOR ACTIONS

ACTIONS

COMMENTS

1. If the defective relief valve can be identified by position lights, close its motor operated isolation valve.
2. If the defective valve cannot be identified by position lights, close all three motor operated PORV isolation valves.
3. If the reactor trips, refer to Emergency Operating Procedure No. OP-5.
4. If a safety injection occurs, refer to Emergency Operating Procedure No. OP-0.

SUBSEQUENT OPERATOR ACTIONS

ACTIONS

COMMENTS

1. If the defective relief valve is isolated without a reactor trip, restore pressurizer pressure and level to reference values.
2. If the defective valve was not identified:
  - a. Wait until the discharge header temperature decreases.
  - b. One at a time, crack open a motor operated isolation valve and identify the defective PORV.
  - c. When identified, close the associated isolation valve at the faulted PORV.
  - d. Open the isolation valves on the unaffected relief valves.
3. With abnormal conditions in the PRT, refer to Operating Procedure No. A-4B.

b. Identify by using the discharge header temperature, PRT conditions and RCS pressure fluxuations.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-13

REVISION 3

DATE 2/1/84

PAGE 9 OF 9

TITLE MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM

APPENDIX Z

EMERGENCY PROCEDURE NOTIFICATION INSTRUCTIONS

1. When this emergency procedure has been activated and upon direction from the Shift Foreman, proceed as follows:
  - a. Notify the Plant Superintendent, Supervisor of Operations and Plant Manager or their designated alternates.
  - b. Designate this event a Significant Event. As a minimum, within one hour notify the NRC Operations Center using the red phone in the Control Room. Gather sufficient information from all sources prior to calling so that the phone call is meaningful. Refer to Operating Procedure O-4 "Operating Order (One Hour Reporting Requirements to the NRC)" for a suggested format for this report. Notify the NRC that your call is pursuant to 10 CFR Part 50.72, (Notification of Significant Events).
  - c. If the pressure transient results in one of the following:
    - 1) Overtemperature  $\Delta T$  or Overpower  $\Delta T$  protection channel activated and not as a result of instrument failure.
    - 2) Exceeding the DNB parameters of technical specification 3.2.5. while in mode 1.
    - 3) Failure of a relief or safety valve to close.

Designate this event a Notification of Unusual Event. Notify Plant staff and response organizations required for this classification by implementing procedures G-2 "Establishment of the On-Site Emergency Organization" and G-3 "Notification of Off-Site Organizations" in accordance with Emergency Procedure G-1 "Accident Classification and Emergency Plan Activation".



Pacific Gas and Electric Company

NUMBER EP OP-25



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

REVISION 2

DATE 2/2/84

TITLE: EMERGENCY OPERATING PROCEDURE  
TANK RUPTURES

PAGE 1 OF 4

APPROVED: R. C. Thornburg  
PLANT MANAGER

2-27-84

DATE

IMPORTANT  
TO  
SAFETY

SCOPE

This procedure outlines the steps to take in the event a gas decay tank, liquid holdup tank or volume control tank ruptures and releases radioactive gas and/or liquid to the auxiliary building.

This procedure and changes thereto requires PSRC review.

SYMPTOMS

1. Plant vent monitor high radiation alarm and containment ventilation isolation.
2. Possible LHUT or VCT low level alarm.
3. Gas decay tank, LHUT, or VCT low pressure alarm.
4. Persons near the affected areas may find themselves contaminated when checking out at access control or exposed to above normal radiation levels.

AUTOMATIC ACTIONS

1. High radiation on plant vent air particulate monitors (R-28 A or B) or plant vent radio gas monitors (R-14 A or B) initiates containment ventilation isolation.
2. At 5% VCT level charging pump suction valves from RWST 8805 A & B open and VCT outlet valves LCV's 112 B & C close.
3. Low pressure or low level in LHUT trips LHUT recirculation pump.

OBJECTIVES

1. Alert on site personnel.
2. Evaluate the release and take appropriate protective measure.

IMMEDIATE OPERATOR ACTIONS

ACTIONS

1. Initiate the site emergency signal

COMMENTS

1. Evacuation of personnel from affected area

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-25  
REVISION 2  
DATE 2/2/84  
PAGE 2 OF 4

TITLE TANK RUPTURES

ACTIONS

2. Place auxiliary building ventilation in charcoal filter mode by SI test signal at POV 2.
3. Either shutdown or place the unaffected units auxiliary building ventilation system in the charcoal filter mode of operation.

COMMENTS

2. To reduce Iodine release from plant vent.

SUBSEQUENT OPERATOR ACTIONS

ACTIONS

1. Evacuate all personnel from the affected area.
2. Refer to the following emergency operating procedures applicable:
  - R-1 Personnel Injury (Radiological Related) and/or overexposure
  - R-2 Release of Airborne Radioactive Materials
  - R-4 High External Radiation
  - R-5 Radioactive Liquid Spill
3. Isolate the release
  - a. For a gas decay tank rupture:
    - 1) Select the affected tank to standby so that it is neither filling nor providing recycle gas.
  - b. For a LHUT rupture:
    - 1) Stop any transfer or recirculation operation involving the affected LHUT.
    - 2) Line up a different LHUT to receive letdown from the primary system other than the affected LHUT.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OP-25  
REVISION 2  
DATE 2/2/84  
PAGE 3 OF 4

TITLE TANK RUPTURES

<u>ACTIONS</u>	<u>COMMENTS</u>
3) Stop any cover gas recycle to the affected LHUT.	
4) Check VCT and accumulator test line discharge lined up to another LHUT and isolate discharge to affected LHUT.	
c. For a VCT rupture	
1) Place the VCT level control LCV-112A in the DIVERT TO HOLDUP TANK position.	
2) Check transferred or transfer charging pump sunction from VCT to RWST (open 8805 A&B and close LCVs 112 B&C).	
3) Terminate VCT makeup.	
4) Secure hydrogen supply to the affected unit's VCT at the hydrogen bottle rack.	4) Make arrangements for an alternate souce of hydrogen makeup to Unit 1 generator.
5) Check closed or close VCT to vent header stop valve (8101) and PZR liquid space and steam space sample line containment isolation valves (9355A, 9355B, 9354A, 9354B).	
6) Commence a controlled reactor shutdown.	6) Drop load on unit as necessary to maintain rod position and Tav <sub>g</sub> approximately equal to Tref.
4. Verify containment ventilation isolation and reset containment ventilation isolation trains A & B	

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP OF-25  
REVISION 2  
DATE 2/2/84  
PAGE 4 OF 4


TITLE TANK RUPTURES

APPENDIX Z

EMERGENCY PROCEDURE NOTIFICATION INSTRUCTIONS

1. When this emergency procedure has been activated and upon direction from the Shift Foreman, proceed as follows:
  - a. The precise designation of this event will be determined by the radiological effect of the leak. Refer to Emergency Procedure R-2 "Release of Airborne Radioactive Material" and R-4 "High Radiation (In-plant)". As a minimum, in the absence of data on radiation levels or release rates, designate this event a Notification of Unusual Event. Notify plant staff and response organizations required by Emergency Procedures G-2 "Establishment of the On-Site Emergency Organization" and G-3 "Notification of Off-Site Organizations" in accordance with Emergency Procedure G-2 "Accident Classification and Emergency Plan Activation."





Pacific Gas and Electric Company

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 1 OF 16



DEPARTMENT OF NUCLEAR PLANT OPERATIONS

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

EMERGENCY PROCEDURE  
PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY  
RELATED) AND/OR OVEREXPOSURE

APPROVED: R. C. Thompson  
PLANT MANAGER

3-20-84  
DATE

### SCOPE

This procedure describes the actions which are to be taken in the event of:

1. Personnel injury or illness (minor or serious) where the victim is radiologically contaminated.
2. Overexposure (or suspected overexposure) from an external source.
3. Overexposure (or suspected overexposure) from an internal source.
4. A combination of the above.

Injuries or illnesses which do not involve radioactive contamination or overexposure are handled in accordance with Emergency Procedures M-1 or M-2. This procedure and changes thereto requires PSRC review.

### DISCUSSION

Any radiologically related injury or illness or potential radiation overexposure is a serious matter requiring prompt attention to the care of the patient and prompt appropriate corrective action to preclude re-occurrence. In addition, followup investigation to quantify the extent of exposure to radiation requires care in the gathering and retention of samples, radiation readings and other evidence which may contribute to the understanding of the incident and assist both in care of the injured and in preventing re-occurrence.

### IMMEDIATE ACTIONS

1. The employee(s) who are at the scene shall:
  - a. Render all necessary first aid.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 2 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

- b. Notify the control room (Shift Foreman) as soon as practical, and provide a phone number for the patients location.

NOTE: The Shift Foreman may be notified by dialing [REDACTED]. Dialing [REDACTED] activates the fire alarm and medical emergency code call. The caller must remain on the phone to enable the Shift Foreman to dial into a conference call.

2. Shift Foreman (Interim Site Emergency Coordinator)

- a. Evaluate plant status that may have produced the personnel injury, illness and/or overexposure. Sound the site emergency signal to clear the affected area, if the situation warrants it.
- b. Dispatch additional first aid personnel such as the project construction EMT [ext. [REDACTED]] to the scene of the injury or illness if required.
- c. Notify Chemistry and Radiation Protection personnel [ext. [REDACTED]].
- d. Call an ambulance if the injury warrants it. Refer to Appendix 1 "Measures to be taken if Medical Care Is Required" for instructions.

SUBSEQUENT ACTIONS

The Shift Foreman shall direct all subsequent actions until relieved by the long-term Site Emergency Coordinator if the situation warrants it.

1. Actions Common to All Occurrences

- a. Transport the patient to the first aid room, provided that this can be done without aggravating the injury.
- b. Take actions as specified in the following sections as appropriate for the particular occurrence.

Section 2: Minor injury when contamination is present.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 3 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY  
RELATED) AND/OR OVEREXPOSURE

Section 3: Serious injury when contamination is present.

Section 4: Overexposure from external source

Section 5: Overexposure from internal source.

- c. Perform the notifications required by Appendix Z "Emergency Procedure Notification Instructions."

NOTE: Form 69-9221 "Emergency Notification Record" is provided to record notifications not documented elsewhere.

- d. Collect personnel dosimetry assigned to the individual and have it evaluated.
- e. Begin gathering information to assist the long-term Site Emergency Radiological Advisor in his evaluation. Guidance on things which should be investigated is given in Appendix 2 "Factors to Consider in Making a Preliminary Evaluation."
- f. Close out the event with the following written reports:
- 1) Report to NRC (required within 24 hours for an Unusual Event, or within 30 days for a report under 10CFR20.403).
  - 2) Form 62-4587 "Report of Industrial Injury to Employee."
  - 3) Form 62-4586 "Employers' Report of Occupational Injury or Illness."
  - 4) Nuclear Plant Problem Report. (See Nuclear Plant Administrative Procedure C-12.)

NOTE: Reports to NRC and the Nuclear Plant Problem Report are not required for minor injuries or illness for which onsite first aid and decontamination is adequate.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 4 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

## 2. Minor Injury or Illness When Contamination is Present

The following steps apply to injuries where prompt medical attention is not required (i.e., first aid at the plant is adequate).

- a. Make the following surveys and record the results on the "Skin and Clothing Decontamination" Form (Form 69-9392).
  - 1) The wound prior to decontamination.
  - 2) The object causing the injury (if possible) and any clothing penetrating or touching the injury. These items should be retained, if possible, until the long-term Site Emergency Radiological Advisor has completed his evaluation so that detailed radionuclide analysis can be performed, if required.
  - 3) The wound during each decontamination and after final decontamination.

NOTE: These personnel surveys are in addition to other radiological surveys (e.g., work area, equipment) which may be required by radiation protection management.

- b. Decontaminate the wound using the standard procedures discussed in Radiation Control Procedure G-4. In cases of severe contamination, where there is a realistic possibility that significant internal retention of radionuclides may have occurred, it is desirable to retain wash solutions (or samples thereof), swabs, and other such material which may be useful to the Site Emergency Radiological Advisor.

NOTE: Refer to Emergency Procedure RB-5 "Personnel Decontamination" in the event normal decontamination facilities are overloaded or unavailable.

- c. Complete any additional first aid measures.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 5 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

- d. Complete accident report Form 62-4587, "Report of Industrial Injury to Employee" and forward to plant clerk for processing.

NOTE: This documentation requirement assumes no medical attention (beyond first aid) is required and that no lost time occurs. If lost time beyond the day of injury is likely, or if medical treatment (including doctor referral) is required, complete Form 62-4586, "Employers' Report of Occupational Injury of Illness" and forward to plant clerk.

3. Serious Injury or Illness When Contamination is Present

The following steps apply to injuries or illnesses where prompt medical attention is required (i.e., the patient must be taken to a hospital) and the patient is contaminated. In this type of circumstance, the need for treatment of the injury and comfort of the patient will take precedence over the need for decontamination.

- a. Call San Luis Ambulance and French Hospital and have the patient transported to French Hospital. The detailed steps to be taken if this is required are given in Appendix 1 of this procedure. The Control Room should keep personnel attending the patient informed of the status of the ambulance.
- b. During the interval until the ambulance arrives keep the patient as comfortable as possible. Survey and decontaminate the patient to the extent that time and conditions permit. Do not decontaminate the patient if it will aggravate his injury. Record survey results on the "Skin and Clothing Decontamination" Form (Form 69-9392.)
- 1) Survey any wounds and/or the victim's skin (if possible).
  - 2) Survey the object causing the injury (if possible) and any clothing penetrating or touching the injury. These items should be retained, if possible, until the long-term Site Emergency radiological Advisor has completed his evaluation so that detailed radionuclide analyses can be performed, if required.

DIABLO CANYON POWER PLANT UNIT NO(S)

1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 6 OF 16

TITLE

PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY  
RELATED) AND/OR OVEREXPOSURE

- 3) Decontaminate the patient using the standard procedures discussed in Radiation Control Procedure G-4. In cases of severe contamination, where there is a realistic possibility that significant internal retention of radionuclides may have occurred, it is desirable to retain wash solutions (or samples thereof), swabs, and other such material which may be useful to the Site Emergency Radiological Advisor.

NOTE: Refer to Emergency Procedure RB-5 "Personnel Decontamination" in the event normal decontamination facilities are overloaded or unavailable.

- c. Have the hospital kit and a handheld radio available for transport to the hospital with the monitor accompanying the patient, or the team dispatched to the hospital.

#### 4. Overexposure From External Source

The following steps apply to cases where the patient has (or is suspected to have) received a dose from an external source to the whole body, or any portion thereof, in excess of an applicable limit contained in Radiation Control Standard No. 1, and where the individual does not require prompt medical attention for any other reason. Personnel suspected of overexposure shall not re-enter radiation controlled areas unless authorized by the Site Emergency Coordinator.

- a. Provide any first aid or medical attention which the patient may require.
- b. Notify San Luis Ambulance and French Hospital and transport the patient to French Hospital in accordance with Appendix 1 for observation or treatment in any of the following circumstances: 1) The patient is known or suspected to have received at least any of the following:
  - a) 25 rem to the whole body, active blood forming organs, lens of eyes, gonads, head or trunk.

DIABLO CANYON POWER PLANT UNIT NO(S)

1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 7 OF 16

TITLE

PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

- b) 150 rem to the skin.
- c) 375 rem to the extremities.
- 2) The patient shows signs of radiation sickness, such as nausea, vomiting, extreme sweating, weakness, diarrhea, extreme anxiety, incoherence, sensitivity of the nerves (tingling or itching sensation).
- 3) The patient shows evidence of radiation dermatitis (skin damage). Except for extremely high skin dose (greater than 5,000 rem), in which case pain occurs promptly and is intense, the symptoms at the time of exposure are a sensation of warmth and itching. Redness, blistering and other effects may not appear for several days.
- c. If the patient requires transportation to the hospital, during the interval until the ambulance arrives keep the patient comfortable. Survey the individual and perform any decontamination which circumstances require and/or permit. Do not aggravate any injury or unduly alarm the patient in performing these operations. Record survey results on the "Skin and Clothing Decontamination" Form (Form 69-9392) and/or "Radiation Dose Rate Survey Record" (Form 69-9316). In cases of severe contamination, handle as in Step 3.c to the extent practical.
- d. To the extent practical, save all vomit, urine, feces or other samples which may assist the long-term Site Emergency Radiological Advisor in evaluating the accident. This is particularly important if internal deposition of radioactive materials is suspected.
- e. Collect the patient's personnel dosimetry and any materials which may have been activated (if a neutron exposure is suspected) such as belt buckles, watches, jewelry, prior to sending him to the hospital or releasing him. This will be processed for evaluation.
- f. Subsequent actions will be based upon the results of the evaluation of the external exposure.

DIABLO CANYON POWER PLANT UNIT NO(S)

1 AND 2

NUMBER EP R-1

REVISION 11

DATE 2/21/84

PAGE 8 OF 16

TITLE

PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

5. Overexposure From Internal Sources

The following steps apply to cases where the patient has (or is suspected to have) ingested a significant quantity of radioactive material. If the ingestion was by breathing, this procedure applies any time that the concentration to which the person has been exposed is greater than or equal to  $(MPC) \times PF$ , where (MPC) refers to the normal (40 hr.) maximum permissible concentration, and PF refers to the protection factor the patient obtained when a quantitatively fit tested to the respirator that was worn for the job.

- a. Take any medical action which may be required as a result of injury or external dose received (Steps 3 and 4 above). The treatment of these effects should take precedence over the evaluation of internal exposure.
- b. Remove and retain for subsequent radiological analysis the patient's clothing and respirator.
- c. Survey the patient thoroughly and record the results on the "Skin and Clothing Decontamination" Form (Form 69-9392).
- d. Decontaminate individual to as low as practical without causing further injury. If practical, save samples of the decontamination solutions, swabs, and other materials which may be of use in subsequent radiological evaluations.
- e. Count the patient on the whole body counter. The results of this analysis will, in large measure, determine the necessity for further medical attention or surveillance.
- f. Collect and save any urine, feces, or vomit which is passed from the patient. The long-term Site Emergency Radiological Advisor may request that special urine samples be collected for bioassay.
- g. Subsequent actions will be based upon the results of the evaluation of the internal exposure.
- h. If the patient is sent to the hospital, make arrangements to have all urine, feces or vomit samples retained for radiological analysis.



DIABLO CANYON POWER PLANT UNIT NO(S)	1 AND 2	NUMBER	EP R-1
		REVISION	11
		DATE	2/21/84
		PAGE	9 OF 16
TITLE	PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE		

#### REFERENCES

1. Radiation Control Standard No. 1, "Personnel Exposure."
2. Radiation Control Standard No. 2, "Internal Exposure Controls."
3. Radiation Control Standard No. 5, "Medical."
4. Radiation Control Standard No. 8, "Reporting Requirements."
5. Radiation Control Procedure No. G-3, "Personnel Internal Exposure Control."
6. Radiation Control Procedure No. G-4, "Personnel Contamination Control."
7. Radiation Control Procedure No. G-7, "Radiation Surveys."
8. Emergency Procedure G-1, "Accident Classification and Emergency Plan Activation."
9. Emergency Procedure G-2, "Establishment of the Onsite Emergency Organization."
10. Emergency Procedure G-3, "Notification of Offsite Organizations."
11. Emergency Procedure R-4, "High Radiation (In Plant)."
12. Emergency Procedure RB-5, "Personnel Decontamination."
13. Emergency Procedure OR-1, "Offsite Support and Assistance"

#### APPENDICES

1. Appendix 1, Measures To Be Taken If Medical Care Is Required.
2. Appendix 2, Factors To Consider In Making A Preliminary Investigation.
3. Appendix Z, Emergency Procedure Notification Instructions.

DIABLO CANYON POWER PLANT UNIT NO(S)

1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 10 OF 16

TITLE

PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY  
RELATED) AND/OR OVEREXPOSURE

ATTACHMENTS

1. Form 69-9221, "Emergency Notification Record."
2. Form 69-9316, "Radiation Dose Rate Survey Record."
3. Form 69-9392, "Skin and Clothing Decontamination."
4. Form 62-4587, "Report of Industrial Injury to Employee."
5. Form 62-4586, "Employers' Report of Occupational Injury or Illness."
6. Form 62-6015, "Medical Referral."
7. Light Duty Program Letter.
8. Safety, Health and Claims Personnel to Be Contacted for Reporting of Injuries at Diablo Canyon (3/83).

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 11 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

APPENDIX 1

MEASURES TO BE TAKEN IF MEDICAL CARE IS REQUIRED

The following are the procedural steps to be taken in the event a contaminated patient must be transported to the hospital for medical treatment:

1. Call San Luis Ambulance (Phone [REDACTED], Emergency No. [REDACTED]) and provide the following information:
  - a. Name of caller.
  - b. Company affiliation.
  - c. Phone number of caller. (Where he can be reached.)
  - d. Name of injured or ill person.
  - e. Where the patient is located.
  - f. Where the patient is to be transported (French Hospital).
  - g. Nature of injury or illness.
  - h. Patient is contaminated.
  - i. Any other medical information which might be pertinent to transporting the patient.

Record this information on Form 69-9221, "Emergency Notification Record," or other suitable log.

2. Contact the Security Shift Supervisor [REDACTED] and have him call the security force at the Port San Luis entrance [REDACTED] and alert them that the ambulance is entering. It is also advisable to have an escort accompany the ambulance from the Security Building to the first aid room to minimize the delay in reaching the destination.
3. The victim shall be transported to French Hospital. Call ahead to the hospital [(Phone [REDACTED])] and provide the following information:
  - a. Name of caller.

DIABLO CANYON POWER PLANT UNIT NO(S)	1 AND 2	NUMBER	EP R-1
		REVISION	11
		DATE	2/21/84
		PAGE	12 OF 16
TITLE	PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE		

APPENDIX 1 (Cont'd)

MEASURES TO BE TAKEN IF MEDICAL CARE IS REQUIRED

- b. Company affiliation.
- c. Phone number of caller. (Where he can be reached.)
- d. Name of injured or ill person.
- e. Age of injured or ill person (approximate if not known).
- f. Extent of injury, illness or symptoms.
- g. Medical history (if known).
- h. Radiological conditions.

Record this information on Form 69-9221, "Emergency Notification Record", or other suitable log.

- 4. Prior to arrival of the ambulance, the patient should be decontaminated to the extent practical without aggravation of injury.
- 5. If the patient cannot be completely decontaminated prior to arrival of the ambulance, wrap him in a blanket prior to placing him in the ambulance in order to minimize the spread of contamination. Alternatively, he may be placed in the plant's Nuclear Accident Emergency Carrier.
- 6. An individual qualified in radiation monitoring shall accompany the victim to the hospital. This individual should take a hospital kit and a handheld radio with him.

NOTE: Two hospital kits and radios are stored in Access Control. Additional equipment and radios are also available at the PG&E San Luis Obispo Service Center.

- 7. Two additional individuals qualified in radiation monitoring should be dispatched to French Hospital to assist hospital personnel.

NOTE: Refer to EP OR-1 "Offsite Support and Assistance" for air ambulance and medivac support.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 13 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY  
RELATED) AND/OR OVEREXPOSURE

## APPENDIX 2

### FACTORS TO CONSIDER IN MAKING A PRELIMINARY INVESTIGATION

It is important to conduct the preliminary investigation in a systematic manner to assure that potentially valuable evidence is not overlooked, lost or destroyed. The following is a reference listing of items which should be checked (if they are applicable). Also, two other factors are important in conducting an investigation of this type, namely: a) information which is gathered should be written down in a comprehensive, neat manner, and b) all samples, clothing, or other articles which are collected should be put in sample bottles or plastic bags, and labelled with the patient's name, date, collection time, sample identification, and other pertinent data.

1. Factors Common to All Accidents
  - a. Date, time of occurrence.
  - b. Basic reconstruction of events.
  - c. Probable source(s) of radioactivity involved.
  - d. Names and addresses of all witnesses.
2. Considerations in Evaluating External Exposure
  - a. Exactly where was the patient located at the time of exposure?
  - b. How was patient physically oriented with respect to source (will help to evaluate nonuniform exposure)?
  - c. On what part(s) of body were dosimeters being worn?
  - d. Were self-reading dosimeter readings recorded and all nonself-reading types collected?
  - e. Are there any "natural" dosimeters available? (Belt buckles, wrist watches, gold tooth fillings, and other such items are useful in determining neutron dose.)
  - f. Exactly what was the time interval over which exposure occurred?

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 14 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

- g. Are there any applicable dose rate measurements, and if so, exactly where and when were they made?
  - 1) Ion chamber measurements
  - 2) Area monitors
  - 3) Other
- h. What was the status of the plant at time of exposure?
- 3. Considerations in Evaluating Internal Exposure
  - a. Where was the patient located at time of exposure?
  - b. Exactly what was the time interval over which exposure occurred?
  - c. Can sample(s) of liquids which were internally deposited be obtained?
  - d. Can samples of airborne activity which were breathed be obtained before the area is purged?
  - e. Are there any applicable monitor readings?
    - 1) Process monitors
    - 2) Continuous Air Monitors
    - 3) Area Monitors
    - 4) Other
  - f. Can samples of patient's clothing, decontamination solutions, secretions, respirator filters, be saved?
  - g. Can the region in the vicinity of the occurrence be smear-tested, or can decontamination solutions be retained?

DIABLO CANYON POWER PLANT UNIT NO(S)	1 AND 2	NUMBER	EP R-1
		REVISION	11
		DATE	2/21/84
TITLE	PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE	PAGE	15 OF 16

APPENDIX Z

EMERGENCY PROCEDURE NOTIFICATION INSTRUCTIONS

1. When this emergency procedure has been activated and upon direction from the Shift Foreman, proceed as follows:
  - a. In case of a minor injury with contamination present or an overexposure case from any source which does not meet the criteria for an Unusual Event, notify the Plant Manager, Plant Superintendent and Supervisor of Chemistry and Radiation Protection or their designated alternates.
  - b. Designate this a Notification of Unusual Event in any case of an injury or overexposure requiring transportation of the patient to an offsite hospital or if extensive onsite decontamination is required (soap and water washings do not remove contamination or offsite decontamination assistance is required). Notify plant staff and response organizations required for this classification by implementing Emergency Procedures G-2 "Establishment of the Onsite Emergency Organization" and G-3 "Notification of Offsite Organizations" in accordance with Emergency Procedure G-1 "Accident Classification and Emergency Plan Activation."
  - c. If the case involves an overexposure from an external source which exceeds:

Immediate Notification\*

25 Rem Whole Body  
 150 Rem Skin  
 375 Rem Extremities

Notification Within 24 Hours

5 Rem Whole Body  
 30 Rem Skin  
 75 Rem Extremities


Notify the Director, NRC Region 5 by telephone and telegraph, mailgram and facsimile within the applicable time frame described above. Indicate the notification is pursuant to 10 CFR20.403 (Notification of Incidents).

\*Designate this a Notification of Unusual Event and complete the additional notifications prescribed in section 1.b. above.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-1  
REVISION 11  
DATE 2/21/84  
PAGE 16 OF 16

TITLE PERSONNEL INJURY OR ILLNESS (RADIOLOGICALLY RELATED) AND/OR OVEREXPOSURE

2. In addition to notification performed above, also notify the following in any case where NRC notification is required.
- a. Supervising Nuclear Generation Engineer (Personnel and Environmental Safety) or his alternate in the Department of Nuclear Plant Operations:
- Mr. W. H. Fujimoto PGandE:  
Plant Ext.:   
Home:
- b. Compensation Claims Representative in the Department of Safety, Health and Claims, per the attached list of personnel.



- NOTE: 1) The System Dispatcher will handle the notification of General Office Personnel if they cannot be promptly reached.
- 2) Nuclear Mutual Limited (NML) holds the Company liability and property damage insurance for Company personnel and property. They should be notified under the same circumstances as the NRC. Notification is made by the Company's Insurance Department. The Department of Nuclear Plant Operations should be requested to interface between the plant and the Insurance Department when required. American Nuclear Insurers/Mutual Atomic Energy Liability Underwriters (ANI/MAELU) holds third party insurance coverage and would be similarly notified in accidents involving a third party.











☐ SKIN

☐ PROTECTIVE CLOTHING

☐ PERSONAL CLOTHING

PACIFIC GAS AND ELECTRIC COMPANY  
 Report of Industrial Injury to Employee

1. Name \_\_\_\_\_ 8. Division \_\_\_\_\_  
 2. Address \_\_\_\_\_ ZIP \_\_\_\_\_  
 3. Telephone No. \_\_\_\_\_ 7. Department \_\_\_\_\_  
 4. Social Security No. \_\_\_\_\_ 8. Date of Accident \_\_\_\_\_  
 5. Occupation \_\_\_\_\_ 9. Time of Accident \_\_\_\_\_  
 10. Location of Accident \_\_\_\_\_ 11. Nature of Injury \_\_\_\_\_  
 12. What were you doing and how did accident occur? \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 13. Describe First Aid rendered: \_\_\_\_\_  
 14. Witnesses to accident  
 1. \_\_\_\_\_  
 2. \_\_\_\_\_  
 3. \_\_\_\_\_ 15. \_\_\_\_\_  
 Signature of Employee  
 16. Date injury reported: \_\_\_\_\_  
 17. Date 30 days elapsed: \_\_\_\_\_ \* See Over 18. \_\_\_\_\_  
 Signature of Supervisor

**INSTRUCTIONS:** This report (Items 1 thru 15) should be written and signed by the employee personally and countersigned by the supervisor. It is for all Industrial Injuries and is in duplicate. The original is to be retained for Company records; the copy is to be detached after completion and given to the employee. Before signing in Item 18, the supervisor should fill in the date of the report (Item 16) and compute and note the date 30 days from the date the injury was reported (Item 17).

If the employee later requires treatment by a doctor or becomes disabled, Form 62-4586 must be prepared and forwarded to the Safety, Health and Claims Department IMMEDIATELY accompanied by the original of this report.

If the employee is unable to fill out or sign this report, it should be prepared, signed by the supervisor and the employee should be given a copy within 5 days as required by law.

If the employee cannot write English, the report may be made according to a verbal statement. If necessary, the employee may sign by a mark and a witness to the report should sign below the employee's mark.

If you wish to exercise your rights under item (ii) of the information section, please enclose this page and present it to your treating physician.

§ 5755. Duties of the Employee-Selected Physician. The physician or facility chosen by the employee who undertakes to provide treatment pursuant to Labor Code Section 4600 shall:

- (a) Within 3 working days after undertaking to provide such treatment notify the employer of the name and address of such treating physician or facility, and
- (b) Within 5 working days following initial examination shall submit a written report to the employer to include:
  - (1) The name and address of injured employee;
  - (2) The employee's medical history as obtained by the physician;
  - (3) Findings on examination;
  - (4) The subjective complaints reported by the employee;
  - (5) The planned course, date and duration of treatment;
  - (6) If appropriate, the estimated return-to-work date;
  - (7) An opinion as to whether residual permanent disability is to be anticipated and, if possible, an estimate of its extent;
  - (8) An opinion as to whether the employee will eventually be able to engage in the usual job being performed at the time of injury.
- (c) At reasonable intervals during active treatment submit progress reports to the employer and, periodically, report promptly to the employer when:
  - (1) The employee's condition permits return to work;
  - (2) The employee's condition requires him or her to leave work;
  - (3) Hospitalization or surgery is indicated or recommended;
  - (4) The employee's condition becomes permanent and stationary;
  - (5) The employee's condition undergoes a previously unexpressed significant change; (this report shall contain a statement of the proposed course of treatment required, if any, by that change);
  - (6) The employee is referred to another physician for consideration;
  - (7) The employee reasonably requests additional appropriate information.

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Employer's Report of Occupational Injury or Illness**  
**CONFIDENTIAL - For Use by Company Attorneys**

DIVISION GENERAL OFFICE OR GENERAL CONSTRUCTION		
DEPARTMENT	DISTRICT, ZONE OR LOCAL OFFICE	P.C. NUMBER
LOCATION OR ITEM NUMBER	ACCIDENT NUMBER	JOB NUMBER

ACCIDENT REPORT NUMBER  
 DATE

Complete this report on employer's report which includes every reported injury or occupational disease which is treated or has been treated the day of injury or is reported under the provisions of the Act. This report is required by the Act, except in cases where the Commission, upon application of the employer, has determined that the injury or occupational disease was not caused by the employment. This report is required by the Act, except in cases where the Commission, upon application of the employer, has determined that the injury or occupational disease was not caused by the employment. This report is required by the Act, except in cases where the Commission, upon application of the employer, has determined that the injury or occupational disease was not caused by the employment.

1. NAME <b>PACIFIC GAS AND ELECTRIC COMPANY</b> 77 BEALS STREET, SAN FRANCISCO, CA 94105	4. NATURE OF BUSINESS <b>PUBLIC UTILITY - Gas &amp; Electric</b>	2. I.D. NO.	PLEASE DO NOT USE THIS COLUMN
		3. SOCIAL SECURITY NUMBER <b>002-2799</b>	
6. DATE	7. SOCIAL SECURITY NUMBER	10. SEX <input type="checkbox"/> MALE <input type="checkbox"/> FEMALE	11. OCCASION / JOB TITLE
8. MONTH ADDRESS	9. AGE	12. OCCASION	13. YEARS OF EXPERIENCE
14. CITY AND ADDRESS OF HOME	15. CITY OF HOME	16. CITY OF HOME	17. CITY OF HOME
18. CITY AND ADDRESS OF HOME	19. CITY OF HOME	20. CITY OF HOME	21. CITY OF HOME
22. CITY AND ADDRESS OF HOME	23. CITY OF HOME	24. CITY OF HOME	25. CITY OF HOME
26. CITY AND ADDRESS OF HOME	27. CITY OF HOME	28. CITY OF HOME	29. CITY OF HOME
30. CITY AND ADDRESS OF HOME	31. CITY OF HOME	32. CITY OF HOME	33. CITY OF HOME
34. CITY AND ADDRESS OF HOME	35. CITY OF HOME	36. CITY OF HOME	37. CITY OF HOME
38. CITY AND ADDRESS OF HOME	39. CITY OF HOME	40. CITY OF HOME	41. CITY OF HOME
42. CITY AND ADDRESS OF HOME	43. CITY OF HOME	44. CITY OF HOME	45. CITY OF HOME
46. CITY AND ADDRESS OF HOME	47. CITY OF HOME	48. CITY OF HOME	49. CITY OF HOME
50. CITY AND ADDRESS OF HOME	51. CITY OF HOME	52. CITY OF HOME	53. CITY OF HOME
54. CITY AND ADDRESS OF HOME	55. CITY OF HOME	56. CITY OF HOME	57. CITY OF HOME
58. CITY AND ADDRESS OF HOME	59. CITY OF HOME	60. CITY OF HOME	61. CITY OF HOME
62. CITY AND ADDRESS OF HOME	63. CITY OF HOME	64. CITY OF HOME	65. CITY OF HOME
66. CITY AND ADDRESS OF HOME	67. CITY OF HOME	68. CITY OF HOME	69. CITY OF HOME
70. CITY AND ADDRESS OF HOME	71. CITY OF HOME	72. CITY OF HOME	73. CITY OF HOME
74. CITY AND ADDRESS OF HOME	75. CITY OF HOME	76. CITY OF HOME	77. CITY OF HOME
78. CITY AND ADDRESS OF HOME	79. CITY OF HOME	80. CITY OF HOME	81. CITY OF HOME
82. CITY AND ADDRESS OF HOME	83. CITY OF HOME	84. CITY OF HOME	85. CITY OF HOME
86. CITY AND ADDRESS OF HOME	87. CITY OF HOME	88. CITY OF HOME	89. CITY OF HOME
90. CITY AND ADDRESS OF HOME	91. CITY OF HOME	92. CITY OF HOME	93. CITY OF HOME
94. CITY AND ADDRESS OF HOME	95. CITY OF HOME	96. CITY OF HOME	97. CITY OF HOME
98. CITY AND ADDRESS OF HOME	99. CITY OF HOME	100. CITY OF HOME	101. CITY OF HOME

Filing of this report is not an admission of liability.  
 "... No report of injury required to be filed by an employer or insurer by this chapter shall be admissible as evidence in any adversary proceeding before the Workmen's Compensation Appeals Board."

Labor Code, Section 6412

**PACIFIC GAS & ELECTRIC COMPANY**

OFFICIAL POSITION: **Mgr., Safety, Health & Claims Dept.**  
 TELEPHONE: **781-4211** EXTENSION: **3171**

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

Report # \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_

Dr. \_\_\_\_\_  
Kindly give to bearer.

Mr./Ms. \_\_\_\_\_  
medical attention, and forward a complete detailed report immediately to Manager, Safety, Health and Claims Dept., 245 Market Street, San Francisco, 94106. Your bills should be itemized and all bills and reports rendered in triplicate.

PACIFIC GAS AND ELECTRIC COMPANY

By \_\_\_\_\_ RC #  
42-0010 (REV. 3/68) Mgr. - Foreman - Supt.

PLEASE COMPLETE AND RETURN TO EMPLOYEE  
(EMPLOYEE MUST HAVE COMPLETED CARD TO RETURN TO WORK)

Pacific Gas and Electric Co.: \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_

Mr./Ms. \_\_\_\_\_

Occupation \_\_\_\_\_ Report # \_\_\_\_\_

Employed By \_\_\_\_\_ RC # Division \_\_\_\_\_

Injured at \_\_\_\_\_  
a.m. on \_\_\_\_\_, 19\_\_

- Return to full work immediately \_\_\_\_\_
- Modified work until \_\_\_\_\_
- Unable to work until \_\_\_\_\_
- Restrictions or limitations \_\_\_\_\_
- Return Appr. Date: \_\_\_\_\_ Time: \_\_\_\_\_
- Discharged from treatment \_\_\_\_\_

Signed \_\_\_\_\_ M.D.



# PACIFIC GAS AND ELECTRIC COMPANY

NOTE -

SHALE CANYON POWER PLANT  
P.O. Box 10 • Area 10 • Contra Costa 94524 • (925) 465-7211

R. C. THORNBERRY  
SUPERVISOR  
AREA 10

Dear Dr.

Thank you for being one of our panel physicians that treat our employees. Our primary goal is to provide employees who sustain industrial injuries requiring medical attention with prompt, first-class treatment. Your assistance in this endeavor is appreciated.

There is an area of concern to us. While the number of employees that require treatment by a physician has remained stable or in some cases declined, the number of disabling injuries requiring time away from work, i.e., lost time injuries, has dramatically increased.

We believe that some of this time away from work might possibly be avoided if the availability of light (modified) duty or desk-type work were more widely known. Some physicians have stated that in some cases the patient will respond more rapidly to treatment if kept busy in a light-duty capacity. Productive, light-duty assignments are almost always available for employees released for work within the medical restrictions established by the physician.

It is our policy to have an injured employee accompanied by a supervisor or other representative on the first doctor's visit. Should there be any question about the availability or type of light duty that can be provided, he or she will be able to answer for us.

Our employees' welfare is our main concern. Should you have any questions about our program, I will be glad to call on you at your convenience.

Sincerely,

R. C. THORNBERRY

RET:kgs

3/83  
RW9

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

Page 1 of 2


Safety, Health and Claims Personnel to be  
Contacted for Reporting of Injuries at Diablo Canyon<sup>1</sup>

EMPLOYEE INJURIES

In all cases of serious employee injuries (for example, injuries involving hospitalization, electric contact, hernia, amputation, fractures, or injuries expected to result in lost time from work beyond the day of injury) or death, which occur while on the job, report should be made as follows:

During Working Hours:


T. B. Honey

PGandE local 

(If Mr. Honey is not available, the person answering the telephone will take the message and notify Mr. Honey or any other parties necessary in the Safety, Health and Claims Department).

Any Other Time:

Report to one of the persons on the following list, trying each in order until one is contacted:

- |                     |               |
|---------------------|---------------|
| 1. T. B. Honey      | Pinole        |
| 2. A. Thomas        | San Francisco |
| 3. C. B. Powell     | San Francisco |
| 4. P. S. Benitez    | San Rafael    |
| 5. T. G. Scott      | Oakland       |
| 6. L. Lasagna       | Albany        |
| 7. C. W. Allen      | San Francisco |
| 8. B. L. Wade       | Larkspur      |
| 9. J. A. Glimme     | Danville      |
| 10. J. C. Yocke     | Lafayette     |
| 11. W. A. Hutchison | San Carlos    |
| 12. M. C. Dolan     | Oakland       |
| 13. M. W. Johnson   | Walnut Creek  |
| 14. R. W. Hall      | Richmond      |
| 15. I. M. Crawford  | Hercules      |
| 16. R. G. Schumaker | El Granada    |
| 17. R. D. Fagg      | San Rafael    |
| 18. P. C. Boettcher | Moraga        |
| 19. H. W. Reynolds  | Sunnyvale     |
| 20. B. P. Sadler    | Belmont       |
- 

<sup>1</sup>This listing extracted from Safety, Health, and Claims memo regarding Personnel to be Contacted for Reporting of Accidents, dated 01/13/83.

Non-Employee Injuries

C. O. Schreil, San Luis Obispo,

[REDACTED] (office)  
[REDACTED] (office)  
[REDACTED] (home)

If he cannot be reached, contact one of the following in order of preference:

During working hours:

1. John C. Echols
2. Doug G. Keeler
3. George G. Perry (collection only)

[REDACTED]


After working hours on Monday through 8:00 a.m. on Friday, except holidays:

- |   |               |
|---|---------------|
| 1. John C. Echols                       | Pleasant Hill |
| 2. Doug G. Keeler                       | Concord       |
| 3. John C. Yocke                        | Lafayette     |
| 4. Amos L. Bechtold                     | Cupertino     |
| 5. William H. Bingaman                  | Novato        |
| 6. E. Anthony Giudici                   | San Carlos    |
| 7. J. Alex McCorquodale                 | San Ramon     |
| 8. Bruce P. Sadler                      | Belmont       |
| 9. George G. Perry<br>(collection only) | Hayward       |
| 10. Stanley W. Johnston                 | Fairfield     |

[REDACTED]

After 5:00 p.m. on Fridays to 8:00 a.m. on Mondays and holidays:

Contact the Investigator delegated to stay on call for all emergencies. He may be reached through the System Dispatcher. If he is not available, the Dispatcher will follow the procedures for "After Working Hours."



Pacific Gas and Electric Company

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 1 OF 10



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

TITLE: EMERGENCY PROCEDURE  
OFFSITE TRANSPORTATION ACCIDENTS

IMPORTANT  
TO  
SAFETY

APPROVED:

*R. C. Thompson*  
PLANT MANAGER

3-9-84  
DATE

#### SCOPE

This procedure discusses the response of the plant personnel to transportation accidents which occur offsite involving shipments of radioactive material. Accidents which occur onsite are handled using Emergency Procedures R-2, R-3, R-4, or R-5 as appropriate. This procedure and changes thereto requires PSRC review.

#### DISCUSSION

Once a shipment of radioactive materials has left the site, or prior to its arrival on the site, the responsibility for it rests with the carrier. In the event of a transportation accident, the responsibility for recovery rests with the carrier and local and state officials, rather than with the Company. However, if an accident occurs in the vicinity of the plant, local officials may request the assistance of plant personnel for radiological monitoring because of their knowledge and experience and because of the monitoring and other equipment at their disposal. Plant personnel should be prepared to assist to the maximum extent practical, while at the same time recognizing that they are acting in a strictly advisory capacity.

#### SYMPTOMS

The Shift Foreman is notified that an accident involving radioactive material has occurred.

#### IMMEDIATE OPERATOR ACTIONS

1. In the initial contact, the individual receiving the message should try to gather the following information:
  - a. Location of accident.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 2 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

- b. Type of material involved:
    - 1) New fuel
    - 2) Spent fuel
    - 3) Solid radwaste
    - 4) Liquid radwaste
    - 5) Pharmaceuticals
    - 6) Sources
    - 7) Special Nuclear Material
  - c. Type of container(s) involved.
  - d. Apparent extent of damage.
  - e. Is there fire or submergence of the containers?
  - f. Are there personnel injuries?
  - g. The results of any measurements which have been made.
  - h. Who is on the scene and who is in charge?
  - i. What recovery actions are planned or being taken?
  - j. The identity of the carrier.
  - k. Origination point and destination of the shipment.
  - l. The name and phone number of the caller.
2. Notify the Shift Foreman.
  3. The Shift Foreman should insure that a record is kept of the initial contact as well as all subsequent contacts with offsite persons. Form 69-9221, "Emergency Notification Record," is provided to assist in this.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 3 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

SUBSEQUENT ACTIONS

1. Perform the notifications required by Appendix Z.
2. Send a two man survey team to the scene. The team should carry the following minimum equipment:
  - a. Dose rate instrument (HPI-1010, Radowl or equivalent).
  - b. G-M survey instrument.
  - c. Alpha survey instrument (only if the accident involves new fuel assemblies or an alpha emitting source).
  - d. Air sampler with appropriate filters and cartridges.
  - e. Radiation barrier rope.
  - f. Warning signs: "Caution - Surface Contamination Area" and "Caution - Radioactive Materials."
  - g. Smear pads and/or 2" duplex papers
  - h. Plastic bag for retention of smear samples.
  - i. Pocket dosimeters and (if time permits) the team members' personnel dosimeters (film badge or TLD).
  - j. Survey forms (Forms 69-9315 and 69-9316 preferred, but Form 69-9259 is also okay).

NOTE 1: It is highly desirable to take a radio if time permits. All but the radio, film badge and alpha survey meter are located in the various emergency kits. Preferably, an entire kit should be taken to the scene. Radios are available in the Security Building, Emergency Operations Facility and Mobile Radiological Van.

NOTE 2: If criticality is a possibility (i.e., if fuel is submerged in water) a neutron dose rate meter (such as the PNR-4or5) could be taken if readily available. This instrument is not necessary, however, since gamma radiation always accompanies a criticality.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 4 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

3. Close out with a verbal summary to offsite authorities in step 1 above. If classified as an Unusual Event, follow with a written summary to NRC within 24 hours.

#### INSTRUCTIONS FOR MONITORING TEAM

1. Make gamma dose rate measurements since this is the most likely hazard. If any significant gamma dose rate is measured, erect a barrier so that all locations where the dose rate is greater than or equal to 5 mR/hr are located within it. Hang Radiation Area signs as appropriate.

NOTE: Members of the general public, not participating in the recovery effort, should be kept at a distance beyond the 0.6 mr/hr isodose line by an appropriate barrier.

2. Make a direct alpha and/or beta-gamma survey, as appropriate, of the ground and the surfaces for the container if contamination is a possibility. If contamination is found, above the specified limits, erect a barrier around all areas where the contlevel is the most restrictive of the following:
  - a. 100 dpm/100 cm<sup>2</sup> if Pu-239 may be present.
  - b. 1000 dpm/100 cm<sup>2</sup> if Pu-239 is not present but uranium, I-131 or Sr-90 may be present.
  - c. 5,000 dpm/100 cm<sup>2</sup> if none of the above are likely to be present in significant quantities.

The survey is made by holding the probe within 1/2 inch of the surface without actual contact. The net count rate is converted to dpm/100 cm<sup>2</sup> by the following formula:

$$[\text{dpm}/100 \text{ cm}^2] = \frac{(\text{CR}_{\text{net}})}{\text{epsilon}_1}$$

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 5 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

where:

$CR_{net}$  = net cpm on instrument  
= (cpm)<sub>gross, shield off</sub> - (cpm)<sub>background</sub>  
 $\epsilon_{1}$  = probe efficiency factor from Table 1

NOTE 1: The alpha probe is sensitive to sunlight. Therefore, shield the probe to the extent practical.

NOTE 2: It is not necessary to erect barriers for both contamination and dose rate. Just erect the one which keeps persons farthest from the source and place both types of signs on it.

3. If significant contamination is found in Step 2 above, smear samples can be taken to determine whether smearable contamination is present. If alpha contamination is likely, use 2" filters for taking the smears. Retain all smear samples for subsequent laboratory analysis.

Count the samples and determine the [dpm/100 cm<sup>2</sup>] in accordance with the following formula:

$$[\text{dpm}/100 \text{ cm}^2] = \frac{(0.11)(CR_{net})}{(\epsilon_{2}) (A)}$$

where:

( $CR_{net}$ ) = net cpm as above  
 $\epsilon_{2}$  = probe efficiency factor from Table 1  
A = area smeared (ft<sup>2</sup>)



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 6 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

4. If criticality or fuel melting is a possibility, erect barriers at least 100 yards from the scene.

NOTE: A criticality is accompanied by a blue flash which is visible even when a person is not looking at the source.

5. Obtain liquid samples if it appears liquid contamination is a problem. These should be labeled and returned to the lab.
6. Report in to the Site Emergency Coordinator at least once per hour and determine the meteorological conditions.
7. Maintain exposure as low as reasonably achievable. Do not exceed any normal exposure limit without authorization of the Site Emergency Coordinator. Try to prevent any unbadged person from receiving more than 250 mrem.
8. Advise state and/or local officials of methods which could be used to contain the spread of contamination or minimize the radiation field. These may include the use of wood or metal sheets, plastic or cloth tarpaulins, firefighting foam or dirt berms and rocks.
9. Advise and assist in the treatment of any injured and/or contaminated personnel using the techniques specified in the Radiation Control Standards and Emergency Procedures.

#### ATTACHMENTS

1. Form 69-9221, "Emergency Notification Record"
2. Form 69-9315, "Contamination Survey Record"
3. Form 69-9316, "Radiation Dose Rate Survey Record"
4. Form 69-9259, "Emergency Environmental Monitoring Field Data Sheet"

DC0009 6111

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 7 OF 10

TITLE: OFFSITE TRANSPORTATION ACCIDENTS

SUPPORTING PROCEDURES

EP G-2 Establishment of the Onsite Emergency Organization  
EP G-3 Notification of Offsite Emergency Organizations  
EP R-1 Personnel Injury (Radiologically Related) and/or Overexposure.  
EP RB-4 Access to and Establishment of Controlled Areas Under  
Emergency Conditions.  
RCP G-6 Release of Materials from Controlled Areas.  
EP RB-6 Area and Equipment Decontamination.

TABLE 1

PROBE EFFICIENCIES FOR SURVEY INSTRUMENTS

<u>PROBE</u>	<u>EPSILON<sup>1</sup> (direct survey)</u> <u>(cpm/dpm/100 cm<sup>2</sup>)</u>	<u>EPSILON<sup>2</sup> (smear)</u> <u>(cpm/dpm)</u>
HP-240	0.011	0.018
HP-260	0.040	0.20
HP-210	0.040	0.18
HP-230A	0.0029	0.016
Alpha	0.056	0.095

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP R-7  
REVISION 4  
DATE 11/21/83  
PAGE 9 OF 10

TITLE OFFSITE TRANSPORTATION ACCIDENTS

APPENDIX Z

EMERGENCY PROCEDURE NOTIFICATION INSTRUCTIONS

1. When this emergency procedure has been implemented, and upon direction from the Shift Foreman, proceed as follows:
  - a. Notify the following plant staff personnel, or their designated alternates:
    - Plant Manager
    - Plant Superintendent
    - Supervisor of Chemistry and Radiation Protection
    - Power Plant Engineer
    - Supervisor of Operations
    - Technical Assistant to the Plant Manager
  - b. Report the situation to the County Sheriff's Office and California Office of Emergency Services. They may already be aware of the situation, so this may be a courtesy call.
  - c. If the shipment originated or had a distinction at the plant, designate this event a Notification of Unusual Event. Notify plant staff and response agencies required by Emergency Procedures G-2 "Establishment of the Onsite Emergency Organization" and G-3 "Notification of Offsite Organizations" in accordance with Emergency Procedure G-1 "Accident Classification and Emergency Plan Activation."
2. In addition to any notifications performed under 1 above, also notify the following company personnel:
  - a. Supervising Nuclear Generation Engineer (Personnel and Environmental Safety):

Mr. W.H. Fujimoto  
PGandE office  
Office  
Home



NOTE: If the above cannot be promptly reached request the system dispatcher to contact alternate personnel.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2	NUMBER EP R-7 REVISION 4 DATE 11/21/83 PAGE 10 OF 10
TITLE OFFSITE TRANSPORTATION ACCIDENTS	

b. Los Padres District Manager:

Mr. D.L. Kennady

Office

Office

Home



NOTE: If the above cannot be promptly reached request Morro Bay Switching Center to contact alternate personnel.



69-9315 7/80 (100)

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT  
 CONTAMINATION SURVEY RECORD

DATE \_\_\_\_\_ TIME \_\_\_\_\_ SWP/RWP NO. \_\_\_\_\_ SURVEY NO. \_\_\_\_\_

AREA OR EQUIPMENT \_\_\_\_\_

DIRECT SURVEY RESULTS

ITEM DESCRIPTION	TYPE		INST. AND S/N	DETECTOR USED	GROSS CPM	BKG CPM	NET CPM	EFFI-CIENCY	$\frac{dpm}{dm^2}$
	$\alpha$	$\beta\gamma$							

REMOVABLE CONTAMINATION SURVEY RESULTS

INSTRUMENT USED \_\_\_\_\_

ITEM DESCRIPTION	TYPE		AREA, $dm^2$	COUNT TIME	TOTAL COUNTS	GROSS cpm	BKG cpm	NET cpm	EFFI-CIENCY	$\frac{dpm}{dm^2}$
	$\alpha$	$\beta\gamma$								

COMMENTS \_\_\_\_\_

SURVEYED BY \_\_\_\_\_ COUNTED BY \_\_\_\_\_ DATE/TIME \_\_\_\_\_

REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_  
 SUPERVISOR





PACIFIC GAS AND ELECTRIC COMPANY  
 NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2  
 EMERGENCY ENVIRONMENTAL MONITORING FIELD DATA SHEET

Team \_\_\_\_\_ Leader \_\_\_\_\_ Member \_\_\_\_\_  
 Monitoring Location \_\_\_\_\_

1. THREE FOOT BETA-GAMMA RADIATION FIELD READINGS

a. Count Rate Calibration Due Date \_\_\_\_\_

Time	Type of Probe	CPM(Shield off(UP))			CPM(Shield on(down))		
		Gross	BKG*	Net	Gross	BKG*	Net
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

b. Dose Rate Calibration Due Date \_\_\_\_\_

Time	Instrument	mR/hr(Window Open)			mR/hr(Window Closed)		
		Gross	BKG*	Net	Gross	BKG*	Net
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

c. Integral Dose

Instrument	① Time Started	② Time Complete	③ Duration(HR) ② - ①	④ Total Dose(mR)	⑤ Dose Rate(mR/hr) ④ ÷ ③
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

2. AIR SAMPLE DATA

Calibration Due \_\_\_\_\_

Sampler	Time Started	Time Completed	Duration (Minutes)	Flow Rate (CFM)	Sample Volume (FT <sup>3</sup> )
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

3. PARTICULATE DETERMINATION


Type of Probe	Gross	CPM(Shield off) BKG*	① Net	② $E_p$	③ $E_f$	④ Volume(FT <sup>3</sup> )	① $\times 1.59 \times 10^{-11}$ ② $\times$ ③ $\times$ ④ ( $\mu$ Ci/ml)
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

4. IODINE DETERMINATION

Type of Probe	Gross	CPM(Shield Off) BKG*	① Net	② $E_p$	③ $E_f$	④ Volume(FT <sup>3</sup> )	① $\times 1.59 \times 10^{-11}$ ② $\times$ ③ $\times$ ④ ( $\mu$ Ci/ml)
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

\*NUMERICAL VALUE FOUND IN EMERGENCY PROCEDURE RB-7 OR RB-8





# Pacific Gas and Electric Company

NUMBER EP M-1  
 REVISION 11  
 DATE 12/29/83  
 PAGE 1 OF 5



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

TITLE EMERGENCY PROCEDURE  
 EMPLOYEE INJURY OR ILLNESS (NONRADIOLOGICAL)

APPROVED: R. C. Thibault 3-5-84  
 PLANT MANAGER DATE

### SCOPE

This procedure describes the actions which are to be taken in the event of an illness or injury to an employee which does not involve radioactive contamination or overexposure. Injuries in which radiological considerations are involved are discussed separately in the R series of Emergency Procedures. This procedure and changes thereto requires PSRC review.




### APPLICABILITY

This procedure is to be followed for incidents involving Nuclear Plant Operations personnel, or other company employees at the plant site at the request of the Nuclear Plant Operations Department. In the event of an incident involving any other company employee (such as a General Construction Employee), perform only the asterisked (\*) steps in this procedure.

### IMMEDIATE ACTIONS

The employee(s) who are at the scene shall:

- \*1. Render all necessary first aid.
- \*2. Notify the control room (Shift Foreman) as soon as practical.

NOTE: The Shift Foreman may be notified by dialing [Ext.   
 Dialing  activates the fire alarm and medical emergency code call. The caller must remain on the phone to enable the Shift Foreman to dial into a conference call.

### SUBSEQUENT ACTIONS

The Shift Foreman shall direct all subsequent actions until relieved by the long term Site Emergency Coordinator if the emergency warrants it. Such actions should include the following:

DIABLO CANYON POWER PLANT UNIT NO(S)      1 AND 2  TITLE      EMPLOYEE INJURY OR ILLNESS (NONRADIOLOGICAL)	NUMBER      EP M-1 REVISION      11 DATE      12/29/83 PAGE      2 OF 5
<p>*1. Sound emergency signal, code override, or other general warning signal to clear the area if the situation warrants it.</p> <p>*2. Dispatch additional first aid personnel such as the project construction EMT (Extension [REDACTED] the scene of the injury or illness if required. Personnel who have not been instructed to provide assistance at the scene should remain on their jobs and stay clear of the affected area.</p> <p>*3. Transport the injured person to a Company panel physician or hospital if the situation warrants it (refer to the attached list). If possible, the employee is to be accompanied by a supervisor. The practices which are to be followed if this step is necessary are given in the following section of this procedure.</p> <p>4. Secure the names and addresses of all witnesses (both Company and non-Company).</p> <p>*5. Perform the notifications required by Appendix Z.</p> <p>6. Complete the appropriate accident report(s) and forward to the office supervisor for processing.</p> <p>a. Form 62-4587, "Report of Industrial Injury to Employee" in cases where no medical treatment was required other than minor first aid at the plant.</p> <p>b. Form 62-4586, "Employer's Report of Occupational Injury of Illness" in all cases requiring medical treatment (including doctor referral) other than first aid or results in lost time beyond the day of injury.</p> <p>c. Form 62-5542, "Report of Automobile Accident" if appropriate.</p> <p><u>TRANSPORTATION OF INJURED PERSONNEL</u></p> <p>1. The preferred mode of transportation for injured persons is by Company panel ambulance service. Company or private vehicles should only be used in cases where the delay associated with securing an ambulance might result in significant deterioration of the injured person's condition, or when the injury is of a minor nature where use of an ambulance is not warranted.</p>	

DIABLO CANYON POWER PLANT UNIT NOIS: I AND 2

NUMBER EP M-1  
REVISION 11  
DATE 12/29/83  
PAGE 3 OF 5

TITLE EMPLOYEE INJURY OR ILLNESS (NONRADIOLOGICAL)

2. When requesting ambulance service (refer to the attached list), provide the following information to the ambulance service.
  - a. Name of caller
  - b. Company affiliation
  - c. Phone number of caller (where he can be reached)
  - d. Name of injured or ill person
  - e. Where the patient is located
  - f. Where the patient is to be transported
  - g. Nature of injury or illness
  - h. Any other medical information which might be pertinent to transporting the injured person

Record this information on Form 69-9221, "Emergency Notification Record", or other log.

- \*3. If ambulance or medical personnel are to enter the site, contact the Security Department [REDACTED] and have them notify the security force at the Port San Luis entrance. It is necessary to have an escort accompany the ambulance personnel from the Security Building to the patient.
4. If possible, have a supervisor accompany the injured person to the hospital (or doctor's office). If this is not practical, call a supervisor and have him meet the patient at the hospital (or doctor's office). The supervisor should inform the doctor about the Company's light duty program.
5. If possible, call ahead to the hospital (or doctor) and provide the following information:
  - a. Name of caller
  - b. Company affiliation

DIABLO CANYON POWER PLANT UNIT NO(S)

1 AND 2

NUMBER EP M-1  
REVISION 11  
DATE 12/29/83  
PAGE 4 OF 5

TITLE EMPLOYEE INJURY OR ILLNESS (NONRADIOLOGICAL)

- c. Phone number of caller (where he can be reached)
- d. Name of injured or ill person
- e. Age of injured or ill person (approximate if not known)
- f. Extent of injury, illness or symptoms
- g. Medical history (if known)
- h. Radiological conditions.<sup>1</sup>

Record this information on Form 18-9221, "Emergency Notification Record", or other log.

6. A medical referral, Form 62-6015, shall be completed and sent to the hospital (or doctor) with the injured person along with a copy of the Light Duty Program Letter (copy attached). These forms should be taken by the accompanying supervisor, the patient, or the ambulance driver, as appropriate. Do not delay transport of seriously ill or injured persons while obtaining these forms.

#### REFERENCES

1. Rule 16, PGandE Accident Prevention Rules.
2. PGandE Standard Practice 250.
3. NRC Information Notice 80-06, "Notification of Significant Events."

#### ATTACHMENTS

1. Form 62-4587, "Report of Industrial Injury to Employee"
2. Form 62-4586, "Employer's Report of Occupational Injury or Illness"

---

<sup>1</sup>If the injury or illness is involved with radiation, see "R" Emergency Procedures. However, the hospital should also be informed when radiation is not involved, because in the absence of such knowledge, they will assume that radiation is involved.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP M-1  
REVISION 11  
DATE 12/29/83  
PAGE 5 OF 5

TITLE EMPLOYEE INJURY OR ILLNESS (NONRADIOLOGICAL)

3. Form 62-6015, "Medical Referral"
4. Form 62-4542, "Report of Automobile Accident"
5. Form 69-9221, "Emergency Notification Record"
6. Light Duty Program Letter
7. Company Panel of Physicians, Ambulance, and Hospitals serving the immediate area around Diablo Canyon.
8. Panel of Physicians, Ambulances and Hospitals, Coast Valley Division, SP 251.1-1.
9. Safety, Health and Claims Personnel to be contacted for Reporting of Injuries at Diablo Canyon.
10. Appendix Z, Emergency Procedure Notification Instructions

PACIFIC GAS AND ELECTRIC COMPANY  
 Report of Industrial Injury to Employee

1. Name \_\_\_\_\_ 5. Division \_\_\_\_\_  
 2. Address \_\_\_\_\_ ZIP \_\_\_\_\_  
 3. Telephone No. \_\_\_\_\_ 7. Department \_\_\_\_\_  
 4. Social Security No. \_\_\_\_\_ 8. Date of Accident \_\_\_\_\_  
 5. Occupation \_\_\_\_\_ 9. Time of Accident \_\_\_\_\_  
 10. Location of Accident \_\_\_\_\_ 11. Nature of Injury \_\_\_\_\_  
 12. What were you doing and how did accident occur? \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 13. Describe First Aid rendered: \_\_\_\_\_  
 14. Witnesses to accident:  
 1. \_\_\_\_\_  
 2. \_\_\_\_\_  
 3. \_\_\_\_\_ 15. \_\_\_\_\_  
 Signature of Employee  
 16. Date injury reported: \_\_\_\_\_  
 17. Date 30 days elapsed: \_\_\_\_\_ \* See Over 18. \_\_\_\_\_  
 Signature of Supervisor

**INSTRUCTIONS:** This report (Items 1 thru 15) should be *written* and *signed* by the *employee personally* and countersigned by the supervisor. It is for all industrial injuries and is in duplicate. The original is to be retained for Company records; the copy is to be detached after completion and given to the employee. Before signing in Item 18, the *supervisor* should fill in the date of the report (Item 16) and compute and note the date *30 days* from the date the injury was reported (Item 17).

If the employee later requires treatment by a doctor or becomes disabled, Form 52-4526 must be prepared and forwarded to the Safety, Health and Claims Department *IMMEDIATELY* accompanied by the original of this report.

If the employee is unable to fill out or sign this report, it should be prepared, signed by the supervisor and the employee should be given a copy within 5 days as required by law.

If the injured employee cannot write English, the report may be made according to a verbal statement. If necessary, the employee may sign by a mark and a witness to the report should sign below the employee's mark.



If you wish to discuss your rights under item (1) of the information section, please contact the DSS and present it to your treating physician.

§ 8785. Duties of the Employee-Sanction Physician. The physician or facility chosen by the employee who undertakes to provide treatment pursuant to Labor Code Section 4600 shall:

- (a) Within 3 working days after undertaking to provide such treatment notify the employer of the name and address of such treating physician or facility, and
- (b) Within 5 working days following initial examination shall submit a written report to the employer to include:
  - (1) The name and address of injured employee;
  - (2) The employee's medical history as obtained by the physician;
  - (3) Findings on examination;
  - (4) The subjective complaints reported by the employee;
  - (5) The planned course, scope and duration of treatment;
  - (6) If appropriate, the estimated return-to-work date;
  - (7) An opinion as to whether "serious permanent disability" is to be anticipated and, if possible, an estimate of its extent;
  - (8) An opinion as to whether the employee will eventually be able to engage in the occupation being performed at the time of injury.
- (c) At reasonable intervals during active treatment submit progress reports to the employer and, periodically, report promptly to the employer when:
  - (1) The employee's condition permits return to work;
  - (2) The employee's condition results him or her to leave work;
  - (3) Resection or surgery is indicated or recommended;
  - (4) The employee's condition becomes permanent and stationary;
  - (5) The employee's condition undergoes a previously unexpected significant change; the report shall contain a statement of the progress course of treatment required, if any, by these changes;
  - (6) The employee is referred to another physician for consultation;
  - (7) The employee reasonably requests additional appropriate information.

PACIFIC GAS AND ELECTRIC COMPANY  
Employer's Report of Occupational Injury or Illness  
CONFIDENTIAL - For Use by Company Attorneys

DIVISION	GENERAL OFFICE OR GENERAL CONSTRUCTION
DEPARTMENT	CONSTRUCTION DEPT. LOCAL OFFICE
LOCATION OR JOB NUMBER	
ACCOUNT NUMBER	
JOB NUMBER	

ACCIDENT REPORT NUMBER

Caution: This report is prepared by the employer for the use of the company's insurance carrier and is not intended for the use of any other party. This report is prepared by the employer and is not intended to be used by the Commission for any purpose. It is the responsibility of the employer to file this report with the Commission in accordance with the provisions of the Workers' Compensation Act. The Commission will not accept a report that is not filed in accordance with the provisions of the Act. The Commission will not accept a report that is not filed in accordance with the provisions of the Act.

1. NAME	PACIFIC GAS AND ELECTRIC COMPANY 17 BEALE STREET SAN FRANCISCO, CA	4. BUSINESS	PUBLIC UTILITY - Gas & Electric	2. SEX	MALE	PLEASE DO NOT USE THIS COLUMN
3. ADDRESS	PHONE	5. EMPLOYMENT NUMBER	102-2799	6. SECURITY NUMBER		
7. DATE OF BIRTH	8a. DATE OF INJURY	9. TIME OF DAY	10. OCCASION	11. HOUR	12. DAY	
13. MARRIAGE	14. CHILDREN	15. YEARS OF EXPERIENCE	16. YEARS OF SERVICE	17. YES	18. NO	
19. TYPE OF INJURY	20. TYPE OF INJURY	21. TYPE OF INJURY	22. TYPE OF INJURY	23. TYPE OF INJURY	24. TYPE OF INJURY	
25. TYPE OF INJURY	26. TYPE OF INJURY	27. TYPE OF INJURY	28. TYPE OF INJURY	29. TYPE OF INJURY	30. TYPE OF INJURY	
31. TYPE OF INJURY	32. TYPE OF INJURY	33. TYPE OF INJURY	34. TYPE OF INJURY	35. TYPE OF INJURY	36. TYPE OF INJURY	
37. TYPE OF INJURY	38. TYPE OF INJURY	39. TYPE OF INJURY	40. TYPE OF INJURY	41. TYPE OF INJURY	42. TYPE OF INJURY	
43. TYPE OF INJURY	44. TYPE OF INJURY	45. TYPE OF INJURY	46. TYPE OF INJURY	47. TYPE OF INJURY	48. TYPE OF INJURY	
49. TYPE OF INJURY	50. TYPE OF INJURY	51. TYPE OF INJURY	52. TYPE OF INJURY	53. TYPE OF INJURY	54. TYPE OF INJURY	
55. TYPE OF INJURY	56. TYPE OF INJURY	57. TYPE OF INJURY	58. TYPE OF INJURY	59. TYPE OF INJURY	60. TYPE OF INJURY	
61. TYPE OF INJURY	62. TYPE OF INJURY	63. TYPE OF INJURY	64. TYPE OF INJURY	65. TYPE OF INJURY	66. TYPE OF INJURY	
67. TYPE OF INJURY	68. TYPE OF INJURY	69. TYPE OF INJURY	70. TYPE OF INJURY	71. TYPE OF INJURY	72. TYPE OF INJURY	
73. TYPE OF INJURY	74. TYPE OF INJURY	75. TYPE OF INJURY	76. TYPE OF INJURY	77. TYPE OF INJURY	78. TYPE OF INJURY	
79. TYPE OF INJURY	80. TYPE OF INJURY	81. TYPE OF INJURY	82. TYPE OF INJURY	83. TYPE OF INJURY	84. TYPE OF INJURY	
85. TYPE OF INJURY	86. TYPE OF INJURY	87. TYPE OF INJURY	88. TYPE OF INJURY	89. TYPE OF INJURY	90. TYPE OF INJURY	
91. TYPE OF INJURY	92. TYPE OF INJURY	93. TYPE OF INJURY	94. TYPE OF INJURY	95. TYPE OF INJURY	96. TYPE OF INJURY	
97. TYPE OF INJURY	98. TYPE OF INJURY	99. TYPE OF INJURY	100. TYPE OF INJURY	101. TYPE OF INJURY	102. TYPE OF INJURY	

Filing of this report is not an admission of liability. No report of injury required to be filed by an employer or insurer by this chapter shall be admissible as evidence in any adversary proceeding before the Workmen's Compensation Appeals Board.  
Labor Code, Section 6412

FIRM: PACIFIC GAS & ELECTRIC COMPANY  
OFFICIAL POSITION: Mgr., Safety, Health & Claims Dept.  
TELEPHONE: 781-4271 EXTENSION: 3171

101

Report # \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_

Dr. \_\_\_\_\_

Kindly give to bearer

Mr. Ms. \_\_\_\_\_

medical attention, and forward a complete detailed report immediately to Manager, Safety, Health and Claims Dept., 245 Market Street, San Francisco 94106. Your bills should be itemized and all bills and reports rendered in duplicate.

PACIFIC GAS AND ELECTRIC COMPANY

By \_\_\_\_\_ REC # \_\_\_\_\_

Mr. - Foreman - Supv.

12-6-15 REV 3/61

PLEASE COMPLETE AND RETURN TO EMPLOYEE  
(EMPLOYEE MUST HAVE COMPLETED CARD TO RETURN TO WORK)

Pacific Gas and Electric Co., Date \_\_\_\_\_, 19\_\_

Mr. Ms. \_\_\_\_\_

Occupation \_\_\_\_\_ Report # \_\_\_\_\_

Employed By \_\_\_\_\_ REC # \_\_\_\_\_ Division \_\_\_\_\_

Injured at \_\_\_\_\_<sup>AM</sup> on \_\_\_\_\_, 19\_\_

- Return to full work immediately \_\_\_\_\_
- Modified work until \_\_\_\_\_
- Unable to work until \_\_\_\_\_
- Restrictions or limitations \_\_\_\_\_
- Return Appt. Date: \_\_\_\_\_ Time: \_\_\_\_\_
- Discharged from treatment \_\_\_\_\_

Signed \_\_\_\_\_ MD.

Report # \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_

Dr. \_\_\_\_\_

Kindly give to bearer,

Mr./Ms. \_\_\_\_\_

medical attention, and forward a complete detailed report immediately to Manager, Safety, Health and Claims Dept., 245 Market Street, San Francisco, 94106. Your bills should be itemized and all bills and reports rendered in triplicate.

PACIFIC GAS AND ELECTRIC COMPANY

By \_\_\_\_\_ RC# \_\_\_\_\_

Mgr. - Foreman - Supt.

62-6016 (REV. 3/66)

PLEASE COMPLETE AND RETURN TO EMPLOYEE  
(EMPLOYEE MUST HAVE COMPLETED CARD TO RETURN TO WORK)

Pacific Gas and Electric Co.: \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_

Mr./Ms. \_\_\_\_\_

Occupation \_\_\_\_\_ Report # \_\_\_\_\_

Employed By \_\_\_\_\_ RC# \_\_\_\_\_ Division \_\_\_\_\_

Injured at \_\_\_\_\_<sup>a.m.</sup> on \_\_\_\_\_, 19\_\_

Return to full work immediately \_\_\_\_\_

Modified work until \_\_\_\_\_

Unable to work until \_\_\_\_\_

Restrictions or limitations \_\_\_\_\_

Return Appt. Date: \_\_\_\_\_ Time: \_\_\_\_\_

Discharged from treatment \_\_\_\_\_

Signed \_\_\_\_\_ MD.





# PACIFIC GAS AND ELECTRIC COMPANY

5041

1000 BAYVIEW BLVD. SUITE 1000  
SAN FRANCISCO, CALIF. 94134

Mr. [REDACTED]  
[REDACTED]  
[REDACTED]

Dear Dr.:

Thank you for being one of our panel physicians that treat our employees. Our primary goal is to provide employees who sustain industrial injuries requiring medical attention with prompt, first-class treatment. Your assistance in this endeavor is appreciated.

There is an area of concern to us. While the number of employees that require treatment by a physician has remained stable or in some cases declined, the number of disabling injuries requiring time away from work, i.e., lost time injuries, has dramatically increased.

We believe that some of this time away from work might possibly be avoided if the availability of light (modified) duty or desk-type work were more widely known. Some physicians have stated that in some cases the patient will respond more rapidly to treatment if kept busy in a light-duty capacity. Productive, light-duty assignments are almost always available for employees released for work within the medical restrictions established by the physician.

It is our policy to have an injured employee accompanied by a supervisor or other representative on the first doctor's visit. Should there be any question about the availability or type of light duty that can be provided, we or she will be able to answer for us.

Our employees' welfare is our main concern. Should you have any questions about our program, I will be glad to call on you at your convenience.

Sincerely,

R. C. THORNBERRY




RCT:kgs

11/83

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT

Company Panel of Physicians, Ambulances, and Hospitals  
Serving the Immediate Area Around Diablo Canyon

Ambulance<sup>2</sup>

<u>Name</u>	<u>Address</u>	<u>Phone</u>	<u>Remarks</u>
San Luis Ambulance Service			Radiation Exposure Patients
Five Cities Ambulance Service			
South Bay Fire/Ambulance			
Bay Ambulance			
CENTRAL DISPATCH FOR ALL OF THE ABOVE AMBULANCE SERVICES			

Hospitals

French Hospital		Radiation Exposure Patients-External Defib. Equip.
**Sierra Vista Hospital (20 minutes to clear for helicopter)		External Defibrillation Equipped
Arroyo Grande Community Hospital and Medical Center		External Defibrillation Equipment



Physicians

San Luis Medical Clinic


\*Richard E. Fleming

.

T. A. Beresky

\*David W. Ralston

Laurence H. Lotz



Industrial Injury  
Treatment and Eye  
Injuries

Eye Injuries

Industrial Injury  
and Preemployment  
Physical Exams

Industrial Injury  
and Preemployment  
Physical Exams

1. This list extracted from Standard Practice No. 251.1-1, Panel of Physicians, Ambulances, and Hospitals, Coast Valleys Division, dated 9/29/83.
2. See also EP OR-1 "Offsite Support and Assistance" for Air Ambulance and Medical Support.

\*Willing to fly

\*\*Helicopter landing facility available

PACIFIC GAS AND ELECTRIC COMPANY  
SAFETY, HEALTH, AND CLAIMS DEPARTMENT  
PANEL OF PHYSICIANS, AMBULANCES, AND HOSPITALS  
COAST VALLEYS DIVISION

• SP 251.1-1

Page 2.1  
Issued: 9/29/83

TOWN                      ADDRESS                      TELEPHONE                      SERVICE

ARROYO GRANDE

Five Cities Ambulance  
Service  
CENTRAL DISPATCH

A.G. Community Hospital  
and Medical Center

ATASCADERO

Doctors


North County Medical  
Services (Emergency  
Medical Technician)  
CENTRAL DISPATCH


Twin Cities Community  
Hospital

BAYWOOD PARK - LOS OSOS

South Bay Fire/Ambulance  
CENTRAL DISPATCH


- I            - Industrial Injury Treatment
- E            - Preemployment Physical Examinations
- EYE        - Eye Injuries
- PM         - Paramedic Services
- "DEF"      - Hospital Equipped with External Defibrillators
- \*           - Willing to Fly
- \*\*         - Helicopter Landing Facility Available
- RAO        - Radiation Exposure Incidents

<u>TOWN</u>	<u>ADDRESS</u>	<u>TELEPHONE</u>	<u>SERVICE</u>	
<u>CAMBRIA</u>				
Cambria Ambulance Service			Ambul	
CENTRAL DISPATCH			Ambul	
<u>CARMEL</u>				
Red Cross Ambulance				Ambul
Community Hospital of the Monterey Peninsula				Hosp DEF
<u>CARMEL VALLEY</u>				
C. Winter Van Horn				I-E
Paulino E. Tocchet				I-E
<u>CASTROVILLE</u>				
Joseph L. Kirch				I-E
Bert Clair Eliason				I-E
<u>HOLLISTER</u>				
N.L. Currie				I-E
Martin M. Bress				I-E
Stephens & Poletti Ambulance				Ambul
Hazel Hawkins Hospital			Hosp DEF	
<u>KING CITY</u>				
Duane F. Hyde			I-E	
South County Ambulance			Ambul	
George L. Mee Memorial Hospital			Hosp DEF	

<u>TOWN</u>	<u>ADDRESS</u>	<u>TELEPHONE</u>	<u>SERVICE</u>
<u>LOMPOC</u>			
Community Ambulance Service			Ambul
Lompoc Hospital District			Hosp DEF
<u>LOS OSOS</u>			
South Bay Fire Department/Ambulance CENTRAL DISPATCH			Ambul
<u>MONTEREY</u>			
W.A. Cannazzo Nello P. Torri Howard Press John J. D'Attilio George S. Campion			I-E I-E I-E Eye Eye
Eskaton Health Care Center (24-hour Emergency Service)			Hosp DEF
Peninsula Community			Hosp DEF
<u>MORRO BAY</u>			
Bay Ambulance			Ambul

<u>TOWN</u>	<u>ADDRESS</u>	<u>TELEPHONE</u>	<u>SERVICE</u>
<u>PASO ROBLES</u>			
	*Stanley J. Kirk Physicians' Exchange		I-E
	Professional Ambulance Service		Ambul
	CENTRAL DISPATCH		Ambul
	Twin Cities Hospital		Hosp DEF
<u>SALINAS</u>			
	W.H. Lawler, Jr.		I-E
	Howard C. Miles Glenn H. Smith E.O. Dong Robert Avila		I-E Eye Eye I-E
	A-1 Ambulance Service		Ambul
	Salinas Valley Memorial Hospital		Hosp DEF
	Robert G. Van Horne		E
<u>SAN LUIS OBISPO</u>			
	*Richard E. Fleming		I-E
	T.A. Beresky		Eye
	Laurence H. Lotz		I-E
<u>SLO Medical Clinic</u>			
	San Luis Ambulance Service		Ambul RAD
	CENTRAL DISPATCH		Ambul
	French Hospital		Hosp DEF RAD
	**Sierra Vista Hospital (20 minutes to clear for chopper)		Hosp DEF
	David W. Ralston		I-E

<u>TOWN</u>	<u>ADDRESS</u>	<u>TELEPHONE</u>	<u>SERVICE</u>
<u>SANTA BARBARA</u>			
	St. Francis Hospital		Hosp DEF
<u>SANTA MARIA</u>			
	Brian J. Kiniry		I
	Jules Bertero		I-E
	*Harry K. Lienke		I-E
	*Donald E. Reiner		I
	D.D. Shepard		Eye
	Industrial Medical Group of		
	Dr. Betty Suits Tibbs		I-E
	Dr. William J. Tibbs		I-E
	Ambulance Service		Ambul PM
	Santa Maria Ambulance Service		Ambul
	Police Department (For Emergency Only)		Ambul
	Marian Hospital		Hosp DEF
	Valley Community Hospital		Hosp
<u>SOLEDAD</u>			
	Soledad Ambulance Service (County Emergency Services)		Ambul

<u>TOWN</u>	<u>ADDRESS</u>	<u>TELEPHONE</u>	<u>SERVICE</u>		
<u>SOLVANG</u>					
F.A. Pedersen			I-E		
W.B. Van Valin			I-E		
Coast Ambulance Service			Ambul		
Santa Ynez Valley Hospital			Hosp DEF		
<u>TEMPLETON</u>					
Peter S. Davis			I-E		
Willard Osibin			I-E		
*R.A. Greenman			E		
CENTRAL DISPATCH			Ambul		
Twin Cities Hospital			Hosp DEF		
<u>WATSONVILLE</u>					
*E.H. Eiskamp	I-E				
P.K. Gilman	I-E				
David E. Bushman	I-E				
Douglas A. Liddicoat	Eye				
W. Webb Wilson	Eye				
A-1 Watsonville Ambulance	Ambul				
**Watsonville Community Hospital	Hosp DEF				

11/83

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

Page 1 of 2

Safety, Health and Claims Personnel to be  
Contacted for Reporting of Injuries at Diablo Canyon<sup>1</sup>

EMPLOYEE INJURIES

In all cases of serious employee injuries (for example, injuries involving hospitalization, electric contact, hernia, amputation, fractures, or injuries expected to result in lost time from work beyond the day of injury) or death, which occur while on the job, report should be made as follows:

During Working Hours:

T. B. Honey

PGandE local

(If Mr. Honey is not available, the person answering the telephone will take the message and notify Mr. Honey or any other parties necessary in the Safety, Health and Claims Department).

Any Other Time:

Report to one of the persons on the following list, trying each in order until one is contacted:

- |                     |               |
|---------------------|---------------|
| 1. T. B. Honey      | Pinole        |
| 2. A. Thomas        | San Francisco |
| 3. C. B. Powell     | San Francisco |
| 4. P. S. Benitez    | San Rafael    |
| 5. T. G. Scott      | Oakland       |
| 6. L. Lasagna       | Albany        |
| 7. C. W. Allen      | San Francisco |
| 8. B. L. Wade       | Larkspur      |
| 9. J. A. Glimme     | Danville      |
| 10. J. C. Vocke     | Lafayette     |
| 11. W. A. Hutchison | San Carlos    |
| 12. M. C. Dolan     | Oakland       |
| 13. M. W. Johnson   | Walnut Creek  |
| 14. R. W. Hall      | Richmond      |
| 15. I. M. Crawford  | Hercules      |
| 16. R. G. Schumaker | El Granada    |
| 17. R. D. Fagg      | San Rafael    |
| 18. P. C. Boettcher | Moraga        |
| 19. H. W. Reynolds  | Sunnyvale     |
| 20. B. P. Sadler    | Belmont       |

<sup>1</sup>This listing extracted from Safety, Health, and Claims memo regarding Personnel to be Contacted for Reporting of Accidents, dated 01/13/83. Found in PG&E Standard Practices S.P.251-2.



Safety, Health and Claims Personnel to Be  
Contacted for Reporting of Injuries at Diablo Canyon

Page 2 of 2

Non-Employee Injuries

C. O. Schreil, San Luis Obispo, [REDACTED] (office)  
[REDACTED] (office)  
[REDACTED] (home)

If he cannot be reached, contact one of the following in order of preference:

During working hours:

1. John C. Echols
2. Doug G. Keeler
3. George G. Perry (collection only)

After working hours on Monday through 8:00 a.m. on Friday, except holidays:

- |   |               |
|---|---------------|
| 1. John C. Echols                       | Pleasant Hill |
| 2. Douglas G. Keeler                    | Concord       |
| 3. John C. Vocke                        | Layfayette    |
| 4. Donald A. Rushton                    | San Mateo     |
| 5. William H. Bingaman                  | Novato        |
| 6. E. Anthony Giudici                   | San Carlos    |
| 7. J. Alec McCorquodale                 | San Ramon     |
| 8. Stanley W. Johnson                   | Fairfield     |
| 9. George G. Perry<br>(collection only) | Hayward       |
| 10. Bruce P. Sadler                     | Belmont       |

After 5:00 p.m. on Fridays to 8:00 a.m. on Mondays and holidays:

Contact the Investigator delegated to stay on call for all emergencies. He may be reached through the System Dispatcher. If he is not available, the Dispatcher will follow the procedures for "After Working Hours."

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2	NUMBER	EP M-1
	REVISION	11
TITLE EMPLOYEE INJURY OR ILLNESS (NON-RADIOLOGICAL)	DATE	12/29/83
	PAGE	1 OF 1


ATTACHMENT 10

EP M-1

APPENDIX Z

1. When this emergency procedure has been implemented for injuries or illnesses occurring within the plant gate, and upon direction from the Shift Foreman, proceed as follows:
  - \*a. Notify the Plant Manager or his designated alternate.
  - b. Notify the Compensation Claims Representative, Department of Safety Health and Claims, per the attached list of personnel.
  - \*c. Review the circumstances causing the injury or illness against the criteria for reports to NRC contained in Administrative Procedure C-11, Supplement 1, "Supplement 1 to Non-Routine Notification and Reporting to the NRC and Other Governmental Agencies," Appendix I.19, "Reporting of Significant Operating Events." If circumstances warrant, designate the event in accordance with the criteria contained in Procedure C-11.
  - \*d. Also notify the following if NRC is notified - Supervising Nuclear Generation Engineer (Personnel and Environmental Safety) or his alternate in the Department of Nuclear Plant Operation:

Mr. W. H. Fujimoto  
 PGandE  
 Plant Extension  
 Home



NOTE: If the above General Office person cannot be promptly reached, request the Systems Dispatcher to contact alternate personnel.

CURRENT  
EMERGENCY PLAN  
IMPLEMENTING PROCEDURES

TABLE OF CONTENTS

Volume 3B

	<u>TITLE</u>	<u>REV</u>
CR-1	Offsite Support & Assistance	3
OR-2	Release of Information to the Public	2
EF-1	Activation and Operation of the Technical Support Center	2
EF-2	Activation of the Operational Support Center	2
EF-3	Activation and Operation of the Emergency Operations Facility	3
EF-4	Activation of the MEML	3
EF-5	Emergency Equipment, Instruments & Supplies	4
EF-6	Operating Procedures For EARS 9845C Controlling Stations	1
EF-6S1	Transfer of EARAUT Control	1
EF-7	Activation of the Nuclear Data Communications Systems	1
EF-8	EARS Operating Procedures for TSC-CC HP-1000 Station	0
RB-1	Personnel Dosimetry	Not Issued
RB-2	Emergency Exposure Guides	0
RB-3	Stable Iodine Thyroid Blocking	0
RB-4	Access to & Establishment of Controlled Areas Under Emergency	0
RB-5	Personnel Decontamination	0
RB-6	Area & Equipment Decontamination	1
RB-7	Emergency On-Site Radiological Environmental Monitoring	3
RB-8	Emergency Off-Site Radiological Environmental Monitoring	2
RB-9	Calculation of Release Rate & Integrated Release	2
RB-10	Protective Action Guidelines	0
RB-11	Emergency Off-Site Dose Calculations	3
RB-12	Mid and High Range Plant Vent Radiation Monitors	1
RB-13	Improved In-Plant Air Sampling for Radioiodines	0

03/26/84

DIABLO CANYON POWER PLANT  
PROCEDURE ON-THE-SPOT CHANGE

Procedure No. EP RB-2 Rev. X0 Unit No. 1  2  1 & 2   
Title EMERGENCY EXPOSURE GUIDES

Type of Change:  PERMANENT (green)  TEMPORARY (yellow); Expiration Date \_\_\_\_\_  
Requesting Department Chemistry & Radiation Protection Originator M. R. Creath

Proposed Change: (Does this alter the intent of original procedure?)  Yes  No  
(Does it constitute an unreviewed safety/environmental question?)  YES  NO

Page 2: Procedure Section 3.b.1)

Change to read: Two (2) direct-reading pencil dosimeters for whole body exposure:

1 - 100 or 50R range  
1 -  - 5 R range.

ORIGINATOR

Reason for Change:

Equipment update.

Authorizations: *M. R. Creath* (Plant Management Staff) *R. Patterson* (Plant Management Staff w/SRO License) 2/23/84 *R. Creath*

Is immediate distribution required?  YES  NO  
If YES, originator must distribute to Control Room, Shift Foreman and QC. Initial Distribution Made By: \_\_\_\_\_  
List other initial distribution to Controlled Copy Holders of this procedure \_\_\_\_\_

RECEIVED  
CONTROL

Date Received by Document Control 2-24-84  
PSRC Review and Plant Manager's approval 3-8-84 Date above + plus 14 days

PSRC MUST  
CHANGE REVIEW

Review Date \_\_\_\_\_  
PSRC recommends approval  Yes  No  
Meeting Number   -       
Plant Manager's Approval  N/A

IN FOR  
E. P. H.

Follow-up To Rejected On-the-Spot Change  Additional Information   
Action Taken/Remarks:

DISTRIBUTION:  Same as Original Procedure Distribution  Others: \_\_\_\_\_ Please see additional sheets



Pacific Gas and Electric Company

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 1 OF 38



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

TITLE EMERGENCY PROCEDURE  
EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

IMPORTANT  
TO  
SAFETY

APPROVED R. C. Thompson 3-5-84  
PLANT MANAGER DATE

SCOPE

This procedure provides an inventory of emergency equipment, instruments, and supplies (both portable and fixed) with inspection frequencies.

This procedure and changes thereto require PSRC review.

PORTABLE EMERGENCY EQUIPMENT

1. Radiological Emergency Kits

The kits consist of three boxes each. Each box is clearly identified first by kit numbers, and second by box letter A, B or C. The contents of each emergency kit are given in Table 1. The contents of each box of an individual emergency kit can be found in the notebook of each box. In addition, protective clothing and shoe covers are located at the Energy Information Center and the DCPD Security Building for use in case personal effects are contaminated.

a. Location

Kit Nos. 1, 2 and 3 - PG&E San Luis Obispo Service Center Mobile Environmental Monitoring Laboratory (MEML) Garage

Kit Nos. 4 and 5 - Diablo Canyon Power Plant Security Building, Exit Foyer.

b. Use

The kits are available for use in case of a radiological emergency by a designated monitoring team composed of at least two individuals trained in emergency radiological monitoring. The team will be directed by the Control Room or TSC (onsite teams) or the EOF (offsite teams) as to which areas they will monitor. Other instructions are contained in the notebook of each kit.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 2 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

c. Obtaining an Emergency Kit

- 1) Kits No. 1, 2 and 3 can be obtained by the designated monitoring teams from the PG&E San Luis Obispo Service Center, in the Mobile Environmental Monitoring Laboratory (MEML) Garage. The personnel dispatched to the MEML garage will generally consist of Chemistry and Radiation Protection Technicians (C&RP), the MEML Operators from PGandE Department of Engineering Research, and San Luis Obispo County Environmental Health Department Personnel.

NOTE: If the MEML garage is locked, personnel should not open the door without a burglar alarm defeat key available. The front door is the only access that has a 45 second time delay to permit use of the defeat key (see Figure 1). The defeat key is available from the plant if the DER personnel are not available. The DER personnel will be called out as part of the call-out list in Emergency Procedure EP G-2.

When PGandE personnel have reached the MEML garage, establish telephone contact with the Radiological Emergency (RERM) at the Emergency Operations Facility (EOF). The phone number is listed in Attachment 1. If the MEML garage is locked and access cannot be obtained from the DER personnel assigned to the van, then use the telephone in the division office building (see Figure 1).

NOTE: If the RERM cannot be reached at the EOF, then contact the Emergency Radiological Advisor (ERA) at the onsite Technical Support Center. The phone number is listed in Attachment 1.

If the RERM or the ERA require immediate deployment of the MEML and/or the field monitoring teams, and access to the garage is still not available, inform the RERM/ERA that access is not available and request the Cypher Pad Code that will open the door. Also, request the ERA to dispatch an individual from the plant to reset the alarm.

Call DCPD security to inform them the MEML garage will be entered, and that the alarm will be actuated. The phone number is listed in Attachment 1.

NOTE: When the alarm is actuated a loud electronic warbler will sound locally, until reset.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 3 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

- 2) Kits No. 4 and 5 can be obtained by the designated monitoring teams from the site security building exit foyer (cabinet in northwest corner).

d. Surveillance Frequency

- 1) Kit inventory will be performed by the Chemistry and Radiation Protection Department annually and after each use. Form 69-9823-1, 69-9823-2, and 69-9823-3 are used to document the inventory.
- 2) Kit radiological instruments will be replaced or recalibrated quarterly in accordance with the normal practice established by the I&C Maintenance Department.
- 3) Dosimeter charger and flashlight batteries will be replaced quarterly.

2. Emergency Evacuation Kits

Each kit consists of a box, clearly identified. The contents of each emergency evacuation kit are given in Table 2. The contents of each box can be found on the inside cover of the box. In addition, two cases of protective clothing and two cases of shoe covers are stored near the evacuation kits for use in case personal effects are contaminated. Additional protective clothing is also available at the Energy Information Center.

a. Location

The two emergency evacuation kits are located in the Exit Foyer of the Plant Security Building.

b. Use

The kits are available for use in the event site evacuation is ordered by the Site Emergency Coordinator. The Evacuation Coordinator would then have the kits and clothing issued to the evacuation team leaders.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 4 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

c. Obtaining an Emergency Evacuation Kit

The emergency evacuation kits can be obtained by going to the Exit Foyer located at the Plant Security Building, and removing them from the storage cabinet in the northwest corner of the foyer.

d. Surveillance Frequency

- 1) Kit inventory will be performed by the Chemistry and Radiation Protection Department annually and after each use. Form 69-9369 is used to document the inventory.
- 2) Survey meters and dose rate meters will be replaced or recalibrated quarterly in accordance with the normal practice established by the I&C Maintenance Department.
- 3) Dosimeter charger, bullhorn, calculator, and flashlight batteries will be replaced quarterly.

3. First Aid Supplies

a. Location

The location of first aid supplies are listed in Table 3.

NOTE: Not all first aid supplies are presently deployed at their locations. However, they will be in place by power ascension above 5%.

b. Surveillance

First aid supplies are inventoried monthly by the Support Services Organization.

4. Hospital Kits

Each kit consists of a box, clearly identified. The contents of each hospital kit are given on Table 4.

a. Location

The two hospital kits are located in the Exit Foyer of the Plant Security Building.



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 5 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

b. Use

The kits are available for use in the event an injury victim, involving radioactive contamination or overdose, is sent to an offsite location for treatment or decontamination.

c. Obtaining a Hospital Kit

The kits can be obtained by going to the Exit Foyer located at the Plant Security Building, and removing them from the storage cabinet in the northwest corner of the foyer.

d. Surveillance Frequency

- 1) Kit inventory will be performed by the Chemistry and Radiation Protection Department annually and after each use.
- 2) Survey meters and dose rate meters will be replaced or recalibrated quarterly in accordance with the normal practice established by the I&C Maintenance Department.
- 3) Dosimeter charger batteries will be replaced quarterly.

5. Respirators (Self-Contained Breathing Apparatus or SCBA)

a. Location

- 1) Eight SCBA units are maintained in the control room for shift fire brigade members.
- 2) Sixteen SCBA units are located in the fire brigade locker on the stairway landing above the 85' elevation between the turbine building and auxiliary building.
- 3) Five SCBA units and five 30-minute spare tanks are located at the Technical Support Center.
- 4) Two SCBA units are maintained on the east side of intake structure in two yellow cabinets.
- 5) Thirty SCBA units are maintained at or near Access Control for normal radiological use. Thirty 30-minute spare tanks are also maintained at this location.

DIABLO CANYON POWER PLANT UNIT NO(S)    1 AND 2	NUMBER    EP EF-5 REVISION    4 DATE    10/28/83 PAGE    6 OF 38
TITLE    EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES	

- 6) Seven SCBA units are stored in the Auxiliary Building stairwell on the west side at the 90' elevation.
- 7) One SCBA unit is maintained at the Unit 2 Auxiliary Operator's Office.
- 8) Forty SCBA units and sixty-five 30-minute spare tanks will be stored in the turbine building.

b. Surveillance

- 1) SCBA units will be inspected by the Chemistry and Radiation Protection Department monthly.
- 2) The forty SCBA's stored in the turbine building will be inspected prior to use.
- 3) All SCBA units will be inventoried semiannually.

6. Portable Survey and Dose Rate Instruments

A variety of portable count rate and dose rate instruments are available at the plant for routine radiological monitoring, and also for use in emergencies, if necessary. The general types and approximate quantities of this equipment are summarized in Table 5 and 6. It should be noted that this list is intended only to be illustrative of the plant's capabilities; precise quantities and models of specific equipment may vary from time to time as conditions change, different products appear on the market, etc. The equipment listed in the table is normally located at access control when not in use.

7. Post-Accident Sample Kit

The kit consists of two storage lockers, clearly identified. The contents of the lockers is given on Table 7.

a. Locations

- 1) 85' locker located in the turbine building elevator vestibule.
- 2) 115' locker located across the passageway from the IPLSS panel.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 7 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

b. Use

The lockers are available for use in the event a high activity sample is anticipated from the post-accident sampling system.

c. Surveillance Frequency

Kit inventory will be performed by the Chemistry and Radiation Protection Department annually and after each use.

8. Protective Clothing

Protective clothing for normal and emergency use is located at access control and the laundry room. Other locations where clean protective clothing may be found are:

- a. Plant warehouse
- b. PGandE Energy Information Center
- c. Operational Support Center (OSC)/DCPP Security Building Exit Foyer
- d. Technical Support Center (TSC)

9. Mobile Environmental Monitoring Laboratory (MEML)

The following equipment is available in the MEML for use in routine and emergency environmental monitoring. Surveillance is performed in normal use.

- a. NaI Detector
- b. IGe Detector
- c. HP 9845C Computer
- d. Multichannel Analyzer
- e. High-Volume Air Sampler
- f. Pressurized Ion Chamber (3)
- g. High-Pressure Gas Sampler
- h. TLD Reader
- i. Instrument-Grade Electric Generators

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/29/83  
PAGE 8 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

10. Plant Vehicles

Plant vehicles shall be inventoried by the Personnel and General Services Department. The plant vehicle list shall be updated annually. The plant vehicle list can be found in Table 8.

11. Radio Pagers

Radio pagers are assigned to selected positions of the emergency organization, as a convenience, for use when the on-call person for the position is not available at their normal telephone numbers. Normal pager assignments are given in Table 8.a. A group page and test message is given on the first of each month at about 8:00 p.m. to provide a check on pager operation.

FIXED EMERGENCY EQUIPMENT

1. Early Warning System

Testing and maintenance for the EWS Siren Units, listed in Table 9, shall be performed by Los Padres District personnel according to the following schedule:

- a. Monthly: A test cancel signal will be initiated, counter readings will be taken and a visual inspection made.
- b. Quarterly: The inside of the compressor and the control and receiver cabinets will be inspected, and the sirens will be growl tested.
- c. Annually: A complete inspection of all major components, as well as lubrication and cleaning of the unit will be done.

EMERGENCY FACILITY EQUIPMENT

1. Control Room

Equipment available in the Control Room for radiological emergency assesment and communication and the surveillance performed on this equipment is listed in Table 10.

2. Technical Support Center (TSC)

Equipment available in the TSC for emergency assessment, communication and other emergency functions of the facility and the surveillance performed on this equipment is listed in Table 11.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 9 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

3. Operational and Operations Support Centers (OSC)

Equipment available in the OSC for emergency functions and communications and the surveillance performed on this equipment is listed in Table 12.

4. Emergency Operations Facility (EOF)

Equipment available in the EOF for emergency assessment, communication and other emergency functions of the facility and the surveillance performed on this equipment is listed in Table 13.

5. Emergency Procedure Phone Numbers

Telephone numbers in the emergency procedures are verified quarterly by the emergency planning staff, using Form 69-9043.

FIGURES

1. MEML Garage Layout and Access

TABLES

1. Contents of Radiological Emergency Kits

2. Contents of Evacuation Kits

3. Locations of First Aid Supplies

4. Contents of Hospital Kits

5. Portable Count Rate Meters

6. Portable Dose Rate Instruments

7. Contents of Post-Accident Sample Kit

8. Plant Vehicle List

8a. Emergency Organization Radio Pagers

9. EWS Siren Locations

10. Control Room Emergency Plan Equipment

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 10 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLES (continued)

11. Technical Support Center Emergency Plan Equipment
12. Operational and Operations Support Center Emergency Plan Equipment
13. Emergency Operations Facility Emergency Plan Equipment

ATTACHMENTS

1. Emergency Facility Phone Numbers
2. 69-9823-1 Emergency Kit Inventory Checklist Box A
3. 69-9823-2 Emergency Kit Inventory Checklist Box B
4. 69-9823-3 Emergency Kit Inventory Checklist Box C
5. 69-9369 Evacuation Kit Inventory Checklist
6. 69-10598 Hospital Kit Inventory Checklist
7. 69-10507 Post-LOCA Sampling Kit Inventory Checklist
8. 69-9043 Emergency Plan Phone Number Verification Checklist
9. 69-10766 Control Room Checklist
10. 69-10767 Technical Support Center Checklist
11. 69-10768 Technical Support Center Equipment Quantity Checklist
12. 69-10769 Operational Support Center and Operations Support Center Checklist
13. 69-10770 Emergency Operations Facility Equipment Function Checklist
14. 69-10771 Emergency Operations Facility Inventory Checklist
15. 69-10582 Emergency Facility Forms File List

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/63  
PAGE 11 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

FIGURE 1 GARAGE LAYOUT AND PHONE ACCESS






FIGURE 1 GARAGE LAYOUT AND PHONE ACCESS



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 12 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 1  
 CONTENTS OF RADIOLOGICAL EMERGENCY KITS

ITEM	QUANTITY				
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>
1. Instructions, Procedures and Supplies					
a. Instruction binder	1	1	1	1	1
b. Table of contents	1	1	1	1	1
c. Sanford Marking Pens	2	2	2	2	2
d. Red Marking Pens	2	2	2	2	2
e. Black Marking Pens	2	2	2	2	2
f. Ball Point Pens	2	2	2	2	2
g. San Luis Obispo County Map	1	1	1	1	1
h. Equipment Location Dwgs. (sets) Unit 1	1	1	1	1	1
i. Emergency Environmental Monitoring Field Data Sheet (Form 18-9259)	100	100	100	100	100
j. "Emergency Onsite Radiological Environmental Monitoring Program" EP RB-7	1	1	1	1	1
k. "Emergency Offsite Radiological Environmental Monitoring Program" EP RB-8	1	1	1	1	1
l. "Emergency Equipment, Instruments and Supplies" EP EF-5	1	1	1	1	1
m. Corporation Key (3A90909)	1	1	1	1	1
n. Information Center Key	0	1	0	1	1
o. Pocket Calculator	1	1	1	1	1
p. High Security Pin Tumbler Key (for PIC)	1	1	1	1	1
q. Record of Potassium Iodine Distribution, Form #18-9395	1	1	1	1	1
r. Computation paper (packet)	1	1	1	1	1



## TITLE EMERGENCY EQUIPMENT, INSTRUMENTS &amp; SUPPLIES

TABLE 1 (Continued)  
CONTENTS OF RADIOLOGICAL EMERGENCY KITS

ITEM	QUANTITY				
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>
2. Monitoring Equipment*					
a. Dose Rate Meter (Rad Owl/ RO-2)	0	1	0	0	0
b. Dose Rate Meter (HPI-1010)	1	1	1	1	1
c. Survey Meter (Eber. E-140 or E-140/N)	1	1	1	1	1
d. Standard G-M Probe (Eber. HP-240/HP-270)	1	1	1	1	1
e. Pancake G-M Probe (Eber. HP-210 or HP-260)	1	1	1	1	1
f. Pocket Dosimeters (0-5R)	2	2	2	2	2
g. Pocket Dosimeters (0-200mR)	2	2	2	2	2
h. Dosimeter Charger	1	1	1	1	1
3. Air Sampling Equipment					
a. 12 V Air Sampler and Sample Head (w/o Battery, Radeco H-809C)	1	1	1	0	0
b. 12 V Air Sampler and Sample Head (w/Battery, Radeco H-809B)	0	0	0	1	1
c. 120 V AC Air Sampler and Sample Head (Radeco HD-28B)	0	1	1	0	0
d. Air Sample Particulate Filters (pkg. of 10)	10	10	10	10	10
e. Iodine Filter Cartridges (pkg. of 10) 2 pkg - TEDA, 3 1 pkg - AgZ		3	3	3	3
f. Smear Packets (5 smear/ Packet)	50	50	50	50	50
g. Paper Envelopes for AIR Particulate Samples	25	25	25	25	25

\*Equipment of equivalent function may be substituted.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 14 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 1 (Continued)  
 CONTENTS OF RADIOLOGICAL EMERGENCY KITS

ITEM	QUANTITY				
	1	2	3	4	5
h. Plastic Envelopes for Iodine Cartridges (Ziploc baggies)	30	30	30	30	30
i. Forceps	1	1	1	1	1
j. Compressed Air Cylinder, 1700 psi	2	2	2	2	2
k. Sample Head w/Adapter to fit Air Cylinder	1	1	1	1	1
l. Air Cylinder Regulator	1	1	1	1	1
4. Protective clothing/Decontamination					
a. Protective Clothing Sets (coveralls, hood, booties, rubbers, gloves)	2	2	2	2	2
b. Full Face Mask	2	2	2	2	2
c. Type GMR-S or GMH-I (or equivalent) Ultra Filters for Face Masks	2	2	2	2	2
d. Skin Decontamination Soap (pt. bottle)	1	1	1	1	1
e. Hand Brush	1	1	1	1	1
f. Floor Scrub Brush	0	1	0	1	1
g. Paper Towels (pkg.)	0	1	0	1	1
h. Smear Pads 8"x8" cotton (pkg of 10)	1	3	1	1	1
i. Plastic Bags (38"x 65")	3	3	3	3	3
j. Bucket (10 quart)	0	1	0	1	1
k. Decontamination Agent (gallon bottles)	1	1	1	1	1
5. Signs/Barriers					
a. Radiation Signs (w/3 inserts)	2	4	2	4	4
b. Radiation Barricade Tape (100' rolls)	2	2	2	2	2

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 15 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 1 (Continued)  
CONTENTS OF RADIOLOGICAL EMERGENCY KITS

ITEM	QUANTITY				
	1	2	3	4	5
6. Sampling Equipment					
a. Sample Bottles (1 liter)	2	6	2	4	4
b. Plastic Bags Approx. (18"x24")	15	15	15	15	15
c. Trowel	1	1	1	1	1
7. Miscellaneous Equipment					
a. First Aid Kit (size 10)	1	1	1	1	1
b. Screwdriver	1	1	1	1	1
c. Crescent Wrench (8")	1	1	1	1	1
d. Scissors	1	1	1	1	1
e. Stopwatch	1	1	1	1	1
f. Roll of Dimes	1	1	1	1	1
g. Masking Tape (2" wide rolls)	2	2	2	2	2
h. Flashlights w/Batteries	1	2	1	2	2
i. Extra Batteries	2	4	2	4	4
j. Battery-Powered Lantern w/6 V Battery	1	1	1	1	1
k. Bolt Cutter	0	0	0	1	1
l. "Kwik-kold" Packs	4	4	4	4	4
m. Grass Shears	1	1	1	1	1
n. KI Tablets (bottle)	1	1	1	1	1
o. Gummed Labels (sheet)	5	5	5	5	5

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 16 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 2  
CONTENTS OF EVACUATION KITS

<u>ITEM</u>	<u>QUANTITY PER KIT</u>
1. Eberline E-140/N Survey Meter with HP-240/HP-210 Standard G-M Probe	1
2. Rad Owl Dose Rate Meter	1
3. Self-Reading Dosimeter Pencils, 0-200 mR Range	4
4. Dosimeter Charger w/extra battery	1
5. Barricade Tape, 100-Foot Rolls	2
6. Packages of 2-Inch Filters (10 filters/package)	50
7. Bullhorn w/extra battery	1
8. Plastic Bags (14' X 24")	3
9. Ballpoint Pens	4
10. Flashlight w/two extra batteries	1
11. Pocket Calculator w/extra battery	1
12. Corporation Key (3A90909)	1
13. Information Center Emergency Room Key	1
14. Instruction Binder:	
a. Emergency Procedure G-5, "Evacuation of Nonessential Site Personnel"	1
b. Form 69-9310, "Post-Evacuation Vehicle Monitoring Data"	50
c. Form 69-9311, "Evacuee Monitoring Data"	100
d. Form 69-9369, "Evacuation Kit Inventory Checklist"	5-10
e. Emergency Procedure G-4, "Personnel Accountability and Assembly"	1
15. Information Center Decontamination Shower Key (A53)	1

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 17 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 3  
LOCATIONS OF FIRST AID SUPPLIES

<u>LOCATION</u>	<u>EQUIPMENT</u>
1. Administration Building	First Aid Station
2. Security Building	First Aid Station
3. Training Building	First Aid Station
4. Intake Structure	First Aid Kit, Basket Stretcher
5. Cold Machine Shop	First Aid Kit
6. Access Control (First Aid Room)	First Aid Locker, Stretcher, Gurney, Scoop Stretcher, Backboard, Oxygen, Splints
7. Turbine Building	
104' Elevator Landing	First Aid Station
119' Elevator Landing	First Aid Station
140' Elevator Landing	First Aid Station
8. Control Room	First Aid Kit, Burn Kit
9. Auxiliary Building	
75' Elevator Landing	First Aid Station
100' Elevator Landing	First Aid Station
115' Elevator Landing	First Aid Station
10. Hot Machine Shop	First Aid Station
11. Containment Personnel Hatch	First Aid Kit, Basket Stretcher

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 18 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 4

CONTENTS OF HOSPITAL KITS

Each of two hospital kits shall contain the following minimum items:

<u>ITEMS</u>	<u>QUANTITY</u>
Full face respirators w/Type H or equivalent filters	2 each
Disposable coveralls	4 each
Hood	4 each
Disposable shoe covers	4 pair
Surgical latex gloves	1 box
Rubbers	4 pair
Masking tape, 2" width	2 rolls
Duct tape, 2" width	2 rolls
"Radioactive Material Area" sign	5 each
"Surface Contamination Area" sign	5 each
"High Radiation Area" sign	2 each
"Radiation Area" sign	5 each
Barricade tape, 100 yd. roll	2 each
Ty raps	Minimum 30
"Radioactive Material" labels 4"x6"	10 each
"Radioactive Material" labels 1"x3"	1 roll
E140N/HP-210T	1 each
HP-260	1 each
Spare detector	1 each
1 Allen wrench 1/16"	1 each
1 HPI-1010 or equivalent	1 each
0-200 mR pencil dosimeters	2 each
0-5R pencil dosimeters	2 each
dosimeter charger	1 each
2" smears w/packets (5 smears/packet)	50 each
2" air sample filters w/envelopes	50 each
Plastic envelopes 3"x5"	30 each
Gummed labels	40 each
Plastic bags 38"x65"	6 each
Grease pencil	2 each
Ballpoint/felt tips pens	3 each
Waterproof pen	2 each
Personnel Decon Record Sheet (69-9392)	6 each
Bendix BDx-60 Air Sampler	1 each
38mm air filters/holders for BDx-60	1 box

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 19 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 4 (Cont'd)

CONTENTS OF HOSPITAL KITS (Cont'd)

<u>ITEMS</u>	<u>QUANTITY</u>
Contamination Survey Sheet (69-9315)	6 each
Radiation Survey Sheet (69-9316)	6 each
Forceps	1 each
Smear pads 8" x 8" cotton (pkg of 10)	2 pkg
Medical referral form 62-6015	3 each
Light duty letter	3 each
Plastic bags 18"x24"	12 each

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 20 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 5

PORTABLE COUNT RATE METERS

<u>Instrument (Model No.)</u>	<u>Detector Type</u>	<u>Radiation Measured</u>	<u>Typical Range</u>	<u>Primary Use</u>
Beta-Gamma Survey Meter (E-140), with the following detectors;			0-700, 0-7000 0-70,000 CPM	General contamination surveys
a) Hand probe (HP-260)	GM	Beta, Gamma		
b) Hand probe, end window, (HP-230A)	GM	Beta, Gamma		
c) Hand probe (HP-240)	GM	Beta, Gamma		
d) Shielded hand probe, (HP-210)	GM	Beta, Gamma		
Count rate meter (RM-15) for use with GM probes listed above, and:			0-500, 0-5K, 0-50K, 0-500K GPM	Personnel contamination surveys
a) alpha scintillation probe (AC-3B-7)	ZnS(Ag), 59 cm <sup>2</sup> sensitive area	Alpha		
b) gamma scintillation probe (SPA-3)	NaI(Tl), 2" x 2"	Gamma		
Count rate meter (PRM-6) for use with GM probes listed above AC-3B-7 and SPA-3 probes	See above	See above	0-500, 0-5K, 0-50K, 0-500K CPM	General contamination surveys



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

 NUMBER EP EF-6  
 REVISION 4  
 DATE 10/28/83  
 PAGE 21 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS &amp; SUPPLIES

TABLE 6

PORTABLE DOSE RATE INSTRUMENTS

<u>Instrument (Model No.)</u>	<u>Detector Type</u>	<u>Radiation Measured</u>	<u>Range</u>	<u>Primary Use</u>
Rad Owl (RO-1)	Ion Chamber 1.7 mg/cm <sup>2</sup> beta window, air fill gas	Beta,Gamma	Dose rate: 0-5, 0-50, 0-500 mR/hr 0-5, 0-50 0-500 R/hr Integrate: 0-5, 0-50, 0-500 mR	Beta and Gamma dose rate
Radgun (AGB-10K-SR)	Pressurized argon fill gas ion chamber, 20 mg/cm <sup>2</sup> beta window, (10 atm)	Beta,Gamma	0.01-10 mR/hr 0.01-10 R/hr 10-10,000 R/hr	Gamma dose rate
HPI Multiplying Ion Chamber (1010)	Multiplying ion chamber tissue equivalent walls and fill gas	Gamma Neutron	Dose rate: 0-0.1, 0-1 0-10, 0-100 0-1000 mrad/ hr Integrate: 0-0.01, 0-0.1, 0-1 mrad	Low level gamma dose rate
Portable REM Counter (PNR-4)	BF <sub>3</sub>	Neutron, thermal to 10 MeV	0-5, 0-50, 0-500,0-5000 mrem/hr	Neutron dose rate
Teletector 6112	Twin G-M tubes 30 mg/ cm <sup>2</sup> beta window	Beta,Gamma	0-2 mR/hr, 0-50 mR/hr 0-2 R/hr 0-50 R/hr 0-1000 R/hr	Beta, Gamma dose rate
RO-2	Ion chamber 3.5 mg/cm <sup>2</sup> beta window, air fill gas	Beta,Gamma	Dose rate: 0-5, 0-50, 0-500 mR/hr 0-5 R/hr	Beta, Gamma dose rate

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 22 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 7  
CONTENTS OF POST-ACCIDENT SAMPLE KIT

<u>ITEM</u>	<u>QUANTITY</u>
1. Instruction Binder	
a. Sanford Marking Pens	2
b. Red Marking Pens	2
c. Black Marking Pens	2
d. Ball Point Pens	2
e. EP EF-5 "Emergency Equipment, Instruments and Supplies"	1
f. CAP G-1 Access to IPLSS Area, Post Accident Sample Preparation, Handling, and Analysis	1
g. CAP G-2 Interim Post LOCA Sampling System	1
h. Emergency Phone Directory	1
i. Adhesive Backed Sample Labels	20
2. Monitoring Equipment	
a. Teletector (Eberline 6112)	1
b. Pocket Dosimeters (0-5R)	2
c. Pocket Dosimeters (0-200mR)	2
d. Dosimeter Charger	1
e. Finger Rings	12
f. Dose Rate Meter (HPI-1010 or RO-2)	1
g. Survey Meter (Eber. E-140/N)	1
h. Pancake G-M Probe (Eber. HP-210 or HP-260)	1
i. Bendix BDX-60 air sampler	1
3. Air Sampling Equipment	
a. Tongs	1
b. Forceps	1
c. Silver Zeolite (AqZ) Cartridges	12
d. 5 cc Shielded Syringes	5
e. Glass vials (14 cc) w/rubber stoppers	12
f. Air Sample filter/cartridge holder assembly	2

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 23 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 7 (Continued)  
CONTENTS OF POST-ACCIDENT SAMPLE KIT

<u>ITEM</u>	<u>QUANTITY</u>
3. Air Sampling Equipment (Continued)	
g. Surgical Tubing (1/4")	5'
h. Duct tape	3
i. Air Sample Particulate Filters (pkg of 10)	3
j. Compressed Air Cylinders	2
k. Air Cylinder Regulator	1
l. Plastic Bags (15" x 30")	20
m. B-D Hypodermic needles (LUER-LOK pkg of 12)	4
n. "Radioactive Material" Labels	1 roll
o. Liquid Sample Vessel adapter tubing (Plastic tubing w/male adapters)	2
p. 38mm Air Filters for Bendix BDx-60 air sampler	1 box
4. Miscellaneous Equipment	
a. Protective Clothing Sets (coveralls, hood, booties, shoe covers, gloves)	2
b. Stopwatch	1
c. Calculator	1
d. Crescent Wrench (8")	1
e. Screwdriver	1
f. Allen wrench (3/32")	1
g. Masking tape (2" wide rolls)	1
h. Flashlight w/batteries	1
i. Extra Batteries	2
j. Allen wrench (5/64")	1
k. Key to East gates outside elevation 115'	1

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
 REVISION 4  
 DATE 10/28/83  
 PAGE 24 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 8  
 DIABLO CANYON POWER PLANT  
 PLANT VEHICLE LIST

Primary position holders of certain emergency response positions are provided with VHF radio-equipped company vehicles. Because these persons are essentially on-call at all times, use of these vehicles is warranted in off hours to ensure rapid communication and response. These personnel are identified in EP G-2, "Establishment of the On-Site Emergency Organization."

<u>MV #</u>	<u>CLASS</u>	<u>DESCRIPTION</u>	<u>MAKE</u>	<u>LICENSE</u>	<u>ASSIGNED TO</u>
8-6145	P-1	Sedan	84 FORD	1HQN330	Plant Manager
8-0402	P-1	Sedan	83 FORD	1FTZ284	Department Head
8-0394	P-1	Sedan	83 FORD	1FTZ282	Department Head
8-0388	P-1	Sedan	83 FORD	1FTY538	Department Head
8-0408	P-1	Sedan	83 FORD	1FTZ285	Department Head
8-0401	P-1	Sedan	83 FORD	1FTZ283	Department Head
8-0389	P-1	Sedan	83 FORD	1FTY983	Department Head
8-7820	P-1	Sedan	84 FORD	1HQN227	Office Supervisor
8-7821	P-1	Sedan	84 FORD	1HQN226	Office Supervisor
8-6470	P-1	Sedan	78 PLYMOUTH	238 UKX	Office Supervisor
8-5014	P-1	Stationwagon	78 PLYMOUTH	745 UUA	Office Supervisor
8-A570	C-2	Van	79 DODGE	137 XLR	Office Supervisor
8-9064	P-1	Sedan	79 PLYMOUTH	292 WEJ	Security Supervisor
8-A713	C-4	Pickup	78 DODGE	1M85862	Security
8-6258		Bronco	84 FORD		Security

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 26 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 8.a  
Emergency Organization Radio Pagers

<u>Emergency Position</u>	<u>Pager Encode Number</u>	<u>Group Page Encode Number</u>
Site Emergency Coordinator		
Emergency Operations Coordinator (Plant Superintendent)		
Emergency Evaluation & Recovery Coord. (Asst. Plt. Mgr./Tech. Svcs.)		
Emergency Radiological Advisor		
Emergency Liaison Coordinator		
Advisor to the County Emergency Organization (Asst. Plt. Mgr./Support Svcs.)		
Emergency Maintenance Coordinator		
Site Chemistry & Radiation Protection Coordinator		
Emergency Liaison Assistant #1		
Emergency Liaison Assistant #2		
Data Processor No. 1		
Data Processor No. 2		
Instrument Maintenance Coordinator		
Electrical Maintenance Coordinator		
Mechanical Maintenance Coordinator		
Fire Marshal		
EARS Operator - TSC		
Mobile Environmental Monitoring Lab Operator		
Interim Public Information Recovery Manager		
Sue Brown Missie Hobson		

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 25 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 8  
DIABLO CANYON POWER PLANT  
PLANT VEHICLE LIST (Continued)

<u>MV #</u>	<u>CLASS</u>	<u>DESCRIPTION</u>	<u>MAKE</u>	<u>LICENSE</u>	<u>ASSIGNED TO</u>
8-2480		Pickup	82 FORD	ZC85704	Security
8-7826		Pickup	84 FORD	2G74627	Mechanical Maintenance
8-A229	C-2	Pickup	78 FORD	1K74799	Mechanical Maintenance
8-0003	C-2	Pickup	73 DODGE	1T39700	Mechanical Maintenance
8-2903	C-2	Boom Truck	72 FORD	69676L	Mechanical Maintenance
8-7331	C-2	Pickup	FORD	1G49905	Mechanical Maintenance
8-A258	C-4	Pickup	79 CHEVROLET	1N20205	Operations
8-3800		Pickup	81 FORD	1Y53259	Operations
8-0435		Pickup	80 CHEVROLET	1V61228	Chem & Rad
8-3597		Pickup	80 CHEVROLET	1S80741	Chem & Rad
8-3882		Pickup	79 CHEVROLET	1P70245	Chem & Rad (on loan to Security)

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 27 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9  
EWS SIREN LOCATIONS

<u>SIREN NO.</u>	<u>LOCATION</u>
1	North Morro Bay - near the intersection of Sequoia and Alder.
1A	Near intersection of So. Ocean and Chaney Ave. off Highway 1.
1B	Near the Cayucos Cemetary on Highway 1.
1C	Cayucos near the intersection of 4th & Park
2	On PG&E property at the Morro Bay Power Plant, Near Highway 1
2A	On PG&E property at the Morro Bay Power Plant, Near the Embarcadero
3	In Morro Bay, on Morro Avenue north of Olive.
3A	In Morro Bay, near the intersection of Ridgeway street and Fairview Avenue.
6	In Baywood Park near the intersection of Santa Ysabel and 2nd St.
6A	In Baywood Park near the intersection of El Morro Avenue and 8th Street.
7	In Los Osos on Pecho Valley Road several blocks west of Pine Avenue.
8A	Montana de Oro Park near the Ranger Station.
8B	Montana de Oro Park near the Ranger's residence.
8C	On the Field's property south of the gate.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 28 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9 (Continued)  
SIREN NO.

LOCATION

8D	On the Field's property near the Field's residence.
9	Near Highway 1 on PG&E's Baywood substation yard.
10	Near Highway 1 west of San Luisito Creek Road.
12	On Highway 1 just north of Cuesta College.
13	On Highway 1 northwest of animal shelter.
14	On Highway 1 about 1/2 mile west of the California Division of Forestry.
15	In San Luis Obispo across the street from City Fire Station on No. Chorro Street.
15A	On Foothill Blvd. just outside San Luis Obispo, 3/10/mi southwest of Rosita St.
16	In San Luis Obispo near Grand Avenue and Slack Street.
17	In San Luis Obispo parking lot next to the fire station on Garden Street.
18	In San Luis Obispo on Augusta St. near Sinsheimer School.
19A	On Clark Valley Rd. off Los Osos Valley Rd. near PG&E 500kV right-of-way.
19C	Los Osos - near the end of Valley View Place.
19D	In Los Osos - on Nipomo Avenue East of South Bay Boulevard between Willow Dr and Andre Ave.
19E	In Los Osos near the fire station on Calle Cardonay.



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 29 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9 (Continued)  
SIREN NO.

LOCATION

20	On Los Osos Valley Road near the 500 kV right of way west of Turri Road.
21	On Los Osos Valley Road east of Turri Road.
22	On Los Osos Valley Road about 2 miles west of Foothill Blvd.
23	Near the intersection of O'Connor Way and Foothill Blvd.
23A	On O'Connor Way about 2 miles west of Foothill Blvd.
24	On Perfumo Canyon Road about 2 miles from Los Osos Valley Rd.
24A	At end of private dirt road about 2000' south from point that Perfumo Canyon Rd pavement ends.
24B	Near the end of Sycamore Canyon Road off Clark Valley Rd.
25	At the top of Perfumo Canyon Road.
25A	On Andres property along Coon Creek Road about 1-3/4 miles west of upper end of See Canyon Road.
26	Near intersection of See Canyon Road and Davis Canyon Road about 3.6 miles off of San Luis Bay Drive.
26A	On See Canyon Rd about 4.6 miles off of San Luis Bay Drive.
27	On See Canyon Rd about 1.2 miles off of San Luis Bay Drive.
27A	On See Canyon Road about 2.4 miles off of San Luis Bay Drive.
27B	On See Canyon Road about 3 miles off of San Luis Bay Drive.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 30 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9 (Continued)

SIREN NO.

LOCATION

27C	On Davis Canyon Rd about 1/2 mile off of See Canyon Road.
B27D	On Davis Canyon Rd about 1.6 miles off of See Canyon Road.
27E	On Davis Canyon Rd about 1 mile off of See Canyon Road.
29	On Los Osos Valley Road about 2000' south of Madonna Road by Pacific Beach Continuation School
29A	Off Los Osos Valley Road in Laguna Lake area by Descanso Drive.
29B	On Calle Joaquin next to Madonna shopping center parking lot in San Luis Obispo.
30	In San Luis Obispo on Prado Road.
31	In PG&E's Service Center yard on So. Higuera.
31A	On Jespersion Road, south of Buckley Road.
31B	On Highway 101 Frontage Road 1 mile south of Higuera off ramp.
31C	On Highway 101 Frontage Road, just off Higuera off-ramp, about 2000' north of 500kV right of way.
31D	Near end of private dirt road west of Higuera off-ramp.
31E	Near 12kV line off Castro Canyon Road 1/2 mile off Highway 101 Frontage Road.
32	On Squire Canyon Road east of Highway 101 near intersection of San Luis Bay Drive and Monte Rd.
33	Across street from Bellview - Santa Fe Elementary School on See Canyon Road off San Luis Bay Drive.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 31 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9 (Continued)  
SIREN NO.

LOCATION

34	In Avila Beach near DCPD security gate.
34A	Light house local coverage.
B34B	4 miles off See Canyon Road near 500kv right of way, by John Knemeyer's house.
35	In downtown Avila Beach near San Antonio Street.
36	Off Highway 101 Frontage Road near intersection of Shell Beach Road and Landing Road.
36A	Off Highway 101 Frontage Road near intersection of Ontario Road and Avila Road.
37A	At Shell Beach fire station.
38	On Mattie Road near McClintock's restaurant.
38A	On Shell Beach Road near Price St. intersection.
39	In San Luis Obispo on Santa Fe Road south of Tank Farm Road.
40	On private property south of San Luis Airport.
41	On Biddle Ranch Rd just east of Edna Road.
42	On Price Canyon Road on Grace Oil property.
43	On Price Canyon Road about 1 mile north of Pismo Beach.
44	In Pismo Beach on a watertank in subdivision above Pismo Beach.
45	In Pismo Beach on Bello Road near Veteran's Hall.
46	On Highway 1 in So. Pismo Beach 1/2 mile north of Grand Ave.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 32 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 9 (Continued)  
SIREN NO.

LOCATION

47	In Grover City - 4th and Manhattan.
48	In Oceano on Railroad Avenue.
49	In Grover City at Water Tower on Hillcrest Dr.
49B	On Oak Park Blvd. in Arroyo Grande .3 miles from Noyes Rd.
49C	In Arroyo Grande near intersection of Oak Park Blvd. and Vista Del Robles.
50	Near Oceano on The Pike between LaVista and So. Elm.
51	In Arroyo Grande near new fire station.
51A	At PGandE Oceano substation on Valley Road south of Arroyo Grande.
52	In Arroyo Grande Road on Huasna Rd east of Stagecoach Rd.
52A	On Printz Road north of Arroyo Grande.
52B	On Noyes Road north of Printz Road.
53	On Valley Road (Highway 1) about 7000 ft. south of 51A and just north of Halcyon Rd.
56	Near intersection of El Campo & Clarkway.
57	On Valley Road (Highway 1) about 7000 ft. South of 53 and 1 mile south of Halcyon Rd.
58	At end of Stanton Road South of Los Berros Road.
59	On Los Berros Rd between Stanton and Pomeroy.
60	On Pomeroy Road 1 mile south of Los Berros Rd. near Camino-Perrillo.
61	On Willow Road at Black Lake County Club.

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 33 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 10

CONTROL ROOM EMERGENCY PLAN EQUIPMENT

<u>ITEM</u>	<u>SURVEILLANCE TYPE/FREQUENCY</u>
a. Emergency Assessment and Response System	See GOAP W-302
1) 9845C Computer	
b. Manual Dose Projection Equipment	Inventory by Emergency Planning/Quarterly (Use form 69-10766)
1) Base Map	
2) Seven Overlays	
c. Closed Circuit TV Cameras	Refer to the Technical Support Center
d. Communications	See STP I-29
1) Radio	
2) Telephone	
3) Emergency Signal	
e. Radiological Display	See STP I-44
f. Radiation Monitoring Display	See STP I-18
g. Portable Video Camera	Inventory by Emergency Planning/Quarterly (Use Form 69-10766)

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 34 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 11

TECHNICAL SUPPORT CENTER EMERGENCY PLAN EQUIPMENT

<u>ITEM</u>	<u>SURVEILLANCE TYPE/FREQUENCY</u>
a. Nuclear Data Communications System	None-used normally
b. Control Room Closed Circuit TV Monitors	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
c. Communications	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
1) Radio	
2) Telephone	
d. Emergency Assessment and Response System	See GOAP W-302
e. Manual Dose Projection Equipment	Inventory/Quarterly <sup>2</sup>
1) Dose Map	
2) Seven Overlays	
f. Computerized Records Management System	Inventory Equipment by Emergency Planning/Quarterly <sup>2</sup>
g. Documents	Normal Document Control Practices, Inventory by Emergency Planning/Quarterly <sup>2</sup>
1) Plant Manuals	
Volume 2 - Operating Procedures	
Volume 3 - Emergency Procedure	
Volume 4 - Licenses & Permits	
Volume 7 - Radiation Control Standards & Procedures	
Volume 9 - Temporary Procedures (Curves & Misc Data)	
Volume 11- Emergency Plans	

<sup>1</sup> Use Form 69-10767  
<sup>2</sup> Use Form 69-10768

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 35 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TECHNICAL SUPPORT CENTER EMERGENCY PLAN EQUIPMENT (cont.)

<u>ITEM TYPE/FREQUENCY</u>	<u>SURVEILLANCE TYPE/FREQUENCY</u>
2) Piping Schematics	
3) Instrument Schematics	
4) Electrical Diagrams, Logic Diagrams and Electrical Arrangements	
5) Operating Valve Diagrams	
6) Drawing 102037 - Instrument Locations	
7) Drawing 102038 - Instrument Reference	
8) Complete Set of Drawings	
9) Complete Set of Documents	
10) Cypher Pad Code for San Luis Obispo Service Center Garage	
11) Corporate Emergency Response Plan	
12) Nuclear Emergency Response Communications Directory	

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 36 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 12

OPERATIONAL AND OPERATIONS SUPPORT CENTER EMERGENCY PLAN EQUIPMENT

<u>ITEM</u>	<u>SURVEILLANCE TYPE/FREQUENCY</u>
Operational Support Center (Security Building)	
a. Kits for Emergency Use	
1) Emergency Kits (2)	Refer to Section 1
2) Evacuation Kits (2)	Refer to Section 2
3) Hospital Kits (2)	Refer to Section 4
b. Communications	
1) Radio	Refer to Security Procedures
2) Telephone	
A) Direct line to TSC/CR	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
B) Rolm phone	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
c. Emergency Desk	
1) Emergency Communications Directory	
2) Workbook	
Operations Support Center (Access Control/Cold Machine Shop)	
a. Communications	
1) Telephone	
A) Direct line to TSC/CR	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
B) Rolm phone	Operability Check by Emergency Planning/Quarterly <sup>1</sup>

<sup>1</sup> Use Form 69-10769



DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/26/83  
PAGE 37 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

TABLE 13

EMERGENCY OPERATIONS FACILITY EMERGENCY PLAN EQUIPMENT

<u>ITEM</u>	<u>SURVEILLANCE TYPE/FREQUENCY</u>
a. Emergency Assessment and Response System (EARS)	See GOAP W-302
1) 9845T Computer	
2) Chromatics Colorgraphics Display	
b. Manual Dose Projection Equipment	Inventory by Emergency Planning/Quarterly <sup>2</sup>
1) Base Map	
2) Seven Overlays	
c. Communications	Operability Check by Emergency Planning/Quarterly <sup>1</sup>
1) Radio	
2) Telephone	
d. Consumables	
1) Emergency Forms	Inventory by Emergency Planning/Quarterly <sup>3</sup>
2) Office Supplies	Check by Emergency Planning/Quarterly <sup>1</sup>

<sup>1</sup> Use Form 69-10770

<sup>2</sup> Use Form 69-10771

<sup>3</sup> Use Form 69-10582

DIABLO CANYON POWER PLANT UNIT NO(S) 1 AND 2

NUMBER EP EF-5  
REVISION 4  
DATE 10/28/83  
PAGE 38 OF 38

TITLE EMERGENCY EQUIPMENT, INSTRUMENTS & SUPPLIES

EMERGENCY OPERATIONS FACILITY EMERGENCY PLAN EQUIPMENT (cont.)

ITEM SURVEILLANCE TYPE/FREQUENCY

e. Documents

- 1) Plant Manuals Normal Document Control  
Practice, Inventory by  
Emergency<sup>2</sup> Planning/  
Quarterly
  - Volume 2 - Operating Procedures
  - Volume 3 - Emergency Procedures  
(3 copies)
  - Volume 4 - Licenses & Permits
  - Volume 7 - Radiation Control Standards  
and Procedures
  - Volume 9 - Temporary Procedure  
(Curves & Misc Data)
  - Volume 11 - Emergency Plans (3 copies)
- 2) Piping Schematics
- 3) Instrument Schematics
- 4) Electrical Drawings
- 5) Operating Valve Identification Diagrams
- 6) Drawing 102037 - Instrument Locations
- 7) Drawing 102038 - Instrument Reference
- 8) Corporate Emergency Response Plan
- 9) Nuclear Emergency Response Communications Directory
- 10) Cypher Pad Code for San Luis Obispo Service Center Garage

---

<sup>1</sup> Use Form 69-10770


<sup>2</sup> Use Form 69-10771

<sup>3</sup> Use Form 69-10582

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY FACILITY PHONE NUMBERS

1. EMERGENCY OPERATIONS FACILITY:  
Radiological Emergency Recovery Manager  
  
Radiological Monitoring Director  
  
UDAC
  
2. TECHNICAL SUPPORT CENTER  
Emergency Radiological Advisor
  
3. DOPP SECURITY  
Security Shift Supervisor  
  
Central Alarm System  
Secondary Alarm System



NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_  
 QUARTER \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX A

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
1. Sampling Equipment				
a. Trowel	<u>1</u>	_____	_____	_____
2. Air Sampling Equipment				
a. 12V Air Sampler + Sample Head (w/Battery, Radeco H-809B)	<u>*</u>	_____	_____	_____
b. 12V Air Sampler + Sample Head (w/o Battery, Radeco H-809C)	<u>*</u>	_____	_____	_____
c. 120V Air Sampler + Sample Head (Radeco HD-288)	<u>*</u>	_____	_____	_____
d. Air Cylinder Regulator	<u>1</u>	_____	_____	_____
e. Compressed Air Cylinders (at 1700 psi)	<u>2</u>	_____	_____	_____
f. Sample Head w/Adapter to fit Air Cylinder	<u>1</u>	_____	_____	_____
g. Air Sample Particulate Filters (pkg of 10)	<u>10</u>	_____	_____	_____

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_  
 QUARTER \* \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX A

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
h. Paper Envelopes for Particulate Samples (Air Sample)	25	_____	_____	_____
i. Smear Packets (5 smear/pkt)	50	_____	_____	_____
j. Plastic Envelopes for Iodine Cartridges (Ziploc Baggies)	30	_____	_____	_____
k. Forceps	1	_____	_____	_____
3. Protective Clothing/Decontamination				
a. Radiacwash Decontamination Agent (1 Gal. or Equiv.)	1	_____	_____	_____
b. Skin Decontamination Soap (1 pt. or Equiv.)	1	_____	_____	_____
c. Hand Brush	1	_____	_____	_____
d. Floor Scrub Brush	*	_____	_____	_____
e. Bucket (10 qt)	*	_____	_____	_____

\*Check with appropriate inventory list located in information binder for kit requirements.

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_

QUARTER \* \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX A

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
4. Monitoring Equipment				
a. Pocket dosimeter (0-5R)	<u>2</u>	<u>      </u>	<u>      </u>	<u>      </u>
b. Pocket dosimeter (0-200MR)	<u>2</u>	<u>      </u>	<u>      </u>	<u>      </u>
5. Miscellaneous				
a. Gummed Labels (sheet)	<u>5</u>	<u>      </u>	<u>      </u>	<u>      </u>
b. Flashlight w/batteries	<u>*</u>	<u>      </u>	<u>      </u>	<u>      </u>
c. Extra Batteries	<u>*</u>	<u>      </u>	<u>      </u>	<u>      </u>
d. Roll of Dimes	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
e. Stopwatch *	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
f. Scissors	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
g. Crescent Wrench (8")	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
h. Screwdriver	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
i. Grass Shear	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
j. KI Tablets (bottle)	<u>1</u>	<u>      </u>	<u>      </u>	<u>      </u>
k. Bolt Cutter	<u>*</u>	<u>      </u>	<u>      </u>	<u>      </u>

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_  
 QUARTER \* \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_  
 BOX B \_\_\_\_\_ QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
1. Instructions, Procedures, and Supplies				
a. Instruction Binder	<u>1</u>	_____	_____	_____
b. Tables of Contents	<u>1</u>	_____	_____	_____
c. Sanford Marking Pens	<u>2</u>	_____	_____	_____ 1
d. Red Marking Pens	<u>2</u>	_____	_____	_____
e. Black Marking Pens	<u>2</u>	_____	_____	_____
f. Ball Point Pens	<u>2</u>	_____	_____	_____
g. SLO County Map	<u>1</u>	_____	_____	_____
h. Equipment Location Drawings (Set) Unit 1	<u>1</u>	_____	_____	_____
i. Corporation Key (3A 90909)	<u>1</u>	_____	_____	_____
j. Information Center Key	<u>*</u>	_____	_____	_____
k. "Emergency Onsite Environment Montr. Prog.", RB-7	<u>1</u>	_____	_____	_____
l. "Emergency Offsite Environment Montr. Prog.", RB-8	<u>1</u>	_____	_____	_____
m. "Emergency Equip., Instr., and Supplies", EF-5	<u>1</u>	_____	_____	_____
n. Record of Potassium Iodide Distribution, Form #18-9395	<u>1</u>	_____	_____	_____

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_

QUARTER \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX B

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
o. Emergency Environmental Monitoring Field Data Sheet (Form 18-9259)	100	_____	_____	_____
p. Computation Paper (Packet)	1	_____	_____	_____
q. Calculator S/N _____	1	_____	_____	_____
r. High Security Pin Tumbler Key (for PIC)	1	_____	_____	_____
2. Air Sampling Equipment				
a. Iodine Filter Cartridges 3 pkgs of 10 filters each:				
1 pkg-AgZ	1	_____	_____	_____
2 pkg-TEDA	2	_____	_____	_____
3. Sampling Equipment				
a. Plastic Bags Approx. (18" x 24")	15	_____	_____	_____
b. Sample bottles (1 liter)	*	_____	_____	_____



NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_  
 QUARTER \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX B

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
4. Protective Clothing/Decontamination				
a. Protective Clothing Sets (Coveralls, hood, booties, rubbers, gloves)	<u>2</u>	_____	_____	_____
b. Full Face Mask	<u>2</u>	_____	_____	_____
c. Type GMR-S Filters or GMH-1 (or equiv.) for Face Masks	<u>2</u>	_____	_____	_____
d. Smear Pads 8" x 8" cotton (Pkg of 10)	<u>*</u>	_____	_____	_____
e. Paper Towels (pkg)	<u>*</u>	_____	_____	_____
f. Plastic Bags (38" x 65")	<u>3</u>	_____	_____	_____

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2EMERGENCY KIT INVENTORY CHECK LISTKIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_  
QUARTER \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX B

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
5. Miscellaneous Equipment				
a. First Aid Kit (Size 10)	<u>1</u>	<u>        </u>	<u>        </u>	<u>        </u>
b. Masking Tape (2" wide rolls)	<u>2</u>	<u>        </u>	<u>        </u>	<u>        </u>
c. Battery Powered Lantern (w/6V Battery)	<u>1</u>	<u>        </u>	<u>        </u>	<u>        </u>
d. "Kwik-kold" Packs	<u>4</u>	<u>        </u>	<u>        </u>	<u>        </u>
6. Signs + Barriers				
a. Radiation Signs (w/3 inserts)	<u>*</u>	<u>        </u>	<u>        </u>	<u>        </u>
b. Radiation Barricade Tape (100' Rolls)	<u>2</u>	<u>        </u>	<u>        </u>	<u>        </u>

\*Check with appropriate inventory list located in information binder for kit requirements.

NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EMERGENCY KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ KIT LOCATION \_\_\_\_\_

QUARTER • \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

BOX C

QUANTITY

	<u>REQUIRED</u>	<u>PRESENT</u>	<u>DEFECTIVE OR MISSING</u>	<u>REPLACED</u>
1. Monitoring Equipment				
a. Dose Rate Meter Rad Ow1/RO-2 (or equiv.)	*	_____	_____	_____
b. Dose Rate Meter HPI-1010 (or equiv.)	*	_____	_____	_____
c. Survey Meter (Eber. E-140 or E-140/N)	1	_____	_____	_____
d. Standard G-M Probe (Eber. HP-240/HP-270 or equiv.)	1	_____	_____	_____
e. Pancake G-M Probe (Eber. HP-210 or HP-260)	1	_____	_____	_____
f. Dosimeter Charger	1	_____	_____	_____

\*Check with appropriate inventory list located in information binder for kit requirements.

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EVACUATION KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED DEFECTIVE OR		REPLACED
		OK	MISSING	
1. Binder Contents				
a. Emergency Procedures G-4, G-5	1 each	[ ]	[ ]	[ ]
b. Form 69-9310	50	[ ]	[ ]	[ ]
c. Form 69-9311	100	[ ]	[ ]	[ ]
d. Form 69-9369	5-10	[ ]	[ ]	[ ]
2. Ballpoint Pens	4	[ ]	[ ]	[ ]
3. Calculator (I.D. No. _____)	1	[ ]	[ ]	[ ]
Battery	1			[ ]
4. Flashlight	1	[ ]	[ ]	[ ]
Batteries	2			[ ]
5. Plastic Bags (14" x 24")	3	[ ]	[ ]	[ ]
6. Bullhorn (I.D. No. _____)	1			[ ]
Batteries	1	[ ]	[ ]	[ ]
7. Packages of 2" Filters (10 filters per package)	50	[ ]	[ ]	[ ]
8. Barricade tape, 100 ft. rolls	2	[ ]	[ ]	[ ]
9. Dosimeter chgr. (I.D. No. _____)	1	[ ]	[ ]	[ ]
Battery				[ ]
10. Dosimeter pencils, 0-200 mR	4	[ ]	[ ]	[ ]

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

EVACUATION KIT INVENTORY CHECK LIST

ITEM	QUANTITY	CHECKED		REPLACED
		OK	DEFECTIVE OR MISSING	
11. Rad Owl (Replacement Inst. No. _____)	1	[ ]	[ ]	[ ]
12. Eberline E-140 Survey Meter or E140N (Replacement Inst. No. _____)	1	[ ]	[ ]	[ ]
13. HP-240 GM Probe or HP-210 (I.D. No. _____)	1	[ ]	[ ]	[ ]
14. Corporation Key (3A90909)	1	[ ]	[ ]	[ ]
15. Information Center Emergency Room Key	1	[ ]	[ ]	[ ]

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

HOSPITAL KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED DEFECTIVE OR		REPLACED
		OK	MISSING	
1. Full Face Respirator w/Type H or equivalent filters	2	[ ]	[ ]	[ ]
2. Disposable Coveralls	4	[ ]	[ ]	[ ]
3. Hood	4	[ ]	[ ]	[ ]
4. Disposable Shoe Covers (pr.)	4	[ ]	[ ]	[ ]
5. Surgical Latex Gloves (box)	1	[ ]	[ ]	[ ]
6. Rubbers (pr.)	4	[ ]	[ ]	[ ]
7. Masking Tape, 2" width (roll)	2	[ ]	[ ]	[ ]
8. Duct Tape, 2" width (roll)	2	[ ]	[ ]	[ ]
9. "Radioactive Material Area" sign	5	[ ]	[ ]	[ ]
10. "Surface Contamination Area" sign	5	[ ]	[ ]	[ ]
11. "High Radiation Area" sign	2	[ ]	[ ]	[ ]
12. "Radiation Area" sign	5	[ ]	[ ]	[ ]
13. Barricade tape, 100 yd. roll	2	[ ]	[ ]	[ ]
14. Ty-wraps	30	[ ]	[ ]	[ ]
15. "Radioactive Material" labels, 4"x6"	10	[ ]	[ ]	[ ]
16. "Radioactive Material" labels, 1"x3" (roll)	1	[ ]	[ ]	[ ]
17. E-140/N w/HP-210T	1	[ ]	[ ]	[ ]
18. HP-260	1	[ ]	[ ]	[ ]

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2HOSPITAL KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED		REPLACED
		OK	DEFECTIVE OR MISSING	
19. Spare Detector	1	[ ]	[ ]	[ ]
20. Allen Wrench, 1/16"	1	[ ]	[ ]	[ ]
21. HPI-1010 or equivalent	1	[ ]	[ ]	[ ]
22. 0-200 mR Pencil Dosimeters	2	[ ]	[ ]	[ ]
23. 0-5R Pencil Dosimeters	2	[ ]	[ ]	[ ]
24. Dosimeter Charger w/Battery	1	[ ]	[ ]	[ ]
25. 2" Smears w/packet (5 smears/packet)	50	[ ]	[ ]	[ ]
26. 2" Air Sample Filter w/envelopes	50	[ ]	[ ]	[ ]
27. 38mm Air Filter for Bendix BDX-60 (box)	1	[ ]	[ ]	[ ]
28. Plastic Envelopes, 3" x 5"	30	[ ]	[ ]	[ ]
29. Gummed Labels	40	[ ]	[ ]	[ ]
30. Plastic Bags, 38" x 65"	6	[ ]	[ ]	[ ]
31. Grease Pencil	2	[ ]	[ ]	[ ]
32. Ballpoint/Felt Tip Pens	3	[ ]	[ ]	[ ]
33. Waterproof Pen	2	[ ]	[ ]	[ ]
34. Personnel Decon. Records (69-9392)	6	[ ]	[ ]	[ ]
35. Contamination Survey Sheet (69-9315)	6	[ ]	[ ]	[ ]
36. Radiation Survey Sheet (69-9316)	6	[ ]	[ ]	[ ]

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

HOSPITAL KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED DEFECTIVE OR		REPLACED
		OK	MISSING	
37. Forceps	1	[ ]	[ ]	[ ]
38. Smear Pads 8" x 8" cotton (Pkg. of 10)	2	[ ]	[ ]	[ ]
39. Medical Referral Form (69-6015)	3	[ ]	[ ]	[ ]
40. Light Duty Letter	3	[ ]	[ ]	[ ]
41. Plastic Bag, 18" x 24"	12	[ ]	[ ]	[ ]
42. BDX-60 Air Sampler	1	[ ]	[ ]	[ ]

REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_



DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

## POST-LOCA SAMPLING KIT INVENTORY CHECK LIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED DEFECTIVE OR		REPLACED
		OK	MISSING	
INSTRUCTION BINDER				
Sanford Marking Pens	2	[ ]	[ ]	[ ]
Red Marking Pens	2	[ ]	[ ]	[ ]
Black Marking Pens	2	[ ]	[ ]	[ ]
Ballpoint Pens	2	[ ]	[ ]	[ ]
EP-EF-5 "Emergency Equipment, Instruments, Supplies"	1	[ ]	[ ]	[ ]
CAP-G-1 "Access to IPLSS Area, Post Accident Sample Preparations, Handling and Analysis"	1	[ ]	[ ]	[ ]
CAP-G-2 "Interim POST LOCA Sampling System"	1	[ ]	[ ]	[ ]
Emergency Phone Directory	1	[ ]	[ ]	[ ]
Adhesive Backed Sample Labels	20	[ ]	[ ]	[ ]
MONITORING EQUIPMENT				
Teletector (Eberline 6112)	1	[ ]	[ ]	[ ]
Pocket Dosimeters (0-5R)	2	[ ]	[ ]	[ ]
Pocket Dosimeters (0-200mR)	2	[ ]	[ ]	[ ]
Dosimeter Charger	1	[ ]	[ ]	[ ]
Finger Rings	12	[ ]	[ ]	[ ]
Dose Rate Meter (HPI-1010 or RO-2)	1	[ ]	[ ]	[ ]
Survey Meter (Eberline E-140/N)	1	[ ]	[ ]	[ ]
Pancake G-M Probe (Eberline HP-210 or HP-260)	1	[ ]	[ ]	[ ]
Bendix BDX-60 Air Sampler	1	[ ]	[ ]	[ ]
AIR SAMPLING EQUIPMENT				
Tongs	1	[ ]	[ ]	[ ]
Forceps	1	[ ]	[ ]	[ ]
Silver Zeolite (AgZ) Cartridges	12	[ ]	[ ]	[ ]
5cc Shielded Syringes	5	[ ]	[ ]	[ ]

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

POST-LOCA SAMPLING KIT INVENTORY CHECKLIST

KIT NO. \_\_\_\_\_ DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

ITEM	QUANTITY	CHECKED DEFECTIVE OR		REPLACED
		OK	MISSING	
Glass vials (14cc) w/rubber stoppers	12	[ ]	[ ]	[ ]
Air Sample Filter Cartridge Assembly	2	[ ]	[ ]	[ ]
Surgical Tubing (1/4")	5ft	[ ]	[ ]	[ ]
Duct tape	3	[ ]	[ ]	[ ]
Air Sample Particulate Filters (Pkg of 10)	3	[ ]	[ ]	[ ]
Compressed Air Cylinders	2	[ ]	[ ]	[ ]
Air Cylinder Regulator	1	[ ]	[ ]	[ ]
Plastic Bags (15" x 30")	20	[ ]	[ ]	[ ]
B-D Hypodermic Needles (LUER-LOK pkg of 12)	4	[ ]	[ ]	[ ]
"Radioactive Material" labels	1roll	[ ]	[ ]	[ ]
Liquid Sample Vessel Adapter Tubing (plastic tubing w/male adapters)	2	[ ]	[ ]	[ ]
38mm Air Filters for Bendix BDX-60 air sampler	1box	[ ]	[ ]	[ ]
MISCELLANEOUS EQUIPMENT				
Protective clothing sets (coveralls, hood, booties, shoe covers, gloves)	2	[ ]	[ ]	[ ]
Stopwatch	1	[ ]	[ ]	[ ]
Calculator	1	[ ]	[ ]	[ ]
Crescent Wrench (8")	1	[ ]	[ ]	[ ]
Screwdriver	1	[ ]	[ ]	[ ]
Allen Wrench (3/32")	1	[ ]	[ ]	[ ]
Masking Tape (2" wide rolls)	1	[ ]	[ ]	[ ]
Flashlight w/batteries	1	[ ]	[ ]	[ ]
Extra batteries	2	[ ]	[ ]	[ ]
Allen Wrench (5/64")	1	[ ]	[ ]	[ ]
Key to East Gates Outside Elevation 115'	1	[ ]	[ ]	[ ]

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT

EMERGENCY PLAN PHONE NUMBER VERIFICATION CHECKLIST

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

PROCEDURE NO.	PAGE NO.	AGENCY	COMMENTS (Note How Checked)
EP OP-6	p. 8	TSC Operator, dedicated shutdown panel, 480V vital switchgear area, 4 KV vital switchgear area	
EP R-1	Attachment 7 p. 1 & 2	Safety, Health & Claims Personnel (Injuries)	
	p. 9	San Luis Ambulance and French Hospital	
	p. 15	Supervising Nuclear Generation Engr.	
EP R-3	p. 3	State Executive Officer, Calif. Regional Water Quality Control Board, Central Coast Region	
EP R-7	p. 8	Supervising Nuclear Generation Engr.	
	p. 9	Los Padres District Manager	
EP M-1	p. 5	Supervising Nuclear Generation Engr.	
	Attachment 7	List of physicians, hospitals & ambulances serving the immediate area of Diablo Canyon.	
	Attachment 8	List of physicians, hospitals, and ambulances serving the immediate area of Diablo Canyon	
	Attachment 9	Safety, Health and Claims.	

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANTEMERGENCY PLAN PHONE NUMBER VERIFICATION CHECKLIST

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

PROCEDURE NO.	PAGE NO.	AGENCY	COMMENTS (Note How Checked)
EP M-2	Appendix Z	Supervising Nuclear Generation Engr. Division Field Claims Investigator	
EP M-4	P. 4, 7, and Attachment	UC Berkeley Seismograph Station	
EP M-6	p. 3	Security Extensions	
	p. 8	Fire Assistance Communications List	
EP M-7	P. 2	PGandE Law Department, Mr. David Williamson	
	p. 2	Organizations to be notified in the event of an oil spill	
	p. 2	California State Office of Emergency Service	
	p. 3	California State Land Commission	
	p. 3	State Executive Officer California Regional Water Quality Control Board Central Coast Region	
EP OR-1	Attachment 2	Table 1 - Offsite Emergency Support Organization	
EP OR-2	Attachment i	Media Notification List	

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT

EMERGENCY PLAN PHONE NUMBER VERIFICATION CHECKLIST

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

PROCEDURE NO.	PAGE NO.	AGENCY	COMMENTS (Note How Checked)
EP EF-1	p. 2, Attachments 1, 2, 4	Hot shutdown panel, dedicated shutdown panel, Control Room, EOF, CIRC, Dosimetry personnel	
EP EF-4	Attachment 1	PT&T and PGandE	
EP EF-5	Attachment 1	EOF, UDAC, TSC, DCPD	
EP RB-8	p. 3	DCPD, EOF, TSC	
EP G-2	Attachment 1 p. 1-28	Emergency Organization Call List	
EP G-3	Attachment 2	Emergency Offsite Organization Call List	
	Attachment 3	Mobile Phone and Pager Instructions	
EP G-4	p. 4	Emergency Conference Line	
	p. 6	Emergency Conference Line	
	p. 7	Control Room, TSC, Cold Machine Shop, Access Control	
	p. 8	Security Building, Temp Training Building, Security Training Trailer	

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: CONTROL ROOM CHECKLIST

---

---

DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

1. Dose Projection Equipment

\_\_\_\_ (1) Base Map

\_\_\_\_ (7) Overlays (Stability Class A-G)

2. \_\_\_\_\_ Portable Video Camera (in Shift Foreman's Office)

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: TECHNICAL SUPPORT CENTER CHECKLIST

---

---

DATE \_\_\_\_\_

PERFORMED BY \_\_\_\_\_

1. Radios

Check functioning of the following: (Use Operating Procedure K-9 "Instructions for Operation of DCPD Radio Systems")

Operations Modules

Check functioning of the Repeater/Local, Backup and Remote modules by selecting one and check module functioning by receiving available traffic or by calling the Information Center (encode 22 on F1) or Morro Bay (encode 33).

[ ]

NOTE: Transmitter functioning is checked by operations using STP I-29

Security Modules

Check function of the Repeater/Local, Backup and Remote modules by selecting one and check module functioning by receiving Local Traffic.

[ ]

NOTE: Transmitter functioning is checked by Security.

Division Radio

Check module functioning of the division radio modules by selecting each and receiving available Traffic.

NOTE: Transmitter functioning is checked by operations using STP I-29.

NOTE: If no Traffic is available note that below.

H/P Radio

Check functioning of the Repeaters, Local and HP Remote modules by selecting one at a time and activating an Emergency Organization pager unit.

[ ]

NOTE: Pager must be outside the TSC to receive the signal.

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: TECHNICAL SUPPORT CENTER CHECKLIST

---

---

Note any problems with the radio console:

---

---

---

---

2. Telephones

NOTE: CBX Telephones are in routine use and need not be checked.

Check functioning of the ROLM Console by turning on, calling the plant emergency number [595-7335] from any phone and receiving the call at the console. Extend the call to any extension and verify connections between the originating phone and the ringing phone. [ ]

TURN OFF CONSOLE AFTER CHECKING

Verify the ATL to San Luis Obispo County Sheriff's Dispatch Center by verifying the phone is answered at that office and two-way communication can be maintained.

Verify the ATL to the State Office of Emergency Services by verifying the phone is answered at that office and two-way communications can be maintained. Check both extensions (Site Emergency Coordinator's desk and EARS office) [ ]

Check functioning of the following ATL's by verifying they ring when selected. Allow to ring long enough so someone in the vicinity can answer, if available: [ ]

	<u>OFFICE</u>	<u>OPERATIONS CENTER</u>	<u>EARS OFFICE</u>
CR-1	[ ]	[ ]	[ ]
CR-2	[ ]	[ ]	[ ]
OSC	[ ]	[ ]	
EOF	[ ]	[ ]	[ ]



PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: TECHNICAL SUPPORT CENTER CHECKLIST

Verify functioning of one SLO off premise extension by calling any plant extension using [REDACTED]

- Office
- Operations Center
- EARS Office

[ ]  
[ ]

3. Verify functioning of The Black Net Telephone by calling any extension.

[ ]

4. Check functioning of the Control Room Closed Circuit TV's as follows (Refer to operating instructions in the TV desk drawer):

Color monitors 1 - 5 receive pictures from cameras 1 - 7

[ ]

Black and White monitor #6 receives pictures from cameras 8 and 9.

[ ]

Pan, zoom and focus controls on cameras 1 - 7 function

[ ]

NOTE: Close the iris on cameras 1 - 7 following check.

5. Equipment Quantities - Check per Form 69-10752

Note Discrepancies Below:

---



---



---



---



---

PACIFIC GAS AND ELECTRIC COMPANY  
 DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: TECHNICAL SUPPORT CENTER EQUIPMENT QUANTITY CHECKLIST

OFFICE

\_\_\_\_\_ • 1 Rolm Telephone Console with Handset  
 \_\_\_\_\_ 1 Emergency Equip. Cabinet: Status Boards (6) and 1 telephone number board  
 \_\_\_\_\_ 2 Headsets  
 \_\_\_\_\_ Box of Office Supplies (Verify ample stationary supplies)  
 \_\_\_\_\_ Emergency Telephone Directory (7)  
 \_\_\_\_\_ 16 Nameplates  
 \_\_\_\_\_ Emergency Classification Diagram  
 \_\_\_\_\_ Emergency Forms per form 69-10582  
 \_\_\_\_\_ 4 TI-1750 III Calculators  
 \_\_\_\_\_ 1 Case of KI

OPERATIONS CENTER

\_\_\_\_\_ Emergency Forms per form 69-10582  
 \_\_\_\_\_ Closed Circuit TV Monitors - 5 color  
 \_\_\_\_\_ 1 Black and White  
 \_\_\_\_\_ Tape drive & disc  
 \_\_\_\_\_ Harris Processor - Computer  
 \_\_\_\_\_ Harris Terminal  
 \_\_\_\_\_ Harris Key Stations - 2 (Terminals)  
 \_\_\_\_\_ Harris Line Printers (2)  
 \_\_\_\_\_ Nicolet Zeta Plotter  
 \_\_\_\_\_ TI ONMI 800 Printer

EARS OFFICE

\_\_\_\_\_ EARS Computer and Operating Terminal  
 \_\_\_\_\_ Emergency Telephone Directory (3)  
 \_\_\_\_\_ Emergency Forms per form 69-10582  
 \_\_\_\_\_ 1 Status Board  
 \_\_\_\_\_ 1 Set Dispersion Overlays and Map in Holder

RECORDS OFFICE

\_\_\_\_\_ Aperature Card Viewer  
 \_\_\_\_\_ Aperature Card Files with Cards  
 \_\_\_\_\_ Microfilm Printer/Viewer with Reels  
 \_\_\_\_\_ Teledyne Geo Tech Auto Met V Computer

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: TECHNICAL SUPPORT CENTER EQUIPMENT QUANTITY CHECKLIST

RECORDS OFFICE (CONTINUED)

Construction DWG Index Books 1 and 2  
7 Phone Books  
• 18 MSA SCBA's  
Panafax Document Transmitter - MV1200  
Micro-fiche Printer/Viewer  
Hewlett Packard Computer Terminal (1)  
Instruction Manuals - Hard Copy in Cabinets (2)  
Plant Manuals

Volume 2 Operating Procedures A-F, G-0, #67  
Volume 3 Emergency Procedures, #66, 67, 79  
Volume 3A Emergency Procedures, #66, 67, 79  
Volume 3B Emergency Procedure, #66, 67, 79  
Volume 4 Licenses & Permits, #67  
Volume 7 Radiation Control Standards, #67  
Volume 9 Temporary Procedures & Instructions, #67  
Volume 11 Emergency Plans, #66, 67, 79  
Volume 16 Annunciator Response, #67  
Volume 1-14 Final Safety Analysis Report

RMS Handbook - TSC  
Equipment Record Number Index  
Corporate Emergency Response Plan, Control #271-272  
Diablo Canyon Emergency Response Communications Directory (2 binders)  
Emergency Response Manual - INPO RP/EP-1 9/80  
Report on Small Break Accidents for Westinghouse NSSS System, Vol. I, II, III  
Reference Dwg. 102037, 102038 - Instrument Locations  
Reference Dwg. 101876-14 - Main Annunciator Input List  
101900 - List of Equipment Location Codes - Unit 1  
Uncontrolled Emergency Procedures Volume - (there are 6 binders all the same)  
Operating Valve Identification Diagrams, Control Copy #31 - Unit 1  
Instrument Schematics, Control Copy #24  
Electrical Diagrams, Logic Diagrams & Electrical Arrangements, Control Copy #27  
Unit 1 and 2  
Piping Schematics, Control Copy #3

NRC OFFICE

NRC Red "Hot Line" Phone  
NRC Blue HPN Phone  
NRC HPN Phone Directory (1)

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: OPERATIONAL SUPPORT CENTER AND OPERATIONS SUPPORT CENTER CHECK LIST

DATE \_\_\_\_\_ PERFORMED BY \_\_\_\_\_

Operational Support Center (Security Building Lunchroom)

- 1. Check CBX extension by calling Unit 1 Control Room  
Verify the Control Room answers. [ ]
- 2. Check ATL to CR/TSC by lifting receiver, verify Control Room answers. [ ]
- 3. Operational Support Center Workbook.\* [ ]

<u>Procedure</u>	<u>Rev. No.</u>
G-4	_____
EF-2	_____

Form 69-9639, Date \_\_\_\_\_, Quantity \_\_\_\_\_ (12)


\*Check procedure revision number and form date against a controlled copy of the emergency procedure (Plant Manual Volume 3A). Note any discrepancies below and provide updated material.

Operations Support Center (Access Control/Cold Machine Shop Area)

- 1. Check emergency CBX extension by calling Unit 1 Control Room.  
Verify the Control Room answers. [ ]
- 2. Check ATL to CR/TSC by lifting receiver, verify Control Room answers. [ ]

TITLE: EMERGENCY OPERATIONS FACILITY EQUIPMENT FUNCTION CHECKLIST

PHONE LIST

<u>TITLE</u>	<u>PHONE #</u>	<u>GOOD</u>	<u>BAD</u>
SPDS		[ ]	[ ]
ESE		[ ]	[ ]
LAW		[ ]	[ ]
MET		[ ]	[ ]
RMD		[ ]	[ ]
UDAC		[ ]	[ ]
UDAC		[ ]	[ ]
UDAC		[ ]	[ ]
DCPP		[ ]	[ ]
LAW		[ ]	[ ]
MET		[ ]	[ ]
RMD		[ ]	[ ]
UDAC		[ ]	[ ]
ELRM		[ ]	[ ]
RM		[ ]	[ ]
OARM		[ ]	[ ]
RERM		[ ]	[ ]
EARS		[ ]	[ ]
PIRM		[ ]	[ ]
ELRM		[ ]	[ ]
RM		[ ]	[ ]
OARM		[ ]	[ ]
RERM		[ ]	[ ]
EARS		[ ]	[ ]
PIRM		[ ]	[ ]
SPDS		[ ]	[ ]
ESE		[ ]	[ ]
SEC		[ ]	[ ]

TITLE: EMERGENCY OPERATIONS FACILITY EQUIPMENT FUNCTION CHECKLIST

LIGHTS

Make sure that all lights turn on and off. (Second floor only)

Note any problems below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

COPIERS

There are 2 Savin 5040 copy machines in the EOF. One is located in the ELRM office, the other is in the UDAC office. Turn on main power switch located at right side of machine. Then push 'on' button on top of the machine. Wait for copier to warm up. A beeping sound will call when machine is ready. Also, the word "READY" will appear on LED display. Set number of copies at 30. Place original in auto-feed. Lighted sign will verify that original is inserted. Press PRINT. Copier should accept original, print 30 copies, and return original. Turn copier off when finished. Check for supplies of copy paper (at least 6 packages). Check for copy machine dispersant and toner (at least 2 bottles of each).

Note any problems or comments below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PANAFAX

Turn on power. Call Admin. operator [redacted] and ask operator for someone to help test Panafax System. Transmit 1 message from EOF to office. Receive 1 message from office.

Note any problems or comments below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: EMERGENCY OPERATIONS FACILITY EQUIPMENT FUNCTION CHECKLIST

PHONES

Check only those phones that exist on the second floor of the building. Check by using the multi-line phone on the Engineering and Logistics Recovery Manager's desk. Lift the receiver, push each button, look for the button light and listen for the dial tone. Now push the button labeled [REDACTED]. Dial all of the [REDACTED] numbers. Then push the button labeled [REDACTED]. Dial all of the [REDACTED] numbers (dial just the last 4 digits). For each of the numbers dialed listen for a ringing tone in the earpiece. NOTE: not all of the phones have an audible telephone bell so listen only for the ringing tone in the earpiece. Check that each phone can maintain two-way communications, using the phone checklist on page 3.

Check the phones in the NRC Office and in the State/FEMA Office following the same format as stated above.

Note any problems or comments below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

RADIOS

Check the radios in the OARM Office, ELRM office, and in the Radiological Monitoring Director's Office. Check handie-talkies in RMD's Office. Call Diablo Canyon Unit 1 by phone [REDACTED] to let control operators know you are going to check the radios. Turn radio on. For the OARM and ELRM office radios with frequency selection, select F2. Pick up handset (radios in OARM Office). Use encoder to call Diablo Canyon control room: code 41, push button 4 and then button 1. Push transmit button on handset or desk top microphone. Transmit message, "Diablo Control, this is the EOF. Radio check, please." Release transmit button and wait for response. If there is no response within 20-30 seconds, repeat encode and message. Make sure power is turned off when finished. For handie-talkies select F5 and call the Radiological Monitoring Director's office, repeat using F6 to check the local receiver.

Note any problems or comments below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PACIFIC GAS AND ELECTRIC COMPANY  
 DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: EMERGENCY OPERATIONS FACILITY INVENTORY CHECKLIST

OFFICE SUPPLIES

- \_\_\_\_\_ Check contents of all desks and file cabinets for ample quantities of stationary supplies, such as: ball point pens, erasers, felt pens (various colors), rubber bands, paper clips, pencils, scissors, rulers, ruled note paper, stapler removers, scotch tape, carbon paper, assorted plain paper, etc.

OPERATIONS AND ANALYSIS RECOVERY MANAGER

- \_\_\_\_\_ 1 Chair
- \_\_\_\_\_ 1 desk
- \_\_\_\_\_ 1 50 mile map
- \_\_\_\_\_ 1 10 mile map
- \_\_\_\_\_ 2 Motorola radio sets with encoder
- \_\_\_\_\_ 1 multi-line phone
- \_\_\_\_\_ Emergency Procedures Vol 3A & 3B (3 binders)
- \_\_\_\_\_ Emergency Plans Vol 11 (2 binders)
- \_\_\_\_\_ Corporate Emergency Response Plan (1)
- \_\_\_\_\_ Nuclear Emergency Response Communications Directory (1)
- \_\_\_\_\_ 3 clipboards

ENGINEERING AND LOGISTICS RECOVERY MANAGER

- \_\_\_\_\_ 6 chairs
- \_\_\_\_\_ 3 desks
- \_\_\_\_\_ 1 table
- \_\_\_\_\_ 1 half-table
- \_\_\_\_\_ 2 Motorola radio sets with encoder
- \_\_\_\_\_ 3 multi-line phones
- \_\_\_\_\_ 2 single-line phones
- \_\_\_\_\_ 1 IBM Selectric III
- \_\_\_\_\_ 1 Panafax machine
- \_\_\_\_\_ 1 Savin 5040 copier
- \_\_\_\_\_ 1 bookcase
- \_\_\_\_\_ 2 SPDS video monitors with display generators (A&B)
- \_\_\_\_\_ 2 SPDS switchboards (A&B)
- \_\_\_\_\_ 1 Tektronix 4631 Hard Copy Machine
- \_\_\_\_\_ 1 IT Intermediate Terminal ADM-31
- \_\_\_\_\_ 1 Tanberg TDC 3000 digital cartridge recorder
- \_\_\_\_\_ 1 Tektronix 4006-1 terminal
- \_\_\_\_\_ 1 Digital Decwriter III
- \_\_\_\_\_ 1 Recall Recorder (plus Giltronix Selectro switch)
- \_\_\_\_\_ 1 coatrack
- \_\_\_\_\_ 1 5-drawer file
- \_\_\_\_\_ 2 clocks
- \_\_\_\_\_ 3 status boards (Significant Events, Plant Status, Radiological Status)
- \_\_\_\_\_ Operating Procedures Vol 2 (5 binders)
- \_\_\_\_\_ Drawing 102037 -- Instrument Locations (1 binder)
- \_\_\_\_\_ Drawing 102038 -- Instrument Reference (1 binder)
- \_\_\_\_\_ Emergency Procedures Vol 3A & 3B (3 binders)
- \_\_\_\_\_ Licenses and Permits Vol 4
- \_\_\_\_\_ Radiation and Control Standards and Procedures Vol 7



TITLE: EMERGENCY OPERATIONS FACILITY INVENTORY CHECKLISTENGINEERING AND LOGISTICS RECOVERY MANAGER (Continued)

\_\_\_\_\_ Chemical and Radiochemical Procedures Vol 8 (3 binders)  
 \_\_\_\_\_ Temporary Procedures and Instructions Vol 9 (2 binders)  
 \_\_\_\_\_ Emergency Plans Vol 11 (2 binders)  
 \_\_\_\_\_ Electrical Drawings Units 1 & 2 (2 binders, green)  
 \_\_\_\_\_ Operating Valve Identification Diagrams Units 1 & 2 (2 binders, black)  
 \_\_\_\_\_ Piping Schematics Units 1 & 2 (2 binders, orange)  
 \_\_\_\_\_ Instrument Schematics Units 1 & 2 (2 binders)  
 \_\_\_\_\_ Hosgri Seismic Evaluation (7 binders)  
 \_\_\_\_\_ Nuclear Emergency Response Communications Directory (6)  
 \_\_\_\_\_ Corporate Emergency Response Plan (1)  
 \_\_\_\_\_ State of California Nuclear Power Plant Emergency Response Plan (7 binders)  
 \_\_\_\_\_ 3 clipboards

RECOVERY MANAGER'S OFFICE

\_\_\_\_\_ 11 chairs  
 \_\_\_\_\_ 1 desk  
 \_\_\_\_\_ 1 8' table  
 \_\_\_\_\_ 1 white board  
 \_\_\_\_\_ 1 50 mile map  
 \_\_\_\_\_ 1 10 mile map  
 \_\_\_\_\_ 1 multi-line speaker phone  
 \_\_\_\_\_ 1 Black-Net phone  
 \_\_\_\_\_ 1 Yellow-Net phone  
 \_\_\_\_\_ 1 bookcase  
 \_\_\_\_\_ 1 5-drawer file  
 \_\_\_\_\_ 1 coatrack  
 \_\_\_\_\_ 1 clock  
 \_\_\_\_\_ Emergency Procedures Vol 3A & 3B (3 binders)  
 \_\_\_\_\_ Emergency Plans Vol 11 (2 binders)  
 \_\_\_\_\_ Corporate Emergency Response Plan (2)  
 \_\_\_\_\_ Nuclear Emergency Response Communications Directory (1)  
 \_\_\_\_\_ 4 clipboards

PG&E LAW OFFICE

\_\_\_\_\_ 1 chair  
 \_\_\_\_\_ 1 desk  
 \_\_\_\_\_ 1 multi-line phone  
 \_\_\_\_\_ 1 clock  
 \_\_\_\_\_ 3 clipboards

TITLE: EMERGENCY OPERATIONS FACILITY INVENTORY CHECKLISTPG&E PUBLIC INFORMATION

\_\_\_\_\_ 4 chairs  
 \_\_\_\_\_ 2 desks  
 \_\_\_\_\_ 1 table  
 \_\_\_\_\_ 2 multi-line phones  
 \_\_\_\_\_ 1 single-line phone  
 \_\_\_\_\_ 1 Yellow-Net Phone  
 \_\_\_\_\_ 1 50 mile map  
 \_\_\_\_\_ 1 10 mile map  
 \_\_\_\_\_ 1 IBM Selectric III  
 \_\_\_\_\_ 1 Remington manual typewriter  
 \_\_\_\_\_ 1 IBM Electric typewriter dedicated to Media Center (older model)  
 \_\_\_\_\_ 1 Sanyo AM-FM cassette radio  
 \_\_\_\_\_ 1 AIWA multi-band cassette radio (Model CS-360, Serial #P30509248)  
 \_\_\_\_\_ 2 TI Silent 700 portable data terminals  
 \_\_\_\_\_ 3 typewriter stands  
 \_\_\_\_\_ 1 white board  
 \_\_\_\_\_ 5 clipboards

RADIOLOGICAL MONITORING DIRECTOR

\_\_\_\_\_ 3 chairs  
 \_\_\_\_\_ 1 desk  
 \_\_\_\_\_ 1 table  
 \_\_\_\_\_ 1 Motorola radio set  
 \_\_\_\_\_ 2 Motorola Handi-Talkies  
 \_\_\_\_\_ 3 Motorola Handi-Talkie Chargers  
 \_\_\_\_\_ 1 5-drawer file  
 \_\_\_\_\_ 1 50 mile map  
 \_\_\_\_\_ 1 10 mile map  
 \_\_\_\_\_ 1 Radeco Particulate Air Sampler  
 \_\_\_\_\_ 1 County Health Team Radio (Motorola Series 90)  
 \_\_\_\_\_ 1 Speedcall Motorola 434 Display  
 \_\_\_\_\_ 4 Clipboards

UNIFIED DOSE ASSESSMENT CENTER

\_\_\_\_\_ 17 chairs  
 \_\_\_\_\_ 6 desks  
 \_\_\_\_\_ 6 tables  
 \_\_\_\_\_ 10 multi-line phones  
 \_\_\_\_\_ 6 50 mile maps  
 \_\_\_\_\_ 6 10 mile maps  
 \_\_\_\_\_ 5 modular shelves with lights  
 \_\_\_\_\_ 1 Overlay Base Map with 7 Overlays (Stability Classes A-G)  
 \_\_\_\_\_ 1 coatrack  
 \_\_\_\_\_ 2 clocks  
 \_\_\_\_\_ 1 Savin 5040 copier  
 \_\_\_\_\_ 1 Rapidprint Time Clock  
 \_\_\_\_\_ 1 IBM Selectric III  
 \_\_\_\_\_ 1 Aerovironmental Model 322A Chart Recorder  
 \_\_\_\_\_ 1 Aerovironmental Model 324 Telephone Line Receiver

---

 TITLE: EMERGENCY OPERATIONS FACILITY INVENTORY CHECKLIST
 

---

UNIFIED DOSE ASSESSMENT CENTER (Continued)

\_\_\_\_\_ 1 Hewlett-Packard 2621P Terminal  
 \_\_\_\_\_ 1 Texas Instruments OMNI 800 Terminal  
 \_\_\_\_\_ 1 Hewlett-Packard 9845C Desk-Top Computer  
 \_\_\_\_\_ 1 Hewlett-Packard 98041 Disc Interface  
 \_\_\_\_\_ 1 Hewlett-Packard 7906 Disc Drive  
 \_\_\_\_\_ 1 Hewlett-Packard 13037C Disc Controller  
 \_\_\_\_\_ 3 5-drawer files  
 \_\_\_\_\_ Emergency Procedures Vol 3A & 3B (3 binders)  
 \_\_\_\_\_ Emergency Plans Vol 11 (2 binders)  
 \_\_\_\_\_ Nuclear Emergency Response Communications Directory (5)  
 \_\_\_\_\_ 4 status boards (Significant Events, UDAC Duty Roster, Field Monitoring  
 Data, Radiological Status)  
 \_\_\_\_\_ 16 clipboards

LUNCH ROOM

\_\_\_\_\_ 27 chairs  
 \_\_\_\_\_ 7 tables  
 \_\_\_\_\_ 1 kitchenette  
 \_\_\_\_\_ 1 clock  
 \_\_\_\_\_ 1 100-cup coffee pot  
 \_\_\_\_\_ Misc. supplies (coffee, cups, etc.)

STATE/FEMA

\_\_\_\_\_ 5 chairs  
 \_\_\_\_\_ 4 desks  
 \_\_\_\_\_ 1 table  
 \_\_\_\_\_ 4 multi-line phones  
 \_\_\_\_\_ 1 single-line phone  
 \_\_\_\_\_ 2 Yellow-Net phones  
 \_\_\_\_\_ 2 status boards (STATE, FEMA)  
 \_\_\_\_\_ 1 50 mile map  
 \_\_\_\_\_ 1 10 mile map  
 \_\_\_\_\_ 1 easel

NRC

\_\_\_\_\_ 12 chairs  
 \_\_\_\_\_ 2 desks  
 \_\_\_\_\_ 3 tables  
 \_\_\_\_\_ 1 10' table  
 \_\_\_\_\_ 4 multi-line phones  
 \_\_\_\_\_ 1 Red phone  
 \_\_\_\_\_ 1 Blue phone  
 \_\_\_\_\_ 1 Black-Net phone  
 \_\_\_\_\_ 1 Yellow-Net phone  
 \_\_\_\_\_ 1 white board  
 \_\_\_\_\_ 1 50 mile map  
 \_\_\_\_\_ 1 10 mile map  
 \_\_\_\_\_ 1 clock

PACIFIC GAS AND ELECTRIC COMPANY  
DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: EMERGENCY FACILITY FORMS FILE LIST

CURRENT FORM DATE	NUMBER	TITLE	APPROXIMATE QUANTITY				
			T-1	T-2	T-3	E-1	E-2
_____	69-9221	Emergency Notification Record	20	20	20	20	20
_____	69-9230	Work Sheet for Determination of X/Q	5		20	5	10
_____	69-9248	Post-Earthquake Evaluation Summary	5				
_____	69-9249	Post-Earthquake Level Indication Checklist	5				
_____	69-9250	Post-Earthquake Area Inspection	5				
_____	69-9251	Post-Earthquake Surveillance Test Check List	5				
_____	69-9252	Electrical Power Check List	5				
_____	69-9259	Emergency Environmental Monitoring Field Data Sheet	20	10	10	20	20
_____	69-9260	Work Sheet for Determination of Release Rate or Total Release from Plant Vent Monitoring	5	5	20	5	10
_____	69-9283	Data Sheet for T-G Peak Recording Accelograph	5				
_____	69-9284	Work Sheet for Estimation of Curie Release	5	5	20	5	20
_____	69-9310	Post-Evacuation Vehicle Monitoring Data	10		10	10	5
_____	69-9311	Evacuee Monitoring Data	10		10	10	5
_____	69-9313	Controlled Area and Airborne Area Entry Log	10		20	5	5
_____	69-9315	Contamination Survey Record	10			10	5
_____	69-9316	Radiation Dose Rate Survey Record	5		5	5	5
_____	69-9320	High Radiation Area Entry Log	10			5	5
_____	69-9321	Containment Entry Log	5			5	5
_____	69-9370	Site Emergency Organization Assignment	10			5	5
_____	69-9371	Environmental Monitoring Data Summary	5		5	5	5
_____	69-9392	Skin and Clothing Decontamination	10			10	5
_____	69-9395	Record of Distribution of Potassium Iodine	10		10	10	10
_____	69-9510	Special Work Permit Request	10		20	5	5
_____	69-10059	Individual Accountability Record	20				
_____	69-10060	Summary of Personnel Accountability	10				
_____	69-10262	Radiological Emergency Status Form	20	5	20	20	20
_____	69-10295	Plant Status Emergency Form	20	20	5	20	20
_____	69-10296	Onsite/Offsite Rad. Field Monitoring and PIC Status Form	20	5	20	20	20
_____	69-10297	Emergency Organization Call List (On-site)	5			5	5
_____	69-10298	Emergency Organization Call List (Off-Site)	5			5	5
_____	69-10554	Emergency Exposure Permit	10			10	10
_____	69-10555	Work Sheet for Release Rate Estimation from Containment High Range Area Monitors	5	5	20	5	10
_____	69-10556	Release Rate Summary	5	5	20	5	10
_____	69-10566	Worksheet for Manual Off-Site Dose Calculations	5		5	5	5
_____	69-10581	Initial Emergency Notification Form	5			5	5

PACIFIC GAS AND ELECTRIC COMPANY  
 DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
 DIABLO CANYON POWER PLANT UNIT NOS. 1 AND 2

TITLE: EMERGENCY FACILITY FORMS FILE LIST

CURRENT FORM DATE	* NUMBER	TITLE	APPROXIMATE QUANTITY				
			T-1	T-2	T-3	E-1	E-2
_____	69-10582	Emergency Facility Forms File List	2			2	2
_____	69-10766	Control Room Checklist	2				
_____	69-10767	Technical Support Center Checklist	2				
_____	69-10768	Technical Support Center Equipment Quantity Checklist	2				
_____	69-10769	Operational Support Center and Operations Support Center Checklist					
_____	69-10770	Emergency Operations Facility Checklist				2	2
_____	69-10771	Emergency Operations Facility Equipment Quantity Checklist				2	2
_____	None	Personnel List Diablo Canyon Power Plant Department of Nuclear Plant Operations				2	2
_____	R-2	Appendix 2 - Instructions for Estimating Noble Gas Release Rate Using Plant Vent Monitors RE-14 or RE-29	5	5	5	5	5
_____	R-2	Appendix 3 - Instructions for Estimating Iodine Release Rate Using Plant Vent Monitor RE-24	5	5	5	5	5
_____	R-2	Appendix 4 - Use of Containment Air Sample Data % Estimate Release Rate	5	5	5	5	5
_____	R-2	Appendix 5 - Use of RCS Coolant Sample During S/G Tube Rupture Accident	5	5	5	5	5

File Locations:

T-1 = TSC-1 = Office Area File  
 T-2 = TSC-2 = Operations Area File  
 T-3 = TSC-3 = Computation Area File  
 E-1 = EOF-1 = ELRM Office File  
 E-2 = EOF-2 = EARS Office File

PACIFIC GAS AND ELECTRIC COMPANY  
CORPORATE EMERGENCY RESPONSE PLAN

IMPLEMENTING PROCEDURE LIST

<u>Number</u>	<u>Revision</u>	<u>Date</u>	<u>Title</u>
1.1	02	07/14/83	Activation of the Corporate Emergency Response Organization
1.2	02	07/15/83	Activation of the Corporate Incident Response Center
2.1	02	07/25/83	Plan Maintenance
2.2	01	01/13/84	Emergency Preparedness Training Program
3.1	02	07/29/83	Governmental Relations
3.2	03	08/25/83	Corporate Communications Department
3.3	02	07/29/83	Law
3.4	02	07/26/83	Insurance
3.5	02	07/22/83	Safety, Health and Claims
3.6	02	07/20/83	Security
3.7	01	09/06/83	Personnel
4.1	02	07/25/83	Materials
4.2	02	07/14/83	Telecommunications
4.3	03	08/30/83	Radiological Analysis and Protection
4.4	02	08/05/83	General Construction
4.5	02	08/30/83	Engineering and Technical Support
4.6	02	09/16/83	Computer Systems and Services
4.7	03	07/29/83	Nuclear Plant Operations
4.8	02	07/28/83	Division Support
4.9	02	07/22/83	Quality Assurance

THIS PAGE INTENTIONALLY LEFT BLANK

PG&E



PACIFIC GAS and ELECTRIC COMPANY  
CORPORATE EMERGENCY RESPONSE PLAN

NUMBER: 2.2  
REVISION: 1  
DATE: 01/13/84  
PAGE 01 OF 08

**IMPLEMENTING PROCEDURE**

TITLE  
EMERGENCY PREPAREDNESS TRAINING PROGRAM

RESPONSIBILITY	SIGNATURE	DATE
	TITLE	
PREPARED BY	<i>P. U. Mack</i> SR. NUCLEAR GENERATION ENGINEER EMERGENCY PLANNING	1/5/84
REVIEWED AND CONCURRED BY	<i>[Signature]</i> SUPERVISING NUCLEAR GENERATION ENGINEER PERSONNEL & ENVIRONMENTAL SAFETY	1/9/84
REVIEWED AND CONCURRED BY	<i>[Signature]</i> MANAGER, NUCLEAR PLANT OPERATIONS	1/10/84
APPROVED BY	<i>[Signature]</i> VICE PRESIDENT, NUCLEAR POWER GENERATION	1/11/84
APPROVED BY	<i>[Signature]</i> CHAIRMAN, PRESIDENT'S NUCLEAR ADVISORY COMMITTEE	1/7/84



**PG&E**

PACIFIC GAS and ELECTRIC COMPANY  
CORPORATE EMERGENCY RESPONSE PLAN

**IMPLEMENTING PROCEDURE**

TITLE

EMERGENCY PREPAREDNESS TRAINING PROGRAM

NUMBER: 2.2

REVISION: 1

DATE: 01/13/84

PAGE 02 OF 08

ORGANIZATIONAL OUTLINE

- I. SCOPE
- II. DISCUSSION
- III. RESPONSIBILITIES
- IV. INSTRUCTIONS
- V. REFERENCES
- VI. ATTACHMENTS

PG&E	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	DATE: 01/13/84 PAGE 03 OF 08

## I. SCOPE

The scope of this Implementing Procedure is to describe the responsibilities and requirements for the Corporate Emergency Response Plan training program as required by 10CFR50.47(b)(15).

## II. DISCUSSION

### A. General

This Implementing Procedure provides instructions for the implementation of a coordinated annual training program for Corporate Emergency Response Organization (CERO) personnel with assignments under the Corporate Emergency Response Plan (CERP). CERO training should be accomplished in three phases with activities in both a classroom atmosphere and participation in drills and exercises.

### B. Definitions of Terms

#### 1. Training activity:

A training activity is the process by which the skills of individual personnel are improved and refined to meet or exceed prescribed qualification standards for the performance of their specified duties and responsibilities under the CERP.

#### 2. Drill:

A drill is a supervised instruction period aimed at developing and maintaining required skills for a particular task/assignment.

#### 3. Exercise:

An exercise is an event which tests a major portion of the basic elements within the CERP and demonstrates the capability of the CERO to respond to an emergency.

### C. Corporate Emergency Response Organization Training Program

#### 1. Program Description

In order to maintain emergency preparedness training requirements as required by NRC regulation 10CFR50.47(b)(15), CERO personnel training may be accomplished in three training activity phases, as described below:

PG&E	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	DATE: 01/13/84 PAGE 04 OF 08

Phase	Activity Description
I	General introductory course to explain the purpose and function of the CERP in support of the Diablo Canyon Power Plant Emergency Plan.
II	Courses designed to provide CERO personnel with specific training instruction for executing assigned duties and responsibilities as identified in Procedure Attachment 1, "CERO Training Program Courses".
III	Drills and exercises designed to provide CERO personnel with "hands on" experience using appropriate facilities, equipment, and procedures.

NOTE: CERO training, drills, and exercises will be conducted in coordination with DCPD training activities.

## 2. Program Objectives

The training program objectives are to provide for the following types of training:

- a. Corporate emergency preparedness management training for those individuals assigned to perform the principal and alternate functions of the CERO Departmental/Functional Group Coordinators and Recovery Manager.
- b. Corporate emergency preparedness procedure training for those individuals assigned specific duties and responsibilities as identified in the implementing procedures.
- c. Corporate emergency preparedness refresher training courses for all emergency response personnel activated under the Corporate Emergency Response Plan.

## 3. Program Requirements

### a. Initial training

- 1) General Office personnel should complete the courses designated for their assigned CERO emergency plan title(s) as specified in Procedure Attachment 2, "CERO Personnel Classroom Training Requirements" for each CERP Implementing Procedure.

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	DATE: 01/13/84 PAGE 05 OF 08

- 2) Non-General Office personnel may complete the required course training for their assigned CERO emergency plan title(s) as specified in Procedure Attachment 2, "CERO Personnel Classroom Training Requirements" by completing Procedure Attachment 3, "Certification of Self-Training Completion".

b. Refresher training

CERO personnel maintain their "trained on an annual basis" status by participating in either of the following activities:

- 1) Scheduled (announced or unannounced) drills throughout the year, the Annual Emergency Preparedness Exercise Dress Rehearsal or Exercise; or
- 2) Applicable phase II training courses as specified in Procedure Attachment 2, "CERO Personnel Classroom Training Requirements".
- 3) Completion of Procedure Attachment 3, "Certification of Self-Training Completion", as requested.

D. Program Conduct & Documentation

1. CERO emergency preparedness training program will be conducted and coordinated with other Departments.
2. Training courses should be conducted in accordance with NPO Administrative Procedures.
3. Approved lesson plans for CERO training courses should be used in the conduct of all classroom training activities.
4. All CERO classroom training activities should be documented with the following records:
  - a. Attendance Records.
  - b. Correlation of attendance with training requirements.
  - c. Maintain status of training completed by individuals.

### III. RESPONSIBILITIES

Personnel with assigned responsibilities under this Procedure, as identified below by their non-emergency titles, should perform their assigned tasks as detailed in the Procedure Instructions section below.

PG&E	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	DATE: 01/13/84 PAGE 06 OF 08

#### IV. INSTRUCTIONS

- A. Supervising Nuclear Generation Engineer, Personnel and Environmental Safety
1. Schedule, coordinate, and implement specialized training programs to instruct and qualify those personnel responsible for implementing the Corporate Emergency Response Plan. The scope, nature, and frequency of those programs shall be specified for all CERO personnel.
  2. Ensure that all drills are supervised and evaluated by a qualified drill instructor and that the basic objective(s) of each drill are met.
  3. Ensure CERO participation in the scheduled monthly communications drills between DCPD and the San Luis Obispo County Sheriff's Office, State Office of Emergency Services and NRC. Such participation shall range from:
    - a. Limited alerting and notification of key CERO personnel and Departmental/Functional Group Coordinators; to
    - b. Full communications alerting/notification of all CERO personnel and possible activation of selected emergency response facilities.
- B. Manager, Nuclear Plant Operations Department
1. Remain cognizant of Corporate emergency preparedness training courses, drills, and exercises to ensure that effective and efficient interfaces between the Site and Corporate emergency response organizations will be maintained during an emergency.
  2. Direct the Supervising Nuclear Generation Engineer, P&ES Section, to schedule, coordinate, and implement the CERP Training Program.
  3. Ensure that critiques of Corporate emergency preparedness drills and exercises are conducted as soon as possible after their performance to ensure that the emergency response actions of the various Departments/Functional Groups within the Corporate Emergency Response Organization are properly evaluated, and any corrective action, if required, is implemented.

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	DATE: 01/13/84 PAGE 07 OF 08

C. Vice President, Nuclear Power Generation Department

1. Provide overall coordination of required emergency preparedness training programs and drills for Company emergency response personnel involved in any way with the Corporate Emergency Response Organization during an event requiring the activation of the Corporate Emergency Response Plan.

D. Departmental/Functional Group Coordinators

1. Participate in the applicable CERP Emergency Preparedness Training Program activities to maintain familiarity with the CERP, its Implementing Procedures, and the Nuclear Emergency Response Communications Directory.
2. Ensure that respective CERO Departmental/Functional Group personnel participate in and maintain training requirements.

E. President's Nuclear Advisory Committee

The President's Nuclear Advisory Committee will oversee required emergency preparedness drills and exercises.

V. REFERENCES

- A. Diablo Canyon Power Plant Emergency Plan.
- B. Corporate Emergency Response Plan.
- C. Nuclear Power Generation Manual, Volume 3, "Nuclear Plant Operations Department Procedures Manual", Chapter II.

VI. ATTACHMENTS

1. CERO Training Program Courses.
2. CERO Personnel Classroom Training Requirements.
3. Certification of Self-Training Completion.

**PG&E**

PACIFIC GAS and ELECTRIC COMPANY  
CORPORATE EMERGENCY RESPONSE PLAN

**IMPLEMENTING PROCEDURE**

TITLE

EMERGENCY PREPAREDNESS TRAINING PROGRAM

NUMBER: 2.2

REVISION: 1

DATE: 01/13/84

PAGE 08 OF 08

THIS PAGE INTENTIONALLY LEFT BLANK

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE		ATTACHMENT 1
EMERGENCY PREPAREDNESS TRAINING PROGRAM		DATE: 01/13/84
		PAGE 01 OF 01

CERO Training Program Courses

Training Phase	Course Number	Course Title	Applicable CERP IP
I. General Emergency Preparedness Program Overview Course			
	EPG-201	Corporate Emergency Response Plan and Diablo Canyon Power Plant Emergency Plan Overview.....	ALL
II. Departmental/Functional Group Courses			
	EPG-210	Governmental Relations Dept. CERP IP Review.....	3.1
	EPG-215	Corporate Communications Dept. CERP IP Review	3.2
	EPG-220	Law Dept. CERP IP Review.....	3.3
	EPG-225	Insurance Dept. CERP IP Review	3.4
	EPG-230	Safety, Health, and Claims Dept. CERP IP Review.....	3.5
	EPG-235	Security Dept. CERP IP Review	3.6
	EPG-240	Personnel Dept. CERP IP Review.....	3.7
	EPG-245	Materials Dept. CERP IP Review	4.1
	EPG-250	Telecommunications Dept. CERP IP Review.....	4.2
	EPG-255	Radiological Analysis and Protection Group CERP IP Review	4.3
	EPG-260	General Construction Dept. CERP IP Review.....	4.4
	EPG-265	Engineering and Technical Support Group CERP IP Review	4.5
	EPG-270	Computer Systems and Services Dept. CERP IP Review.....	4.6
	EPG-275	Nuclear Plant Operations Dept. CERP IP Review	4.7
	EPG-280	Division Support Group CERP IP Review.....	4.8
	EPG-285	Quality Assurance Dept. CERP IP Review	4.9
	EPG-290	CERO Management Personnel Responsibilities.....	1.1
<u>Miscellaneous Courses</u>			
	EPG-202	SLO County Nuclear Power Plant Emergency Response Plan Overview.....	NONE
	EPG-203	NOTEPAD Computer Conferencing System	3.2
	EPG-204	CIRC Administrative Support Staff Responsibilities.....	1.2



<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	
	<b>IMPLEMENTING PROCEDURE</b>	
TITLE		

THIS PAGE INTENTIONALLY LEFT BLANK

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 01 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERO Personnel Classroom Training Requirements  
 \*CERO MANAGEMENT (CERP IP 1.1)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																				
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290
Recovery Manager	●	x																●			●
Corporate Emergency Coordinator	●	x																			●
Corp. Technical and Logistical Coordinator	●	x																●			●
Corp. Liaison Coordinator	●	x		●														●			●
Public Information Recovery Mgr.	●	x				●															●
Radiological Emergency Recovery Manager	●	x												●				●			●
Engineering and Logistics Recovery Manager	●	x																●			●
Operations and Analytical Recovery Manager	●	x																●			●
Electric System Dispatcher - Shift Supervisor	●	x																			
Communications PBX Operator	●	x																			

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		ATTACHMENT: 2
		DATE: 01/13/84
		PAGE 02 OF 18

CERO Personnel Classroom Training Requirements  
\*ACTIVATION OF THE CORPORATE INCIDENT RESPONSE CENTER (CERP IP 1.2)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																						
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290		
Corp. Liaison Coordinator	●	x		●																	●	●	
CIRC Administrative Support Group Coordinator	●		●	●																			
CIRC Administrative Support Group Coordinator Staff	●		●	●																			
CIRC Telephone Operator	●			●																			

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	IMPLEMENTING PROCEDURE	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	ATTACHMENT: 2
		DATE: 01/13/84
		PAGE 03 OF 18

CERO Personnel Classroom Training Requirements  
\*GOVERNMENTAL RELATIONS DEPARTMENT (CERP IP 3.1)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corp. Governmental Relations Coordinator	●	x			●																	●
Governmental Relations Representatives	●	x			●																	

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
IMPLEMENTING PROCEDURE		REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	ATTACHMENT: 2
		DATE: 01/13/84
		PAGE 04 OF 18

CERO Personnel Classroom Training Requirements  
\*CORPORATE COMMUNICATIONS DEPARTMENT (CERP IP 3.2)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corp. Public Information Coord.	●	x				●																●
Media Center Representative	●	x	●			●																
News Director	●	x	●			●																
Interim Public Information Recovery Manager	●	x	●			●																
Public Information Recovery Mgr.	●	x	●			●																●
Public Information Specialist	●	x	●			●																
Technical Advisor to the Public Information Recovery Manager		*																				
Technical Advisor to the News Director	●					●																

x = As Needed  
\* = DCPD Course EPD 500

PACIFIC GAS and ELECTRIC COMPANY  
CORPORATE EMERGENCY RESPONSE PLAN

<b>PG&amp;E</b>	<b>IMPLEMENTING PROCEDURE</b>	NUMBER: 2.2
		REVISION: 1
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		ATTACHMENT: 2
		DATE: 01/13/84
		PAGE 05 OF 18

CERO Personnel Classroom Training Requirements  
\*LAW DEPARTMENT (CERP IP 3.3)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER
Corporate Law Department Coord.	201
	202
	203
	204
	210
	215
	220
	225
	230
	235
	240
	245
	250
	255
	260
Onsite Attorney	265
	270
	275
Staff Members	280
	285
	290











<b>PG-E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 10 OF 18
IMPLEMENTING PROCEDURE		
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	

CERO Personnel Classroom Training Requirements  
\*MATERIALS DEPARTMENT (CERP IP 4.1)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																				
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290
Corporate Materials Coordinator	●											●									●
Procurement Coordinator	●											●									
Transportation Coordinator	●											●									



<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 12 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERO Personnel Classroom Training Requirements  
 \*RADIOLOGICAL ANALYSIS AND PROTECTION GROUP (CERP IP 4.3)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																						
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290		
Radiological Emergency Recovery Manager	●	x												●				●				●	
Emergency Supervising Engineer	●	x												●									
Radiological Monitoring Director	●	x												●									
CIRC EARS Operator	●	x												●									
EOF EARS Operator	●	x												●									
Supervising Meteorologist	●	x												●									
Near Site Meteorologist	●	x												●									
General Office Meteorologist	●	x												●									
DER Laboratory Director	●	x												●									
EOF Secretary	●	x												●									
UDAC Liaison	●	x												●									
EOF Administrative Staff	●													●									

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 13 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERO Personnel Classroom Training Requirements  
 \*GENERAL CONSTRUCTION DEPARTMENT (CERP IP 4.4)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corporate Construction Coordinator	●															●						●
Site Construction Coordinator	●															●						
Manager, Line Department	●															●						
Manager, Civil-Hydro Department	●															●						
Manager, Gas-Mechanical Services Department	●															●						
Manager, Personnel and Clerical Services Department	●															●						

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 14 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	

CERO Personnel Classroom Training Requirements  
 \*ENGINEERING DEPARTMENT (CERP IP 4.5)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corporate Engineering Coordinator	●															●						●
Chief, Design Drafting	●															●						
Chief Mechanical and Nuclear Engineer	●															●						
Chief Electrical Engineering	●															●						
Chief Civil Engineering	●															●						

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 15 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERO Personnel Classroom Training Requirements  
 \*COMPUTER SYSTEMS AND SERVICES DEPARTMENT (CERP IP 4.6)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corporate Computer Applications Coordinator	●																●					●
Supervising Engineering Computer Applications Specialist	●																●					
Supervising Computer Technology Specialist	●																●					
Supervising Computer Operations Specialist	●																●					
Supervising Information Systems Specialist	●																●					
Administrative Support Coordinator	●																●					
Information Systems Specialist	●																●					
Materials Management Software Specialist	●																●					
Nuclear Records Management Specialist	●																●					
Emergency Computer Applications Functional Specialist	●																●					
Time Sharing Operations Processing Resource Specialist	●																●					
Computer Technology Software Specialist	●																●					
Computer Operations Shift Supervisors	●																●					



<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 16 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERC Personnel Classroom Training Requirements  
 \*NUCLEAR PLANT OPERATIONS DEPARTMENT (CERP IP 4.7)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Recovery Manager	●	x																	●			●
Corporate Liaison Coordinator	●	x		●															●			●
Corporate Technical and Logistical Coordinator	●	x																	●			●
Operations and Analytical Recovery Manager	●	x																	●			●
Radiological Emergency Recovery Manager	●	x												●					●			●
Engineering and Logistics Recovery	●	x																	●			●
Emergency Personnel Access Coordinator	●																		●			

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2
	<b>IMPLEMENTING PROCEDURE</b>	REVISION: 1
TITLE	EMERGENCY PREPAREDNESS TRAINING PROGRAM	ATTACHMENT: 2
		DATE: 01/13/84
		PAGE 17 OF 18

CERO Personnel Classroom Training Requirements  
\*DIVISION SUPPORT GROUP (CERP IP 4.8)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corporate Division Coordinator	●	x																	●	●		

x = As Needed

<b>PG&amp;E</b>	PACIFIC GAS and ELECTRIC COMPANY CORPORATE EMERGENCY RESPONSE PLAN	NUMBER: 2.2 REVISION: 1 ATTACHMENT: 2 DATE: 01/13/84 PAGE 18 OF 18
<b>IMPLEMENTING PROCEDURE</b>		
TITLE EMERGENCY PREPAREDNESS TRAINING PROGRAM		

CERO Personnel Classroom Training Requirements  
 \*QUALITY ASSURANCE DEPARTMENT (CERP IP 4.9)\*

EMERGENCY PLAN TITLE	EMERGENCY PREPAREDNESS COURSE (EPG) NUMBER																					
	201	202	203	204	210	215	220	225	230	235	240	245	250	255	260	265	270	275	280	285	290	
Corporate Quality Assurance Coordinator	●																				●	●
Records Management Coordinator	●																				●	
Senior Quality Engineer - Program Development	●																				●	
Senior Quality Engineer - Auditing	●																				●	
Quality Assurance Supervisor	●																				●	
Design Drafting Records Coordinator	●																				●	

CERTIFICATION OF SELF-TRAINING COMPLETION

The Corporate Emergency Response Plan Implementing Procedure 2.2, "Emergency Preparedness Training Program" makes provision for personnel with responsibilities assigned to them in the Corporate Emergency Response Organization to comply with the required training by certifying that they have:

1. Familiarized themselves with the "Nuclear Emergency Response Communications Directory" and its contents, and
2. Read their applicable CERP Implementing Procedure(s).

This "Certification of Self-Training Completion" is provided to document my completion of the above training requirements and that I have reviewed and understand the following CERP Implementing Procedures:

<u>CERP IP</u> <u>NUMBER</u>	<u>REVISION</u> <u>NUMBER</u>	<u>CERP IMPLEMENTING PROCEDURE TITLE</u>
---------------------------------	----------------------------------	--

SIGNATURE \_\_\_\_\_ DATE \_\_\_\_\_

NAME (PRINTED) \_\_\_\_\_

CERO TITLE \_\_\_\_\_

Return to T. A. Mack, Rm. 1403, 77 Beale St.