



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

May 19, 1995

TVA-SQN-TS-95-07

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

) Docket Nos. 50-327
) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS)
CHANGE 95-07, "CONDITIONAL EXEMPTION TO END-OF-LIFE (EOL)
MODERATOR TEMPERATURE COEFFICIENT (MTC) SURVEILLANCE
MEASUREMENT"

In accordance with 10 CFR 50.90, we are enclosing an amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed TS change will conditionally exempt the EOL MTC measurement required in TS Surveillance Requirement 4.1.1.3. Complementary changes to the administrative section of the TS are also provided. This change is similar to that proposed by D.C. Cook Nuclear Plant on July 26, 1994.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant safety hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3. Enclosure 4 provides a draft with the necessary changes to the Core Operating Limits Report for Units 1 and 2. The Westinghouse Electric Corporation Safety Evaluation Check List 93-117, R1 is supplied in Enclosure 5 for additional supporting documentation.

9505260208 950519
PDR ADDCK 05000327
P PDR

DD301

U.S. Nuclear Regulatory Commission

Page 2

May 19, 1995

SQN Unit 2 is expected to attain a boron concentration of 300 parts per million in November 1995. Therefore, TVA is requesting NRC approval prior to this time so the benefits afforded by this TS change can be utilized for this operating cycle.

TVA requests a 45-day implementation period for this TS change following issuance.

Please direct questions concerning this issue to W. C. Ludwig at (615) 843-7460.

Sincerely,

R. H. Shell

R. H. Shell
Manager
SQN Site Licensing

Sworn to and subscribed before me
this 19th day of May 1995

Gregg M. Billingsley
Notary Public

My Commission Expires Oct 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission
Page 3
May 19, 1995

(Enclosures):

Mr. D. E. LaBarge, Project Manager
Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
3rd Floor
L & C Annex
401 Church Street
Nashville, Tennessee 37243-1532

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711