

Jersey Central Power & Light Company

MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 539-6111

September 14, 1972

Mr. Frank E. Kruesi, Director
Directorate of Regulatory Operations
United States Atomic Energy Commission
Washington, D. C. 20545

Dear Mr. Kruesi:

Subject: Oyster Creek Station
Docket No. 50-219
Quarterly Personnel Exposures


Subsequent to my letter to you of August 10, 1972, subject as above, an internal audit of all personnel exposure calculations and records was completed. As a result, it was determined that an addition mistake was made for one individual and when corrected his total exposure for the quarterly period April 1, 1972 through June 30, 1972 was 3.060 rem.

The reason for this exposure and the corrective action being taken are the same as those reported to you in my letter of August 10, 1972.

The exposure of this individual by name is listed in Attachment A to this letter and the individual has been given written notification of his exposure.

We are enclosing 40 copies of this letter.

Very truly yours,


Ivan R. Finfrock, Jr.
Vice President

IRF:ss

Attachment

cc: Mr. J. P. O'Reilly, Director
Directorate of Regulatory Operations, Region 1

B303310282 730131
PDR ADOCK 05000219
PDR
G

50-219
inquiry

2 1313

Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 539-6111

April 3, 1973

Mr. Frank E. Kreusi, Director
Directorate of Regulatory Operations
United States Atomic Energy Commission
Washington, D. C. 20545

Dear Mr. Kreusi:

Subject: Oyster Creek Station
Docket No. 50-219
Additional Information/Personnel Overexposures

This letter is in response to your January 31, 1973 letter to Mr. Ivan R. Finfrock, Jr. requesting additional information regarding the results of our investigation into the overexposures reported to your office by letter dated August 10, 1972.

The special General Office Review Board investigation determined the major factors leading to this incident were the unexpectedly high radiation levels encountered and the unanticipated repair work associated with the plant shutdown. The incident resulted from the desire of some personnel involved to insure that the work required was properly performed to insure satisfactory performance of the plant and from the lack of a specifically defined and enforced radiation exposure limit (below the allowable level) at which the men should not have been permitted to work in radiation areas except under very close control.

The action taken to prevent similar exposures from reoccurring were as follows:

1. No person will be permitted to incur doses in excess of 2500 mrem whole body per calendar quarter without written authorization from the Manager, Nuclear Generating Stations. Persons so authorized will be subject to special control while accumulating any additional exposure.

2. A daily report, current as of the previous day, will be issued by the radiation protection group at Oyster Creek showing accumulative quarterly exposure of all personnel for which such exposure exceeds 1.25 rem whole body. The report will be distributed to all foremen, supervisors, the station superintendent, and the Manager, Nuclear Generating Stations. It contains the man's name, position, and controlling record of exposure. Station operating procedures have been changed to reflect all of the above items.

Very truly yours,

Donald A. Ross

Donald A. Ross
Manager, Nuclear Generating Stations

pk

cc: Mr. James P. O'Reilly
Mr. S. W. Porter

Handwritten: 50219

3 0131