

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

April 11, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station, Unit 1
Docket No. 50-413
Proof and Review Technical Specifications

Dear Mr. Denton:

In the Catawba SER on page 7-22 it is stated "until an acceptable circuit modification is installed, the staff will require Technical Specifications to include monthly tests (instead of quarterly) of any slave relay that has a proving lamp."

Please be advised that the required circuit modification will be installed prior to fuel load. Therefore, no change to the Technical Specifications will be required.

Very truly yours,

H.B. Tucker / HBT

Hal B. Tucker

RWO/php

cc: Mr. James P. O'Reilly
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert Guild, Esq.
Attorney-at-Law
P. O. Box 12097
Charleston, South Carolina 29205

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

8404240256 840411
PDR ADCK 05000413
E PDR

Boal 1/0