

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Docket Nos. 50-254, 50-265

Licenses No. DPR-29; DPR-30

Licensee: Commonwealth Edison Company
Post Office Box 767
Chicago, IL 60690

Facility Name: Quad Cities Nuclear Power Station

Examination Administered At: Quad Cities Nuclear Power Station

Examination Conducted: March 12-15, 1984

Examiners: *J. I. McMillen for*
T. Lang (Chief Examiner)

4/11/84
Date

J. I. McMillen for
W. Cliff

4/11/84
Date

Approved By: *J. I. McMillen*
J. I. McMillen, Chief
Operator Licensing Section

4/11/84
Date

Examination Summary

Examination administered on March 12-15, 1984

Written and oral examinations were administered to six SRO candidates.

Results: Of the six candidates five successfully passed the written and the oral examination and will be issued licenses.

DETAILS

1. Examiners

*T. Lang (NRC)
W. Cliff (PNL)

*Chief Examiner

2. Examination Review Meeting

At the conclusion of the written examination the examiners met with Messrs. J. Neal and W. Graham of the Training Department to review the written examination and answer key. All comments made concerning the answer key were for clarification only. No comments were made in regard to the questions.

3. Exit Meeting

At the conclusion of the site visit the examiners met with representatives of the plant staff to discuss the known results of the examination. Those individuals who clearly passed the oral examination were identified in this meeting.

The examiners stated that they considered the candidates' knowledge of electrical distribution to be a potential training program weakness. The licensee agreed to review this potential weakness.

U. S. NUCLEAR REGULATORY COMMISSION
 SENIOR REACTOR OPERATOR LICENSE EXAMINATION

M. J. C.

FACILITY: Quad-Cities
 REACTOR TYPE: BWR
 DATE ADMINISTERED: March 14, 1984
 EXAMINER: T. Lang
 APPLICANT: _____

INSTRUCTIONS TO APPLICANT:

Use separate paper for the answers. Write answers on one side only. Staple question sheet on top of the answer sheets. Points for each question are indicated in parentheses after the question. The passing grade requires at least 70% in each category and a final grade of at least 80%.

Category Value	% Of Total	Applicant's Score	% Of Category Value	Category
<u>25</u>	<u>25</u>	_____	_____	5. Theory of Nuclear Power Plant Operation, Fluids, and Thermodynamics
<u>25</u>	<u>25</u>	_____	_____	6. Plant Systems Design, Control, and Instrumentation
<u>25.5</u>	<u>25.5</u>	_____	_____	7. Procedures - Normal, Abnormal, Emergency, and Radiological Control
<u>24.5</u>	<u>24.5</u>	_____	_____	8. Administrative Procedures, Conditions, and Limitations
<u>100</u>	<u>100</u>	_____	_____	TOTALS

Final Grade _____ %

All work done on this exam is my own, I have neither given nor received aid.

 Applicant's Signature

5. Theory of Nuclear Power Plant Operations, Fluids, and Thermodynamics (25)

- 5.1 a. If your reactor had a doubling time of one minute, what would be the reactor period? (0.5)
- b. Using the point formula show how doubling time can be related to reactor period. (1.0)
- 5.2 Explain how rod worth will change for an increase in the following core parameters.
- a. Fuel temperature *Applicant told that* (1.0)
- b. Void content *Explain, must show and why!* (1.0)
- c. Core age *why!* (1.0)
- 5.3 a. Equilibrium Xenon implies that the Rate of Production = Rate of Removal. What is the source of each of these terms? (1.0)
- b. Explain how and why Xenon changes following a scram from full power. *Applicant told that need to be consistent & same* (2.0)
- 5.4 The reactor is exactly critical Low in the IRM range, when a control rod is withdrawn one notch.
- a. Describe what happens to indicated neutron level and why? (Continue your discussion until a steady state condition is reached. Assume no further operator action other than to up range the IRMs.) (1.0)
- b. Describe how reactor period would respond and why? (1.0)
- 5.5 How and why does the magnitude (reactivity added per change in degree F) of the Fuel Temperature Coefficient, Doppler, change given the following changes in core conditions:
- a. Core Age (BOL to EOL) (1.0)
- b. A significant increase in fuel temperature (1.0)
- c. A significant increase in core void fraction (1.0)
- 5.6 Define the following terms.
- a. Latent Heat of Vaporization (1.0)
- b. Enthalpy (0.5)
- 5.7 Assume the plant is at 100% power and flow. Explain why core flow would increase with a reduction in reactor power. (Assume constant recirc. pp. speed.) (1.5)

- 5.8 Explain the effects of increasing the following core parameters on steady state critical power.
- a. Core flow (0.5)
 - b. Inlet subcooling (0.5)
 - c. Reactor Pressure (0.5)

5.9 Does the centerline temperature of the fuel pin located closest to a control rod change when the control rod is moved when operating near full power? Explain your answer using general concepts of heat transfer. (2.0)

5.10 Reactor water level is maintained between a High limit and a Low limit. The High limit protects the turbine, and the Low limit protects the recirc. pumps. What are each of these limits protecting against? Be specific in your answer, explain all terms. *High limit is to prevent turbine from tripping and low limit is to prevent pumps from tripping.* (2.0)

5.11 a. Why is the feedwater at your plant heated prior to returning it to the vessel? (0.5)

b. In your feedwater heaters, cascading drains are used. Why isn't each heater drain just routed back to the condenser? (0.5)

- 5.12 What is the purpose or basis for the following limits?
- a. LHGR (1.0)
 - b. APLHGR (1.0)
 - c. MAPRAT (1.0)

These limits are to prevent the reactor from exceeding its design limits. LHGR is the maximum average power density, APLHGR is the maximum average power density in the core, and MAPRAT is the maximum average power density in the fuel assembly.

These limits are to prevent the reactor from exceeding its design limits.

6. Plant System Design, Control, and Instrumentation (25)
- 6.1 In regards to the HPCI system:
- a. Valves 35 and 36 (Torus suction valves) auto open and are interlocked open if either of two (2) conditions occur. What are these conditions? (1.0)
 - b. If either the 35 or the 36 valve is full open, valves 10, 15 and 49 auto close and are interlocked closed. Explain why. (1.0)
 - c. If both the 35 and the 36 valves are full open, the 6 valve (Suction from CST) auto closes, and is interlocked closed. Explain why. (1.0)
- 6.2 If the SBLC system were to be injected what are three methods which could be used to determine if it were actually injecting? (1.5)
- 6.3 a. The difference in speeds of the recirc. pumps is limited based on power level. What are these limits? (1.0)
- b. Give two (2) reason for these limits. (1.0)
- 6.4 a. Assume that the station is on-line at 50% power. Describe the resultant effect of lowering the load limit to 40%. (1.0)
- b. What is the intent or purpose of the max combined flow limit? (1.0)
- c. What is the setting of the max combined flow limit during a normal unit startup? (0.5)
- 6.5 In regards to the CRD system:
- a. Explain why you should close valve 305-101, control rod drive below piston isolation valve, before closing either valve 305-102 or 305-112 when isolating the CRD mechanism from the hydrolic module. (1.0)
 - b. Why should you not take an HCU out of service while at operating temperature and pressure. (1.0)
 - c. After a scram, the CRD pumps will attempt to charge all the accumulators at once. During these conditions, what prevents, the pump from going into "run out"? (1.0)
- 6.6 The RWM and the RBM are two systems which protect the fuel from damage during rod movement.

- a. Although similar, each protects fuel during different events. What event does each system protect against? (1.0)
- b. When is each system required to be in operation? Explain why. (2.0)
- 6.7 One of the flow units associated with the APXM's is inoperative.
- a. What automatic action will result from the inop. signal? (1.0)
- b. Other than an inop. What are two signals associated with the flow units which will cause the same auto action to occur as in part "a" above? (1.0)
- c. What are two (2) conditions which will cause an inop. trip of a flow unit? (1.0)
- 6.8 Concerning the 1/2 DG ON/OFF switch. (Answer each part as an individual question)
- a. What position(s) are the switches normally in, assuming 100% power and no system faults. (1.0)
- b. If both units experienced a loss of voltage, to which unit would the 1/2 DG close? Why. (1.0)
- c. If an undervoltage condition occurred on Unit 1, and the 1/2 DG closed to Unit 1, what affect if any would there be if the Unit 1 on/off switch were placed in the ON position. Explain your answer. *What does switch do - no answer* (1.0)
- 6.9 If a feedwater heater were taken out of service; generator output should be reduced. What is the basis for dropping or limiting MW output? (1.0)
- 6.10 What are four of the five interlocks which must be satisfied in order to have an Auto Start permissive for a BFP? (2.0)
- 6.11 In order to place a Limitorque Operator in manual it is necessary to trip the feed breaker, then disconnect the motor from the hand wheel by pressing the clutch lever. Once in manual how is it return to automatic. (1.0)

7. Procedures - Normal, Abnormal, Emergency, and Radiological Control (25.5)
- 7.1 According to QCP 1-1 "Normal Unit Startup" the use of the Notch Override switch is limited.
- a. When is Notch Override Not allowed? (2.0)
 - b. Why is it necessary to limit the use of Notch Override? Explain. (2.0)
- 7.2 Reactor Vessel Pressurization requires that the pressure regulator setpoint be maintained higher than reactor pressure.
- a. How much higher is the setpoint maintained? (1.0)
 - b. If this setpoint were not maintained higher than reactor pressure what could occur? Explain. (1.0)
- 7.3 What are four (4) of five (5) steps which must be performed prior to transferring the mode switch to "Run"? (2.0)
- 7.4 a. If an ATWS Event were to occur there would be two indications which would be the key to recognition of the event. What are these two indications? (1.0)
- b. How does an "ATWS Event" differ from a "Failure of Control Rods to Insert During a Scram"? *only* (2.0)
- 7.5 What are ~~five~~ immediate operator actions required for a gross fuel failure? (2.5)
- 7.6 According to QGA T1 "Threat of Loss of Reactor Shutdown or Cooling Capability Flow Diagram." What are four actions or methods to scram the reactor other than Automatically? (2.0)
- 7.7 For the following torus temperatures what action (8) must be performed? (2.0)
- a. 95°
 - b. 101° ← *Temp*
 - c. 110°
 - d. 120° *base temp*
- 7.8 According to your procedure for "High Airborne Activity" the immediate actions require you to start service air compressor 2-4601 and stop service air compressors 1A-4601 and 1B-4601. Why is this done? (1.0)

- 7.9 a. What are two actions ~~are~~ required when a loss of feedwater heaters occurs. (Assume multiple heaters). *Assume that...* (1)
- b. Why is each action performed? *Assuming!* (1.0)
- 7.10 If the following fire protection equipment were found to be inoperative what action(s) would be necessary? Assume individual failures.
- a. Unit 2 HPCI Sprinkler System. (0.5)
- b. Unit 2 Cable Tunnel Sprinkles System. (0.5)
- c. CO₂ system in DG room. (0.5)
- d. Fire stop protecting safety related area not intact. (0.5)
- 7.11 If a Turbine Runback were to occur due to a loss of Stator Cooling.
- a. What signals will initiate a stator cooling runback. (1.5)
- b. The immediate action required would be different depending on the conductivity prior to the loss of the Stator Cooling System. Explain how a change in conductivity changes the required actions. (1.5)

8. Administrative Procedures, Conditions and Limitations (24.5)
- 8.1 In regards to Temporary Changes to Procedures:
- a. Who must concur with Temporary changes to operating procedures which do not change the intent of the permanent procedure? (1.0)
 - b. What are three guidelines used to determine if the intent of a procedure is changed? (1.5)
 - c. If the authorizing personnel needed to change an operating procedure are available can they authorize or sign concurrence to temporary procedures dealing in other areas, such as maintenance, technical staff, or security? (1.0)
- 8.2 In accordance to procedure QAP 1150-2 "Access to the Drywell or Suppression Chamber" four conditions must exist simultaneously in order for access to the Drywell to be unlimited. What are these conditions? *do not list RP requirements* (2.0)
- 8.3 Other than the on-shift personnel who by title is allowed unlimited access to the control room? (Five required for full credit.) (2.5)
- 8.4 The operations department has control of "S", "R", and "V" keys.
- a. What is the function or purpose of each key? (1.5)
 - b. Five "V" keys are distributed to on-shift personnel. How many, and to whom are the keys assigned? (0.5)
- 8.5 Who by title makes up the on-shift fire brigade? (2.0)
- 8.6 a. According to QEP 360-4 who has the authority to recommend the use of KI Tablets? (1.0)
- b. During normal operation where are these tablets located? (0.5)
- 8.7 a. How is coupling integrity verified for each withdrawn control rod, after a refueling outage. (2.0)
- b. Why are control rod withdrawal sequences established? (1.0)
- 8.8 What is the basis for the following scrams?
- a. Condenser Low Vacuum. (1.0)
 - b. Turbine Stop Valve Closure. (1.0)
 - c. Main Steamline Isolation Valve Closure. (1.0)

8.9 Explain what is meant by the following terms.

- a. Instrument Calibration (1.0)
- b. Instrument Functional Test (1.0)
- c. Instrument Check. (1.0)

8.10 When a system is determined inoperable solely because its emergency or normal power source is inoperable, it may be considered operable for the purpose of satisfying the requirements of its Limiting Conditions for Operations, provided what two (2) conditions are met? (2.0)

$$f = ma$$

$$v = s/t$$

$$\text{Cycle efficiency} = (\text{Network out})/(\text{Energy in})$$

$$w = mg$$

$$s = V_0 t + 1/2 at^2$$

$$E = mc^2$$

$$KE = 1/2 mv^2$$

$$a = (V_f - V_0)/t$$

$$A = \lambda N$$

$$A = A_0 e^{-\lambda t}$$

$$PE = mgh$$

$$V_f = V_0 + at$$

$$w = \theta/t$$

$$\lambda = \ln 2 / t_{1/2} = 0.693 / t_{1/2}$$

$$t_{1/2}^{\text{eff}} = \frac{[(t_{1/2})(t_0)]}{[(t_{1/2}) + (t_0)]}$$

$$\Delta E = 931 \Delta m$$

$$I = I_0 e^{-\lambda x}$$

$$\dot{Q} = \dot{m} c_p$$

$$\dot{Q} = UA \Delta T$$

$$\text{Pwr} = W_f \Delta n$$

$$I = I_0 e^{-\mu x}$$

$$I = I_0 10^{-x/\text{TVL}}$$

$$\text{TVL} = 1.3/\mu$$

$$\text{HVL} = -0.693/\mu$$

$$P = P_0 10^{\text{SUR}(z)}$$

$$P = P_0 e^{z/T}$$

$$\text{SUR} = 26.06/T$$

$$\text{SCR} = S/(1 - K_{\text{eff}})$$

$$\text{CR}_x = S/(1 - K_{\text{eff}x})$$

$$\text{CR}_1(1 - K_{\text{eff}1}) = \text{CR}_2(1 - K_{\text{eff}2})$$

$$\text{SUR} = 26.0/z + (\beta - \rho)T$$

$$M = 1/(1 - K_{\text{eff}}) = \text{CR}_1/\text{CR}_0$$

$$M = (1 - K_{\text{eff}0})/(1 - K_{\text{eff}1})$$

$$\text{SDM} = (1 - K_{\text{eff}})/K_{\text{eff}}$$

$$z^* = 10^{-4} \text{ seconds}$$

$$\bar{\lambda} = 0.1 \text{ seconds}^{-1}$$

$$T = (z^*/\rho) + [(1 - \rho)/\lambda \rho]$$

$$T = z/(\rho - \beta)$$

$$T = (\beta - \rho)/(\lambda \rho)$$

$$\rho = (K_{\text{eff}} - 1)/K_{\text{eff}} = \Delta K_{\text{eff}}/K_{\text{eff}}$$

$$\rho = [(z^*/(T K_{\text{eff}}))] + [\bar{\lambda}_{\text{eff}}/(1 + \lambda T)]$$

$$P = (zeV)/(3 \times 10^{10})$$

$$z = eN$$

$$I_1 d_1 = I_2 d_2$$

$$I_1 d_1^2 = I_2 d_2^2$$

$$R/\text{hr} = (0.5 \text{ CE})/d^2 (\text{meters})$$

Water Parameters

$$1 \text{ gal.} = 8.345 \text{ lbm.}$$

$$1 \text{ gal.} = 3.78 \text{ liters}$$

$$1 \text{ ft}^3 = 7.48 \text{ gal.}$$

$$\text{Density} = 62.4 \text{ lbm/ft}^3$$

$$\text{Density} = 1 \text{ gm/cm}^3$$

$$\text{Heat of vaporization} = 970 \text{ Btu/lbm}$$

$$\text{Heat of fusion} = 144 \text{ Btu/lbm}$$

$$1 \text{ atm} = 14.7 \text{ psi} = 29.9 \text{ in. Hg.}$$

Miscellaneous Conversions

$$1 \text{ curie} = 3.7 \times 10^{10} \text{ dps}$$

$$1 \text{ kg} = 2.21 \text{ lbm}$$

$$1 \text{ hp} = 2.54 \times 10^3 \text{ Btu/hr}$$

$$1 \text{ mw} = 3.41 \times 10^6 \text{ Btu/hr}$$

$$1 \text{ in} = 2.54 \text{ cm}$$

$$^\circ\text{F} = 9/5^\circ\text{C} + 32$$

$$^\circ\text{C} = 5/9 (^\circ\text{F} - 32)$$

Table 1. Saturated Steam: Temperature Table

Temp Fahr t	Abs Press Lb per Sq in p	Specific Volume			Enthalpy			Entropy			Temp Fahr t
		Sat Liquid v _l	Evap v _{lg}	Sat Vapor v _g	Sat Liquid h _l	Evap h _{lg}	Sat Vapor h _g	Sat Liquid s _l	Evap s _{lg}	Sat Vapor s _g	
32 F	0.08555	0.016022	3304.7	3304.7	-0.0175	1075.5	1075.5	0.0000	2.1873	2.1873	32 F
34 F	0.09600	0.016021	3061.9	3061.9	1.996	1074.4	1076.4	0.0041	2.1762	2.1802	34 F
36 F	0.10295	0.016020	2839.0	2839.0	4.008	1073.2	1077.2	0.0081	2.1651	2.1732	36 F
38 F	0.11249	0.016019	2634.1	2634.2	6.018	1072.1	1078.1	0.0122	2.1541	2.1663	38 F
40 F	0.12163	0.016019	2445.8	2445.8	8.027	1071.0	1079.0	0.0162	2.1432	2.1564	40 F
42 F	0.13143	0.016019	2272.4	2272.4	10.035	1069.8	1079.9	0.0201	2.1325	2.1527	42 F
44 F	0.14191	0.016019	2112.8	2112.8	12.041	1068.7	1080.7	0.0242	2.1217	2.1459	44 F
46 F	0.15314	0.016020	1965.7	1965.7	14.047	1067.6	1081.6	0.0282	2.1111	2.1395	46 F
48 F	0.16514	0.016021	1830.0	1830.0	16.051	1066.4	1082.5	0.0321	2.1006	2.1327	48 F
50 F	0.17796	0.016023	1704.8	1704.8	18.054	1065.3	1083.4	0.0361	2.0901	2.1262	50 F
52 F	0.19165	0.016024	1589.7	1589.7	20.057	1064.2	1084.2	0.0400	2.0798	2.1197	52 F
54 F	0.20625	0.016026	1484.4	1484.4	22.058	1063.1	1085.1	0.0439	2.0695	2.1134	54 F
56 F	0.22183	0.016028	1383.6	1383.6	24.058	1061.9	1086.0	0.0478	2.0593	2.1070	56 F
58 F	0.23843	0.016031	1292.2	1292.2	26.057	1060.8	1086.9	0.0516	2.0491	2.1008	58 F
60 F	0.25611	0.016033	1207.6	1207.6	28.055	1059.7	1087.7	0.0555	2.0391	2.0946	60 F
62 F	0.27494	0.016036	1129.2	1129.2	30.052	1058.5	1088.6	0.0593	2.0291	2.0885	62 F
64 F	0.29497	0.016039	1056.5	1056.5	32.048	1057.4	1089.5	0.0632	2.0192	2.0824	64 F
66 F	0.31626	0.016043	989.0	989.0	34.043	1056.3	1090.4	0.0670	2.0094	2.0764	66 F
68 F	0.33885	0.016048	926.5	926.5	36.037	1055.2	1091.2	0.0708	1.9996	2.0704	68 F
70 F	0.36277	0.016053	868.9	868.9	38.030	1054.0	1092.1	0.0746	1.9900	2.0645	70 F
72 F	0.38804	0.016059	816.3	816.3	40.022	1052.9	1093.0	0.0783	1.9805	2.0587	72 F
74 F	0.41468	0.016066	767.4	767.4	42.013	1051.8	1093.8	0.0821	1.9711	2.0529	74 F
76 F	0.44270	0.016073	722.4	722.4	44.003	1050.7	1094.7	0.0858	1.9618	2.0472	76 F
78 F	0.47211	0.016081	681.4	681.4	46.000	1049.5	1095.6	0.0895	1.9526	2.0415	78 F
80 F	0.50293	0.016089	643.3	643.3	48.000	1048.4	1096.4	0.0932	1.9436	2.0359	80 F
82 F	0.53518	0.016097	608.1	608.1	50.000	1047.3	1097.3	0.0969	1.9346	2.0303	82 F
84 F	0.57000	0.016106	575.8	575.8	52.000	1046.1	1098.2	0.1006	1.9257	2.0248	84 F
86 F	0.60741	0.016115	546.3	546.3	54.000	1045.0	1099.0	0.1043	1.9169	2.0193	86 F
88 F	0.64754	0.016125	519.6	519.6	56.000	1043.9	1099.9	0.1079	1.9082	2.0139	88 F
90 F	0.69041	0.016135	495.7	495.7	58.000	1042.7	1100.8	0.1115	1.8996	2.0085	90 F
92 F	0.73614	0.016146	474.5	474.5	60.000	1041.6	1101.6	0.1151	1.8911	2.0031	92 F
94 F	0.78475	0.016157	455.9	455.9	62.000	1040.5	1102.5	0.1187	1.8827	1.9978	94 F
96 F	0.83628	0.016169	439.8	439.8	64.000	1039.3	1103.3	0.1224	1.8744	1.9926	96 F
98 F	0.89076	0.016181	426.1	426.1	66.000	1038.2	1104.2	0.1260	1.8662	1.9876	98 F
100 F	0.94823	0.016193	414.7	414.7	68.000	1037.1	1105.1	0.1296	1.8581	1.9826	100 F
102 F	1.00874	0.016206	405.3	405.3	69.995	1035.9	1105.9	0.1331	1.8501	1.9776	102 F
104 F	1.07233	0.016219	397.7	397.7	71.990	1034.8	1106.8	0.1366	1.8421	1.9726	104 F
106 F	1.13905	0.016233	391.7	391.7	73.985	1033.6	1107.6	0.1401	1.8342	1.9676	106 F
108 F	1.20895	0.016247	387.1	387.1	75.978	1032.5	1108.5	0.1437	1.8264	1.9626	108 F
110 F	1.28208	0.016262	383.7	383.7	77.969	1031.4	1109.3	0.1472	1.8186	1.9577	110 F
112 F	1.35848	0.016277	381.3	381.3	79.958	1030.3	1110.2	0.1507	1.8109	1.9527	112 F
114 F	1.43819	0.016292	379.8	379.8	81.945	1029.3	1111.0	0.1542	1.8033	1.9478	114 F
116 F	1.52125	0.016308	379.1	379.1	83.929	1028.2	1111.9	0.1577	1.7958	1.9429	116 F
118 F	1.60770	0.016324	379.1	379.1	85.910	1027.2	1112.7	0.1611	1.7884	1.9380	118 F
120 F	1.69758	0.016341	379.7	379.7	87.889	1026.1	1113.6	0.1646	1.7811	1.9331	120 F
122 F	1.79093	0.016358	380.9	380.9	89.866	1025.0	1114.4	0.1680	1.7739	1.9282	122 F
124 F	1.88779	0.016376	382.7	382.7	91.841	1023.9	1115.3	0.1715	1.7668	1.9233	124 F
126 F	1.98820	0.016394	385.1	385.1	93.814	1022.8	1116.1	0.1749	1.7598	1.9184	126 F
128 F	2.09220	0.016413	388.1	388.1	95.785	1021.7	1117.0	0.1783	1.7529	1.9135	128 F
130 F	2.20000	0.016432	391.7	391.7	97.754	1020.6	1117.8	0.1817	1.7461	1.9086	130 F
132 F	2.31173	0.016452	395.9	395.9	99.721	1019.5	1118.6	0.1851	1.7393	1.9037	132 F
134 F	2.42752	0.016472	399.7	399.7	101.686	1018.4	1119.5	0.1885	1.7326	1.8988	134 F
136 F	2.54740	0.016493	404.1	404.1	103.649	1017.3	1120.3	0.1919	1.7260	1.8939	136 F
138 F	2.67150	0.016514	409.1	409.1	105.610	1016.2	1121.1	0.1953	1.7194	1.8890	138 F
140 F	2.80000	0.016536	414.7	414.7	107.569	1015.1	1122.0	0.1987	1.7129	1.8841	140 F
142 F	2.93390	0.016558	420.9	420.9	109.526	1014.0	1122.8	0.2021	1.7064	1.8792	142 F
144 F	3.07330	0.016581	427.7	427.7	111.481	1012.9	1123.6	0.2055	1.7000	1.8743	144 F
146 F	3.21830	0.016604	435.1	435.1	113.434	1011.8	1124.5	0.2089	1.6936	1.8694	146 F
148 F	3.36900	0.016628	443.1	443.1	115.385	1010.7	1125.3	0.2123	1.6873	1.8645	148 F
150 F	3.52550	0.016652	451.7	451.7	117.334	1009.6	1126.1	0.2157	1.6811	1.8596	150 F
152 F	3.68800	0.016677	460.9	460.9	119.281	1008.5	1126.9	0.2191	1.6749	1.8547	152 F
154 F	3.85650	0.016702	470.7	470.7	121.226	1007.4	1127.7	0.2225	1.6688	1.8498	154 F
156 F	4.03100	0.016728	481.1	481.1	123.169	1006.3	1128.5	0.2259	1.6627	1.8449	156 F
158 F	4.21150	0.016754	492.1	492.1	125.110	1005.2	1129.4	0.2293	1.6567	1.8400	158 F
160 F	4.39800	0.016781	503.7	503.7	127.049	1004.1	1130.2	0.2327	1.6507	1.8351	160 F
162 F	4.59050	0.016808	515.9	515.9	128.986	1003.0	1131.0	0.2361	1.6447	1.8302	162 F
164 F	4.78900	0.016836	528.7	528.7	130.921	1001.9	1131.8	0.2395	1.6388	1.8253	164 F
166 F	4.99350	0.016864	542.1	542.1	132.854	1000.8	1132.6	0.2429	1.6329	1.8204	166 F
168 F	5.20400	0.016893	556.1	556.1	134.785	999.7	1133.4	0.2463	1.6270	1.8155	168 F
170 F	5.42050	0.016922	570.7	570.7	136.714	998.6	1134.2	0.2497	1.6211	1.8106	170 F
172 F	5.64300	0.016952	585.9	585.9	138.641	997.5	1135.0	0.2531	1.6153	1.8057	172 F
174 F	5.87150	0.016982	601.7	601.7	140.566	996.4	1135.8	0.2565	1.6095	1.8008	174 F
176 F	6.10600	0.017013	618.1	618.1	142.489	995.3	1136.6	0.2599	1.6037	1.7959	176 F
178 F	6.34650	0.017044	635.1	635.1	144.410	994.2	1137.4	0.2633	1.5980	1.7910	178 F

Table 1. Saturated Steam: Temperature Table—Continued

Temp Fahr t	Abs Press Lb per Sq in p	Specific Volume			Enthalpy			Entropy			Temp Fahr t
		Sat Liquid v _l	Evap v _{lg}	Sat Vapor v _g	Sat Liquid h _l	Evap h _{lg}	Sat Vapor h _g	Sat Liquid s _l	Evap s _{lg}	Sat Vapor s _g	
180.0	7.5110	0.016510	50.21	50.22	148.00	990.2	1138.2	0.2631	1.5480	1.8111	180.0
181.0	7.850	0.016522	48.172	18.185	150.01	985.0	1139.0	0.2667	1.5413	1.8075	181.0
182.0	8.203	0.016534	46.237	46.249	152.01	981.8	1139.8	0.2694	1.5346	1.8040	182.0
183.0	8.568	0.016547	44.383	44.400	154.02	978.5	1140.5	0.2725	1.5279	1.8004	183.0
184.0	8.947	0.016559	42.621	42.638	156.03	985.3	1141.3	0.2756	1.5213	1.7969	184.0
185.0	9.340	0.016572	40.941	40.957	158.04	984.1	1142.1	0.2787	1.5148	1.7934	185.0
186.0	9.747	0.016585	39.331	39.354	160.05	982.8	1142.9	0.2818	1.5082	1.7900	186.0
187.0	10.168	0.016598	37.801	37.824	162.05	981.6	1143.7	0.2848	1.5017	1.7865	187.0
188.0	10.605	0.016611	36.348	36.364	164.06	980.4	1144.4	0.2879	1.4952	1.7831	188.0
189.0	11.058	0.016624	34.954	34.970	166.08	979.1	1145.2	0.2910	1.4888	1.7798	189.0
190.0	11.526	0.016637	33.622	33.639	168.09	977.9	1146.0	0.2940	1.4824	1.7764	190.0
191.0	12.011	0.016650	31.135	31.151	172.11	975.4	1147.5	0.3001	1.4697	1.7698	191.0
192.0	12.568	0.016663	29.861	29.878	176.14	972.8	1149.0	0.3061	1.4571	1.7632	192.0
193.0	13.191	0.016675	28.787	28.796	180.17	970.3	1150.5	0.3121	1.4447	1.7568	193.0
194.0	13.881	0.016688	27.878	27.884	184.20	967.8	1152.0	0.3181	1.4323	1.7505	194.0
195.0	14.640	0.016700	27.131	27.148	188.23	965.2	1153.4	0.3241	1.4201	1.7442	195.0
196.0	15.470	0.016712	26.529	26.545	192.27	962.6	1154.9	0.3300	1.4081	1.7380	196.0
197.0	16.375	0.016724	26.063	26.073	196.31	960.0	1156.3	0.3359	1.3961	1.7320	197.0
198.0	17.358	0.016736	25.721	25.718	200.35	957.4	1157.8	0.3417	1.3842	1.7260	198.0
199.0	18.421	0.016748	25.454	25.451	204.40	954.8	1159.2	0.3476	1.3725	1.7201	199.0
200.0	19.576	0.016760	25.254	25.261	208.45	952.1	1160.6	0.3533	1.3609	1.7142	200.0
201.0	20.825	0.016772	25.113	25.120	212.50	949.5	1162.0	0.3591	1.3494	1.7085	201.0
202.0	22.170	0.016784	25.021	25.028	216.56	946.8	1163.4	0.3649	1.3379	1.7028	202.0
203.0	23.613	0.016796	24.978	24.985	220.62	944.1	1164.7	0.3706	1.3266	1.6972	203.0
204.0	25.157	0.016808	24.982	24.989	224.69	941.4	1166.1	0.3763	1.3154	1.6917	204.0
205.0	26.804	0.016820	25.034	25.041	228.76	938.7	1167.4	0.3819	1.3043	1.6862	205.0
206.0	28.557	0.016832	25.133	25.140	232.83	935.9	1168.7	0.3876	1.2932	1.6808	206.0
207.0	30.419	0.016844	25.278	25.285	236.91	933.1	1170.0	0.3932	1.2822	1.6755	207.0
208.0	32.394	0.016856	25.469	25.476	240.99	930.3	1171.3	0.3987	1.2713	1.6702	208.0
209.0	34.485	0.016868	25.705	25.712	245.08	927.5	1172.5	0.4042	1.2607	1.6650	209.0
210.0	36.705	0.016880	26.000	26.007	249.17	924.6	1173.8	0.4097	1.2503	1.6598	210.0
211.0	39.057	0.016892	26.361	26.368	253.27	921.7	1175.0	0.4152	1.2399	1.6548	211.0
212.0	41.544	0.016904	26.794	26.801	257.37	918.8	1176.2	0.4207	1.2297	1.6498	212.0
213.0	44.169	0.016916	27.307	27.314	261.48	915.8	1177.4	0.4262	1.2196	1.6449	213.0
214.0	46.935	0.016928	27.900	27.907	265.6	912.8	1178.6	0.4317	1.2096	1.6400	214.0
215.0	49.845	0.016940	28.582	28.589	269.7	909.7	1179.7	0.4372	1.1996	1.6351	215.0
216.0	52.902	0.016952	29.353	29.360	273.8	906.6	1180.9	0.4426	1.1897	1.6303	216.0
217.0	56.118	0.016964	30.214	30.221	277.9	903.4	1182.0	0.4479	1.1798	1.6256	217.0
218.0	59.496	0.016976	31.165	31.172	282.0	900.2	1183.1	0.4532	1.1699	1.6209	218.0
219.0	63.038	0.016988	32.206	32.213	286.1	897.0	1184.1	0.4585	1.1600	1.6162	219.0
220.0	66.747	0.017000	33.337	33.344	290.2	893.8	1185.2	0.4638	1.1501	1.6116	220.0
221.0	70.627	0.017012	34.558	34.565	294.3	890.6	1186.2	0.4691	1.1402	1.6071	221.0
222.0	74.681	0.017024	35.869	35.876	298.4	887.4	1187.2	0.4744	1.1303	1.6026	222.0
223.0	78.913	0.017036	37.270	37.277	302.5	884.2	1188.2	0.4797	1.1204	1.5981	223.0
224.0	83.327	0.017048	38.761	38.768	306.6	881.0	1189.2	0.4850	1.1105	1.5936	224.0
225.0	87.927	0.017060	40.342	40.349	310.7	877.8	1190.2	0.4902	1.1006	1.5891	225.0
226.0	92.716	0.017072	42.013	42.020	314.8	874.6	1191.2	0.4955	1.0907	1.5846	226.0
227.0	97.698	0.017084	43.774	43.781	318.9	871.4	1192.2	0.5007	1.0808	1.5801	227.0
228.0	102.876	0.017096	45.625	45.632	323.0	868.2	1193.2	0.5060	1.0709	1.5756	228.0
229.0	108.253	0.017108	47.566	47.573	327.1	865.0	1194.2	0.5112	1.0610	1.5711	229.0
230.0	113.833	0.017120	49.597	49.604	331.2	861.8	1195.2	0.5165	1.0511	1.5666	230.0
231.0	119.619	0.017132	51.718	51.725	335.3	858.6	1196.2	0.5217	1.0412	1.5621	231.0
232.0	125.614	0.017144	53.929	53.936	339.4	855.4	1197.2	0.5270	1.0313	1.5576	232.0
233.0	131.821	0.017156	56.230	56.237	343.5	852.2	1198.2	0.5322	1.0214	1.5531	233.0
234.0	138.243	0.017168	58.621	58.628	347.6	849.0	1199.2	0.5375	1.0115	1.5486	234.0
235.0	144.883	0.017180	61.102	61.109	351.7	845.8	1200.2	0.5427	1.0016	1.5441	235.0
236.0	151.744	0.017192	63.673	63.680	355.8	842.6	1201.2	0.5480	0.9917	1.5396	236.0
237.0	158.829	0.017204	66.334	66.341	359.9	839.4	1202.2	0.5532	0.9818	1.5351	237.0
238.0	166.141	0.017216	69.085	69.092	364.0	836.2	1203.2	0.5585	0.9719	1.5306	238.0
239.0	173.683	0.017228	71.926	71.933	368.1	833.0	1204.2	0.5637	0.9620	1.5261	239.0
240.0	181.459	0.017240	74.857	74.864	372.2	829.8	1205.2	0.5690	0.9521	1.5216	240.0
241.0	189.473	0.017252	77.878	77.885	376.3	826.6	1206.2	0.5742	0.9422	1.5171	241.0
242.0	197.728	0.017264	80.989	80.996	380.4	823.4	1207.2	0.5795	0.9323	1.5126	242.0
243.0	206.227	0.017276	84.190	84.197	384.5	820.2	1208.2	0.5847	0.9224	1.5081	243.0
244.0	214.974	0.017288	87.481	87.488	388.6	817.0	1209.2	0.5900	0.9125	1.5036	244.0
245.0	223.971	0.017300	90.862	90.869	392.7	813.8	1210.2	0.5952	0.9026	1.4991	245.0
246.0	233.221	0.017312	94.333	94.340	396.8	810.6	1211.2	0.6005	0.8927	1.4946	246.0
247.0	242.727	0.017324	97.894	97.901	400.9	807.4	1212.2	0.6057	0.8828	1.4901	247.0
248.0	252.492	0.017336	101.545	101.552	405.0	804.2	1213.2	0.6110	0.8729	1.4856	248.0
249.0	262.419	0.017348	105.286	105.293	409.1	801.0	1214.2	0.6162	0.8630	1.4811	249.0
250.0	272.510	0.017360	109.117	109.124	413.2	797.8	1215.2	0.6215	0.8531	1.4766	250.0
251.0	282.768	0.017372	113.038	113.045	417.3	794.6	1216.2	0.6267	0.8432	1.4721	251.0
252.0	293.196	0.017384	117.049	117.056	421.4	791.4	1217.2	0.6320	0.8333	1.4676	252.0
253.0	303.796	0.017396	121.150	121.157	425.5	788.2	1218.2	0.6372	0.8234	1.4631	253.0
254.0	314.570	0.017408	125.341	125.348	429.6	785.0	1219.2	0.6425	0.8135	1.4586	254.0
255.0	325.520	0.017420	129.622	129.629	433.7	781.8	1220.2	0.6477	0.8036	1.4541	255.0
256.0	336.648	0.017432	134.093	134.100	437.8	778.6	1221.2	0.6530	0.7937	1.4496	256.0
257.0	347.957	0.017444	138.754	138.761	441.9	775.4	1222.2	0.6582	0.7838	1.4451	257.0
258.0	359.449	0.017456	143.605	143.612	446.0	772.2	1223.2	0.6635	0.7739	1.4406	258.0
259.0	371.127	0.017468	148.646	148.653	450.1	769.0	1224.2	0.6687	0.7640	1.4361	259.0
260.0	382.993	0.017480	153.877	153.884	454.2	765.8	1225.2	0.6740	0.7541	1.4316	260.0
261.0	395.049	0.017492	159.298	159.305	458.3	762.6	1226.2	0.6792	0.7442	1.4271	261.0
262.0	407.297	0.017504	164.909	164.916	462.4	759.4	1227.2	0.6845	0.7343	1.4226	262.0
263.0	419.738	0.017516	170.610	170.617	466.5	756.2	1228.2	0.6897	0.7244	1.4181	263.0
264.0	432.374	0.017528	176.501	176.508	470.6	753.0	1229.2	0.6950	0.7145	1.4136	264.0
265.0	445.207	0.017540	182.582	182.589	474.7	749.8	1230.2	0.7002	0.7046	1.4091	265.0
266.0	458.239	0.017552	188.853	188.860	478.8	746.6	1231.2	0.7055	0.6947	1.4046	266.0
267.0	471.472	0.017564	195.314	195.321	482.9	743.4	1232.2	0.7107	0.6848	1.4001	267.0
268.0	484.908	0.01757									

Table 1. Saturated Steam: Temperature Table—Continued

Temp Fahr t	Abs Press Lb per Sq in p	Specific Volume			Enthalpy			Entropy			Temp Fahr t
		Sat Liquid v _f	Evap v _{fg}	Sat Vapor v _g	Sat Liquid h _f	Evap h _{fg}	Sat Vapor h _g	Sat Liquid s _f	Evap s _{fg}	Sat Vapor s _g	
462.0	466.87	0.01961	0.97463	0.99474	441.5	763.2	1204.8	0.6405	0.8795	1.4704	462.0
464.0	485.86	0.01969	0.95888	0.95557	441.1	758.6	1204.7	0.6454	0.8713	1.4667	464.0
466.0	504.83	0.01976	0.94885	0.91862	450.7	754.0	1204.6	0.6502	0.8127	1.4629	466.0
472.0	574.67	0.01984	0.86245	0.83379	455.2	749.3	1204.5	0.6551	0.8047	1.4592	472.0
476.0	545.11	0.01992	0.82958	0.84950	459.9	744.5	1204.3	0.6599	0.7956	1.4555	476.0
482.0	566.15	0.02000	0.79716	0.81717	464.5	739.6	1204.1	0.6648	0.7871	1.4518	482.0
484.0	587.81	0.02009	0.76513	0.78622	469.1	734.7	1203.8	0.6696	0.7785	1.4481	484.0
486.0	610.10	0.02017	0.73441	0.75658	473.8	729.7	1203.5	0.6745	0.7700	1.4444	486.0
488.0	633.03	0.02026	0.70494	0.72870	478.5	724.6	1203.1	0.6793	0.7614	1.4407	488.0
494.0	656.61	0.02034	0.68065	0.70100	483.2	719.5	1202.7	0.6842	0.7528	1.4370	494.0
500.0	680.86	0.02043	0.65448	0.67482	487.9	714.3	1202.2	0.6890	0.7443	1.4333	500.0
504.0	705.78	0.02053	0.62938	0.64991	492.7	709.0	1201.7	0.6939	0.7357	1.4296	504.0
508.0	731.40	0.02062	0.60530	0.62592	497.5	703.7	1201.1	0.6987	0.7271	1.4258	508.0
512.0	757.72	0.02072	0.58216	0.60289	502.3	698.2	1200.5	0.7036	0.7185	1.4221	512.0
516.0	784.76	0.02081	0.55997	0.58079	507.1	692.7	1199.8	0.7085	0.7099	1.4183	516.0
520.0	812.53	0.02091	0.53864	0.55956	512.0	687.0	1199.0	0.7133	0.7013	1.4146	520.0
524.0	841.04	0.02101	0.51814	0.53916	516.9	681.3	1198.2	0.7182	0.6926	1.4108	524.0
528.0	870.31	0.02112	0.49843	0.51955	521.8	675.5	1197.3	0.7231	0.6839	1.4070	528.0
532.0	900.34	0.02123	0.47947	0.50070	526.8	669.6	1196.4	0.7280	0.6752	1.4032	532.0
536.0	931.17	0.02134	0.46123	0.48257	531.7	663.6	1195.4	0.7329	0.6665	1.3993	536.0
540.0	962.79	0.02146	0.44367	0.46513	536.6	657.5	1194.3	0.7378	0.6577	1.3954	540.0
544.0	995.22	0.02157	0.42677	0.44834	541.5	651.3	1193.1	0.7427	0.6489	1.3915	544.0
548.0	1028.49	0.02169	0.41048	0.43217	546.5	645.0	1191.9	0.7476	0.6400	1.3876	548.0
552.0	1062.56	0.02181	0.39479	0.41660	551.5	638.5	1190.6	0.7525	0.6311	1.3837	552.0
556.0	1097.45	0.02194	0.37964	0.40160	557.2	632.0	1189.2	0.7575	0.6222	1.3797	556.0
560.0	1133.38	0.02207	0.36507	0.38714	562.4	625.3	1187.7	0.7625	0.6132	1.3757	560.0
564.0	1170.10	0.02221	0.35099	0.37320	567.6	618.5	1186.1	0.7674	0.6044	1.3716	564.0
568.0	1207.72	0.02235	0.33741	0.35975	572.9	611.5	1184.5	0.7725	0.5955	1.3675	568.0
572.0	1246.24	0.02249	0.32429	0.34678	578.3	604.5	1182.9	0.7775	0.5865	1.3634	572.0
576.0	1285.74	0.02264	0.31162	0.33426	583.7	597.2	1181.2	0.7825	0.5776	1.3592	576.0
580.0	1326.17	0.02279	0.29937	0.32216	589.1	589.9	1179.5	0.7876	0.5687	1.3550	580.0
584.0	1367.57	0.02295	0.28753	0.31048	594.6	582.4	1177.8	0.7927	0.5598	1.3507	584.0
588.0	1410.00	0.02311	0.27608	0.29919	600.1	574.7	1176.0	0.7978	0.5509	1.3464	588.0
592.0	1453.53	0.02327	0.26499	0.28827	605.7	566.8	1174.2	0.8030	0.5420	1.3420	592.0
596.0	1498.18	0.02345	0.25422	0.27770	611.4	558.8	1172.2	0.8082	0.5330	1.3375	596.0
600.0	1543.97	0.02364	0.24384	0.26747	617.1	550.6	1169.7	0.8134	0.5240	1.3330	600.0
604.0	1590.92	0.02383	0.23374	0.25757	622.9	542.2	1167.1	0.8187	0.5150	1.3284	604.0
608.0	1639.03	0.02403	0.22384	0.24799	628.8	533.6	1164.4	0.8240	0.5060	1.3238	608.0
612.0	1688.30	0.02423	0.21422	0.23869	634.8	524.7	1161.5	0.8294	0.4969	1.3191	612.0
616.0	1738.75	0.02444	0.20496	0.22960	640.8	515.6	1158.4	0.8348	0.4878	1.3144	616.0
620.0	1790.39	0.02466	0.19615	0.22081	646.9	506.3	1155.0	0.8403	0.4786	1.3097	620.0
624.0	1843.22	0.02489	0.18777	0.21224	653.1	496.6	1151.4	0.8458	0.4695	1.3049	624.0
628.0	1897.24	0.02514	0.17980	0.20394	659.5	486.7	1147.6	0.8514	0.4604	1.2999	628.0
632.0	1952.45	0.02539	0.17224	0.19591	666.0	476.4	1143.2	0.8571	0.4512	1.2948	632.0
636.0	2008.86	0.02566	0.16507	0.18819	672.4	465.7	1138.1	0.8628	0.4421	1.2895	636.0
640.0	2066.49	0.02593	0.15827	0.18072	679.1	454.6	1132.7	0.8686	0.4330	1.2841	640.0
644.0	2125.33	0.02621	0.15184	0.17349	685.9	443.1	1127.0	0.8745	0.4239	1.2786	644.0
648.0	2185.38	0.02650	0.14576	0.16634	692.9	431.1	1121.0	0.8804	0.4147	1.2730	648.0
652.0	2246.63	0.02680	0.13999	0.15916	700.0	418.7	1114.7	0.8864	0.4055	1.2673	652.0
656.0	2309.07	0.02711	0.13461	0.15195	707.4	405.7	1108.1	0.8925	0.3963	1.2615	656.0
660.0	2372.70	0.02743	0.12960	0.14471	714.9	392.1	1101.0	0.8987	0.3871	1.2556	660.0
664.0	2437.51	0.02776	0.12494	0.13744	722.9	377.7	1093.4	0.9050	0.3779	1.2495	664.0
668.0	2503.50	0.02811	0.12060	0.13017	731.5	362.7	1085.3	0.9113	0.3687	1.2433	668.0
672.0	2570.67	0.02847	0.11654	0.12274	740.2	347.1	1076.6	0.9177	0.3594	1.2369	672.0
676.0	2639.02	0.02884	0.11279	0.11519	749.2	330.9	1067.2	0.9242	0.3501	1.2304	676.0
680.0	2708.55	0.02922	0.10932	0.10777	758.5	314.1	1057.1	0.9308	0.3407	1.2238	680.0
684.0	2779.26	0.02961	0.10611	0.10041	768.1	296.7	1046.4	0.9375	0.3313	1.2170	684.0
688.0	2851.14	0.03001	0.10313	0.09309	778.0	278.7	1035.0	0.9443	0.3219	1.2101	688.0
692.0	2924.19	0.03042	0.10036	0.08580	788.2	260.1	1023.0	0.9512	0.3124	1.2031	692.0
696.0	3008.40	0.03084	0.09779	0.07854	798.7	241.0	1010.3	0.9582	0.3029	1.1960	696.0
700.0	3093.77	0.03127	0.09540	0.07131	809.4	221.4	1000.0	0.9653	0.2934	1.1888	700.0
704.0	3180.30	0.03171	0.09317	0.06411	820.4	201.3	989.0	0.9725	0.2839	1.1815	704.0
708.0	3267.99	0.03216	0.09108	0.05693	831.7	180.7	977.3	0.9798	0.2744	1.1741	708.0
712.0	3356.84	0.03262	0.08912	0.04977	843.3	159.6	965.0	0.9872	0.2649	1.1666	712.0
716.0	3446.85	0.03309	0.08728	0.04263	855.2	138.0	952.0	0.9947	0.2554	1.1590	716.0
720.0	3538.02	0.03357	0.08555	0.03551	867.4	115.9	938.3	1.0023	0.2459	1.1513	720.0
724.0	3630.35	0.03406	0.08392	0.02841	880.0	93.2	924.0	1.0100	0.2364	1.1435	724.0
728.0	3723.84	0.03456	0.08238	0.02132	892.9	70.0	909.0	1.0178	0.2269	1.1356	728.0
732.0	3818.49	0.03507	0.08092	0.01424	906.2	46.3	893.3	1.0257	0.2174	1.1276	732.0
736.0	3914.30	0.03559	0.07953	0.00717	920.0	22.1	877.0	1.0337	0.2079	1.1195	736.0
740.0	4011.27	0.03612	0.07820	0.00011	934.2	-2.6	860.0	1.0418	0.2000	1.1113	740.0

*Critical temperature

Muster

ANSWERS

5.1 a. $D.T. \times 1.443 = T = 86.6 \text{ sec.}$

- b. $P = P_0 e^{-t/T}$
 $2P = P_0 e^{-t/T}$
 $\ln 2 = -t/T$
 $T = t/\ln 2$
 $T = t/.693$
 $T = 1.443 \times \text{time}$

Ref: Rx Physics Review page 20

- 5.2 a. Fuel temperature primarily affects fast and intermediate neutrons which are resonantly captured, and control rods are thermal neutron absorbers. Therefore control rod worth remains constant as the temperature of the fuel increases.
- b. As void content in the core region increases, less moderator is available for moderation. Thermal neutrons travel a greater distance (L increases) in a less dense moderator; however, the voids depress the thermal neutron flux significantly because they are not moderating very many neutrons thus rod worth decreases.
- c. Control rod worth changes with respect to exposure are very complex, but essentially it follows a curve similar to the change in K_{eff} over core life. Early in core life, as fission products build up, control rods are withdrawn, increasing core size and decreasing worth.

Ref: Reactor Physics Review page 36, 37, and 38.

5.3 a. $\text{Production} = \text{Production rate from direct fission yield} + \text{production rate from decay of Iodine.}$

$\text{Removal} = \text{Removal rate by burnout} + \text{Removal by decay.}$

- b. Following a scram, the burnup term goes to zero while production continues from the decay of iodine. Since the half life of I^{135} is smaller than the half life of Xe^{135} , there is a net increase in Xe^{135} . The magnitude of the increase is significant and the peak occurs 7-11 hours after the scram. Following the peak removal is by decay with the production by decay decreasing.

Ref: Reactor Physics Review page 44 and 45

- 5.4 a. Neutron level would start and continue to increase until the point of adding heat is reached. As the coolant heats up negative reactivity is added and power turns. Power would stabilize at the point of adding heat.

- b. Period would take a step jump due to the production of prompt neutrons. Immediately after this step, the rate of power change decreases to a rate controlled by delayed neutrons until the reactivity is no longer being increased. Then a sharp drop would occur as the rate of reactivity addition drops to zero. A stable period would continue until negative reactivity is inserted. Stabilizes at infinity.

Ref: Reactor Physics Review page 49 & 50

- 5.5 a. Increases or becomes more negative due to the buildup of resonance absorption materials, such as Pu -240 and fission products not present at BOL.
- b. Decreases or becomes less negative due to a smaller fractional change in the neutrons being resonantly captured.
- c. Increase or becomes more negative due to an increase in neutron slowing down length, causes neutrons to spend more time in resonance region.

Ref: Reactor Physics Review pages 30 and 31

- 5.6 a. The point where further heat addition or removal to a substance will cause it to boil or condense without a change in temperature at a constant pressure.
- b. Measure of energy content of a substance.

Ref: Thermodynamics Heat Transfer and Fluid Flow for RO/SRO License Class page 8.

- 5.7 Insertion of control rods to reduce power will result in an increase in core flow. Reduced power lowers the resistance to flow by lowering the core and separator differential pressures. Since the driving force (Recirc. pps.) remain constant, and the resistance to flow decreases, core flow will increase.

Ref: Thermodynamics Heat Transfer and Fluid Flow for RO/SRO License Class page 40.

- 5.8 a. As flow increases CP increases since more power required to boil water in the shorter time it's present in the core.
- b. As incoming water temperature decreases (Subcooling increases) CP will increase since more power required to boil water.
- c. As pressure increases CP decreases since less enthalpy required to boil water. This is a small effect until water temperature approaches saturation.

Ref: Heat Transfer and Fluid Flow for RO/SRO License Class page 82.

- 5.9 Yes. As the rod is moved, neutron flux will change. Heat flux from fission is directly proportional to neutron flux. The water temperature next to the fuel rod will change only slightly if at all. (The only change would be heating up the subcooled water to saturation conditions in the lower part of the fuel.) Heat transfer is directly proportional to differential temperature. As water temperature stays approximately constant, centerline temperature must change as flux changes. (Will except either an up or down change.)
- 5.10 If the water level were too high carry over would occur. Carry over is a condition which occurs where moisture droplets are swept into the steam exiting the core due to high water level resulting in a low exit quality. These high velocity water droplets will cause excessive pipe erosions to occur. Damage by impingement to turbine and contamination of pure water by condenser breakdown.

If water level were too low carry under would occur. Carry under is a condition which occurs in the separator area whereas core water level is so low the water seal around the separator is broken and steam blowby to the annulus region occurs. This would result in steam bubbles being swept into the suction of the recirc pump, lowering the pumps NPSH and resulting in a loss of flow.

Ref: Heat Transfer and Fluid Flow for RO/SRO License Class page 79.

- 5.11 a. The hotter the feedwater is when it is returned to the vessel the higher the cycle efficiency.
- b. It would be a waste of energy (heat) to dump each heater drain back to the condenser. The water drained from a heater is hotter than the feedwater in a lower pressure heater and this temperature difference can be used to pre-heat the feedwater.
- 5.12 a. LHGR is based on prevention of 1% plastic strain on clad due to pellet swelling.
- b. Used to limit clad temperature during a DBA to 2200°F.
- c. Will ensure APLHGR limits are not exceeded.

Ref: Heat Transfer and Fluid Flow page 81.

- 6.5 a. The 101 valve should be closed prior to closing the 102 or 112 to prevent serious damage if a scram occurred while 101 was open and 102 or 112 was closed.
- b. The HCU should not be isolated except during periods when the reactor is in the cold shutdown condition in order to prevent seal damage due to a lack of cooling water.
- c. After a scram, the pumps will try to charge all the accumulators at once. Therefore, they would go into "run out" if not restricted. Pump damage or trips are prevented by a series of restricting orifices in the charging line which limits flow to a safe value.

Ref: QOP 300-8

- 6.6 a. The RBM - prevents local fuel damage that may result from a single rod withdrawal error or the RBM prevents the power in fuel bundles surrounding a control rod being withdrawn from approaching thermal limits.

The RBM is a backup to procedural control to limit control rod worth during startup and low power operation, so that in the event of a control rod drop accident the reactivity addition rate would not lead to damage of the fuel.

- b. The RBM is required to be in operation 30% power or greater. It is in operation greater than 30% because the RBM protects against erroneous rod withdrawal in areas of high power density during high power operation. The RBM is required to be operational below 20% power because above 20% power there is no possible rod worth which if dropped at the design rate of the velocity limiter, could result in a peak enthalpy of 280 cal/gm or result in fuel damage.

- 6.7 a. Alarm and Rod block.
- b. Hi -110% flow converter output mismatch -10% mismatch between two converters.
- c. Any two for full credit.
1. Mode switch not in operate
 2. Module unplugged.
 3. High voltage Power Supply low

Ref: SRO-700-4 page 4

6.8 a. OFF

- b. The 1/2 DG will close to the first unit which experienced the undervoltage. As to which would get the DG would depend on which logic had the fastest relays.
- c. By placing the switch in the ON position with the DG tied to that unit it would prevent the DG from transferring to Unit 2 if an ECCS and undervoltage condition occurred.

6.9 Removal of a Feedwater heater would cause undue stress and loading to be placed on the turbine. To prevent unbalance loads the feedwater heater removal would cause the MW output is limited.

Ref: QOP 3500-3 page 1

6.10 Any four for full credit.

- 1. RFP suction pressure greater than 120 psig.
- 2. Bearing lube oil pressure greater than 10 psig.
- 3. Condensate booster pump in service.
- 4. RFP ventilation fan in service.
- 5. Selected for standby.

Ref: QOP 3200-3 page 2.

6.11 The operator will remain in manual operation indefinitely until the electric motor is energized. When the handwheel is turned, it does not rotate the motor.

Ref: QOP 040-1 page 1

ANSWERS

- 7.1 a. Use of the Notch Override switch is not allowed between positions 04 and 12 on control rod arrays 3 and 4 and between positions 00 and 24 from half control rod density until the reactor pressure is 920 psig with at least one bypass valve partially open.
- b. High rod and notch worths can be encountered during approach to criticality on a hot startup following a scram. The fast recovery after a scram results in peak Xenon conditions at the time you're trying to go critical, and when combined with the zero voids and hot temperatures, can result in very large notch worths in the region of criticality. Caution should be exercised in this area to avoid pulling into a short period with a single notch withdrawal.
- 7.2 a. 50 psig.
- b. If pressure regulator setpoint should become less than reactor pressure with condenser vacuum less than or equal to 7 inches, upon attaining 7 inches of vacuum, a reactor scram could occur from the sudden opening of all turbine bypass valves.
- 7.3 Any four for full credit.
- a. Verify all APRM are indicating between 4% and 12%.
- b. Verify that all APRM DOWNSCALE lights are not illuminated.
- c. Verify the main condenser backpressure is less than 7 inches Hg (> 23" Hg Vacuum).
- d. Verify that Channel A/B Low Vacuum alarm is cleared.
- e. Place one IRM/APRM recorder on each RPS channel to APRM.
- 7.4 a. Reactor pressure and/or neutron flux indication increases abruptly, and may go off-scale on recorders.
- b. An ATWS Event is one in which the conditions which should initiate a scram are present but no scram occurs. A "Failure of Control Rods to Insert During a Scram" is when a scram has occurred with a failure of two (2) or more adjacent control rods or thirty (30) or more rods fail to insert below the 06 position.
- 7.5 a. Verify Reactor Scram.
- b. Verify Group 1 Isolation if required.
- c. Verify off-gas holdup line isolation if required.
- d. Take off-gas and reactor water samples as necessary to determine the amount of activity present and to determine any trends.

e. Notify the Load Dispatcher and the Shift Engineer.

Ref: QGA-16

- 7.6 a. Manual
- b. Tripping CB in Aux Electric Room
- c. Tripping RPS MG sets at MCC
- d. Stop air to scram solenoid valves.

Ref: QGA T-1

- 7.7 a. 95° - verify adequate RHRS discharge pressure and flow, to achieve less than 95° pool temperature.
- b. 101° - Do not allow pool temperature to exceed 100° if testing HPCI, RCIC or Relief Valves.
- c. Scram Reactor.
- d. Maintain 100°/hr cooldown if torus temperature reaches 120° if the reactor is isolated from its main heat sink. Continue until less than 150 psig.

7.8 The suction for compressor 2-4601 comes from outside the turbine building. This allows for non-contaminated air to be supplied for breathing purposes when the air around the compressors is contaminated.

Ref: QOA 1800-2

- 7.9 a. 1. Reduce recirculation flow at least 20% then -
2. Insert control rods.

Ref: QOA 3500-1

- b. Control rods are inserted to clear the APRM highs. As feedwater temperature decreases, core inlet subcooling increases. This along with rod insertion tends to peak power low in the core. Recirc. flow is reduced to limit power rise in the lower region to help maintain PCIOMR limits to prevent cladding damage.
- 7.10 a. Unit 2 HPCI Sprinkler System - Backup fire suppression equipment must be established and inspections twice per shift.
- b. Unit 2 Cable Tunnel Sprinkler System. Backup fire suppression equipment must be established within one hour and a continuous fire watch provided.
- c. Unit 2 DG room CO₂ - backup fire suppression equipment must be provided within 1^{1/2} hour. Inspections twice per shift.

d. Penetration fire stop - continuous fire watch established within one hour for one side of penetration.

7.11 a. Turbine runback if any of the following exist.

1. Cooling water pressure at stator inlet drops to 13 psig.
2. Water temperature at the stator outlet increases to 95°C.
3. Stator cooling water low flow (98" H₂O DP)

b. If conductivity was greater than 10 umho/cm, trip the unit. If conductivity was greater than 05 umho/cm, reduce generator load to zero and trip the unit within 3 minutes. If conductivity was less than 05 umho/cm, continue operation at less than or equal to 7380 generator stator amps for 60 minutes if desired.

Ref: QOA 5300-1

ANSWERS

- 8.1 a. Temporary Changes to Permanent Procedures, which do not change the intent of Permanent Procedures, may be made with the concurrence of 1 SRO and one of the individuals identified in the third column of QAP 1100-T1 (for operating procedures it would be another SRO).
- b. The "intent" of a procedure is changed if one or more of the following conditions are met:
1. The procedure is a new procedure being implemented with Temporary Procedure Request sheet.
 2. The Temporary Change to a Permanent Procedure is "less conservative" with respect to Technical Specifications or the FSAR than the permanent procedure.
 3. The Temporary Changes alters the content or order of the "principle" steps.
- c. No they (2 SROs) can authorize or concur with Temporary Changes in all groups except Tech. Staff procedures.
- 8.2 Access to the Drywell is not limited if all of the following conditions exist simultaneously:
1. Reactor is subcritical.
 2. Mode switch is in "Shutdown" or "Refuel."
 3. Reactor is vented.
 4. Tip system is out of service.
- 8.3
1. Station Superintendent
 2. Assistant Superintendent
 3. Operating Engineers
 4. Tech Staff Supervisor
 5. Station Quality Assurance Personnel
- u. NRC
Ref: QAP 1900-3
- 8.4 a. "S" (To lock the 345 KV yard or/and to lock valves and equipment in the proper position for safe plant operation according to prepared locked valve checklists.
- "R" Locks and keys are used to control access to potentially high radiation areas.

"V" Vital area doors.

- b. Shift Engineer (4) SCRE (1) Total of 5.

Ref: QAP 1900-9

- 8.5 Shift Foreman
Radwaste Foreman
Three Equipment Attendants
Duty RCT

Ref: QEP 340-5

- 8.6 a. Rad Chem Director *Rad Chem Director*

- b. (Operational Support Center) *(TSC) (OTF) -* *Safety*

Ref: QEP 360-4

- 8.7 a. When the rod is withdrawn the first time subsequent to each refueling outage or after maintenance, observe discernible response of the nuclear instrumentation; and observe that the drive does not go to the overtravel position.

Ref: T.S. 3.3/4.3-2

- b. Control rod withdrawal sequences shall be established so that the maximum reactivity that could be added by dropout of any increment of any one control blade would be such that the rod drop accident design limits are not exceeded.

Ref: T.S. 3.3/4.3-3

- 8.8 a. The condenser low vacuum scram is an anticipatory scram to the stop valve closure scram and causes a scram before the stop valves are closed and thus the resulting transient is less severe.

- b. The turbine stop valve closure scram trip anticipates the pressure, neutron flux, and heat flux increases that could result from rapid closure of the turbine stop valves.

- c. The low pressure isolation of the main steamlines at 825 psig was provided to give protection against rapid depressurization and the resulting rapid cooldown of the vessel. Advantage was taken of the scram feature in the Run mode which occurs when the main steamline isolation valves are closed to provide for reactor shutdown so that high power operation at low reactor pressures does not occur, thus providing protection for the fuel cladding integrity safety limit.

Ref: T.S. Basis 1.2/2-1-3

- 8.9 a. Instrument Calibration - means the adjustment of an instrument signal output so that it corresponds, within acceptable range and accuracy, to a known value of the parameter which the instrument monitors. Calibration shall encompass the entire instrument including actuation, alarm or trip.
 - b. Instrument Functional Test - means the injection of a simulated signal into the instrument primary sensor to verify the proper instrument response alarm and/or initiating action.
 - c. Instrument Check is a qualitative determination of acceptable operability by observation of instrument behavior during operation. This determination shall include, where possible, comparison of the instrument with other independent instruments measuring the same variable.
- 8.10 a. Its corresponding normal or emergency power source is operable.
 - b. All of its redundant system(s) in the other division are operable, or likewise satisfy the requirements of the specification.