

Telegram

TBD2G1(1517)(2-003829E291)PD 10/18/73 1514

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 40 10-18 0314P EST

FON 4045264503

US ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE
ST NORTHWEST *attn. Ga 30303*

ATLANTA GA 30303

SUBJECT BFAO-7328T

DURING ROUTINE SURVEILANCE TESTING ON OCTOBER 17 1973 HPCI CONDENSATE
HEADER LOW LEVEL SWITCHES LS-73-56 A AND B WERE FOUND TO OPERATE
OUTSIDE TECHNICAL SPECIFICATIONS TRIP LEVEL SETTINGS EQUAL TO
OR GREATER THAN ELAVATION 551 FEET

H J GREEN BROWNS FERRY NUCLEAR PLANT

SF-1201 (7-2-69)

8308240324 731126
PDR ADQCK 05000259
S PDR

W. King
8-257