

Telegram

1242P EDT AUG 14 73 AC123 AAE130(11113)(1-010087C226)PD

08/14/73 1111

URGENT BY TELEPHONED TELEGRAM

ICS IPMCHCA CTA

01058 CHATTANOOGA TN 63 08-14 1107A EDT

PMS U S ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS

FON 404-526-4503

230 PEACHTREE ST NORTHWEST

Atlanta Ga 30303

ATLA 30303

BFNP AO 73 T

DURING ROUTINE SURVEILLANCE TESTING, PRESSURE SWITCH PDIS-1-36A, MAIN STEAM LINE "C" HIGH FLOW WAS FOUND OUTSIDE TECHNICAL SPECIFICATIONS TRIP LEVEL SETTINGS OF LESS THAN, OR EQUAL TO, 140-0/0 FLOW WHICH CORRESPONDS TO 108.75 PSID. THE SWITCH OPERATED AT 111.5 PSID. THE SWITCH WAS RESET TO A SETPOINT OF 106.5 PSID AND CHECKED FOR REPEATABILITY.

*KAC
20.432p mail*

F-1201 (R5-69)

TENNESSEE VALLEY AUTHORITY

H J GREEN

BROWNS FERRY NUCLEAR PLANT

8308290097 730823
PDR ADOCK 05000259
S PDR

*hwy
50-257*

Files

Telegram from Tennessee Valley Authority, H. J. Green,
dated August 14, 1973 - 50-259

AUG 21 1973

DISTRIBUTION:

H. D. Thornburg, RO (2)

→ RO:HQ (5)

DR Central Files

Regulatory Standards (3)

Directorate of Licensing (13)

PDR

Local PDR

NSIC

OIS, OR

State