



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

June 30, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 2 - DOCKET
NO. 50-328 - FACILITY OPERATING LICENSE DPR-79 - LICENSEE EVENT REPORT
(LER) 50-328/95003

The enclosed LER provides details concerning an automatic turbine and reactor trip resulting from an actuation of the main generator stator cooling water failure circuit. This report is being submitted in accordance with 10 CFR 50.73(a)(2)(iv) as an event that resulted in the automatic actuation of engineered safety features, including the reactor protection system.

Sincerely,

R. J. Adney
Site Vice President

Enclosure

cc: See page 2

050052

9507070202 950630
PDR ADOCK 05000328
S PDR

TE22
11

U.S. Nuclear Regulatory Commission

Page 2

June 30, 1995

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711