

POINT BEACH NUCLEAR PLANT

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER - 1991

Docket No. 50-301
 Unit Name Point Beach, Unit 2
 Date November 19, 1991
 Completed By D. C. Peterson
 Telephone No. 414/755-2321, Ext. 361

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action To Prevent Recurrence
1	910928	S	745	C	1				Scheduled refueling and maintenance outage, UZR17. Major work items include inspection and eddy current testing of steam generators, installation of full flow test lines for residual heat removal, safety injection and containment spray pumps and increase of the steam-driven auxiliary feedwater pump mini-recirculation line.
	911210 PDR R	100274 ADOCK	911206 05000266 PDR						

F: Forced
 S: Scheduled

²Reason:
 A - Equipment Failure (explain)
 B - Maintenance or Testing
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training &
 Licensing Exam
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

³Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation of
 Previous Shutdown
 5 - Reduced Load
 6 - Other (explain)

⁴Exhibit G - Instructions
 for preparation of
 data entry sheets
 LER file (NUREG-0161)

⁵Exhibit I - Same Source

POINT BEACH NUCLEAR PLANT
UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER - 1991

Docket No. 50-266
Unit Name Point Beach, Unit 1
Date November 19, 1991
Completed By D. C. Peterson
Telephone No. 414/755-2321, Ext. 361

No.	Date	Type ¹	Duration	Reason ²	Method of Shutting Down	Licensee Event	System	Component	Cause and Corrective Action
5	911005	S	3	H	5	N/A	SJ	Hx	Repair and return to service of LP heater 4A and optional testing of main steam isolation valves and non-return valves.
6	911013	S	0	H	5	N/A	IB	Instru.	Load reduction to repair N-44, power range detector. Shutdown aborted because the Kewaunee Nuclear Plant tripped off-line on that date, causing concern over grid stability.
7	911026	S	23	H	1	N/A	IB	Instru.	Shutdown to replace N-44, power range detector and inspect MSIV valve operators.

¹F: Forced
S: Scheduled

²Reason:
A - Equipment Failure (explain)
B - Maintenance or Testing
C - Refueling
D - Regulatory Restriction
E - Operator Training & Licensing Exam
F - Administrative
G - Operational Error (explain)
H - Other (explain)

³Method:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation of Previous Shutdown
5 - Reduced Load
6 - Other (explain)

⁴Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

⁵Exhibit I - Same Source