



231 W Michigan, PO Box 2046, Milwaukee, WI 53201

(414) 221-2345

VPNPD-91-448
NRC-91- 151

December 19, 1991

Document Control : sk
U. S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301
NRC BULLETIN NO. 90-01, LOSS OF FILL OIL
IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

In our July 6, 1990 response to NRC Bulletin No. 90-01, Wisconsin Electric (WE) committed to replace four Rosemount Model 1154 differential pressure transmitter sensing modules in 1991. The replacement of these modules is complete.

The four modules were replaced with new sensing modules manufactured after July 11, 1989. WE also replaced a spare module which is maintained in our parts inventory at Point Beach Nuclear Plant.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'James J. Zach'.

James J. Zach
Vice President
Nuclear Power

Copies to: NRC Resident Inspector
NRC Regional Administrator, Region III

9112270126 911219
PDR ADOCK 05000266
0 PDR

JEH 1/0