

FROM TELECOPY NUMBER (404) 825-3811 or 8-608-3811
VERIFICATION NUMBER (404) 825-3811 or 8-608-3811

A-62

EQUIPMENT: CANON FAXPHONE 20

GPC EXHIBIT 62
WARD EX. D

95 JUL 14 A9:48

TELECOPY OPERATOR: DONNA HOLMES

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

DATE: April 11, 1990 TIME: 9:30 AM

TELECOPY TO: Mr. Lewis Ward / Mr. Ken Barr
Seafco - Vogtle Project

NUMBER OF PAGES ATTACHED: 1 (NOT INCLUDING COVER SHEET)

THIS TELECOPY SENT FROM: Herbert Beacher
DEPARTMENT: NSAC/TECHNICAL SUPPORT EXT. NO. 3769/138

VOGTLE ELECTRIC GENERATING PLANT
NUCLEAR OPERATIONS
ROUTE 2, BOX 1000
MARIETTA, GEORGIA 30060

SPECIAL INSTRUCTIONS: _____

9508030219 950607
PDR ADOCK 05000424
G PDR

NUCLEAR REGULATORY COMMISSION
50-424-01A-3
50-425-01A-3
Docket No. _____
Official Exh. No. 62 Ward D
In the matter of Seafco
Staff _____
Applicant ✓ IDENTIFIED ✓
Intervenor _____ RECEIVED ✓
Config Offr _____ REJECTED _____
Contractor _____
Other _____ DATE 6-7-95
Reporter SW Witness WARD

INTERVENOR
EXH.#78
7-19-94 WWS

82 PROJECT 059870

UNIT 1 A TRAIN DIESEL GENERATOR

AIR RECEIVER DEM POINT MEASUREMENTS

<u>PMO NO.</u>	<u>DATE</u>	<u>RECEIVER KO1</u>	<u>RECEIVER KO2</u>	
19001651	4/8/90	34°F	33°F	
19001513	3/31/90	60°F	60°F	<i>defective instrument</i>
19000899	3/12/90	48°F	45°F	
	3/9/90	61°F	66°F	<i>after maint. overhaul</i>
19000465	2/11/90	37°F	37°F	
18906445	1/18/90	44°F	44°F	
18906199	12/19/89	40°F	37°F	
18905007	11/20/89	40°F	47°F	
18904442	10/20/89	38°F	45°F	
18903652	9/27/89	45°F	45°F	
18903214	8/24/89	37°F	35°F	
18902798	7/30/89	45°F	49°F	
18902453	6/28/89	48°F		KO2 was tagged out for maintenance
18900984	3/16/89	22.6°F	20.1°F	