

NRC MONTHLY OPERATING REPORT

DOCKET NO. 50-361
 UNIT NAME SONGS - 2
 DATE 1/16/84 (as re-
 vised 3/15/84)
 COMPLETED BY C. A. Morris
 TELEPHONE (714) 492-7700
 Ext. 56264

OPERATING STATUS

1. Unit Name: San Onofre Nuclear Generating Station, Unit 2
2. Reporting Period: 1 December 1983 through 31 December 1983
3. Licensed Thermal Power (MWt): 3,390
4. Nameplate Rating (Gross MWe): 1,127
5. Design Electrical Rating (Net MWe): 1,070
6. Maximum Dependable Capacity (Gross MWe): 1,127
7. Maximum Dependable Capacity (Net MWe): 1,070
8. If Changes Occur In Capacity Ratings (Items Number 3 Through 7)
 Since Last Report, Give Reasons:

NA

9. Power Level To Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

NA

NA

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	3505	3505
12. Number Of Hours Reactor Was Critical	307.4	2612.7	2612.7
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	274.6	2561.7	2561.7
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	885,405	8,493,535	8,493,535
17. Gross Electrical Energy Generated (MWH)	306,662	2,911,964	2,911,964
18. Net Electrical Energy Generated (MWH)	284,352	2,775,644	2,775,644
19. Unit Service Factor	36.9	73.1	73.1
20. Unit Availability Factor	36.9	73.1	73.1
21. Unit Capacity Factor (Using MDC Net)	35.7	74.0	74.0
22. Unit Capacity Factor (Using DER Net)	35.7	74.0	74.0
23. Unit Forced Outage Rate	0	3.8	3.8
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	NA		

25. If Shut Down At End Of Report Period, Estimated Date of Startup: NA
26. Units In Test Status (Prior To Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

NA

NA

NA

NA

NA

NA

8403200077 840315
 PDR ADOCK 05000361
 R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-361

UNIT SONGS - 2

DATE 1/16/84 (as revised)
3/15/84

COMPLETED BY C. A. Morris

TELEPHONE (714) 492-7700
Ext. 56264

MONTH: December 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	0
18	0
19	0
20	58.42
21	818.96
22	1099.90
23	1106.25
24	1113.23
25	1139.58
26	1166.56
27	1079.90
28	1146.88
29	1203.75
30	1109.50
31	1133.40

0565u

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH DECEMBER, 1983

DOCKET NO. 50-361
UNIT NAME SONGS - 2
DATE 1/16/84 (as revised 3/15/84)
COMPLETED BY C. A. Morris
TELEPHONE (714) 492-7700
Ext. 56264

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down ³ Reactor	LER No.	System ⁴ Code	Component ⁵ Code	Cause & Corrective Action to Prevent Recurrence
25	831114	S	469.4	F	4	NA	NA	NA	18-Month Surveillance Outage.

1 F-Forced S-Scheduled	2 Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)	3 Method: 1-Manual 2-Manual Scram. 3-Automatic Scram. 4-Continuation from Previous Month 5-Reduction of 20% or Greater in the Past 24 Hours 6-Other (Explain)	4 Exhibit F - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 0161)	5 Exhibit H-Same Source
------------------------------	--	---	--	----------------------------

0565u