

June 20, 1984

Docket No. 50-333

Mr. J. P. Bayne
Executive Vice President,
Nuclear Generation
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Bayne:

SUBJECT: SAFETY EVALUATION OF THE IMPLEMENTATION
OF NUREG-0313, REVISION 1

Re: James A. FitzPatrick Nuclear Power Plant

Generic Letter 81-04, dated February 26, 1981, requested that you review all ASME-Code Class 1 and 2 pressure boundary piping, safe ends, and fitting materials, including the weld metal in the James A. FitzPatrick Nuclear Power Plant to determine if they were in compliance with the guidelines of NUREG-0313, Revision 1 "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," dated July 1980. By letters dated July 31, 1981, September 28, 1981 and January 19, 1983 you provided information in response to this Generic Letter.

The NRC staff has completed its review of your responses to Generic Letter 81-04. Our contractor, EG&G, concluded that your responses did not fully meet the guidelines set forth in NUREG-0313, Revision 1. However, recent experience related to intergranular stress corrosion cracking (IGSCC) and evaluation of the results of inspections conducted in response to I.E. Bulletins 82-03 and 83-02 and orders were outside of the scope of the review of issues addressed in Generic Letter 81-04. Therefore, we conclude that the assessment regarding conformance with NUREG-0313, Revision 1 guidelines is not currently germane because of the recently issued generic letters (Generic Letters 84-07 and 84-11) on this subject.

We are transmitting the enclosed Safety Evaluation, which also includes the Technical Evaluation Report prepared by our contractor, for your information and for assisting you in preparing your responses to Generic Letters 84-07 and 84-11 addressing this issue in terms of both short term reinspection and guidance for replacement of any affected system piping in your plant.

8407110223 840620
PDR ADOCK 05000333
P PDR

Mr. J. P. Bayne

- 2 -

This completes our action in reviewing your responses to Generic Letter 81-04 (NUREG-0313, Revision 1).

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File

NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
OELD
SNorris
HAbelson
RHermann
ELJordan
JNGrace
ACRS (10)
Gray File

DL:ORB#2
SNorris:ajs
06/15/84

DL:ORB#2
HAbelson
06/15/84

DL:ORB#2
RHermann
06/20/84

~~DSI:MTEB
06/ /84~~

DV
DL:ORB#2
DVassallo
06/20/84

Mr. J. P. Bayne
Power Authority of the State of New York
James A. FitzPatrick Nuclear Power Plant

cc:

Mr. Charles M. Pratt
Assistant General Counsel
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

U. S. Environmental Protection
Agency
Region II Office
Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

Mr. Corbin A. McNeill, Jr.
Resident Manager
James A. FitzPatrick Nuclear
Power Plant
Post Office Box 41
Lycoming, New York 13093

Mr. J. A. Gray, Jr.
Director - Nuclear Licensing - BWR
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Robert P. Jones, Supervisor
Town of Scriba
R. D. #4
Oswego, New York 13126

Mr. Leroy W. Sinclair
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. Jay Dunkleberger
Division of Policy Analysis
and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Post Office Box 136
Lycoming, New York 13093

Mr. A. Klausman
Vice President - Quality Assurance
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. George Wilverding, Chairman
Safety Review Committee
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. M. C. Cosgrove
Quality Assurance Superintendent
James A. FitzPatrick Nuclear
Power Plant
Post Office Box 41
Lycoming, New York 13093

Thomas A. Murley
Regional Administrator
Region I Office
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406