

DISTRIBUTION:
DOCKET FILE ✓
NRR READING
ICSB READING

Ps Reading

Docket Nos. 50-329
50-330

MEMORANDUM FOR: D. Vassallo, Assistant Director
for Light Water Reactors, DPM

FROM: R. Tedesco, Assistant Director
for Plant Systems, DSS

SUBJECT: RESULTS OF REVIEW OF SUPPLEMENTAL INFORMATION RECEIVED
IN RESPONSE TO OUR REVIEW OF AMENDMENT 32 (TAC-3239)
OF THE MIDLAND APPLICATION

In response to my May 26, 1977, memorandum requesting additional information and clarification concerning the subject Amendment, the Consumers Power Company responded via letter S. H. Howell to R. Boyd dated June 27, 1977.

We have reviewed this supplemental information clarifying their criteria for separation and administrative procedures for Class 1E Balance of Plant Equipment and Circuits and have concluded it is acceptable at the Construction Permit stage, for ensuring separation as required by General Design Criteria 3, 17 and 21.

This concludes our review of this criteria per TAR 3239, forwarded by memorandum S. Varga, DPM to R. Maineman, DSS, dated April 15, 1977.

Original signed by:
Robert L. Tedesco

Robert L. Tedesco, Assistant Director
for Plant Systems
Division of Systems Safety

- cc: S. Henner
- F. Schroeder
- R. Boyd
- W. McDonald
- S. Varga
- T. Ippolito
- B. Hood
- C. Miller
- J. Glynn
- C. Long
- J. Smith

POOR ORIGINAL

Contact:
J. Smith
#77233

9006240820

memo

APPROVED BY: <i>[Signature]</i>	DSS:ICSB	DSS:ICSB	DSS:ICSB	DSS:ADPS <i>[Signature]</i>	772150488
FORWARDED BY: <i>[Signature]</i>	JSmithHR:s1	Miller	T Ippolito	RTedesco	
DATE:	9/28/77	9/29/77	9/29/77	9/30/77	