



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUN 9 1980

2-7  
54-105

MEMORANDUM FOR: T. A. Ippolito, Chief  
Operating Reactors Branch No. 2  
Division of Licensing

FROM: R. M. Satterfield, Chief  
Instrumentation & Control Systems Branch  
Division of Systems Integration

SUBJECT: UPDATED ENCLOSURE TO OUR SER FOR MONTICELLO NUCLEAR  
GENERATING PLANT, UNIT 1, DATE NOVEMBER 14, 1979

The Safety Evaluation Report on Monticello, Unit 1 for N-1 Loop Operation dated November 14, 1979 enclosed a technical evaluation by Lawrence Livermore Laboratory/EG&G (Consultant). The consultant has modified the conclusion section of his technical evaluation. The changes are editorial to emphasize that plant specific analysis of ECCS in the single-loop mode of operation, not yet completed by the licensee, will require additional review of the instrumentation system. Our evaluation of November 14, 1979, addressed this concern. The April 1980 issue of the consultant's technical evaluation is herewith attached as a replacement for the enclosure to our SER of November 14, 1979 for Monticello Unit 1.

*R. M. Satterfield*  
R. M. Satterfield, Chief  
Instrumentation & Control Systems Branch  
Division of Systems Integration

cc: ~~J. Kevern~~

Contact: J. Burdoin, x29434

54-263

8606240863

XA

Monticello Single Loop  
page 2.

2-6



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SEP 10 1982

Docket Nos.: 50-263

MEMORANDUM FOR: Gus C. Lainas, Assistant Director for Operating Reactors, Division of Licensing

FROM: Themis P. Speis, Assistant Director for Reactor Safety Division of Systems Integration

SUBJECT: SAFETY EVALUATION OF MONTICELLO NUCLEAR GENERATING PLANT SINGLE LOOP OPERATION

Plant Name:	Monticello Nuclear Generating Plant
Docket Numbers:	50-263
NSSS Supplier:	General Electric
Responsible Branch:	ORB-2
Project Manager:	H. Nicolaras
Review Status:	Complete

Enclosed is the Safety Evaluation Report to permit Monticello Nuclear Generating Plant to operate on a single loop with power limited to 50%. This completes one action under multiplant item E-04. (TAC #48646)

Themis P. Speis, Assistant Director  
for Reactor Safety  
Division of Systems Integration

Enclosure: As stated

cc: R. Mattson	R. Capra
L. Phillips	T. Marsh
G. Schwenk	G. Mazetis
Richard Clark	N. Lauben
D. B. Vassallo	

CONTACT: G. Thomas  
X29445

~~8209240430~~

1P.