

50-329/330 OM, OL
Midland Plant, Unit 1&2

Exhibits of John P. Matra, Jr. 5154]

Naval Surface Weapons Center
(NSWC Consultant)

during

Oral Deposition on 1/7/81

Exhibits 1-4
1



8102271547

T ~~XXXXXXXXXX~~

JOHN P. MATRA JR

STRUCTURAL ANALYSIS STAFF
NAVAL SURFACE WEAPONS CENTER



JOHN P. MATRA JR
14010 JARRETTSVILLE PIKE
PHOENIX MD 21131

EMPLOYED AS A STRUCTURAL ENGINEER ON THE
STRUCTURAL ANALYSIS STAFF OF THE
NAVAL SURFACE WEAPONS CENTER, WHITE OAK
SILVER SPRING, MD. 20910

PROFESSIONAL QUALIFICATION

- 1) GRADUATED FROM NORTH TARRY TOWN HIGH SCHOOL 1948
ALSO RECEIVED COLLEGE ENTRANCE DIPLOMA
FROM NEW YORK STATE.
- 2) RECEIVED BACHELOR OF AERONAUTICAL ENGINEERING
(MAJORED IN STRUCTURES) FROM RENSSELAER POLYTECHNIC
INSTITUTE. (1953)

HAVE BEEN ELECTED TO GAMMA ALPHA ETO
A NATIONAL AERONAUTICAL HONORARY SOCIETY
- 3) RECEIVED MASTER OF SCIENCE IN MECHANICAL ENGINEERING
FROM DREXEL INSTITUTE OF TECHNOLOGY. (1962)
(MAJORED IN STRUCTURES)

Matra dep Ex 1
1-7-81 CFB

- 4) TOOK COURSES AT HOPKINS AND THE UNIVERSITY OF MARYLAND TOWARD A DR DEGREE IN APPLIED MATH. HAVE ABOUT 20 CREDITS TOWARD THIS - DEGREE DO NOT HAVE DEGREE.

PROFESSIONAL EXPERIENCE

- 1) 1953 TO 1967 GREEN L. MARTIN CO.
(STRUCTURAL ENGINEER)
- 2) 1967 TO PRESENT NAVAL SURFACE WEAPONS CENTER
(STRUCTURAL ENGINEER)

PUBLISHED THESIS

- 1) ON THE PROPAGATION OF A DISTURBANCE IN A VISCO-ELASTIC MEDIUM.
- 2) ON THE DEVELOPMENT OF THEORETICAL METHODS OF PREDICTING THERMAL PROPERTIES OF A HETEROGENEOUS MATERIAL.

FACILITY REVIEW - ADMINISTRATIVE DATA

Applicant CONSUMERS POWER COMPANY (CPCo)
 Facility Name 1. ... 2. ...
 Pocket Numbers 50-329 & 50-330 Pocket Date 1-1
 Project Leader _____ Branch _____
 Branch Chief _____ DL or CP _____
 Assistant Director _____ Group _____
 Reviewer _____ Assignment Date 1/1

Acceptance Review

Start 1/1 Complete 1/1
 Hours _____ Percent Deficient _____

Initial Review

Start 1/1 Complete 1/1
 Hours _____ No. of Questions _____

Second Review

Initial Response 1/1 Complete Response 1/1
 Start 1/1 Complete 1/1
 Hours _____ No. of Questions: New _____ Peak _____

Third Review

Initial Response 1/1 Complete Response 1/1
 Start 1/1 Complete 1/1
 Hours _____ No. of Remaining Inadequate Responses _____

Evaluation Report

Start 1/1 Complete 1/1 Hours _____

Outstanding Issues:

Evaluation Report Supplement

Start 1/1 Complete 1/1 Hours _____

Figure 1

SEB Form 1A dtd 1 OCT 79

*Ma.tra ...
 1-7-81 ...*

CORRESPONDENCE SUMMARY

Document

Date Dispatched

Comments

Figure 1 (cont'd)

SEE Form 10 dtd 1 OCT 70

1976 FWS Technical Data

NUCLEAR POWER FACILITY NAME: MIDLAND PLANT
 STRUCTURAL DATA SHEET UNITS 1 AND 2

GENERAL PLANT DATA AND STRUCTURES

LOCATION SOUTH SHALE OF THE TIPPICANNOUSVILLE L...
 THE CITY IS MIDLAND, MISSOURI, AREA:
 THE LOW CHEMICAL CONTAINING MINERAL ING
 DOCKET NUMBER 50-329 COMP. UTILITY / MIDLAND, MO.
 OWNER CONSUMER POWER CO
 NEW PART OF WATER NEW
 TYPE 2-2-72 SUPPLIER BARCO & WILSON, CONRAD
 ARCHITECT/ENGINEER BECHTEL PRINCIPAL CONTRACTOR BECHTEL

CONTAINMENT: TYPE PRE-TENSIONED REINFORCED CONCRETE
A STEEL LINER

OVERALL REFERENCE DUGS (CITE ASSESS. REFERENCE)
 PLAN 1.2-8 1.2-9 E/W ELEV 1.2-11 N/S ELEV

FOUNDATION FINISHED GRADE ELEVATION 634 (10)
 DEPTH TO ROCK (FT) 289' 6" ELEVATION OF ROCK
 BASE SLAB 592' 6" ANCHORS?
 GROUND WATER HEIGHT (FT) - VALUES ABOVE SLAB 10' 6" ROCK/JOEL
 ROCK/JOEL CLASSIFICATION

ONE SLAB
 OUTSIDE
 DIAMETER (FT) 124 FT SLAB THICKNESS (FT) 9' TO 13' SURF
 THICKNESS (FT)

WALLS (SHELL)
 HEIGHT, ONE SLAB
 TOP TO SPONGE/SLAB 153' WALL THICKNESS: 24" 3' 6" AT BASE HEIGHT

DOMES ELLIPTICAL (✓) OR SPHERICAL ()
 SURFACE RADIUS (AT) 87' 6" (RADIUS) 34' 6" THICKNESS: APPROX 3' AT

LINER
 THICKNESS (IN) 1/4" FLOOR

OTHER CATEGORY I STRUCTURES:

STRUCTURE	TYPE	REF. CONCRETE	TOP OF CONCRETE
UNIT (1) CONTAINMENT	REF CONCRETE		593.
UNIT (2) CONTAINMENT	11		593.
AUXILIARY BUILDS			
DIESEL GEN BUILDS			
SERVICE WATER COOLERS			
BOILER WATER STORAGE TANKS			7

NUCLEAR POWER FACILITY NAME
STRUCTURAL DATA SHEET

NAME

NO. 1

DATE

AGE
TWO
OR
FEET

SITE DATA

WIND 3.2.1.1
DESIGN SPEED (MAX, 30' LEVEL) 85 MPH REFERENCE
INTERNAL (PS) 100

TORNADO 3.3.2.1
TRANSLATIONAL SPEED (MAX) 360 MPH RADIATIONAL SPEED (MAX) 290 MPH
TOTAL PRESSURE 3 PSI DYNAMIC PRESSURE (REF/3000) 2 PSF/SEC
TORNADO WINDSPEED SPECTRUM: 3.5
TABLE 3.5-9, 3.5-10

FLOOD 3.4
HEIGHT ABOVE GRADE, MAX. DESIGN BASIS FLOOD 635 FT
MAX. HISTORIC FLOOD (AT) 610 FT
HEIGHT 631 MAX. GROUND WATER TABLE 610 FT
PLANT FLOOD PROTECTION FEATURES:
3 FT WATER TIGHT WALL, WATER TIGHT CURB - 2 1/2"

SNOW/ICE 2.4.12.1
DESIGN LOAD (L/FT²) 1.5 KIPS/FT REFERENCE
INTERNAL (YRS) 100 YEARS
PLANT ENVIRONMENT (DESIGNS)
SEL 2.2.3.1.1.1 OVERPRESSURE - NOT TO EXCEED, 2.3 #/IN

AIRCRAFT IMPACT ENVIRONMENT (DESIGNS)

SEISMOLOGY 3.5.1

NEAREST RAIL 70 MI HOWELL ANTICLINE
TO SITE (MI) 70 MI LUCAS - MONROE

OBE: VERTICAL 0.01 (9) HORIZONTAL 0.06 (9)
OBE (9): VERTICAL 0.08 (9) HORIZONTAL 0.12 (9)

ITE RESPONSE SPECTRA: TYPE 3B-TOL-4-A

LOCATION

33	20	9	5	25	1	0.25	0.1
				8			

FREQUENCY

MOD. AMP. FACTOR (2% DAMPING)

SOIL PROFILE

ELEV	SOIL CLASS
630	111111111111
5:4	2222222222
	TYPE
	UNIT WT 125 #/FT ³
	MOHRIE 1.71x10 ⁶ PSI
	POISSON'S RATIO 0.42
	SOIL STRATA I
	TYPE
	UNIT WT 125 #/FT ³
	MOHRIE 1.57x10 ⁶ PSI
	POISSON'S RATIO 0.42
	SOIL STRATA II
	TYPE
	UNIT WT
	MOHRIE
	POISSON'S RATIO
	SOIL STRATA III
	TYPE
	UNIT WT
	MOHRIE
	POISSON'S RATIO
	SOIL STRATA IV
	TYPE
	UNIT WT
	MOHRIE
	POISSON'S RATIO

SHRINKAGE
PLASTICITY 5000 FT/IN
SHEAR MODULUS 2.9x10⁶ PSI
BULK MODULUS
E = 2.16x10⁶ PSI

OBE =
OPER BAC
SF =
SAFE
RANGE
Vect =

AVG. WAVE VELOCITY = 10,000

NUCLEAR POWER FACILITY
STRUCTURAL DATA SHEET

NAME:

DATE:

PAGE
THREE
OF
EIGHT

MISSILE BARRIER DESIGN

BARRIER DESIGN PROCEDURES:

DESCRIPTION IN RC-TOP-9-A

DESIGN APPROACHES:

CAT. 2 STRUCTURES	METHODS EMPLOYED	METHOD OR OVERALL REF
CONTAINMENT		
REACTOR (R) CONTAINMENT		
AUXILIARY BUILD	ANALYSIS	
WATER TREATMENT BUILD		
CONDENSER WATER TREATMENT BUILD		
WATER TREATMENT BUILD		

DESIGN AGAINST TURBINE MISSILE NEEDED (?) YES NO

IF YES, DESCRIBE METHOD USED AND SAR REF. PAGE: 3.5-29

ANALYSIS OF TURBINE MISSILE IMPACT ON REACTOR CONTAINMENT
WATER TREATMENT BUILD

DESIGN AGAINST AIRCRAFT MISSILE NEEDED (?) YES NO

IF YES, DESCRIBE METHOD USED AND SAR REF. PAGE: 3.5-29
RC-TOP-9-A

SEISMIC SYSTEM AND SUBSYSTEM DESIGN & ANALYSIS

METHOD OF SEISMIC ANALYSIS: TIME HISTORY METHOD (✓)
RESPONSE SPECTRUM METHOD (✓)
OTHER EQUIVALENT STATIC METHOD (✓) MOULD SUPERPOSITION

SEISMIC MOTION DEFINITION:

R.G. 1.60 SPECTRA _____ SITE SPECIFIC SPECTRA ^{HORIZONTAL AND NEAR-FIELD RESPONSE SPECTRA} MODIFIED TAFT W/2IE, 1952

SITE SPECIFIC ENSEMBLE OF TIME HISTORIES _____

DAMPING VALUES USED: R.G. 1.61 - ANNEX 3A BGTUP-4A (?)

R.G. 1.61 DAMPING VALUE 0 TO 5% OTHER DAMPING VALUES _____

SUPPORTING MEDIA FOR SEISMIC CATEGORY 2 STRUCTURES:

CONTAINMENT _____ OTHER CAT. 2 STRUCTURES _____

SPECIAL STRUCTURES _____ TURBINE BUILDING _____

IS SOIL-STRUCTURE INTERACTION ANALYSIS EXPLORED? YES NO

IF YES, DESCRIBE THE METHOD USED: COUPLING STRUCTURE ANALYSIS

(FOR USE IN DISEIGN, POWER PLANT ANALYSIS PROCEDURES) (ANNEX 3.2.1)

ANNEX 3.2.1 - TABLE 3-2 - RC-TOP-9-A

FROM
RC-TOP-9-A
PAGE 3-2-1

NUCLEAR POWER FACILITY
STRUCTURAL DATA SHEET

JAMES

DATE: _____
PAGE: _____
OF: _____
SHEET

FEED SYSTEM & SUBSYSTEM DESIGN AND ANALYSIS (CONT'D)

STRUCTURAL MODELING METHODS: (CHECK APPROPRIATE SPACES)

NAMES OF CAT. 2 STRUCTURES	FEM/FINITE DIFF.		STICK MODEL	OTHER MODELING METHODS
	2D	3D	2D, 3D	
CONTAINMENT				
CONTAINMENT				
REACTOR BUILDING				
REACTOR BUILDING				
REACTOR BUILDING				
REACTOR BUILDING				
REACTOR BUILDING				

NOTES:

DEVELOPMENT OF FLOOR RESPONSE SPECTRA: (EC-107-13)

TIME HISTORY METHOD , OTHER EQUIVALENT METHOD _____

THREE COMPONENTS INPUT _____ TWO COMPONENTS INPUT _____ OTHERS _____

IS FLOOR SPECTRA PEAK BROADENING APPLIED? YES _____, NO _____

IF YES, INDICATE THE BROADENING % APPLIED, = 10% _____, 20% _____, 30% _____

IF MODAL ANALYSIS IS USED, INDICATE METHOD OF

MODAL RESPONSE COMBINATION ADOPTED: SRSS _____, SRS / MS FOR UNIFORM _____

OTHER COMBINATION METHODS _____

3.7.2-11
IF TORSIONAL JOINT EFFECTS ARE ACCOUNTED FOR? YES , NO _____

IF YES, DESCRIBE HOW? APPLICATION - HVED SEISMIC ANALYSIS - TORSIONAL EFFECTS
DEVELOPED USING SYSTEM ANALYSIS AT AN ECCENTRICITY OF 10%
THE LOCATION OF THE S.E. ECCENTRICITY IS 10% OF THE
WIDTH OF THE STRUCTURE NORMAL TO THE DIRECTION OF INPUT

IF ACCIDENTAL TORSIONAL EFFECTS ARE ACCOUNTED FOR? YES _____, NO _____

IF YES, DESCRIBE HOW? _____

IS INTERACTION OF NON CAT. 2 STRUCTURES & CAT. 2 STRUCTURE IS CONSIDERED?

YES , NO _____ IF YES, DESCRIBE HOW? P-DELTA - U/A

SAFETY FACTORS AGAINST SEISMIC OVERTURNING _____, SLIDING _____

MAX. ALLOW. BEARING PRESSURE _____

PROCEDURES FOR ACCOUNTING DIFF. DAMPING VALUES IN DIFF. STRUCTURAL PARTS

STIFFNESS MATRIX WEIGHTING _____, MASS MATRIX WEIGHTING _____

OTHER METHOD _____, DESCRIBE THE METHOD BRIEFLY _____

NUCLEAR POWER FACILITY
STRUCTURAL DATA SHEET

NAME:

DATE: FILE
PAGE OF
FIGURE

SEISMIC SYSTEM AND SUBSYSTEM DESIGN AND ANALYSIS (CONT'D)

EQUIVALENT STATIC METHOD OF ANALYSIS FOR SUBSYSTEMS: YES , NO

IF YES, DESCRIBE THE CRITERIA USED REVISION 100-100-100 MO-110
CA-TOP-0-15

ANALYSIS CRITERIA AND PROCEDURES FOR PIPING: SEE

SEISMIC ANALYSIS OF MULTIPLE SUPPORTED SUBSYSTEMS: SEE

TORSIONAL EFFECTS IN SUBSYSTEM ANALYSIS: (DESCRIBE THE CRITERIA)

SEISMIC ANALYSIS AND DESIGN OF SPECIAL STRUCTURES

CATEGORY I DAM STRUCTURE: YES , NO

IF YES, DESCRIBE STRUCTURAL DIMENSIONS AND ANALYSIS CRITERIA:

CATEGORY I INTAKE STRUCTURE AND SUBMERGED PIPE/TUNNELS: YES , NO

IF YES, DESCRIBE KEY STRUCTURAL DIMENSIONS AND ANALYSIS CRITERIA:

CATEGORY I BURIED PIPING/TUNNELS: YES , NO

IF YES, DESCRIBE KEY STRUCTURAL DIMENSIONS AND ANALYSIS CRITERIA:

CA-TOP-0-15

NUCLEAR POWER FACILITY
STRUCTURAL DATA SHEET

NAME:

DATE:

PAGE
SIX OF
EIGHT

SEISMIC ANALYSIS AND DESIGN OF SPECIAL STRUCTURES (CONT'D)

SEISMIC ANALYSIS OF STRUCTURE/PILE/SOIL MEDIUM SYSTEM: YES NO
IF YES, DESCRIBE STRUCTURAL MODELING, ANALYSIS CRITERIA, ASSUMPTIONS
AND COMPUTER CODES USED: _____

SEISMIC ANALYSIS AND DESIGN OF CATERGUT & TANKS: YES NO
IF YES, DESCRIBE STRUCTURAL MODELING, ANALYSIS CRITERIA, ASSUMPTIONS
AND COMPUTER CODES USED: _____

SEISMIC ANALYSIS AND DESIGN OF UNDERDRAIN SYSTEMS: YES NO
IF YES, DESCRIBE KEY STRUCTURAL DIMENSIONS, ANALYSIS CRITERIA AND
DESIGN PROCEDURES USED: _____

SEISMIC DESIGN AND ANALYSIS OF SPENT/LOW FUEL POOL STRUCTURES:
YES NO
IF YES, DESCRIBE KEY DIMENSIONS, DESIGN AND ANALYSIS CRITERIA,
STD. OR CODES USED: _____

SEISMIC INSTRUMENTATION

DESCRIBE TYPE, NOS, LOCATION OF SEISMIC INSTRUMENTATIONS USED:
SITE TYPICAL TIME-HISTORIC, SHOCK METER, ACCELEROMETER, etc.
TANK, SPENT FUEL POOL, AND REACTOR VESSEL
TANK, SPENT FUEL POOL, AND REACTOR VESSEL
AND REACTOR VESSEL, SPENT FUEL POOL, AND REACTOR VESSEL
TANK, SPENT FUEL POOL, AND REACTOR VESSEL

(NO) IS INSTRUMENTATION NEEDED FOR MEASURING TORSIONAL INPUT PROVIDED
IF YES, DESCRIBE TYPE, NOS, AND LAYOUT OF THE TORSIONAL INSTRUMENT
TATION: _____

NUCLEAR POWER FACILITY STRUCTURAL DATA SHEET	NAME:	DATE:	PAGE SERIAL EXTENT
---	-------	-------	--------------------------

CATEGORY I STRUCTURES

CONTAINMENT STRUCTURE: REINFORCED CONCRETE
 TYPE OF CONTAINMENT: CONCRETE (), CONCRETE (), STEEL ()

DESIGN CODES USED: ASCE 3.2-1 ASCE 3.19 ASCE 3.11 ASCE 3.12

LOAD COMBINATIONS: a) D + F + I + T b) L + F + I + T

STATIC ANALYSIS METHOD AND CODES: ELAS - ANALYSIS OF PLASMA LOAD CONDITION
INCLUDING NON-LINEAR TRANSIENT LOADS

DYNAMIC ANALYSIS METHOD AND CODES: _____

SPECIAL CONSTRUCTION TECHNIQUES USED, IF ANY: 3.2.1.6

UNIQUE PROBLEMS (IF ANY) AND THEIR DISPOSITION: _____

DESCRIPTION OF BASE MAT, DOME, HATCH AND PENETRATION DESIGN: PL 3.2-1-2
BASE MAT - REINFORCED CONCRETE SLAB - APPROX 14" THICK - ON GRADE - FOR PARTIAL
DOME - REINFORCED CONCRETE - WITH THICKNESS VARYING FROM 12" TO 18"
HATCH - REINFORCED CONCRETE - WITH THICKNESS VARYING FROM 12" TO 18"
PENETRATIONS - NOT FREQUENTLY OF STEEL SHEET PILING TO LINE WITH ANCHORS TO

FLAR CRANE SUPPORT DESIGN: PL 3.2-46

CONTAINMENT MAT BEARING PRESSURE: _____

CONTAINMENT INTERIOR STRUCTURE DESIGN: _____

"KEY CONTAINMENT INTERIOR STRUCTURES" DESIGN METHOD CODES: ASCE 3.2-1
ASCE 3.19 ASCE 3.11 ASCE 3.12

CONTAINMENT DETAIL DESIGN AND TESTING: _____

NUCLEAR-POWER FACILITY
STRUCTURAL DATA SHEET

NAME:

DATE:

PAGE
EIGHT
EIGHT

CATEGORY 1 STRUCTURES (CONT'D)

DESIGN METHOD/CODES FOR OTHER CATEGORY 2 STRUCTURES:

CATEGORY 2 STRUCTURES
(OTHER THAN CONTAINMENT)

DESIGN CODE AND
ANALYSIS METHODS

LOAD COMBINATIONS
(PROVIDE REF. SUP. NO. IF

P. 3
P. 3
M.S.P.
1. 2

ASME B31.1
ASME B31.3
ASME B31.4
ASME B31.5

ASME B31.1
ASME B31.3
ASME B31.4
ASME B31.5

ASME B31.1
ASME B31.3
ASME B31.4
ASME B31.5

EXCEPTIONS TAKEN TO THE DESIGN CODE USED: (IF APPLICABLE)

UNIQUE DESIGN PROBLEM(S) (IF ANY) AND THEIR DISPOSITION:

NATURAL, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES:

SUBSECTION 3.5.1.6

TESTING, INSPECTION REQUIREMENTS:

SPECIAL DESIGN AND ACCEPTANCE CRITERIA:
(IF ANY)

SPECIAL DESIGN AND ANALYSIS PROCEDURES:

OTHER ITEMS:

II. REVIEW TECHNICAL CHECKLIST AND ELEMENTS SUMMARY

CHECKLIST AND REVIEW SUMMARY

SECTION 3.3.1 WIND LOADING

- A. DESIGN WIND VELOCITY, RECURRENT INTERVAL, VERTICAL VELOCITY PROFILES AND GUST FACTORS (3.3.1.1)

3.3-1

Values reviewed for information only

~~SWEEP~~
~~80 MPH~~ ^{51.7} ~~100 YEAR~~ ^{OF 1.00}

VERTICAL VELOCITY PROFILE AS PER ASCE 308 TABLE 1.0.2

- B. WIND FORCE DISTRIBUTION, EXPOSURE COEFFICIENTS AND VELOCITY/PRESSURE TRANSFORMATION PROCEDURES (3.3.1.2)

3.3-1

The provision of ASCE 1-1972 are applied

~~The provisions of ASCE 3-1989 are applied~~
 - or -

STORE & WEBSITE
 SATT; 1/1/00; ROOT SHESSAP

- C. OTHER CONSIDERATIONS

NA

SECTION 3.3.2 TORNADO LOADINGS

3.5

7

- A. TORNADO TRANSLATIONAL AND TANGENTIAL VELOCITIES, TORNADO PRESSURE DIFFERENTIAL AND TIME INTERVAL AND TORNADO MISSILE SPECTRUM WITH SPECIFIED CHARACTERISTICS (3.3.2.1)

Values reviewed for information only

PG 3.3-2
Pg 2.2-7

SWISSAP
TRANSLATIONAL $V_t = 5^{th} TO 11th$ RE-ENTRANCE $V_{re} = 290 MPH$

WINDSPEED DIFFERENTIAL = 3.26 IN/SEC DROP IN 1/2 SEC FOLLOWED BY A RISE OF 2.5 IN/SEC FOR 1/2 SEC - WINDSPEED = 3.26 IN/SEC IN 1/2 SEC

- B. TORNADO FORCE DISTRIBUTION, SHAPE COEFFICIENTS AND VELOCITY/CORRECTION TRANSFORMATION PROCEDURES (3.3.2.2)

The provisions of ASCE 1-1972 with shapes as specified in ASCE 32nd are applied

PG 3.3-2

The provisions of ASCE Part 10 are applied, respectively

SWISSAP
(ECF-3-a)

- C. VENTING CONSIDERATIONS (3.3.2.3)

The procedures by which venting, if considered, is used to reduce to tornado vacuum are described

PG 3.3-2

EC-TOP-3, SWISSAP

APPLIES TO AUXILIARY BULD ONLY - OTHER BUILDING NOT MENTIONED

- D. TORNADO MISSILE LOAD TRANSFORMATION PROCEDURES (3.3.2.4)

The procedures by which tornado generated missiles are transformed into effective loads are described

PG 2.5-23
INFO 3

EC-TOP-4, SWISSAP

- E. TORNADO LOAD EFFECT COMBINATION (3.3.2.5)

The tornado wind and pressure effects will be combined directly in a manner such as to be conservative for the structural element being considered. A satisfactory method of combining these effects is as follows:

PG 3.3-2

(i) $W_e = W_w$

(ii) $W_e = W_w$

(iii) $W_e = W_w$

$$(iv) W_t = W_w + .5 W_p$$

$$(v) W_t = W_w = W_m$$

$$(vi) W_t = W_w + .5 W_p = W_m$$

where: W_t total tornado load,
 W_w tornado wind load,
 W_p tornado differential pressure load, and
 W_m tornado missile load.

For each particular structure or portion thereof, the most adverse of the above combinations are used, as appropriate

- or -
BC-TOP-3, SWESSAP.

F. PROVISIONS FOR CATEGORY I STRUCTURES FROM TORNADO FAILURE OF NON-CATEGORY I STRUCTURES (3.3.2.3)

FIG. 3.3-3

Structures and components exposed to but not designed for tornado loads will be determined not to fail or generate missiles to the extent that Category I structures will be damaged.

- or -
Category I structures are designed to resist failure, collapse and missiles from structures and components not designed for tornado loads

- or -
BC-TOP-3, SWESSAP.

G. OTHER CONSIDERATIONS

FIG. 3.3-192

SECTION 3.3.1.2 STATES THAT DESIGN WIND LOADINGS FOR EACH CATEGORY I STRUCTURE IS SHOWN IN FIG. 3.3.1.2. HERE ONLY FOR THE AUXILIARY BUILDING, THE SERVICE WATER PUMP STRUCTURE, DIESEL GENERATOR BUILDING AND THE CONTAINMENT ARE IDENTIFIED. IN SECTION 3.3 YOU IDENTIFY MORE THAN FOUR BUILDINGS AS CATEGORY I STRUCTURES. WHERE IS INFO FOR OTHER CATEGORY I STRUCTURES?

SECTION 3.4.2 ANALYSIS PROCEDURES (FLOOD)

- A. DESIGN FLOOD AND/OR GROUND WATER LEVELS AND LOADINGS (3.4.2) P34-1-7
 Flood level values reviewed for information only. Flood levels indicated as applied as hydrostatic loadings or properly relieved by appropriate means

- or -
 SNESSAP.

COMPLIANT WITH REGULATORY GUID 1.59?
(HARDEN DESIGN APPROACH)

- B. DYNAMIC FLOOD-TO-LOAD TRANSFORMATION PROCEDURES (3.4.2) P34-1-7
 The procedures as delineated in the U.S. Army Coastal Engineering Research Center Technical Report No. 4 are applied

- or -
 SNESSAP.

COMPLIANT WITH REGULATORY GUID 1.59?
(HARDEN DESIGN APPROACH)

- C. STATIC FLOOD-TO-LOAD TRANSFORMATION PROCEDURES (3.4.2) P34-1-7
 Except where relieved by drainage and pumping, the hydrostatic head from highest flood or ground water level is applied as a direct foundation slab and basement wall load for structural and buoyancy computations. For lateral and overturning effects total wave included head is considered

- or -
 SNESSAP.

COMPLIANT WITH REGULATORY GUID 1.59?

(HARDEN DESIGN APPROACH)

WHAT IS MEANT BY PROVISIONS THAT ALLOW DOCS TO USE OF THESE TWO APPROACHES TO REPORT RESULTS?

HARDEN DESIGN APPROACH - STRUCTURAL PROVISIONS ARE INCORPORATED IN THE PLANT'S DESIGN THAT PROTECT SAFETY-RELATED STRUCTURES, SYSTEMS, AND COMPONENTS FROM THE STATIC AND DYNAMIC EFFECTS OF A FLOOD.


D. OTHER CONSIDERATIONS

3.4-263

WATER LEVEL 635.5

GRADE LEVEL 634.0

WATER MEMBRANE LEVEL 632.0 ?



SECTION 3.5.3 STRUCTURAL (BARRIER) DESIGN PROCEDURES

- A. PROCEDURES FOR CONCRETE LOCAL DAMAGE PREDICTION (3.5.3) P 3.5-28
Modified Petry equation as given in "Design of Protective Structures" (Amerikian), NP-3725.
- or -
Other equations shown to have equivalent conservatism.
- or -
Test data for missiles and barriers employed.

USE BC-TOP-9 SNESAP.

CONSIDER FRED CRACKS FOR BUILDING WITH SETTLEMENT
PROGRAMS AND TIME EVALUATION

- B. PROCEDURES FOR STEEL LOCAL DAMAGE PREDICTION (3.5.3) P 3.5-28
Stanford Research Institute equations
- or -
Other equations shown to have equivalent conservatism
- or -
Test data for missiles and barriers employed

BC-TOP-9 SNESAP

- C. PROCEDURES FOR COMPOSITE SECTION LOCAL DAMAGE PREDICTION (3.5.3) P 3.5-28
The method of Pecht and Iscon is applied when the first barrier is steel

BC-TOP-9

- D. PROCEDURES FOR OVERALL RESPONSE PREDICTION (3.5.3) P 3.5-28
The Williamson and Alvy procedure (NP-6515) is employed
- or -
Procedures that produce comparable results are employed.

BC-TOP-9 SNESAP.

- E. SPALLING AND SCABRING PROCEDURES P 3.5-28-19
Reviewed on a case-by-case basis. "No position."
J.V. P. - "RESULTS OF MISSILE IMPACT TESTS ON
REINFORCED CONCRETE PANELS" (NP 3.5-28)

- G. OTHER CONSIDERATIONS, 3.5-29
ARE TURBINE MISSILES AND OTHER COMPONENTS CONSIDERED TRIP & FI
TURBINE AXES PARALLEL TO CONTAINMENT, AX-BUILD & DRIFT BLDG
ARE COMPARISON OF LOW TRIP AND HIGH TRIP SECTION, ALTERN. G.

SECTION 3.7.1 SEISMIC INPUT

APPROVED BY: [Signature]
DATE: [Date]

A. DESIGN RESPONSE SPECTRA (SSE AND CRE) (3.7.1.1)

P. 3.7-1

Application factors are indicated as following Regulatory Guide 1.60 for all damping values and applied at finished grade.

* - or -
90-TOP-4, SWISSAP

~~REQUIRE DESIGN DIFFER FROM REGULATORY
WERE APPLIED TO ALL INPUT PER REQUIREMENT
AND DESIGN REQUIRED AND DESIGN OF...~~
~~SEE APPENDIX 3A FOR TABLE 3.7-1~~

B. RESOLUTION ANALYSIS PROCEDURES (3.7.1.1)

NA

The maximum acceleration at foundation level shall not be less than 50% of that at the surface and the procedures used are described.

~~NOT DISCUSSED~~

~~APPLIED @ FOUNDATION LEVEL~~

C. RESPONSE SPECTRA APPLICABILITY FOR VARIOUS FOUNDATION LOCATIONS (3.7.1.)

NA

The basis for the location selected should be described.

~~NOT DISCUSSED~~

~~APPLIED @ FOUNDATION LEVEL~~

D. RESPONSE SPECTRA/TIME HISTORY COMPARISON (3.7.1.0)

P. 3.7-1

Time history response spectra envelope the design response spectra for all damping values used in design with no more than five (5) points falling below (all within ten (10) percent) design spectra.

- or -

90-TOP-4 (if 2 points below are allowed), SWISSAP

~~USED TO CHECK & COMPARE WITH~~

~~THE DESIGN SPECTRA~~

* *

E. PERIOD INTERVALS FOR TIME HISTORY RESPONSE SPECTRA (3.7.1.2)

P. 3.7-1

Frequency intervals demonstrated small enough that reduction does not result in more than ten (10) percent change in computed spectra.

- or -

Minimum set chosen such that each frequency is within ten (10) percent of previous one

- or -

Table 3.7.1.1 review plan values are used.

- or -

90-TOP-4 SWISSAP

F. PERCENTAGE OF CRITICAL DAMPING VALUES (3.7.1.3)

7.3.7-1c

Damping values are indicated as being in accord with Regulatory Guide 1.61.

- or -

Higher values are justified.

- or -

PC-TOP-4 SHESSAP

SEE APPENDIX 3 A REGULATORY GUIDE 1.61

FOR CALCULATION OF ROTATION VELOCITY - NO CREDIT FOR MATERIALS

G. SUPPORTING MEDIA FOR EACH CATEGORY I STRUCTURE (3.7.1.4)

7.3.7-2

Information is provided for each structure of foundation attachment depth; to bedrock, foundation width, structure height and soil properties (shear-wave velocity, shear modulus, density) as a function of depth.

VALUES FOR ALL BUT THE BOARDS

WATER STORAGE TANKS. I DON'T SEE THEM IN THE TABLE

H. OTHER CONSIDERATIONS

3.7-6

CONSIDERATION OF THE EFFECTS DUE TO ACCIDENTAL TORSIONAL FORCES IN DESIGN (AS A MAXIMUM 5% BASE DIMENSION OFF-SETTING CRITERIA SHOULD APPLY).

FRANK
X

CHECK PROGRAM WITH SPECTRA. IT APPEARS THEY HAVE A DIP IN THE MIDDLE FREQUENCIES, ACCORDING TO ONE REVIEWER. SEE PART 2 - SAME COMMENT

SECTION 3.7.2 SEISMIC SYSTEM ANALYSIS

A. DYNAMIC SEISMIC ANALYSIS METHODS USED (3.7.2.1)

Time history or response spectrum method is used.

- or -

Equivalent static load method is fully justified

- or -

SOIL RC-TOP-4

SWISSAP

USGS Response Spectra Method

(WENT TO OTHER METHOD - FULL TIME, NORMAL)

P 3.7-2

B. DYNAMIC SEISMIC ANALYSIS METHOD ACCOUNTING FOR SOIL-STRUCTURE INTERACTION (3.7.2.2)

An appropriate method for consideration of soil-structure interaction is indicated to include consideration given to adjacent structures. For rock foundations and shallowly embedded deep soil foundations with uniform properties, single or multiple spring mass or finite element methods is used. For deeply embedded soil cases the finite element method is used. For all other cases either the multiple-spring-mass or finite element method is used.

- or -

RC-TOP-5

IMPEDANCE FUNCTIONS ~ EQUIVALENT SOILING
RADIATION DAMPING COEFF ~ RC-TOP-4

P 3.7-4

C. DYNAMIC SEISMIC ANALYSIS METHOD CONSIDERATION OF FOUNDATION TORSION, ROCKING AND TRANSLATION (3.7.2.1)

Consideration is given to foundation torsion, rocking, and translation in the model.

- or -

RC-TOP-4, SWISSAP

READ PER 3.7.2.11

P 3.7-6

D. SELECTION OF SIGNIFICANT MODES (3.7.2.1)

Investigation is made to ensure that inclusion of additional modes in the result will not effect the result by more than a ten (10) percent increase in response.

- or -

Twice the number of modes with frequencies lower than 10 cps is used in the result.

- or -



RC-TOP-4

P 3.7-2

E. DYNAMIC SEISMIC ANALYSIS CONSIDERATION OF MAXIMUM RELATIVE DISPLACEMENT ALONG SUPPORTS (3.7.2.1)

p 3.7-2

Consideration is given in the seismic dynamic analyses of support relative displacement.

- or -

BP-TOP-1 (for piping), SWISSAR

MAXIMUM RELATIVE SEISMIC DISPLACEMENT

ARE CONSIDERED IN ACCORDANCE WITH BC TOP-U-6

F. OTHER SIGNIFICANT EFFECTS ACCOUNTED FOR IN DYNAMIC SEISMIC ANALYSIS SUCH AS EXTERNAL RESTRAINTS, PIPING INTERACTIONS, HYDRODYNAMIC EFFECTS AND NON-LINEAR RESPONSE (3.7.2.1)

p 3.7-2

Consideration is indicated for inclusion of specific significant effects.

- or -

BP-TOP-1 (but not hydrodynamic effects and nonlinear response), SWISSAR

HYDRODYNAMIC EFFECTS CONSIDERED IN THE

SEISMIC SUPPORT ANALYSIS

G. MODAL RESPONSE COMBINATION PROCEDURE (3.7.2.7)

p 3.7-5

Modes are combined by square root of sum of squares except where closely spaced modes (i.e., modes with frequencies within 10% of each other) are encountered. For closely spaced modes the absolute sum is used

- or -

$$R = \sqrt{\sum_{k=1}^N R_k^2} = \sum_{i=1}^m R_i R_m^{1/2}$$

- or -

REGULATORY GUIDE 1.92 - WITH EXCEPTIONS

STATES IN APPENDIX 3A

H. DYNAMIC ANALYSIS DAMPING SYNTHESIS PROCEDURES (3.7.2.15)

p 3.7-3

The usage of a mass weighting function (fixed base model)

- or -

The usage of a stiffness weighting function (lump spring or (fixed base models)

- or -

A structural and foundation modal synthesis procedure

- or -

The method of Tsai is indicated.

- or -

BC-TOP-4 SWISSAR

EXCEPT DAMPING VALUES ARE SPECIFIED

IN SUBSECTION 3.7.1.3

REFERS TO APPENDIX 3A FOR DISCUSSION W R 6.61

J. CRITERIA EMPLOYED FOR SYSTEM/SUBSYSTEM DECOUPLING (3.7.2.3)

p3.7-4

The following criteria are acceptable:

If $R_m < 0.01$, decoupling can be done for any R_f

If $0.01 \leq R_m \leq 0.1$, decoupling can be done

If $R_f < .8$ or $R_f < 125$

If $R_m > 0.1$, an appropriate model of the subsystem is included

If $R_m > 0.1$, an appropriate model of the subsystem is included where

$$R_m = \frac{\text{Total Mass s Supported}}{\text{Total Mass of Support}}$$

$$R_f = \frac{\text{Fundamental frequency, supported system}}{\text{Frequency of predominant support motion.}}$$

SUBSYSTEM DECOUPLING IN ACCELERATION WITH

SECTION 3.2 OF BC-TOP-4-15

K. SELECTION OF LUMPED MASS PROCEDURES (3.7.2.3)

p3.7-4

The number of masses selected is adequate when the addition of masses (degrees of freedom) does not result in more than a ten (10) percent increase in response.

BC-TOP-4

L. MODELING THREE DIMENSIONAL CONSIDERATIONS (3.7.2.3)

p3.7-4

Three dimensional models should be used unless it is justified that coupling among omitted degrees-of-freedom are not significant.

- or -

BC-TOP-4, SHEAR

FEEL YOU NEED MORE JUSTIFICATION.

M. USE OF CONSTANT VERTICAL AMPLIFICATION FACTORS (3.7.2.10)

p3.7-4

Structure is justified as rigid in vertical direction by showing that lowest frequency is more than 25-cps

- or -

A vertical seismic dynamic analysis model is indicated.

- or -

BC-TOP-1, SHEAR

CONSTANT VERTICAL FACTORS ARE NOT USED.

4. MET-HDS FOR ACCOUNTING FOR TORSIONAL EFFECTS (3.7.2.11) p 3.7-6
Dynamic analysis model incorporated torsional degrees-of-freedom

Justified static factors are employed.

BC-TOP-4, SWISSAR
Application of an eccentricity value not less than 5% of the width of the column normal to the direction of the wind motion

5. FLOOR RESPONSE SPECTRA DEVELOPMENT PROCEDURE (3.7.2.12) p 3.7-5
The three components of motion of individual floor response spectra are combined by square root of sum of square addition at each frequency.

BC-TOP-4

6. FLOOR RESPONSE SPECTRA BROADENING (3.7.2.13) p 3.7-6
Effect of parameter variation in floor response spectrum are accounted for by increasing individual peak widths by a factor

local frequencies are varied according

$$\Delta f_j = \sqrt{(0.03f_j)^2 + Z(\Delta f_j)_m}$$

BC-TOP-4, SWISSAR

7. SEISMIC OVERTURNING MOMENT AND BASE SHEAR CALCULATIONS (3.7.2.14) p 3.7-7
The seismic overturning moment calculation includes consideration of three components of earthquake motion and conservative consideration of vertical and lateral seismic forces.

BC-TOP-4, SWISSAR

8. INTERACTION OF CATEGORY-I STRUCTURES WITH NON-CATEGORY-I STRUCTURES (3.7.2.15) p 3.7-5
The interface between both types is designed for loads produced by both types of structures. In addition, all non-category I structures are provided for such that 1) collapse will not strike a Category I structure, or 2) collapse impact will not impair integrity of impacted

Category I structures, or 3) non-Category I structures are designed and analyzed to Category I standards.

ANALYSIS OF STRUCTURES IN BC-70-4

6. TIME HISTORY/RESPONSE SPECTRUM RESPONSE COMPARISON (3.7.2.12) p 3.7-7
Results of modal time history and modal response spectra analysis are compared at selected points as a methods check for equivalency.

SEE: 12

COMPARISON FOR CONTINUOUS ANALYSIS

AUXILIARY BUILDING PORTIONED IN TABLE 3.7-3

7. THREE COMPONENT EARTHQUAKE STRUCTURAL RESPONSE PROCEDURES (3.7.2.6) pg 5.7
When response spectra method is used, the maximum structural response due to each of the three components is obtained as the square root of the sum of the squares of the maximum codirectional response

- or -
If the time history method is used, either the maximum response due to each of three components is obtained and combined as indicated previously or the three components are added algebraically at each time step.

BC-709-4, pg 1.92

8. NATURAL FREQUENCIES, RESPONSE LOADS AND RELATED DATA (3.7.2.2) p 3.7-6
A summary is provided for representative Category I structures of natural frequencies, mode shapes and modal responses. Time histories are provided for major plant equipment elevations and points of support.

UNIT FOR EQUIPMENT & AUXILIARY BUILDINGS

9. METHODS FOR CATEGORY I DAM SEISMIC ANALYSIS (3.7.2.13) p 3.7-7
A finite element analysis procedure which accounts for time history of forces, behavior of soils and evaluation of deformation is used.

- or -
The method of Seed, Lee and Tokimatsu is employed

NOT UTILIZED

SECTION 3.7.3 SEISMIC SUBSYSTEM ANALYSIS

A. SEISMIC ANALYSIS METHOD USED (3.7.3.1)

The procedures of 3.7.2 are applied as indicated in 3.7.2, items A, C, D, E, F

P3.7-9

SWISSAP

SPRING CAPACITY 2 SUBSYSTEMS OTHER THAN PIPES
ANALYSIS REVIEW OF THE DYNAMIC SPECTRUM METHOD (BC-74-

BC-74-11)

B. SEISMIC CYCLES FOR SUBSYSTEMS (3.7.3.2)

The SSE and five CSE are assumed with one number of maximum stress cycles obtained from a time history of ten seconds minimum duration equal to a minimum of ten maximum stress cycles

P3.7-9
REVISION 10
P 30-13

SWISSAP

ASME SECTION II NUCLEAR CLASS I PIPING
FOR TWO OCCASIONS ONE PIPE WITH THE NUMBER OF
MAXIMUM STRESS CYCLES IN SIMILAR TO THAT IN SECTION
II D CONDITION IS USED IN THE CALCULATION OF PRIMARY S.S.
(NO-3630 PIPING SECTION)

C. PROCEDURES FOR ANALYTICAL MODELING (3.7.3.3)

The procedures of 3.7.2 are applied as indicated in 3.7.2, items I, J, K, L

P3.7-11
CHAPTER 2-

SWISSAP

ALSO BC-TOP-4-14

D. DYNAMIC CHARACTERISTICS OF SUBSYSTEMS (3.7.3.4)

Fundamental frequency of subsystems is controlled to be greater than twice or less than one-half the dominant frequency of supporting system

P3.7-11

EQUIVALENT STATIC LOADS FOR BC-TOP-4-14
WITH BC-TOP-4-A

E. EQUIVALENT STATIC LOAD METHOD (3.7.3.5)

Justification is provided that system can be represented by single modal and conservative results are obtained in terms of structural response

P3.7-11/12

The method accounts for relative motion between all points of structural response

A factor of 1.5 is applied to applicable design response spectra or a lesser factor justified

BC-TOP-4, SWISSAP

SEE APPENDIX 3D SECTION 362 & 314

- F. MODELING THREE DIMENSIONAL CONSIDERATION (3.7.3.6)
The procedures of 3.7.2 are applied as indicated in 3.7.2,
item L

p 3.7-12

- or -
BC-TOP-4, SHEETS

SEE APPENDIX 3D -

- G. MODAL RESPONSE COMBINATION PROCEDURES (3.7.3.7)
The procedures of 3.7.2 are applied as indicated in 3.7.2,
item M

p 3.7-12

- or -
BC-TOP-4, SHEETS

SEE APPENDIX 3D - SECTION 30.1

- H. PIPING ANALYSIS PROCEDURES (3.7.3.8)
The procedures of 3.7.2 are applied as indicated in 3.7.2,
items A, C, D, E, F (dynamic analysis)

p 3.7-13

- or -
BC-TOP-1, SHEETS

The procedures of 3.7.3 are applied as indicated in 3.7.2,
item E

BC-TOP-1, SHEETS

SEE SECTION 30.2 OF APPENDIX 3D

ALSO LOOK AT BC-TOP-4

- I. MULTIPLY SUPPORTED SUBSYSTEM PROCEDURES (3.7.3.9)
An upper bound envelope of all individual support point
response spectra or, for multiple supports on a single system,
the worst floor response spectrum from a set of floor response
spectra obtained at various floors is employed to be applied
at all support points. In addition, the most unfavorable
combination of relatively support point displacements is
determined.

p 3.7-13

- or -

Time histories of all support point motions can be applied
directly and simultaneously.

- or -
BC-TOP-1 or BC-TOP-4

NOTE: NO MASS SUBSYSTEMS ARE
CONSIDERED AS MULTIPLY SUPPORTED
APPENDIX 3D

- J. TORSIONAL EFFECTS OF ECCENTRIC MASSES (3.7.3.11)
If the torsional effect of eccentric mass is significant
the mass and its eccentricity are included in the model.
Criteria for "significance" judged on case-by-case basis.

p 3.7-14

- or -

RC-TOP-4, SWISSAP

SEE APPENDIX 3D - SECTION 3.2.2 OF
APPENDIX 3D OF SIGNIFICANT TRENCHING
EFFECTS TAKEN INTO ACCOUNT TO GROUND MOTIONS

L. BURIED PIPING AND TUNNELS (3.7.3.12)

p. 3.7-14

The initial effects due to earthquakes are considered on the analysis using the procedures established in "Fundamentals of Earthquake Engineering" or Newmark's paper on "Earthquake Response Analysis of Reactor Structures" in NE and O, vol 20, pp. 303-322.

- and -

The static resistance of surrounding soil is considered using "Peens on Elastic Foundation"

- and -

The effects of local soil arching and settlement are considered.

- or -

RC-TOP-4, SWISSAP

SEE APPENDIX 3D - SECTION 3.0.4 - DISCUSS
THE TECHNIQUES USED TO CALCULATE TRENCHING AND
SEISMIC LOADS FOR BURIED PIPING AND TUNNELS

M. INTERACTION OF CATEGORY I AND NON-CATEGORY I PIPING (3.7.3.13)

p. 3.7-14

Non-Category I piping is designed to be isolated from Category I piping or analyzed according to Category I seismic criteria.

- or -

SWISSAP

TECHNIQUES USED DESCRIBED IN SECTION 3.4
OF GP-TOP-1

N. CRITERIA FOR SEISMIC ANALYSIS OF REACTOR INTERNALS (3.7.3.14)

p. 3.7-14

Dynamic analysis is employed with procedures equivalent to those established for seismic systems. The three components of earthquake motion are considered in a manner analogous to that used for seismic systems.

METHODS USED IN B&W ORDINANCE WITH B&W TOPICAL REPORT
B&W-10000 & B&W TOPICAL REPORT B&W-10000

O. DYNAMIC ANALYSIS DAMPING SYNTHESIS PROCEDURES (3.7.3.15)

The procedures of 3.7.2 are applied as indicated in 3.7.2, item H.

- or -

RC-TOP-4 SWISSAP

EXCEPT DAMPING VALUES SPECIFIED
IN SUBSECTION 3.7.1.3 OF FSAR

SECTION 3.7.4 SEISMIC INSTRUMENTATION

4. ADHERENCE TO REGULATORY GUIDE 1.12 (3.7.4.1) p 3.7-15

The seismic instrumentation is in compliance with
REG. RG 1.12.

- or -
SKESAP

COMPLIANCE WITH REGULATORY GUIDE 1.12
DISCUSSED IN APPENDIX 3B
RECORDED IN APPENDIX 3B

5. INSTRUMENT LOCATION AND DESCRIPTION (22) (3.7.4.2) p 3.7-15

A triaxial time history accelerometer will be installed in the free field or on the containment foundation; a seismic switch with control room readout will be installed on the containment foundation or free field; a triaxial response spectrum recorder with remote control room readout will be installed on the containment foundation; and, in addition, additional instrumentation will be provided at other locations.

- or -
SKESAP

6. SEISMIC INSTRUMENTATION PLAN (21) (3.7.4.2) p 3.7-15

A detailed plan that includes a description of instrumentation locations and how these locations are related to output vibratory motion is provided.

- or -
SKESAP

7. OPERATOR NOTIFICATION (3.7.4.3) p 3.7-17

The seismic switch located on the foundation of the containment is connected to event indicators in the control room in such a manner that a signal is given when the preset threshold level (0.5g acceleration) is exceeded.

- and -
The triaxial time history monitor will readout peak acceleration in the control room.

- and -
The response spectrum recorder will readout values at discrete frequencies.

SKESAP

SECTION 3.8.1 CONCRETE CONTAINMENT

1. CONTAINMENT GENERAL DESCRIPTION (3.8.1.1) 2.2.1-1-2
The description includes plans and sections of the containment and adjacent and adjoining structures, systems and components; details of the base slab; and details of the containment wall and roof.

- or -
SPPSSAP, PC-TOP-6
REINFORCED CONCRETE CONTAINMENT WALLS AND SLABS
1/2" LINDS W/ 4000 SCHEDULE 40 RINGS AND 1/2" S.C.

2. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.1.2) 2.2.1-2-4
The following are employed:
ACI/ASME 359; PG 1.10, 1.15, 1.19, 1.20, 1.25, 1.30

- or -
SPPSSAP
ACI-359 NOT USED. MAJORITY OF CONTAINMENT
DESIGN DONE PRIOR TO ISSUANCE OF ACI-359
TABLE 2.2-25 CONCRETE REINFORCEMENT

3. LOADS AND LOADING COMBINATIONS (3.8.1.3) P3.1.1-3.2.7
The loads and loading combinations are as specified in ACI-359 where test-load flooding is a design consideration. $1.0D + 1.0L + 1.0F_{ext}$ is also applied.

HOW ABOUT THE PARALLEL TEST LOADS?
LOAD COMBINATIONS SPECIFIED ON DRAWING 3.1-4
OF PS&C
SEE NOTE ABOVE ON ACI-359 CASE

4. DESIGN AND ANALYSIS PROCEDURES (3.8.1.4) 2.2.1-4-2
The design and analysis procedures are as established in ACI-ASME 359, Article CC-3000. WINDER 1977

- or -
For boundary conditions using foundation finite elements, a further extension would not affect results by more than fifteen (15 percent). For boundary conditions not using foundation finite elements, the foundation slab is used as a boundary with appropriate soil spring representation. The effects of non-axisymmetric loads such as those induced by wind, tornado, earthquakes and pipe rupture are considered. For localized and transient loads, the overall behavior is determined first and the localized load is superimposed. For stress, shrinkage and cracking, appropriate procedures are employed. For computer programs, the program is a recognized program; or the program has been checked against a recognized program; or it has been verified against analytical solutions and experimental tests and a history of successful use is provided. For tangential shear the provisions of Article CC-3000 are applied.

F. Flooded...
Veg. ...

For physical material properties variations, codes and
 design bound values are used.
 For thickened penetrations, total effect classifications apply.
 For steel liner and anchors, CC-3700 applies.
 For steel penetrations, section 37 applies.

SWISSAP

5.2.1.5 ACCEPTANCE CRITERIA (3.9.1.5)

23.1-12

For containment shell acceptance, the stress and strain limits
 are in accordance with CC-3700 provisions, except that for
 section CC-3711.5, the tangential shear stress carried by
 concrete, V_c , is limited to 40 psi and 60 psi for the 7th and
 8th divisions of shell CC-3711-1.

For liner plant acceptance, the stress and strain allowable
 of Tables CC-3700-1 and CC-3700-2 are applied.

SWISSAP, BC-TOP-5

← why not use CC-3711-1?

BC-3711-1-1971 ACI-317-67 ASTM FAC 1 - 672 311

5.2.1.6 MATERIALS, QUALITY CONTROL AND CONSTRUCTION TECHNIQUES (3.9.1.6)

23.1-19-46

The material provisions of Article CC-3700 of ACI-308 are
 being followed. The construction and quality control pro-
 visions of ACI-308 are being followed.

SWISSAP

UPON ASTM C 150, ASTM C 22, ACC 612, ACC 211
 ACC 219. ETC

Mix

5.2.1.7 TESTING AND INSERVICE SURVEILLANCE (3.9.1.7)

23.1-19-46

The provisions of Article CC-3700 of ACI-308 are being
 followed as required by the provisions of 3.9.1.5. For
 prestressed containments, the inservice surveillance
 requirements of 3.9.1.5 (unprestressed) or 3.9.1.5
 (prestressed) are followed as applicable.

SWISSAP

BC-TOP-5 R-03

TEST PROCEDURES COMPATIBLE WITH NRC REG. 101
 RECENT REVISIONS IN APPENDIX 50

TESTING

SECTION 3.9.2 STEEL CONTAINMENT SYSTEM

NA

A. CONTAINMENT GENERAL DESCRIPTION (3.9.2.1)

p. 3.2-47

General information pertaining to the containment shell is provided on (1) the bottom of the steel containment, (2) the cylindrical wall, (3) the dome of the steel shell and (4) major penetrations.

CONTAINMENT - PRESTRESSED, REINFORCED CONCRETE
STRUCTURE - THIS SECTION DOES NOT APPLY

B. ACCEPTABLE CODES, STANDARDS AND SPECIFICATIONS (3.9.2.2)

NA

Subsection NE of the ASME, Section III Division 1 and Regulatory Guide 1.57 are employed.

C. ACCEPTABLE CODES, STANDARDS AND SPECIFICATIONS (3.9.2.3)

NA

Subsection NE of the ASME, Section III Division 1 and Regulatory Guide 1.57 are employed.

D. LOADS AND LOADING COMBINATIONS (3.9.2.3)

NA

The loads are as specified in Subsection NE, Section III of the ASME Code and R.G. 1.57. The load combinations employed are: (1) $D+L+P_e+T_e$; (2) $D+L+T_e+P_o$; (3) $D+L+T_e+P_o+E$; (4) $D+L+T_e+R_e+P_e+E'$; (7) $D+L+T_e+P_e+P_e+E'$; (8) $D+L+T_e+P_e+P_e+Y_r+Y_j+Y_m+E'$; and (9) $D+L+P-L+E$

E. DESIGN AND ANALYSIS PROCEDURES (3.9.2.4)

NA

The design and analysis procedures are indicated as in compliance with article NE-3000 of the ASME Code Section III Division 1 and R.G. 1.57. Specific treatment of axisymmetric and non-axisymmetric loads and treatment of transient and localized loads is indicated. Computer codes used in the analysis are described and indicated.

F. STRUCTURAL ACCEPTANCE CRITERIA (3.9.2.5)

NA

The stress allowable are indicated as in compliance with Subsection NE, Section III of the ASME Code as indicated by Table 3.9.2-1 on page 3.9.2-2 of the Standard Review Plan.

F. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES (3.9.2.6) 111

The provisions of Article NB-2000 of the ASME Code Section III Division 1 are followed and the C/A program is in accordance with Articles NB-4000 and NB-5000 of the ASME Code Section III Division 1. Special construction techniques used are discussed and justified.

G. TESTING AND INSPECTION SUPERVISANCE REQUIREMENTS (3.9.2.7) 111

The preparational structural proof test is indicated as following Article NB-6000 of ASME Section III Division 1.

SECTION 3.2.3 CONCRETE AND STRUCTURAL STEEL INTERNAL STRUCTURES OF
Shell of Containment Building

A. DESCRIPTION OF INTERNAL STRUCTURES (3.2.3.1)

238-11

For PWR dry containments the description includes reactor supports, steel or another supports, reactor coolant pump supports, primary and secondary shield walls, floors and solar crane structures. For BWR ice condenser containments the description includes, in addition, the divider barrier and ice condenser. For BWR containments the description includes the drywell, refueling coil, insertion floor, reactor and recirculatory pump supports, reactor basket, reactor shield and miscellaneous platforms.

- or -

SWISSAR

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.2.3.2)

032-110

The following are employed:

ACI 318; ACI 309; ASME X-RTV Code, Section III, Division 1, Subsections MB and MF; AISC Specifications; ANSI M48.2.5; PG 1.10; PG 1.15; PG 1.55.

- or -

SWISSAR

See 3.2-67 702

C. LOADS AND LOAD COMBINATIONS (3.2.3.3)

232-72
 (USE WIRE MESHING AT)

Except for divider-barrier and ice-condenser elements of PWRs, the drywell of PWR Mark III containments, and linear steel supports of the reactor coolant system, the following apply:

Service Load Conditions:

Concrete and Steel for USD:

D+L, D+L+E and, if thermal stress is present,

(S)

(1.35S-Concrete)
 (1.50S-Steel)

D+L+To + Po, D+L+To + Po + E

Concrete for USD:

(II)

1.40 + 1.7L, 1.40 + 1.7L + 1.0E

and where thermal stress is present:

(II)

(.75) (1.40 + 1.7L + 1.7To + 1.70 Po)

(.75) (1.40 + 1.7L + 1.0E + 1.7To + 1.7Po)

Steel for Plastic Design:

1.7D + 1.7L, 1.7D + 1.7L + 1.0E

and where thermal stress is present:

(III)

1.3 (D+L + To + Po)

1.3 (D+L + E+To + Po)

Reaction Load Conditions:

Steel for USD

(1.45)

D+L+To+Po+E', D+L+Ta+Ra+Pa,

$D+L+T_a+P_a+Q_a+Y = F$
 $D+L+T_a+P_a+Q_a = Y + F'$
 Steel for Plastic Design and concrete for ASD: (1.75)
 (.95)

$D+L+T_c+P_c+Q_c+Y = F$, $D+L+T_a + P_a + 1.5P_a$,
 $D+L+T_c+1.05 P_c + Y = 1.25 F$,
 $D+L+T_c+P_c+Q_c + Y + e'$

For the divider barrier and Mark III drywall the loads, load combinations and stress limits of CC-3000 apply. For ice condenser elements the following apply:
Service Load Combinations:

Steel for ASD:
 $D+L$, $D+L+E$
 Steel for Plastic Design: (V)
 $1.7D + 1.7L$, $1.7D+1.7L+1.7E$
 Steel for test verification: (c)
 $1.9D+1.9L+1.9E$

Where thermal stresses are present, the procedures of NF-3221.1 are applied.

F. MATERIALS QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES (3.8.4.5) P 3.8-19

Compliance with ACI 318-71 for concrete, AISC-69 for steel, ASME NF for linear supports (Category I components), AWS D48.2.8 for general quality control, and ACI-309 for repairing bar welding.

SHESSAR
SEE PAGE 3.8-19 TO 41 ALSO
PAGE 3.8-60 TO 3.8-70 R

G. TESTING AND INSERVICE SURVEILLANCE (3.8.4.7) P 3.8-76

No specific requirements
COMPLY WITH RC-TOP-I-A & NEC R.6.1.18 PG. 3.8-40
NOT PLANNED FOR INTRAAS SURVEILLANCE P 3.8-76

F. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES
(3.9.3.3)

P. 3.9-57

The procedures and methods for the Category I containment structures are applied for containment base slab. No special acceptance standards apply to others.

SWISSAR

Suisse

I. 2.1.6

HEAD OF REAR CONTAINMENT (3.9.3.4)

P. 3.9-58

Factored Load Conditions:

Steel for WSD:

(1.35)

$D+L+E'$, $D+L+Pa$, $D+L+Pa+E'$ (1.6S)

Steel for Plastic Design:

(Y)

$1.3D+1.3L+1.3E'$, $1.3D+1.3L+1.3Pa$,

$1.2D+1.2L+1.2Pa+1.2E'$

Steel for test verification:

(C)

$1.4D+1.4L+1.4E'$, $1.4D+1.4L+1.4Pa$

$1.3D+1.3L+1.3Pa+1.3E'$

For reactor coolant linear steel supports, the following apply:

For WSD:

(Limit of X111-1100, MF)

$D+L+E$ (X 1.0), $D+L+E'$ (X 1.0), $D+L+E'+Pa+Y$ (X 1.5)

For Plastic Design:

(1.0)

1.7 (D+L+E)

1.2 (D+L+E')

1.0 (D+L+E'+Pa+Y)

- or -

SWISSAR

DESIGN AND ANALYSIS PROCEDURES (3.9.3.4)

P. 3.9-67

For BN Dry Containments the design and analysis procedures for linear reactor coolant supports are in accordance with Subsection III. The primary shield wall, secondary shield wall, other interior structures and the reactor cavity design and analysis procedures are in accordance with ACI 319-71.

For BN Ice-condenser divider barriers and BN drywells, design and analysis procedures are in accordance with those delineated in section CC-3007 of ACI-308 for concrete elements and Subsection III for steel elements. For BN steel drywell elements the design and analysis acceptance criteria of Section 3.9.3.4 apply.

SWISSAR

WSM STEEL

WSM CONCRETE

BN-TOP-2 & BC TOP-94 (PIPE BREAK EFFECT)

PIPE CONT

3.9.3.3

DESIGN AND ANALYSIS PROCEDURES

ASME DIVISION I

CONCRETE WATER PENETRATION

2. STRUCTURAL ACCEPTANCE CRITERIA (3.2.2.5)

3.2.2.5

With the exception of the divider-barrier and ice condenser elements of the containment; the forewall of the Mark III; and the linear steel supports of the reactor coolant system; the stress limits tabulate describe the load equations apply. Here S = the required section stress based on S_u allowable of ACI 318 and the AISI specifications, Part I; Y = the required section ultimate strength, Y = the AISI specification allowable, Part II, and C = tested collapse strength. For the Mark III divider-barrier and Mark III forewall, concrete design is used. For the Mark III divider-barrier and Mark III forewall, Section II applies.

- OF -

SISSSR

Structural Acceptance Criteria Summary 3.2.6.5

3. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES (3.2.2.6)

3.2.2.6

Compliance with ACI 318-71 for concrete, AISI-69 for steel, ASME WP for reactor coolant system supports, ANSI NS-2.5 for general quality control and ACI-309 for reinforcing bar welding.

SUB-CRITERIA 3.2.1.6

SECTION 3.8.4 OTHER CATEGORY I STRUCTURES

A. DESCRIPTION OF OTHER CATEGORY I STRUCTURES (3.8.4.1)

93.8-51

For other Category I structures the description includes the containment enclosure building, auxiliary building, fuel storage building, control building, diesel generator building, and miscellaneous Seismic Category I structures.

SHESSAP

CONTAINMENT ENCLOSURE BUILDING, DIESEL GENERATOR BUILDING, FUEL STORAGE BUILDING, CONTROL BUILDING, AUXILIARY BUILDING, MISCELLANEOUS CATEGORY I STRUCTURES, AND MISCELLANEOUS CATEGORY I STRUCTURES.

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.4.2)

93.8-52

The following are employed:

ACI 318; ACI 309; ASME B31M Code Section III, Div. 1, Subsections NF and NE; AISC; ANSI A5.2.3; RC 1.10; RC 1.11;

SUBSECTION 3.8.4.2 + SPECIFIC DETAILS

C. LOADS AND LOAD COMBINATIONS (3.8.4.3)

93.8-53 25

The following load combinations apply

Service Load Conditions:

Concrete and Steel for MSD:

(S)

$D+L, D+L+E, D+L+W$

and if thermal stress is present

(1.35-Concrete
1.35-steel)

$D+L+T_0+P_0, D+L+T_0+P_0+E$

$D+L+T_0+P_0+W$

Concrete for USD:

$1.4D+1, 1.4D+L+1.9E,$

$1.4D+1.7L+1.7W$

and if thermal stress is present

(U)

$(.75) (1.4D+1.7L+1.7T_0+1.7P_0)$

$(.75) (1.4D+1.7L+1.9E+1.7T_0+1.7P_0)$

$(.75) (1.4D+1.7L+1.7W+1.7T_0+1.7P_0)$

Steel for Plastic Design:

(Y)

$1.7D+1.7L, 1.7D+1.7L+1.7E,$

$1.7D+1.7L+1.7W$

Factored Load Conditions:

Steel for USD:

(1.5S)

$D+L+T_0+P_0+E'$ and $W_T, D+L+T_0+P_0+P_0$

$D+L+T_0+P_0+P_0+Y+E'$

Steel for plastic design and concrete for USD:

(1.5U)

$D+L+T_0+P_0+E'$ and $W_T, D+L+T_0+P_0+1.5-E'$

$D+L+T_0+1.5P_0+Y+1.2EE,$

$D+L+T_0+P_0+P_0+Y+E'$

- or -

SHESSAP

D. DESIGN AND ANALYSIS PROCEDURES (3.3.4.3)

P. 3.3-55

For concrete structures ACI 318-71 is utilized. For steel structures, AISC specifications are utilized.

- or -

SWISSAR

Subsection 3.3.4.3 - SPECIFICS ON ACI & AISC CODES

E. STRUCTURAL ACCEPTANCE CRITERIA (3.3.4.4)

P. 3.3-56

The stress limits tabulated opposite the load equations apply.

- or -

SWISSAR

SEE SPECIFICATIONS 3.3.4.4

TABLE 3.3-10¹² 22 27 28 31

MIDLAND PLANT [UNIT 1 & 2]

CATEGORY I STRUCTURES

(PG - 3.8-51)

- 1) UNIT 1 & 2 CONTAINMENT
- 2) AUXILIARY BUILD.
- 3) DIESEL GEN. BUILD.
- 4) SERVICE WATER COOLING TOWER
- 5) CORRUGATED WATER STORAGE TANKS.

QUESTIONS

Section 3.3

① CATEGORY I STRUCTURES - SHOWING WIND FORCES & DISTRIBUTION. SEE THE AUXILIARY BUILDING, CONTAINMENT, SERVICE WATER PUMP STRUCTURE AND THE DIESEL GENERATOR BUILDING. WHAT ABOUT THE BOATED WATER STORAGE TANKS? DO NOT SEE ANY ^{WIND} LOADINGS FOR THIS (CATEGORY 2) STRUCTURE.

② FIG 3.3-1 & 3.3-2

③ IN CASE OF RUPTURE OF THE BOATED WATER TANKS DUE TO A TORNADO OR TORNADO GENERATED MISSILE, THE LIQUID WOULD BE CONTAINED WITHIN THE REINFORCED CONCRETE DYKE SURROUNDING THE TANKS. (PG 3.8-54 -) 7.7

QUESTIONS

SECTION 3.4.2

- ① DO THE FLOOD STATIC & DYNAMIC EFFECTS AS DESCRIBED IN REGULATORY GUIDE 1.54 COMPLY WITH THE U.S. ARMY CORP. COASTAL ENGINEERING RESEARCH CENTER TECHNICAL REPORT NO 4 OF SWELLAGE?

QUESTIONS 3.5.3

① FOR CONCRETE LOCAL DAMAGE PREDICTION
WHAT IF ANY ARE THE DIFFERENCES BETWEEN THE
MODIFIED PETRY EQUATION AS GIVEN IN
"DESIGN OF PROTECTIVE STRUCTURES" (AMERICAN), NP-776
AND BC-TOP-9, OR SWISSAP?

② PROCEDURES FOR STEEL LOCAL DAMAGE PREDICTION

WHAT IF ANY ARE THE DIFFERENCES BETWEEN THE
STANFORD RESEARCH INSTITUTE EQUATIONS AND
BC-TOP-9, OR SWISSAP?

③ PROCEDURES FOR COMPOSITE SECTION LOCAL DAMAGE
PREDICTION.

WHAT IF ANY ARE THE DIFFERENCES BETWEEN THE
METHOD OF RECHT AND IPSON IS APPLIED ~~IS~~ WHEN
THE FIRST BARRIER IS STEEL & WHEN BC-TOP-9
IS USED UNDER SIMILAR CONDITIONS?

④ PROCEDURES FOR OVERALL RESPONSE PREDICTION

WHAT IF ANY ARE THE DIFFERENCES BETWEEN
WILLIAMSON AND ALVY PROCEDURE (NP-6515)
AND BC-TOP-9 OR SWISSAP?

⑤ ~~QUESTIONS~~ QUESTIONS 1 TO 4 ARE FOR MYSELF-

QUESTIONS 3.7-1

① SUPPORTING MEDIA FOR EACH CATEGORY I STRUCTURE.

DID NOT SEE VALUES FOR BOLATED WATER STORAGE TANKS
(TABLE 3.7-1). I BELIEVE THE BOLATED WATER
TANKS ARE CATEGORY I STRUCTURES - AM I CORRECT?

IF SO WOULD LIKE TO SEE THESE VALUES.
(IN TABLE)

① EMBEDMENT DEPTH

② BEDROCK

③ FOUNDATION WIDTH (52' DIA TANK)

④ STRUCTURE HEIGHT (32' HEIGHT)

QUESTION 3.7.2-3

- 1) THE STATEMENT THE CONSTRUCTION AND DESIGN OF CATEGORY I STRUCTURES MINIMIZE THE COUPLING EFFECTS BETWEEN PRINCIPAL BUILDING DIRECTIONS BY ITSELF DOES NOT JUSTIFY THE USE OF LESS COMPLEX THAN COMPLETE 3-D MODELS. BUT TELL WHAT IN THE CONSTRUCTION AND DESIGN LEADS YOU TO THIS CONCLUSION?

3.7-20 TO 3.7-4

QUESTIONS 3.8.5 FOUNDATION

- ① P. 3.8-57 OF FSAR MENTIONS THAT THE FOUNDATION DESIGN INCORPORATES A WATERPROOF MEMBRANE UP TO ELEVATION 432 FT FOR THE CONTAINMENT, THE AUXILIARY BUILDINGS AND PORTIONS OF THE TUNNEL BUILDINGS.

WHAT IS THIS WATERPROOF MEMBRANE?
IS IT THE $\frac{1}{4}$ STEEL LINER FOR THE CONTAINMENT?

- ② P. 3.8-57 OF FSAR STATES THAT DUE TO THE MULTILEVEL CONFIGURATION OF THE FOUNDATION, SHEAR TRANSFER WILL NOT BE AFFECTED BY THE MEMBRANE. WHAT DO THE MEMEN BY THIS.

THE AUXILIARY BUILD FOUNDATION IS AT SIX DIFFERENT ELEVATIONS - THE CONTAINMENT IS AT ONE - JUST DONT UNDERSTAND THEIR STATEMENT? DOES IT APPLY TO ALL CAT 1 STRUCTURES?

LOADS & LOADINGS COMBINATIONS

CONTAINMENT - DESIGN LOADS (WORKING STRESS BASIS)

$$\begin{aligned} a. & D + F + L + T_0 \\ b. & D + F + L + P + T_A \\ c. & D + L + F + P_E + T_E \end{aligned}$$

D = DEAD LOAD

F = PRE STRESS LOAD

L = LIVE LOAD

P_E = PRESSURE (STRUCTURAL INTEGRITY OR LEAK RATE TEST)

P = DESIGN PRESSURE LOAD WITHIN CONTAINMENT - CENTRAL & DESIGN PRESSURE ADJUSTMENT

T₀ = THERMAL LOAD DUE TO OPERATING TEMP

T_A = THERMAL EFFECTS AND LOADS DURING TEST

T_B = THERMAL LOADS BASED ON TEMPERATURE DISTRIBUTION CORRESPONDING TO ACCIDENT PRESSURE

FACTORED LOADS

$$a) C = \frac{1}{\phi} (1.05 D + 1.5 P + 1.0 T_A + 1.0 F)$$

$$b) C = \frac{1}{\phi} (1.05 D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F)$$

$$c) C = \frac{1}{\phi} (1.05 D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_0)$$

$$d) C = \frac{1}{\phi} (1.05 D +$$

QUESTIONS SECTION 3.3.2 ^{OF} SER

- ① TORNADO MISSILE SPECTRA DOES NOT INCLUDE TOTAL MISSILE SPECTRA OF STANDARD REVIEW FROM 3.5.1.1 WHICH ARE PART OF CURRENT NRC MISSILE SPECTRA?
- ② IN SECTION 3.11 ARE QUESTIONS ON HOW VENTS (AUXILIARY BUILD) ARE IF NOT ALL FROM MISSILES?
- ③ PROVIDE INFORMATION ON BUILD DESIGN WIND LOADS FOR ALL OUTDOOR STRUCTURES - DON'T SEE ANY INFO FOR THE BOLTED WATER STORAGE TANKS?
- ④ STATEMENT ON EVALUATION FINDINGS - SHOULD THIS BE CHANGED WHEN DISCREPANCIES OR QUESTIONS ON SECTION EXIST?

QUESTION SECTION 3.4.2 OF RFR

RUDIT
①

HOW DOES THE PROCEDURES AS DETERMINED IN THE
U.S. ARMY CORP. ENGINEERING RESEARCH CENTER
TECHNICAL REPORT NO 4 COMPARE WITH
REGULATORY GUID 1.59 ?? - QUESTION RISED
SINCE THEY MENTION R.G. 1.59 ?

RUDIT
②

HOW DOES THE HARDEN PROTECTION APPROACH
COMPARE WITH R.G. 1.59 ??

③

WEIR CRUEL	635.5	(MAX FLOOD)
GRADE LEVEL	634.0	
WEIR MEMBRANE LEVEL	632.0	??

← This seems to be below WATER LEVEL

- WHAT EFFECT - DOES THIS HAVE ON STRUCTURE?
- DURING FLOOD - CAN WATER SEEP - INTO BUILDS.
- WHY NOT bring MEMBRANE ABOVE MAX FLOOD WATER LEVEL?

④ STATEMENT ON EVALUATION FINDINGS -
SHOULDN'T THESE BE DERIVED.

SECTION 3.8.3 & C

REQUESTED APPLICANT TO GIVE ALL DETAILS
INFORMATION ON CATEGORY = CONCEPT WITH

REF MEMO APPLICANT, 1983

FINAL EVALUATION TO BE COMPLETED UNDER
CARE OF THIS INFORMATION

WANT COPY OF THIS REQUEST
WHO WROTE IT & TO WHOM?
WHAT DETAILS & INFORMATION
WAS USED FOR -

Section 3.3.1 A SCE PAPER 3259

3.3.2 BCTOP 3-11
BCTOP - 9-11

3.4.2 2 1.59

3.5.2 BCTOP - 9-15

3.7.1 ? BCTOP - 4-11

3.7.2 RG 1.92

3.7.3 } → BCTOP - 1
BCW TOP BCTOP 1-11 1-11 1-11

3.8.1 16. 1.10

1.15

1.15

1.79

1.25

RG 1.75

BCTOP - 7/6

BCTOP - 5/4

3.9.2 BC 71A - 2

SECTIONS 3.3

3.4

3.5.3

3.7

3.9

CONTAINMENT DESIGNED BY
BECHTEL POWER CORPORATION (BCHP)

PRINCIPAL BUILDINGS AND STRUCTURES

UNIT 1 CONTAINMENT STRUCTURE

UNIT 2 CONTAINMENT STR

TURBINE BUILDINGS

AUXILIARY BUILDINGS

ADMINISTRATIVE AND SERVICE BUILDINGS

DIESEL GENERATOR BUILDINGS

SOLID RADIOACTIVE BUILDINGS

COMBINATION SHOP

COOLING POND WITH INTAKE AND DISCHARGE STR

SERVICE WATER COOLING TOWERS

RIVER INTAKE AND DISCHARGE STR

page 1-26 - COOPS AND STANDARD SPECIFICATIONS -

CAN STAY RICK SHACK DOWN - ?

SL MUST TAKE 100% WITH A

CERTAIN SET - ?

ASCE PAPER 3289

3.5.3

NATIONAL DEFENSE RESEARCH COMMITTEE FORMULA (NDR)

CONCRETE BUILDINGS

BRITISH RESEARCH LABORATORY FORMULA (BRL) STRUC

input for local buckling - the allowable
stress - the correct effects of temperature are
90% Yield for steel →
100% for concrete

GENERAL SOFTWARES

① FINEL - FINITE ELEMENT STRESS ANALYSIS

STATIC ANALYSIS OF PLATE AND SHELLS

② ANISOL - AXISYMMETRIC SHELLS & SOLID ANALYSIS

STATIC ANALYSIS OF LINEAR ELASTIC

AXISYMMETRIC STRUCTURES WITH ROTATIONAL
OR NON-AXISYMMETRIC LOADINGS

③ SAF - STRUCTURAL ANALYSIS PROGRAM

STATIC ANALYSIS OF LINEAR ELASTIC

THREE-DIMENSIONAL STRUCTURES USING FEM

④ KSTEL - ANALYSIS OF AXISYMMETRIC SHELLS

PROGRAM CALCULATES ELASTIC DEFLECTIONS AND
STRESSES IN THIN WALLS AXISYMMETRIC SHELLS
SUBJECTED TO ARBITRARY SURFACE EDITIONS AND
RING LOADS (MECHANICAL AND THERMAL)

SHELL WALL CAN CONSIST OF LAYERS OF
DIFFERENT ISOTROPIC OR ORTHOTROPIC MATERIALS

STRUCTURAL ACCEPTANCE CRITERIA

DATE FEB 1 1973 ACI 318-63

(DATE FEB 1 1973 ACI 318-71

EXCEPTIONS

- a) FACTORED LOAD CONDITIONS
- b) COMPRESSION IN CONCRETE

SHALL NOT EXCEED .007 C

STRAIN SHALL NOT EXCEED .003

TENSION IN CONCRETE

TENSION, SPREADS, ETC.
IN RESISTING FLEXURAL MEMBERS
FORCES

BRICK, SPALL IN CONCRETE PAGE 3.0-12 814

MEMBRANE CURVE IN CONCRETE PAGE 3.0-11

DBSAP BECHTEL STRUCTURAL ANALYSIS PROGRAM
MODIFIED VERSION OF SAP

③ ICES-STRUDL - INTEGRATED CIVIL ENGINEERING
SYSTEM STRUCTURAL DESIGN LANGUAGE

Performs linear elastic, static, frame
analysis.

SEISMIC STATIC AND DYNAMIC STRUCTURAL ANALYSIS SYSTEM

F.E. Program - analyze linear elastic structures

634	634	634
- 50	140	300
50	404	296

COMPUTER PROGRAMS USED IN THE SEISMIC ANALYSIS

- 1) SPECTRA
- 2) MODAL ANALYSIS OF PLANE FRAMES
- 3) TIME HISTORY ANALYSIS
- 4) RESPONSE SPECTRA
- 5) COMPOSITE DAMPING FOR SOIL-STRUCTURE SYSTEMS
- 6) BENTEL STRUCTURAL ANALYSIS PROGRAM

WANT BC-TOP-4-A
BC-TOP-9-A

APPENDIX 3D

BCW TOPICAL REPORT BAW 70503
PART 1 REV 1

BCW TOPICAL REPORT BAW 70503 REV 1

NEW FILE ACCIDENTAL - TORSIONAL EFFECTS

1) Multiple Support Systems
TORSIONAL EFFECTS

2) BILDER STEINER

3) STRUCTURE / PIPE / SOIL MOUNT SYSTEM

4) COUPLER / TUBES

5) UNDERDRAIN SYSTEMS

6) SPICE / NEW TUBES

7) SPICE / NEW TUBES

SEISMIC ANALYSIS

1) SEISMIC ANALYSIS OF PIPING SYSTEMS

2) LINEAR ELASTIC ANALYSIS OF PIPING

BC-TOP-7-4
BC-TOP-8 REV 1 → BUSTERS AND OTHER TENDON ANCHOR REGION

BC-TOP-1 REV 1 → SMALL PENETRATION BLANKS

BC-TOP-9-A
KSHALL → PIPE RESTRAINT - ENCROACHMENTS

BC-TOP-5A → RADIAL TENSION DUE TO CURVATURE IN PWT TERMINAL
SUGGESTION 4.5.9-6

ACT 318-63
ACT 318-71

> RASIAL SKELETON

See page 314
see page 315

- 1) $L = D + F$ (INITIAL TRANSFER OF PROTEAS)
- 2) $L = D + F$ (SUSTAINING PROTEAS)
- 3) $L = D + F + L + T_0$ (WINTER) → OK
- 4) $L = D + F + L + T_0$ (SUMMER)
- 5) $L = L + F + L + P + T_A$ (WINTER) → OK
- 6) $L = D + F + L + P + T_0$ (SUMMER)
- 7) $L = D + F + L + P_T$ → OK
LEFT OUT $T_0 - T_{A,0}$
- 8) $L = 1.05D + F + 1.5P + T_A$ (WINTER) → OK
- 9) $L = 1.05D + F + 1.5P + T_A$ (SUMMER)
- 10) $L = 1.05D + F + 1.25P + T_A + 1.25E$ (WINTER) → NO H₁
- 11) $L = 1.05D + F + 1.25P + T_A + 1.25E$ (SUMMER)
- 12) $L = 1.05D + F + T_0 + 1.25E$ (WINTER) → NO H₁
- 13) $L = 1.05 + F + T_0 + 1.25E$ (SUMMER) → NO H₁
- 14) $L = D + F + P + T_0 + E'$ (WINTER) → NO H₁
- 15) $L = D + F + P + T_0 + E'$ (SUMMER)
- 16) $L = D + F + T_0 + E'$ (WINTER) → NO H₁
- 17) $L = D + F + T_0 + E'$ (SUMMER) → NO H₁

$c = \frac{1}{6} (1.0D + 1.0M + 1.0F)$ ←

FILE 3.8-85 # 3.8-26

NOTE: SEIZING LOADS TAKEN FROM ASHED -
IN THE AND SUPPORTS AND
THE FINAL RESULTS

TRMS 3.8-1 - THROUGH 17

COMPUTER PROGRAMS - CONTINUUM MECHANICS
3.8-47

- ① SAP - BSEP
- ② FINEL
- ③ IDEF - STRUDAC
- ④ STADYME

COMPLEX PROGRAM - OTHER (GENERAL) STRUCTURE
3.8-5


- ① STRESS - STRUCTURAL ENGINEERING SYSTEMS COURSE
DISPLACEMENT METHOD - LINEAR ELASTIC - STATICALLY DETERMINATE
- ② PLATE BENDING - FINITE ELEMENT LINEAR ELASTIC
- ③ BUILDING DEFORMATIONS (TOWARDS) THREE DIMENSIONAL

FOUNDATIONS OF CAT I STRUCTURE DEFINED - ON PHAS 3.8-51

LOADS - DEFINITION OF TRMS - 3.8-96 B, C, D, - 7/

POSSIBLE MAXIMUM FLOOD (PMF) - ASCENDING FOR IN SEC 2

MODAL SUPERPOSITION METHOD



SEISMIC CATEGORY = SYSTEMS - MODAL SUPERPOSITION METHOD (MSM)

B DESIGN SYSTEM RESPONSE - (MSM) + SITE DESIGN SPECTRA

C) - RESONANT SPECTRA - (MSM) + DESIGN TIME HISTORY

3.7-4

The effects of multiple components of seismic motion are considered in system design rather than the seismic analysis.

uniform pseudostatic method
(Soil dynamic modulus of elasticity = 22,000 KSCF)
poisson's ratio = .42

3.5.4 Signal Instrumentation

- a) 6 - String Motor oscillation (SMA)
- b) 3 - Peak voltage oscillation (PRA)
- c) 2 - Current oscillation (CS)
- d) 1 - Signal spectrum analysis
- e) Recording and playback console

3.1.2.4 Soil Structure Interaction.

(a) LUMPED PARAMETER REPRESENTATION WHERE USE IS MADE OF A SINGLE DISTANCE OF SOIL WAS EMPLOYED.

(b) UNIFORM FOUNDATION MEDIA $E = 22,000 \text{ kg/cm}^2$
 $f = 0.42$

(c) Finite element method to design of foundation-media interaction with for all seismic category I structure.

LUMPED MASS SPRING MODEL USED FOR CASES WHERE DEPTH OF EMBEDMENT IS SHALLOW

AND SOIL FOUNDATION IS PRECISELY UNIFORM.

AND SUFFICIENT DEPTH THAT IT CAN BE

CONSIDERED AS HALF SPACE.

(d) Small ratio of structure embedment depth to structure width reduces influence of embedment effect - BC-TOP-4-A APPENDIX 1

3.7.2.1 Dynamic Analysis - M. L. L. L.

Category I systems analyzed - dynamic response

lumped mass model used for analysis
and analysis building

would see consideration of torsion, coupling and
translation response of structures and their foundation

3.7.2.2 NATURAL FREQUENCIES AND RESPONSES

3.7.2.3 PROCEDURE USED FOR MIXIN

Q.1 DO NOT SEE JUSTIFICATION THAT THE
COUPPING EFFECTS OF DEGREES OF
FREEDOM THAT ARE OMITTED, FREEDOM
THE THREE-DIMENSIONAL MODELS ARE
NOT SIGNIFICANT?

Q.2 DON'T SEE WHERE D. IS SATISFIED?
THE SUBSYSTEM IS SATISFIED?

C MENTION OF SECTION 3.2 OF BCTD-U-8
IS GIVEN - BUT THE RESULTS OF
THIS ARE NOT GIVEN - SEE S.R.P. 3.7.2

17.2

Dynamic Analysis of Dams

The Component of Earthquake Motion

7. 2L

8. 2L

9. 2L

10. 2L Conduct Vertical Earthquake 1/3 U.S.C.

11. - TORSIONAL EFFECTS NOT INCLUDED IN DYNAMIC ANALYSIS

LOW DAMPED HORIZONTAL SEISMIC RECORDS OBTAIN FROM DECOUPLED SEISMIC SYSTEMS ASSUMED IN AN IDEALIZATION IN CASE THREE THE SEISMIC COEFFICIENTS ECCENTRICITY OF 5% OF THE WIDTH OF THE STRUCTURE NORMAL TO THE DIRECTION OF THE INPUT MOTION UNDER CONSIDERATION

12. COMPARISON SHOW 0 TO 64% DIFFERENCE BETWEEN RESPONSE SPECTRUM & TIME HISTORY METHODS - FOR CONTAINMENT & AUXILIARY BLDG

13. OK NO (DAMS)

14. (OK)

15. FURTHER COMPLETE MODEL DRAINING OR REDUCE SYNTHESIS TECHNIQUE - ACCOUNT FOR ELEMENT ASSOCIATED DAMPING (USE SETOP-4-A)

C

3.2 DESIGN CATEGORY ± STRUCTURES

3.2.1 DESCRIPTION OF CONTAINMENT ±

3.2.1.2 Minimum Design Standards for Containment Structures
 ISSUANCE OF REG-359 - APRIL 1972
 TAKE 3.2-25 COMPARE APPROXIMATE COST PER LB OF
 WITH THIS APPROX. COST

REGULATORY GUIDES 1.10, 1.15, 1.17, 1.17, 1.25, 1.25 USE

3.2.1.2.1 LOADS & LOAD COMBINATIONS

USE 3.2.1.2.1 EQUATION (b) LEFT OUT LIVE LOAD
 (a) & (c) OK

USE 3.2.1.2.1 EQUATION (a) LEFT OUT LIVE LOAD
 (1) USE 1.0 INSTEAD OF 1.0 FOR FACTOR ON DEAD LOAD
 (2) FACTOR $1/8$?
 (4) USE 0.5 FOR FACTOR ON

USE 1/8 FACTOR

USE 1.0

EQUATION (b) (1) LEFT OUT LIVE LOAD
 (2) USE 1.0 INSTEAD OF 1.0 FOR FACTOR ON DEAD LOAD
 (3) FACTOR $1/8$?

REGULATORY/GENERAL REQUIREMENTS

(4) USE 1.25 FOR FACTOR OF THERMAL EXPANSION DUE TO SIZE - GUID 4.102 1.0 AS FACTOR BUT IS FOR THERMAL EXPANSION AND NOT DBA AND INCLUDE THERMAL EXPANSION AND LOAD DURING NORMAL OPERATION OF SYSTEM - NOT DURING TRANSIENT OR STEADY STATE CONDITION

EQUATION C

GENERAL /
SEVERE ENVIRONMENTAL

- (1) LEFT OUT LIVE LOAD
- (2) USED 1.05 FACTOR INSTEAD OF 1.0 FOR DEAD LOAD
- (3) INCLUDED PIPE RUST AT NOT INCLUDED IN SECTION
- (4) PIPE TENSILE RESISTANCE USED FACTOR 1.25 SPEC. USED 1.0

EQUATION D

GENERAL

- (1) LEFT OUT LIVE LOAD
- (2) USED 1.05 FACTOR INSTEAD OF 1.0 FOR DEAD LOAD
- (3) INCLUDED TOWER LOAD - NOT CALLED FOR IN SECTION

EQUATION E

GENERAL /
EXTREME ENVIRONMENTAL

- (1) LEFT OUT LIVE LOAD
- (2) DOES NOT INCLUDE PIPE RESISTANCE TERMS

EQUATION F

EXTREME / ENVIRONMENTAL

- (1) LEFT OUT LIVE LOAD
- (2) INCLUDED PIPE RESISTANCE
- (3) INCLUDED PIPE RUPTURE
- (4) DOES NOT INCLUDE EXTERNAL PRESSURE TERMS

EQUATION G

MAX FLOOD

- (1) LIVE LOAD LEFT OUT

Slip 7 of 17 cases

Part of page 3.8-7

C

EQUATION C

- (1) LEAF OUT LIVE LOAD
- (2) USES 1.05 FACTOR INSTEAD OF 1.0 FOR DEAD LOAD
- (3) INCLUDES PIPE BURSTURE NOT INCLUDED IN OTHERS
- (4) PIPE INTERNAL PRESSURE LOAD

REMARKS / SPECIAL REQUIREMENTS

EQUATION D

- (1) LEAF OUT LIVE LOAD
- (2) USES 1.05 FACTOR INSTEAD OF 1.0 FOR DEAD LOAD
- (3) INCLUDES TOWER LOAD NOT CALLED FOR IN OTHERS

REMARKS

EQUATION E

- (1) LEAF OUT LIVE LOAD
- (2) DOES NOT INCLUDE PIPE REMOVAL ITEMS

REMARKS

FAILURE REQUIREMENTS

EQUATION F

- (1) LEAF OUT LIVE LOAD
- (2) INCLUDES PIPE REMOVAL
- (3) INCLUDES PIPE BURSTURE
- (4) DOES NOT INCLUDE EXTERNAL PRESSURE TERM.

REMARKS / ENVIRONMENTAL

EQUATION G

- (1) LIVE LOAD LEAF OUT

MAX FLOOR

STAY 7 9 17 CASES

End of page 3.8-7

3.8.1.4 DESIGN & ANALYSIS PROCEDURE

~~(Design and Analysis Procedure)~~

3.8.1.7

3.8.2 STEEL CONFINEMENT NOT APPLICABLE

3.8.3 CONCRETE & SPECIAL STEEL INTERNAL STRUCTURES

3.8.3.1 DESCRIPTION OF INTERNAL STRUCTURES

3.8.6.3 - OTHER SEISMIC CATEGORY I STRUCTURES

STEEL STRUCTURES - OTHER THAN PIPE RESTRAINTS
DESIGNED BY WELDING STEEL
CONCRETE STRUCTURES - ULTIMATE STRAINING METHOD

3.8.6.3.2 PAGE 3.8-72

EQUATION (1) OK
(2)

ACI - 309

D = DEAD LOAD

L = LIVE LOAD

F = FLOOR FINISH LOAD

T₀ = THERMAL LOAD NORMAL OPERATION

R₀ = PIPE REACTION

P_V = EXTERNAL PRESSURE LOADS

P_E = PRESSURE LOAD DURING LOCAL PIPE FAILURE

T₁ = THERMAL LOAD DURING TEST

W = LOADS GENERATED BY DESIGN WIND

E₀ = LOADS GENERATED BY OBE

E₁ = LOADS GENERATED BY SSE

W₀ = TORNADO LOADING INCLUDING MISSILE IMPACT
A NOTE ENCLOSED IN W₀ HAS THE FOLLOWING:

W₀₀ = TORNADO WIND PRESSURE LOAD

W₀_p = DIFFERENTIAL PRESSURE LOADS DUE TO ATMOSPHERIC PRESSURE GRADIENT

W₀_m = TORNADO GENERATED MISSILE IMPACT EFFECT
(DESIGN BASE ACCIDENT) (DBA)

P₀ = DESIGN PRESSURE LOAD WITHIN CONTAINMENT

T₀ = THERMAL LOADS GENERATED BY (DBA) INCLUDING T₀

E₀ = PIPE REACTION (DBA) INCLUDING R₀

P_E = LOCAL EFFECTS (DBA) INCLUDING THE FOLLOWING:

P_{RR} = REACTION OF A RUPTURED HIGH ENERGY PIPE (DBA)

P_{RJ} = JET IMPINGEMENT FROM " " " (DBA)

P₀ = IMPACT OF A RUPTURED " " " (DBA)

SERVICE

TEST

$$D + L + F + P_v + T_o$$

Equation 10 p. 3.7-1

② SERVICE

$$D + L + F + T_o$$

Equation 11 p. 3.7-1

③ NORMAL

$$D + L + F + T_o + R_o + P_v$$

Equation 12

④ SEVERE ENVIRONMENTAL

$$D + L + F + T_o + E_o + R_o + P_v$$

$$D + L + F + T_o + W + R_o + P_v$$

20%
10%
10%
10%
10%
10%
10%
10%
10%
10%

FACTORS

⑤ SEVERE ENVIRONMENTAL

$$D + 1.13L + F + T_o + 1.5E_o + R_o + P_v$$

$$D + 1.13L + F + T_o + 1.5W + R_o + P_v$$

⑥ EXTREME ENVIRONMENTAL

$$D + L + F + T_o + E_{ss} + P_v$$

$$D + L + F + T_o + W_{ss} + P_v$$

⑦ ABNORMAL

$$D + L + F + 1.5P_a + T_a + R_a$$

$$D + L + F + P_a + T_a + 1.25R_a$$

⑧ ABNORMAL/SEVERE ENVIRONMENTAL

$$D + L + F + 1.25P_a + T_a + 1.25E_o + R_a$$

$$D + L + F + 1.25P_a + T_a + 1.25W + R_a$$

$$D + L + F + T_o + E_o + W$$

⑨ ABNORMAL/EXTREME ENVIRONMENTAL

$$D + L + F + P_a + T_a + E_{ss} + R_a + R_r$$

SERVICE LOGO CONDITIONS

$$D+L$$

$$D+L+E$$

IF THROUGH STAGE PRESENT

$$D+L+T_0+P_0$$

$$L+T_0+P_0+E$$

COMPOSITE

$$1.4D+1.7L$$

$$1.4D+1.7L+1.9E$$

WITH THROUGH STAGE PRESENT

$$.75(1.4D+1.7L+1.7T_0+1.7P_0)$$

$$.75(1.4D+1.7L+1.9E+1.7T_0+1.7P_0)$$

RINKLO

MIDLAND NPP - REVIEW Units 1 & 2

by: Frank Rinkala

START: 4-21-80

pro - ACI-35T

CONSUMER POWER CO. (CPCO)

Midland City Michigan

BEU: NSSS

1,300 MWe PWR

SRP RG 1.70 R-2 + Exception Letter 6/17

CHECKLIST AND REVIEW SUMMARY

SECTION 3.3.1 WIND LOADING

A. DESIGN WIND VELOCITY, RECURRENCE INTERVAL, VERTICAL VELOCITY PROFILES AND GUST FACTORS (3.3.1.1)

Values reviewed for information only ✓

- OF -

WESSAR

BSM04 @ 30FT 100YR GF 1.05

VERTICAL VELOCITY PROFILE AS PER ASCE 7-98 Table 1(4)

B. WIND FORCE DISTRIBUTION, SHAPE COEFFICIENTS AND VELOCITY/PRESSURE TRANSFORMATION PROCEDURES (3.3.1.2)

The provision of ASCE 7-98 are applied

- OF -

The provisions of ASCE 7-98 are applied ✓

- OF -

WESSAR

C. OTHER CONSIDERATIONS

N.A.

(*) OTHER CAT I STRUCTURES DO NOT HAVE 150FT RADII
LIMITATION FOR 360 MPH INSTEAD THE 360 MPH IS A
UNIFORM CONSIDERATION.

(*) TORNADO MISSILE SPECTRA TABLE 3.5-9

DOES NOT INCLUDE TOTAL MISSILE SPECTRA

PLANK }
ROD } INCLUDED
AUTO }
SOLE }

3"Ø STL PIPE }
6"Ø " " } NOT
12"Ø " " } INCLUDED

Q

Consider the effect of the missiles not considered in your missile spectra, which are part of the current NRE missile spectra and assess the protection provided by the current design parameters of controlling roof and wall slabs to the impact of these additional missiles. In the event that the current barriers are not capable of meeting the current acceptance criteria, identify the consequences. Pls, consider in your evaluation the effect of the cracks reported for several Category I structures as result of the settlement problem for the Midland NPP currently reported to NRE

SECTION 3.3.2 TORNADO LOADINGS

- A. TORNADO TRANSLATIONAL AND TANGENTIAL VELOCITIES, TORNADO PRESSURE DIFFERENTIAL AND TIME INTERVAL AND TORNADO MISSILE SPECTRUM WITH SPECIFIED CHARACTERISTICS (3.3.2.1)

Values reviewed for information only

3.3-2



SWESSAR

360 MPH (290 ROT. + 70 TRANSL.) R=150 FT.

3 PSI @ 2 PSI/SEC + 2 PSI/SEC + 3 PSI (A) (B)

- B. TORNADO FORCE DISTRIBUTION, SHAPE COEFFICIENTS AND VELOCITY/PRESSURE TRANSFORMATION PROCEDURES (3.3.2.2)

3.3-2

The provision of ASCE 1-1972 with shapes as specified in ASCE 32FF are applied

- or -

The provisions of ASCE Paper 3090 are applied exclusively

- or -

SWESSAR BC TOP 3-A ✓

- C. VENTING CONSIDERATIONS (3.3.2.2)

3.3-2

The procedures by which venting, if considered, is used to reduce to tornado vacuum are described

- or -

RC-TOP-3 SWESSAR

Applied to auxiliary Bldg not other Bldgs are mentioned. VENTS PROTECTION FROM MISSILES

- D. TORNADO MISSILE LOAD TRANSFORMATION PROCEDURES (3.3.2.2)

3.3-2

The procedures by which tornado generated missiles are transformed into effective loads are described

- or -

BC-TOP-9 SWESSAR

Section 3.5 for INPD.

- E. TORNADO LOAD EFFECT COMBINATION (3.3.2.2)

3.3-2

The tornado wind and pressure effects will be combined directly in a manner such as to be conservative for the structural element being considered. A satisfactory method of combining these effects is as follows:

(i) $W_t = W_w$

(ii) $W_t = W_p$

(iii) $W_t = W_m$

$$(iv) W_t = W_w + .5 W_p$$

$$(v) W_t = W_w = W_m$$

$$(vi) W_t = W_w + .5 W_p = W_m$$

where: W_t total tornado load,

W_w tornado wind load,

W_p tornado differential pressure load, and

W_m tornado missile load.

For each particular structure or portion thereof, the most adverse of the above combinations are used, as appropriate

- or -
BC-TOP-3, SWISSAP.

Section 3.4 of REFERENCE

F. PROVISIONS FOR CATEGORY I STRUCTURES FROM TORNADO
FAILURE OF NON-CATEGORY I STRUCTURES (3.3.2.3)

3.3-3

Structures and components exposed to but not designed for tornado loads will be determined not to ~~fail or otherwise~~ generate missile to the extent that Category I structures will be damaged.

- or -

Category I structures are designed to resist failure, collapse and missiles from structures and components not designed for tornado loads

- or -

BC-TOP-3, SWISSAP.

G. OTHER CONSIDERATIONS GENERAL

Fig 3.3-1d

Q Figures 3.3-1d-2 identify the Auxiliary Building, the Service Water Pump Structure and the Containment Building as the Category I Structures for the plant. In section 3.3 you identify more than three buildings as Category I structures. Pls provide the same type of information provided in Figs 3.3-1d-2 for the remainder of the Category I structures.

CONSIDERATIONS FOR UNDER DRAINING - WELL QUALIFICATION

SECTION 3.4.2 ANALYSIS PROCEDURES (FLOOD)

- A. DESIGN FLOOD AND/OR GROUND WATER LEVELS AND LOADINGS (3.4.2) 3.4-1
 Flood level values reviewed for information only. Flood levels indicated as applied as hydrostatic loadings or properly relieved by appropriate means

- or -
 SNESSAP.

RG 1.59 Table 3.4-1 Special Use Systems Protected

Design Basis Flood = Worst Probable Site Related Flood

- B. DYNAMIC FLOOD-TO-LOAD TRANSFORMATION PROCEDURES (3.4.2) 3.4-1e-2
 The procedures as delineated in the U.S. Army Coastal Engineering Research Center Technical Report No. 4 are applied

- or -
 SNESSAP.

RG 1.59 Appendix 3A

2.43.3 ; 2.43.5 ; 2.43.6

- C. STATIC FLOOD-TO-LOAD TRANSFORMATION PROCEDURES (3.4.2) 3.4-1e-3
 Except where relieved by drainage and pumping, the hydrostatic head from highest flood or ground water level is applied as a direct foundation slab and basement wall load for structural and buoyancy computations. For lateral and overturning effects total wave included head is considered

- or -
 SNESSAP.

RG 1.59 B HAZARDOUS PROTECTION APPROACH


Q WHAT IS THIS HAZARDOUS APPROACH
HOW THE USE OF TWO CRITERIA EFFECTS

- D. OTHER CONSIDERATIONS 3.4-2e-3



WATER LEVEL 635.5

GRADE LEVEL 634.0

WATER MEMBRANE LEVEL 632.0



- MINIMUM WALL THICKNESS ACCEPTANCE CRITERIA CHANGED
- CONSIDERATION OF CRACKS IN EVALUATION OF ROCKET ENGINE FAILURE
- EFFECTS OF MISSILE SPECTRA NOT SAME AS CURRENT SPECTRA:
 - WHAT EFFECTS LEAD TO TBM FAILURE, POSTERIOR TO
 - (COMPLETED)



SECTION 3.5.3 STRUCTURAL (BARRIER) DESIGN PROCEDURES

3.5-28

- A. PROCEDURES FOR CONCRETE LOCAL DAMAGE PREDICTION (3.5.3)
 - Modified Petry equation as given in "Design of Protective Structures" (American), NP-3726.
 - or -
 - Other equations shown to have equivalent conservatism.
 - or -
 - Test data for missiles and barriers employed.

BC-TOP-9A SNASSAP.
 CONSIDER THEM CRACKS FOR BLOSS
WITH SUFFICIENT PROBLEMS IN THE EVALUATION

TABLE 3.5-18
 FOR WALLS & ROOF
 DESIGN DATA

3.5-28

- B. PROCEDURES FOR STEEL LOCAL DAMAGE PREDICTION (3.5.3)
 - Stanford Research Institute equations
 - or -
 - Other equations shown to have equivalent conservatism
 - or -
 - Test data for missiles and barriers employed

BC-TOP-9A SNASSAP

- C. PROCEDURES FOR COMPOSITE SECTION LOCAL DAMAGE PREDICTION (3.5.3) 3.5-28
 - The method of Pecht and Ioson is applied when the first barrier is steel
 - or -

BC-TOP-9A

- D. PROCEDURES FOR OVERALL RESPONSE PREDICTION (3.5.3)
 - The Williamson and Alvy procedure (NP-3515) is employed
 - or -
 - Procedures that produce comparable results are employed.

BC-TOP-9A SNASSAP.

- E. SPALLING AND SCABRING PROCEDURES 3.5-29
 - Reviewed on a case-by-case basis. No position.


Protective equipment considered by Applicant

- F. OTHER CONSIDERATIONS 3.5-29 -

Tables + Figures

TURBINE MISSILES and other components considered
 Axis Parallel to Containment, Aux. Bldg & Diesel Bldg.
 Comparison of Low Trajectory & High Trajectory Missiles Considered

⊕ For certain frequencies are less conservative
there was a question on this
was the answer it? Is it ok!



SECTION 3.7.1 SEISMIC INPUT

A. DESIGN RESPONSE SPECTRA (SSE AND OBE) (3.7.1.1)

3.7-1

Application factors are indicated as following Regulatory Guide 1.60 for all damping values and applied at finished grade.

- or -

BC-TOP-4, SWESSAP

Has new Design Response Spectra increased by 50% to bring comp with Newmann's support spectra. Comparison with RGL based in Appendix 3 - Vertical 2/30 In Gov of Spectra



B. DECONVOLUTION ANALYSIS PROCEDURES (3.7.1.1)

NA

The maximum acceleration at foundation level shall not be less than 50% of that at the surface and the procedures used are described.

Applied @ Foundation Level!

C. RESPONSE SPECTRA APPLICABILITY FOR VARIOUS FOUNDATION LOCATIONS (3.7.1.)

NA

The basis for the location selected should be described.

Applied @ Foundation Level

D. RESPONSE SPECTRA/TIME HISTORY COMPARISON (3.7.1.2)

3.7-1

Time history response spectra envelope the design response spectra for all damping values used in design with no more than five (5) points falling below (all within ten (10) percent) design spectra.

- or -

BC-TOP-4-V (if 8 points below are allowed), SWESSAP

Taft N21E, 1952 Record



Fig 3.7-3 to 3.7-8 Comparison with Site Spectra @ Foundation

E. PERIOD INTERVALS FOR TIME HISTORY RESPONSE SPECTRA (3.7.1.2)

3.7-1

Frequency intervals demonstrated small enough that reduction does not result in more than ten (10) percent change in computed spectra.

- or -

Minimum set chosen such that each frequency is within ten (10) percent of previous one

- or -

Table 3.7.1.1 review plan values are used.

- or -

BC-TOP-4A SWESSAP

F. PERCENTAGE OF CRITICAL DAMPING VALUES (3.7.1.3)

3.7-1 & 2

Damping values are indicated as being in accord with Regulatory Guide 1.61.

- or -

Higher values are justified.

- or -

✓ PC-TOP-4: SWISSAP

Approved: 2h for Comparison to RG 1.61

for calculation of Radiation Damping - No credit for Vibration Damping

G. SUPPORTING MEDIA FOR EACH CATEGORY I STRUCTURE (3.7.1.4)

3.7-2

Information is provided for each structure of foundation embedment depth, to bedrock, foundation width, structure height and soil properties (shear wave velocity, shear modulus, density) as a function of depth.

Table 3.7-1

H. OTHER CONSIDERATIONS

3.7-6

CONSIDERATION OF THE EFFECTS DUE TO ACCIDENTAL TORSIONAL FORCES IN DESIGN (AS A MINIMUM

5% BASE DIMENSION OFF-SETTING CRITERIA SHOULD APPLY)

CHECK PROBLEM WITH CPOTRA IT APPEARS THAT THERE ARE A DIP IN THE MIDDLE FREQUENCIES, ACCORDING TO OUR REVIEWER:

See page 22 ⊗ Same Concern

SECTION 3.7.2 SEISMIC SYSTEM ANALYSIS

A. DYNAMIC SEISMIC ANALYSIS METHODS USED (3.7.2.1)

3.7-2

Time history or response spectrum method is used.

- or -

Equivalent static load method is fully justified

- or -

RC-TOP-46 S.E.S.S.A.P.

See 3.7-9 to 3.7-11 & 3.7-68

Use Compliance method for utilization soil method

B. DYNAMIC SEISMIC ANALYSIS METHOD ACCOUNTING FOR SOIL-STRUCTURE INTERACTION (3.7.2.4)

3.7-4

An appropriate method for consideration of soil-structure interaction is indicated to include consideration given to adjacent structures. For rock formations and shallowly extended deep soil foundations with uniform prospectus, single or multiple spring-mass or finite element methods is used. For deeply embedded soil cases the finite element method is used. For all other cases either the multiple-spring-mass or finite element method is used.

(3.7-1)

Table 3.7-1

2.5.2.7

- or -

RC-TOP-41

Appendix A of this Topical discusses Embedment Effect

Cont. & Anal. of Analysis w/ Coupling and Constraints. O.H. Crater

C. DYNAMIC SEISMIC ANALYSIS METHOD CONSIDERATION OF FOUNDATION TORSION, ROCKING AND TRANSLATION (3.7.2.1)

3.7-2

Consideration is given to foundation torsion, rocking, and translation in the model.

- or -

RC-TOP-4A S.E.S.S.A.P.

D. SELECTION OF SIGNIFICANT MODES (3.7.2.1)

3.7-2

Investigation is made to ensure that inclusion of additional modes in the result will not effect the result by more than a ten (10) percent increase in response.

- or -

Twice the number of modes with frequencies lower than 33 cps is used in the result.

- or -

RC-TOP-4A

E. DYNAMIC SEISMIC ANALYSIS CONSIDERATION OF MAXIMUM RELATIVE DISPLACEMENT ALONG SUPPORTS (3.7.2.1)
 Consideration is given in the seismic dynamic analyses of support relative displacement.

3.7-2

- or -
 BP-TOP-1 (for piping), SWESSAR

BP-TOP-4A for MAX DISPLACEMENT DUE TO SEISMIC LOADS
 ATTEND 30

F. OTHER SIGNIFICANT EFFECTS ACCOUNTED FOR IN DYNAMIC SEISMIC ANALYSIS SUCH AS EXTERNAL RESTRAINTS, PIPING INTERACTIONS, HYDRODYNAMIC EFFECTS AND NON-LINEAR RESPONSE (3.7.2.1)

3.7-2

Consideration is indicated for inclusion of specific significant effects.

- or -
 BP-TOP-1 (but not hydrodynamic effects and nonlinear response), SWESSAR

HYDRODYNAMIC EFFECTS CONSIDERED

G. MODAL RESPONSE COMBINATION PROCEDURE (3.7.2.7)

3.7-5

Modes are combined by square root of sum of squares except where closely spaced modes (i.e., modes with frequencies within 10% of each other) are encountered. For closely spaced modes the absolute sum is used

$$R = \sqrt{\sum_{K=1}^N R_k^2} = s \sum R_1 R_m \quad 1/2$$

RG 1.92 as discussed in Appendix 3A FOR EXCEPTIONS

H. DYNAMIC ANALYSIS DAMPING SYNTHESIS PROCEDURES (3.7.2.15)

3.7-7

The usage of a mass weighting function (fixed base model)

- or -
 The usage of a stiffness weighting function (lump spring or (fixed base models)

- or -
 A structural and foundation modal synthesis procedure

- or -
 The method of Tsai is indicated.

- or -
 EC-TOP-4A SWESSAR

Section 3.2 & 3.3 Method Values as per Section 3.7.1.3 which refers to Appendix 3A for discussion of Comparison of Risks!

J. CRITERIA EMPLOYED FOR SYSTEM/SUBSYSTEM DECOUPLING (3.7.2.3)

3.7-4

The following criteria are acceptable:

If $R_m < 0.01$, decoupling can be done for any R_f

If $0.01 \leq R_m \leq 0.1$, decoupling can be done

If $R_f < .8$ or $R_f < 125$

If $R_m > 0.1$, an appropriate model of the subsystem is included

If $R_m > 0.1$, an appropriate model of the subsystem is included where

$$R_m = \frac{\text{Total Mass s Supported}}{\text{Total Mass of Support}}$$

$$R_f = \frac{\text{Fundamental frequency, supported system}}{\text{Frequency of predominant support motion.}}$$

Section 3.3 of BC-TOP-4A

K. SELECTION OF LUMPED MASS PROCEDURES (3.7.2.3)

3.7-4

The number of masses selected is adequate when the addition of masses (degrees of freedom) does not result in more than a ten (10) percent increase in response.

- or -

BC-TOP-4A

L. MODELING THREE DIMENSIONAL CONSIDERATIONS (3.7.2.3)

3.7-5

Three dimensional models should be used unless it is justified that coupling among omitted degrees-of-freedom are not significant.

- or -

BC-TOP-4A SWESSAR

See Compliance w/ LG 1.92 as discussed in Appendix 3A

M. USE OF CONSTANT VERTICAL AMPLIFICATION FACTORS (3.7.2.10)

3.7-6

Structure is justified as rigid in vertical direction by showing that lowest frequency is more than 33 cps

- or -

A vertical seismic-dynamic analysis model is indicated.

- or -

BC-TOP-1, SWESSAR

Constant Vertical Load Factors are not used for the design of Cat. I systems

N. METHODS FOR ACCOUNTING FOR TORSIONAL EFFECTS (3.7.2.11)

3.7-6

Dynamic analysis model incorporated torsional degrees of freedom

- or -

Justified static factors are employed.

- or -

BC-TOP-4, SWESSAR

O. FLOOR RESPONSE SPECTRA DEVELOPMENT PROCEDURES (3.7.2.8)

3.7-5

The three components of motion of individual floor response spectra are combined by square root of sum of square addition at each frequency.

- or -

BC-TOP-4A

P. FLOOR RESPONSE SPECTRA BROADENING (3.7.2.9)

3.7-6

Effect of parameter variation in floor response spectrum are accounted for by increasing individual peak widths by ± 15 percent

- or -

modal frequencies are varied according

$$\text{to } \Delta f_j = \sqrt{(0.05f_j)^2 - z(\Delta f_j)_m}$$

- or -

BC-TOP-4A SWESSAR

Q. SEISMIC OVERTURNING MOMENT AND BASE SHEAR CALCULATIONS (3.7.2.14)

3.7-7

The seismic overturning moment calculation includes consideration of three components of earthquake motion and conservative consideration of vertical and lateral seismic forces.

- or -

BC-TOP-4A SWESSAR

R. INTERACTION OF CATEGORY I STRUCTURES WITH NON-CATEGORY I STRUCTURES (3.7.2.8)

3.7-5

The interface between both types is designed for load produced by both types of structures. In addition, all non-category I structures are provided for such that 1) collapse will not strike a Category I structure, or 2) collapse impact will not impair integrity of impacted

Category I structure, or (3) non-Category I structures are designed and analyzed to Category I standards.

- S. TIME HISTORY/RESPONSE SPECTRUM RESPONSE COMPARISON (3.7.2.12)

3.7-7

TABLE 3.7-1

Results of modal time history and modal response spectra analysis are compared at selected points as a methods check for equivalency.

- or -

SMERSAP

Response Spectrum Method with Time History & Modal Test record for floor response spectra determination.

- T. THREE COMPONENT EARTHQUAKE STRUCTURAL RESPONSE PROCEDURES (3.7.2.5)

3.7-5

When response spectra method is used, the maximum structural response due to each of the three components is obtained as the square root of the sum of the squares of the maximum codirectional response

- or -

If the time history method is used, either the maximum response due to each of three components is obtained and combined as indicated previously or the three components are added algebraically at each time step.

- or -

BC-TOP-4, PG 1.92

See Comparison in Appendix 3A

- U. NATURAL FREQUENCIES, RESPONSE LOADS AND RELATED DATA (OL) (3.7.2.2)

3.7-2a

A summary is provided for representative Category I structures of natural frequencies, mode shapes and modal responses. Time histories are provided for major plant equipment elevations and points of support.

Table 3.7-2 + Fig 3.7-12 to 3.7-53

- V. METHODS FOR CATEGORY I DAM SEISMIC ANALYSIS (3.7.2.13)

3.7-7

A finite element analysis procedure which accounts for time history of forces, behavior of soils and evaluation of deformation is used.

- or -

The method of Seed, Lee and Idriss is employed

N.A

SECTION 3.7.3 SEISMIC SUBSYSTEM ANALYSIS

A. SEISMIC ANALYSIS METHOD USED (3.7.3.1) 3.7-8

The procedures of 3.7.2 are applied as indicated in 3.7.2, items A, C, D, E, F

- or -

SMESSAP

Fig 3.7-54 to 3.7-63

Appendix 3B

B. SEISMIC CYCLES FOR SUBSYSTEMS (3.7.3.2) 3.7-9

One SSE and five CRE are assumed with the number of maximum stress cycles obtained from a time history of ten seconds minimum duration equal to a minimum of ten maximum stress cycles

- or -

SMESSAP

Section 3D.1. Appendix 3D

Also see ¹¹Appendix to R.G. 1.48 IC.3

C. PROCEDURES FOR ANALYTICAL MODELING (3.7.3.3) 3.7-10

The procedures of 3.7.2 are applied as indicated in 3.7.2, items I, J, K, L

- or -

SMESSAP

Appendix 3D

D. DYNAMIC CHARACTERISTICS OF SUBSYSTEMS (3.7.3.4) 3.7-11

Fundamental frequency of subsystems is controlled to be greater than twice or less than one-half the dominant frequency of supporting system

BC-TOP-4A Sect 4.2.1

Breakdown between NSSS Subsystems and Non-NSSS Subsystem

E. EQUIVALENT STATIC LOAD METHOD (3.7.3.5) 3.7-11

Justification is provided that system can be represented by simple model and conservative results are produced in terms of structural response

- and -

The method accounts for relative motion between all points of structural response

- and -

A factor of 1.5 is applied to applicable floor response spectra or a lesser factor justified

→ BC-TOP-4, SMESSAP

See Appendix 3D Section 3D.2 & 3D.4 For Piping

F. MODELING THREE DIMENSIONAL CONSIDERATION (3.7.3.6) 3.7-12
The procedures of 3.7.2 are applied as indicated in 3.7.2,
item L

- or -
BC-TOP-4, SHESSAP

Appendix 3D

G. MODAL RESPONSE COMBINATION PROCEDURES (3.7.3.7) 3.7-12
The procedures of 3.7.2 are applied as indicated in 3.7.2,
item G

- or -
BC-TOP-4, SHESSAP

Appendix 3D

H. PIPING ANALYSIS PROCEDURES (3.7.3.8) 3.7-13
The procedures of 3.7.2 are applied as indicated in 3.7.2,
items A, C, D, E, F (dynamic analysis)

- or -
The procedures of 3.7.3 are applied as indicated in 3.7.2,
item E

- or -
PP-TOP-1, SHESSAP

Appendix 3D - Also Sect 3.7.3.1.2

I. MULTIPLY SUPPORTED SUBSYSTEM PROCEDURES (3.7.3.9) 3.7-13
An upper bound envelope of all individual support point
response spectra or, for multiple supports on a single system,
the worst floor response spectrum from a set of floor response
spectra obtained at various floors is employed to be applied
at all support points. In addition, the most unfavorable
combination of relatively support point displacements is
superimposed.

- or -
Time histories of all supports point motions can be applied
directly and simultaneously.

- or -
BC-TOP-4 or PP-TOP-1

Also Section 3D.4 of Appendix 3D

V. TORSIONAL EFFECTS OF ECCENTRIC MASSES (3.7.3.11) 3.7-14
If the torsional effect of eccentric mass is significant
the mass and its eccentricity are included in the model.
(Criteria for "significance" judged on case-by-case basis.)

BC-TOP-4, SNESSAP

Section 3D.2 Appendix 3D

L. BURIED PIPING AND TUNNELS (3.7.3.12)

3.7-14

The initial effects due to earthquakes are considered on the analysis using the procedures established in "Fundamentals of Earthquake Engineering" or Newmark's paper on "Earthquake Response Analysis of Reactor Structures" in NE and D, vol 20, pp. 303-322.

- and -

The static resistance of surrounding soil is considered using "Beams on Elastic Foundation"

- and -

The effects of local soil arching and settlement are considered.

- or -

BC-TOP-4, SNESSAP

Section 3D.2 of Appendix 3D

M. INTERACTION OF CATEGORY I AND NON-CATEGORY I PIPING (3.7.3.13)

3.7-14

Non-Category I piping is designed to be isolated from Category I piping or analyzed according to Category I seismic criteria.

- or -

SNESSAP

Section 3.4 BP-TOP-1

N. CRITERIA FOR SEISMIC ANALYSIS OF REACTOR INTERNALS (3.7.3.14)

3.7-14

Dynamic analysis is employed with procedures equivalent to those established for seismic systems. The three components of earthquake motion are considered in a manner analogous to that used for seismic systems.

B&W TOP Report 1-0002 1-0-25

O. DYNAMIC ANALYSIS DAMPING SYNTHESIS PROCEDURES (3.7.3.15)

3.7-15

The procedures of 3.7.2 are applied as indicated in 3.7.2, item H

- or -

BC-TOP-4A SNESSAP

Section 3.2.1 Except

Damping Values as per Section 3.7.1.3

SECTION 3.7.4 SEISMIC INSTRUMENTATION

A. ADHERANCE TO REGULATORY GUIDE 1.12 (3.7.4.1)

3.7-15

The seismic instrumentation is in compliance with
AEC PG 1.12. *Revised 1 April 1974*

- or -
SNESSAP

Discussed in Appendix 3L

B. INSTRUMENT LOCATION AND DESCRIPTION (CP) (3.7.4.3)

3.7-15

A triaxial time history accelograph will be installed in the free field or on the containment foundation; a seismic switch with control room readout will be installed on the containment foundation or free field; a triaxial response spectrum recorder with remote control room readout will be installed on the containment foundation; and, in addition, additional instrumentation will be provided at other locations.

- or -
SNESSAP

C. SEISMIC INSTRUMENTATION PLAN (OL) (3.7.4.2)

3.7-15 & 16

A detailed plan that includes a description of instrumentation locations and how these locations are related to output vibratory motion is provided.

- or -
SNESSAR

D. OPERATOR NOTIFICATION (3.7.4.3)

3.7-17

The seismic switch located on the foundation of the containment is connected to event indicators in the control room in such a manner that a signal is given when the preset threshold level (ORE) acceleration) is exceeded

- and -
The triaxial time history monitor will readout peak acceleration in the control room

- and -
The response spectrum recorder will readout values at discrete frequencies

- or -
SNESSAR

SECTION 3.8.1 CONCRETE CONTAINMENT

A. CONTAINMENT GENERAL DESCRIPTION (3.8.1.1)

3.8-1-2

The description includes plans and sections of the containment and adjacent and adjoining structures, systems and components; details of the base slab; and details of the containment wall and domes.

- OR -

SWISSAR, RC-TOP-5

PRESTRESSED CONCRETE CONTAINMENT CYLINDRICAL DOME (S/A 200)

2-1/2" W/STAINLESS STEEL @ 4" O.C. WALLS 2-1/2" W/STAINLESS STEEL @ 4" O.C.

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.1.2)

3.8-2

The following are employed:

ACI/ASME 359; PG 1.10, 1.15, 1.18, 1.19, 1.25, 1.55.

- OR - *Cracks, Aging, Fire, Corrosion, Spalls, Concrete Placement*

SWISSAR

Codes used as Reference - ACI 359 (S)

ASTM
TOPICALS as identified in Section 1.6

C. LOADS AND LOADING COMBINATIONS (3.8.1.3)

3.8-4

The loads and loading combinations are as specified in ACI-359. Where post-LULR flooding is a design consideration $1.0D + 1.0L + 1.0F_{ext}$ is also applied

19

- OR -

SWISSAR

*C. 11/1/76
P. 155
7.2.1*

[19] How about the Pressure-Test Equation

D. DESIGN AND ANALYSIS PROCEDURES (3.8.1.4)

3.8-7

3.8-61

The design and analysis procedures are as established in ACI-ASME 359, Article CC-3000. Winter 1975

By COMPARISON

- OR -

For boundary conditions using foundation finite elements, a further extension would not affect results by more than fifteen (15 percent). For boundary conditions not using foundation finite elements, the foundation slab is used as a boundary with appropriate soil spring representation. The effects of non-axisymmetric loads such as those induced by wind, tornado, earthquakes and pipe rupture are considered. For localized and transient loads, the overall behavior is determined first and the localized load is superimposed. For creep, shrinkage and cracking, appropriate procedures are employed.

For computer programs, the program is a recognized program; or the program has been checked against a recognized program; or it has been validated against classical solutions and experimental tests and a summary comparison of all validations are provided.

For tangential shear the provisions of Article CC-3000 are applied.

For physical material properties variations, upper and lower bound values are used.
 For thickened penetrations, local effect considerations apply.
 For steel liner and anchors, CC-3600 applies.
 For steel penetrations, section HE applies.

- or -

SWISSAP

FINEL ASHSD

BC-TOP-7A ; - 8 ksi ; - 1 ksi ; 9A ; SA Set 45.9 Ex DE-2

F. STRUCTURAL ACCEPTANCE CRITERIA (3.8.1.5)

3.8-12



For containment shell acceptance, the stress and strain limits are in accordance with CC-3400 provisions, except that for section CC-3411.5, the tangential shear stress carried by concrete, V_c , is limited to 40 psi and 60 psi for the 7th and 7th combinations of Table CC-3200-1.

- and -

For liner plant acceptance, the stress and strain allowables of Tables CC-3700-1 and CC-3700-2 are applied.

- or -

SWISSAP, BC-TOP-5 ACI-318-71 (6) w/ some exceptions ← WHY NOT USE THE THE CONSTRUCTION

G. MATERIALS, QUALITY CONTROL AND CONSTRUCTION TECHNIQUES (3.8.1.6)

3.8-19

The material provisions of Article CC-2000 of ACI-309 are being followed. The construction and quality control provisions of ACI-309 are being followed.

- or -

SWISSAP

ASTM A61 AWS

H. TESTING AND INSERVICE SURVEILLANCE (3.8.1.7)

3.8-40

The provisions of Article CC-6000 of ACI-309 are being followed as augment by the provisions of PG 1.18. For prestressed containments, the inservice surveillance requirements of PG 1.35 (uncrouted tendons) or PG 1. (grouted tendons) are followed as applicable.

- or -

SWISSAP, BC-TOP-3A Riv-3 Req Guide 1.18 as

discussed in Appendix 3A

TEST LOG

SECTION 3.8.2 STEEL CONTAINMENT SYSTEM

N.A.

A. CONTAINMENT GENERAL DESCRIPTION (3.8.2.1)

General information pertaining to the containment shell is provided on (1) the bottom of the steel containment, (2) the cylindrical wall, (3) the dome of the steel shell and (4) major penetrations.

B. ACCEPTABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.2.2)

Subsection NE of the ASME, Section III Division 1 and Regulatory Guide 1.57 are employed.

B. ACCEPTABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.2.2)

Subsection NE of the ASME, Section III Division 1 and Regulatory Guide 1.57 are employed.

C. LOADS AND LOADING COMBINATIONS (3.8.2.3)

The loads are as specified in Subsection NE, Section III of the ASME Code and R.G. 1.57. The load combinations employed are: (1) $D+L+T_e$; (2) $D+L+T_e+P_o$; (3) $D+L+T_e+P_o+E$; (4) $D+L+T_e+R_e+P_e+E'$; (5) $D+L+T_e+R_e+P_e+E'$; (6) $D+L+T_e+P_a+P_r+Y_r+Y_m+E'$; and (7) $D+L+F+L+E$

D. DESIGN AND ANALYSIS PROCEDURES (3.8.2.4)

The design and analysis procedures are indicated as in compliance with article NE-3000 of the ASME Code Section III Division I and R.G. 1.57. Specific treatment of axisymmetric and non-axisymmetric loads and treatment of transient and localized loads is indicated. Computer codes used in the analysis are described and indicated.

E. STRUCTURAL ACCEPTANCE CRITERIA (3.8.2.5)

The stress allowables are indicated as in compliance with Subsection NE, Section III of the ASME Code as interpreted by Table 3.8.2-1 on page 3.8.2-8 of the Standard Review Plan.

F. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES
(3.P.26)

The provisions of Article NE-2000 of the ASME Code Section III Division 1 are followed and the O/A program is in accordance with Articles NE-4000 and NE-5000 of the ASME Code Section III Division 1. Special construction techniques used are discussed and justified.

G. TESTING AND INSERVICE SURVEILLANCE REQUIREMENTS (3.P.2.7)

The preoperational structural proof test is indicated as following Article NE-6000 of ASME Section III Division 1.

SECTION 3.8.3 CONCRETE AND STRUCTURAL STEEL INTERNAL STRUCTURES OF STEEL OR CONCRETE CONTAINMENTS

A. DESCRIPTION OF INTERNAL STRUCTURES (3.8.3.1)

3.8-41

For PWR dry containments the description includes reactor supports, steam generator supports, reactor coolant pump supports, primary and secondary shield walls, floors and polar crane structures. For PWR ice condenser containments the description includes, in addition, the divider barrier and ice condenser. For BWR containments the description includes the drywell, weir-wall, refueling pool, operatin floor, reactor and recirculatory pump supports, reactor pedestal, reactor shield and miscellaneous platforms.

- or -

SMESSAR

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.3.2)

3.8-46

The following are employed:

ACI 318; ACI 309; ASME PWP Code, Section III, Division 1, Subsections NE and NF; AISC Specifications; ANSI N45.2.5; RG 1.10; PG 1.15; RG 1.55.

- or -

SMESSAR

SubSection 3.8.6.2 p.38-60 to p.38-70

C. LOADS AND LOAD COMBINATIONS (3.8.3.3) See SubSection 3.8.6

3.8-46

Except for divider-barrier and ice-condenser elements of PWRs, the drywell of PWR Mark III containments, and linear steel supports of the reactor coolant system, the following apply:

Service Load Conditions:

Concrete and Steel for USD:

$D+L, D+L+E$ and, if thermal stress is present,

(S)
(1.3SS-Concrete)
(1.5SS-Steel)

$D+L+T_o + P_o, D+L+T_o + P_o + E$

Concrete for USD:

$1.4D + 1.7L, 1.4D + 1.7L + 1.9E$

(U)

and where thermal stress is present;

(U)

$(.75) (1.4D + 1.7L + 1.7T_o + 1.7P_o)$

$(.75) (1.4D + 1.7L + 1.9E + 1.7T_o + 1.7P_o)$

Steel for Plastic Design:

$1.7D + 1.7L, 1.7D + 1.7L + 1.7E$

(Y)

and where thermal stress is present:

$1.3 (D+L + T_o + P_o)$

$1.3 (D+L + E+T_o + P_o)$

Factored Load Conditions:

Steel for USD

(1.6S)

$D+L+T_o+P_o+E', D+L+T_o+R_a+P_a,$

$$D+L+T_a+P_a+P_a+Y+E'$$

$$D+L+T_a+P_a+P_a+Y+E'$$

Steel for Plastic Design and concrete for USD: (1.75)
(.9Y)

$$D+L+T_a+P_a+E', D+L+T_a+P_a+1.5P_a,$$

$$D+L+T_a+1.25P_a+Y+1.25E,$$

$$D+L+T_a+P_a+P_a+Y+e'$$

For the divider barrier and Mark III drywell the loads, load combinations and stress limits of CC-3000 apply.

For ice condenser elements the following apply:

Service Load Conditions: (5)

Steel for WSD:

$$D+L, D+L+E$$

Steel for Plastic Design: (7)

$$1.7D+1.7L, 1.7D+1.7L+1.7E$$

Steel for test verification: (c)

$$1.9D+1.9L+1.9E$$

Where thermal stresses are present, the procedures of NF-3221.1 are applied.

F. MATERIALS QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES (3.8.4.6) 3.8-51

Compliance with ACI 318-71 for concrete, AISC-69 for steel, ASME NF for linear supports (Category I components), ANSI N45.2.5 for general quality control, and ACI-309 for repairing bar welding.

- or -

SMESSAR

Subsection 3.8.1.6

G. TESTING AND INSERVICE SURVEILLANCE (3.8.4.7) 3.8-51
No specific requirements

SECTION 3.8.5 FOUNDATIONS

A. DESCRIPTION OF FOUNDATIONS (3.8.5.1)

3.8-57

For foundations, the descriptive information consists of plans and sections for each Category I foundation and method of separation between foundations. For containment base slab, the general arrangement and method of shear transfer is described.

- or -

SWESSAP

Fig 3.8-30-31 Anchorage; -1/3 Reinforcement; -61 Air Blt;

-5 Diesel Bldg; -56 Service Water Bldg; etc.

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.5.2)

3.8-58

The following are employed:
ACI 318, ACI 309; ASME PSPV Code, Section III, Div 1, Subsections NE and NF; AISC; ANSI M45.2.5; RG 1.10; RG 1.15, RG 1.55

- or -

SWESSAP

Subsection 3.8.1.2 For Containment

" 3.8.3.2 For Internal Structures

" 3.8.4.2 For Other Cat I Bldg

CONTAINMENT
4th Ed. 1988

C. LOADS AND LOAD COMBINATIONS (3.8.5.3)

3.5-59

Load combinations and stress limits of 3.8.4 apply.

3.8-75

Additional load combinations of sliding and overturning are

	Sliding	Overturning	Floatation
D+H+E, D+H+W,	1.5	1.5	-
D+H+E', D+H+W'	1.1	1.1	-
D+F'	-	-	-

1.5
else 1.1

- or -

SWESSAP

Subsections 2.8.1.3 Containment

" 3.8.6 Other Cat. I Structures

D. DESIGN AND ANALYSIS PROCEDURES (3.8.5.4)

3.8.59

For concrete structures, ACI 318-71 is utilized. For steel structures, AISC specifications are utilized.

Table 3.8-22

- or -

SWESSAP

Subsection 3.8.1.4 Containment

- see Appendix 3C for Specific Assumptions

Subsection 3.8.4.4 for Other Cat. I Structures

Table 3.8-23 S.F. for SLIDING OVERTURNING

E. STRUCTURAL ACCEPTANCE CRITERIA (3.8.5.5)

3.8-59

The limits tabulated opposite the load equations apply.

Table 3.8-23

- or -

SWESSAP

Subsections 2.8.1.5; 3.8.3.5; 3.8.4.5; Table 3.8-24

Settlements Fig. 2.5-48; Table 3.8-24

F. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES
(3.8.5.6)

3.8-59

The procedures and methods for the Category I containment structures are applied for containment base slab. No special acceptance standards apply to others.

SWESSAR

LOAD & LOAD COMBINATIONS (3.8.3.3)

3.8-46

Factored Load Conditions:

Steel for MSD: (1.35) N/A

$D+L+E'$, $D+L+Pa$, $D+L+Pa+E'$ (1.6S)

Steel for Plastic Design: (Y)

$1.3D + 1.3L + 1.3E'$, $1.3D+1.3L+1.3Pa$,

$1.2D + 1.2L + 1.2Pa+1.2E'$

Steel for test verification: (C)

$1.4D+1.4L + 1.4E'$, $1.4D+1.4L+1.4Pa$

$1.3D + 1.3L + 1.3Pa + 1.3E'$

For reactor coolant linear steel supports, the following apply:

For MSD: (Limit of X111-1100, NF)

$D+L+E$ (X 1.0), $D+L+E'$ (X 1.e), $D+L+E' + Pa + Y$ (X 1.6)

For Plastic Design:

1.7 (D+L+E)

1.3 (D+L+E')

1.0 (D+L+E' + Pa + Y)

- or -

SWESSAR

D. DESIGN AND ANALYSIS PROCEDURES (3.8.3.4)

3.8-47

For PWR Dry Containments the design and analysis procedures for linear reactor coolant supports are in accordance with Subsection NF. The primary shield wall, secondary shield wall, other interior structures and the reactor cavity design and analysis procedures are in accordance with ACI 318-71.

For PWR ice-condenser divider barriers and BWR drywells, design and analysis procedures are in accordance with those delineated in section CC-3000 of ACI-359 for concrete elements and subsection NE for steel elements. For BWR steel drywell elements the design and analysis acceptance criteria of Section 3.8.2 apply.

SWESSAR

WSM steel

USM concrete

BN-TOP-2 & BC-TOP-9A (Pipes Break Effects)

E. STRUCTURAL ACCEPTANCE CRITERIA (3.8.3.5)

3.8-57

With the exception of the divider-barrier and ice condenser elements of PWR containments; the drywell of the Mark III; and the linear steel supports of the reactor coolant system; the stress limits tabulate opposite the load equations apply where s = the acquired section strength based on WSD allowables of ACI-318 and the AISC specifications, Part I; U = the required section ultimate strength, Y = the AISC specification allowables, Part II, and C = tested collapse strength. For the PWR divider barrier and BWR dry well, concrete CC-3400 applies. For the PWR divider-barrier and BWR drywell steel, Subsection NE applies.

- or -

SMESSAR

Subsection 3.8.6.5 Tables 3.8-29 & 30

F. MATERIALS, QUALITY CONTROL AND SPECIAL CONSTRUCTION TECHNIQUES (3.8.3.6)

3.8-51

Compliance with ACI 318-71 for concrete, AISC-69 for steel, ASME NF for reactor coolant system supports, ANSI N45.2.5 for general quality control and ACI-309 for reinforcing bar welding.

As Subsection 3.8.1.6

SECTION 3.8.4 OTHER CATEGORY I STRUCTURES

A. DESCRIPTION OF OTHER CATEGORY I STRUCTURES (3.8.4.1)

3.8-51

For other Category I structures the description includes the containment enclosure building, auxiliary building, fuel storage building, control building, diesel generator building, and miscellaneous Seismic Category I structures.
 Serviceability loads - or - Serviceability Stress Limits
 SNESSAR

B. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS (3.8.4.2)

3.8-53

The following are employed:
 ACI 318; ACI 309; ASME B31V Code Section III, Div. 1, Subsections NF and NF; AISC; ANSI A5.2.5; RG 1.10; PG 1.15; PG 1.55
Subsection 3.8.6.2 Plus Specific Details

C. LOADS AND LOAD COMBINATIONS (3.8.4.3)

3.8-54

The following load combinations apply
Service Load Conditions:

Concrete and Steel for USD:

(S)

$D+L, D+L+E, D+L+W$

and if thermal stress is present

(1.35-Concrete
1.55-steel)

$D+L + T_o + P_o, D+L+T_o+P_o+E$

$D+L+T_o+P_o+W$

Concrete for USD:

$1.4D+1, 1.4D+L+1.9E,$

$1.4D-1.7L+1.7W$

and if thermal stress is present

(U)

$(.75) (1.4D+1.7L+1.7T_o+1.7P_o)$

$(.75) (1.4D+1.7L+1.9E+1.7T_o+1.7P_o)$

$(.75) (1.4D+1.7L+1.7W+1.7T_o+1.7P_o)$

Steel for Plastic Design:

(Y)

$1.7D+1.7L, 1.7D+1.7L+1.7E,$

$1.7D+1.7L+1.7W$

Factored Load Conditions:

Steel for USD:

(1.65)

$D+L+T_o+P_o+E'$ and $W_T, D+L+T_a+R_a+P_a$

$D+L+T_a+R_a+P_a+Y+E'$

Steel for plastic design and concrete for USD:

(1.75)

$D+L+T_o+P_o+E'$ and $W_T, D+L+T_a+R_a+1.5a$

$D+L+T_a+1.25P_a+Y+1.25E,$

$D+L+T_a+P_a+Y+E'$

- or -

SNESSAR

Handwritten notes:
 Storage
 12.10.1972

Handwritten numbers:
 42
 39

- D. DESIGN AND ANALYSIS PROCEDURES (3.2.4.4)
For concrete structures ACI 318-71 is utilized. For steel
STRUCTURES, AISC specifications are utilized.

3.8-55

SWISSAR

Subsection 3.8.6 States specifics on ACI & AISC Code

Requirements

- E. STRUCTURAL ACCEPTANCE CRITERIA (3.2.4.5)
The stress limits tabulated opposite the load equations
apply.

3.8-56

- or -

SWISSAR

Subsection 3.8.6.5

Tables 3.8-19 to -22 + 27; 28 ; 31

MIDLAND NPP - RG COMPLIANCE

RINTAL

- RG 1.10 — MECHANICAL (CADWELD) SPICES IN REINFORCING BARS IN
(EXCEPTIONS) CATEGORY I CONCRETE STRUCTURES (REV. 1) (1-2-73)
- RG 1.12 — INSTRUMENTATION AND EXPERIMENTATION (REV. 1) (1-73)
(EXCEPTIONS) Accepted NRC Letter 6-8-76
Modified per NRC CR 135119
- RG 1.15 — TESTING OF REINFORCING BARS FOR CAT. I CONCRETE
(EXCEPTIONS) STRUCTURES (REV. 1) (12-28-72)
Prohibit alternate use of rejected material even
with the project Engineer approval
- RG 1.18 — STRUCTURAL ACCEPTANCE TEST FOR CONCRETE PRIMARY
(EXCEPTIONS) REACTOR CONTAINMENTS (REV. 1) (12-28-72)
Accepted NRC Letter 6-8-76
- RG 1.19 — NON-DISTRUCTIVE EXAMINATION OF PRIMARY CONTAINMENT
(EXCEPTIONS) LINER WELDS (REV. 1) (8-11-72)
Accepted NRC Letter 6-8-76
- RG 1.35 — IN-SERVICE INSPECTION OF UNGRADED TENDONS IN
(BC-TOP-5A) PRESTRESSED CONCRETE CONTAINMENT STRUCTURES
(REV. 1) (4/74)
BC-TOP-5A Rev 3 (2/75)
NRC Letter 6-8-76
- RG 1.55 — CONCRETE PLACEMENT IN CAT. I STRUCTURES
(COMPLIES)

(over)

RG 1.57 — DESIGN LIMITS AND LOADING COMBINATIONS FOR METAL PARTS OF REACTOR CONTAINMENT SYSTEM COMPONENTS (6/73)
(N.A.)

RG 1.57 — DESIGN LIMITS FOR THE NPP (Rev. 0) (10/73)
(EXCEPTIONS) SAND EJECTION
Consideration for Qualification of Well-Systems

RG 1.60 — DESIGN RESPONSE SPECTRA FOR SEISMIC DESIGN OF NPP (Rev. 1) (12/73)
(EXCEPTIONS)
Plant Design prior to RG 1.60 Issuance
NRC Letter 6-8-76
Buried Pipes BC-75F-4R
For Earthquakes of moderate distance from Epicenters ACC TID-7024

RG 1.61 — DAMPING VALUES FOR SEISMIC DESIGN OF NPP (Rev. 0) (10/73)
(EXCEPTIONS)
NRC Letter 6-8-76

RG 1.90 — INSERVICE INSPECTION OF PRESTRESSED CONCRETE CONTAINMENT STRUCTURE WITH EXPOSED JOINTS (11/74)
(N.A.)
NRC Letter 6-8-76

RG 1.92 — COMBINATION OF MODES & SPATIAL COMPONENT
(EXCEPT) IN SEISMIC RESPONSE ANALYSIS (Rev. 1) (2/76)

RG 1.102 — FLOOD PROTECTION FOR NPP (Rev. 1) (9/76)
COMPLIES WITH RG 1.59

RG 1.103 — POST-TENSIONED PRESTRESSING SYSTEMS FOR CONCRETE
(COMPLIES) REACTOR VESSELS AND CONTAINMENTS (Rev. 1) (10/76)

RG 1.107 — QUALIFICATION OF CEMENT GROUTING FOR
(NA) PRESTRESSING TENDONS IN CONTAINMENT STRUCTURES
(11/75)

RG 1.122 — DEVELOPMENT OF FLOOR RESPONSE SPECTRA FOR
(COMPLIES) SEISMIC DESIGN OF FLOOR SUPPORTED EQUIPMENT,
OR COMPONENTS (Rev. 1) (2/78)

RG 1.127 — INSPECTION OF WATER CONTROL STRUCTURE
(COMPLIES) ASSOCIATED WITH NPP (Rev. 1) (3/78)

RG 1.142 — ENDORSEMENT OF ACI 349 w/ EXCEPTION
(NA COMPLIES)

C

MIDLAND NPP - COMPUTER PROGRAMS

APPENDIX - 3C

Purpose: to verify computer programs used for Midland NPP against other acceptable programs or conventional methods of calculation

3C.1 - AXISYMMETRIC SHELL AND SOLID COMPUTER PROGRAMS (ASHSD)

- ELASTIC
- STATIC or DYNAMIC
- AXISYMMETRIC SHELL or SOLIDS

Original Code developed @ University of California Berkeley - Current Code modified for NPP use

- Finite Element Shell w/ interaction stiffness not allows Analysis of layered shells
- Bonded or Unbonded layers ie linear Unbonded
- Isotropic or Anisotropic Elastic Constants
- Non-uniform Thermal Gradient from shell
- Programs computes Eigenvalues/vectors
- Dynamic-loading Uncoupled (Model) Coupled (Direct Integration)
- Response Spectrum Model Analysis for { ABSI, SRS, SRSS

DISPLACEMENT & STRESSES

- Time history allows Arbitrary Damping distribution
- Stiffness & Mass Matrices obtained from other programs

3C.2

FINITE ELEMENT COMPUTER PROGRAM: (FINEL) p 3C-54

2-D STATIC ANALYSIS STRESS/STRAIN ANALYSIS

FOR IRREGULAR STRUCTURES

BILINEARITY IN COMPRESSION

" " TENSION FOR CRACKING - CRACKING

AUTO-MESH GENERATOR

DISPLACEMENTS OF CORNERS OF ELEMENTS

STRESS/STRAIN FOR EACH ELEMENT

3C.3

BECHTEL STRUCTURE ANALYSIS PROGRAM (BSAP) p 3C-127

(BSAP)

Original SAP 49 Univ. of California, Berkeley

Used in Design/Analysis Work

Finite Element for Structural Analysis of Systems
subject to static/dynamic & thermal loads

3C.4

PLATE BENDING -

p 3C-167

Linear Elastic Analysis

Stiffness Based

Arbitrary Shape & Supports

Elastic Equilibrium

See p 3C-169-170 for Assumptions & Limitations

3C.5

BUILDING DEPRESSURIZATION

p-3C-185

Compute Change in Pressure in Components

TORNADO APPLICATION: Time dependent atmospheric

pressure change to a partially vented Bldg of Calculated

Differential pressure histories across Dist. and

Internal walls. (Low-dimensional Quasi-Static, for flow thru openings)

- 3C.6 SPECTRA p 3C-219
 Computes Response Spectra from Time Histories
 (Max Values are selected)
- 3C.7 MODAL ANALYSIS OF PLANE FRAMES p 3C-240
 • Computes: FREQUENCIES, MODE SHAPES, GENERALIZED MASSES,
 PARTICIPATION FACTORS, MODAL DAMPING FOR A GIVEN STRUCTURE.
 The program can also compute or accept a REDUCED STIFFNESS MATRIX
- 3C.8 SPECTRAL RESPONSE OF PLANE FRAMES p 3C-250
 Modal Response of plane frame/Frames
 Absolute Sum or SRSS output available
- 3C.9 TIME HISTORY ANALYSIS p 3C-263
 Responses as: Displacements, Velocity, Acceleration, etc.
- 3C.10 RESPONSE SPECTRA p 3C-280
 Response Spectra computed from an Acceleration Time History.
- 3C.11 COMPOSITE FORMING OF SOIL-STRUCTURE SYSTEM p 3C-290
 Frequencies, Mode Shapes, Composite Modal Damping of
 a lumped soil-structure system for lateral or vertical
 seismic analysis. Applies for structures on common soil.
- 3C.12 BSAP POST-PROCESSOR PROGRAM OPTION MODULE p 3C-300
 given force determines prestressing steel section
 AT LIVER PLATE consideration possible
 optimizes steel for a given design.

QUESTIONS AND OPEN ITEMS

1-7-51

Q1. The Tornado Missile Spectra does not fully comply with the current NRC Tornado Missile criteria. Specifically, the applicant has not considered the three steel pipe missiles (3" dia., 6" dia., 12" dia.). From a structural point of view, the 12" diameter steel pipe controls the design of the concrete barriers. Therefore, further evaluation for this Tornado Missile is required. In addition, the applicant should demonstrate that the vents used to reduce the differential pressure in other category I structures, are adequate to resist the missile impact.

Q2. The applicant has not established the effectiveness of the ground-water well-system. These wells are needed to control the ground water level and prevent soil-liquifaction. The proposed dewatering system should be categorized in its entirety or in part, as per determination of the system evaluation and geo-science personnel, as Category 1 systems and should be designed and constructed to resist the loads of OBE/SSZ and other pertinent soil loads.

Q3. Due to settlement and inadequate compaction in the plant fill area, the applicant has agreed to re-run the seismic analyses of all Category I structures in this area. In addition, we require as necessary, the revision of structural analyses of all Category I structures affected.

Q4. Because of the strengthening measure to the backfill with caissons or piles, the foundation of structure will be different from that of the original. Such a change will require a re-run of seismic analysis.

The floor response spectra for the diesel generator building were generated on the assumption that the shear wave velocity would not be lower than 500 FPS. We recommend that the surveillance of the soil properties be conducted throughout the entire period of consolidation of the building to verify the validity of this assumption.

Q5. Some areas of the fill material under the Northern part of the service water pump structure have not been sufficiently compacted. The portion of the structure over the fill material is being supported by the rest of the structure founded on natural material through cantilever action. A static analysis of the structure by the applicant indicated that the total design loads cannot be supported by the main structure through cantilever action. The corrective action stated in MCAR 24 (issued 9/7/78) Interim Report 6, consist of placing pilings under the North wall of the structure.

Two questions regarding this corrective action of concern to NRC should be addressed by the applicant. They are listed below.

(1) The method of attaching the corbels by using long longitudinal bolts through the walls would require the bolts to resist bending. This is not an effective way of utilizing bolts. Other methods should be considered and compared.

(2) In the proposed re-analysis of the service water pump structure for seismic loading, it is not clear how the piling will be treated. The vertical piling cannot resist horizontal forces unless proper bracing is provided. Will the piling still be effective to support vertical load after an earthquake?

Q6. The reactor vessel support system is under review because of the failure of some anchor bolts under pretension load. A new design has been proposed by the applicant. Provide the final design and analysis.

DUE TO DIFFERENTIAL SETTLEMENT THE FOUNDATION
SUPPORTING THE BUILDING IN THE FRONT END BEARS
AND BECOME ELASTICALLY SETTLED FROM THE ORIGINAL
DESIGN. CONSEQUENTLY BUILD A DIFFERENT STRUCTURAL
SYSTEM THAN ORIGINALLY USED NOW. THIS
NEW STRUCTURAL SYSTEM SHOULD BE REANALYSED TO
SATISFY ALL THE DESIGN LOADS AND WAS SUBMITTED.

Q7. In the response to question 15 of NRC requests regarding plant fill, the applicant has stated that "differential settlement primarily induces additional strain, which is a self-limiting effect and does not affect the ultimate strength of the structural members." Additional clarification of this statement is needed.

Q8. The applicant responses to questions 14, 28, and 29 of NRC request regarding the causes of cracks due to settlement of plant fill, the significance of the extent of cracks and the consequences of cracking gives us a better insight of the existing condition of the category I structures. We further recommend that the following information be given.

a. Provide the tension field data, if any under the design load combinations at all crack locations for each Category I structure.

b. Provide analysis to show the limiting tension field condition in which a crack will not enlarge or propagate.

c. Show that the existing cracks shall not propagate further due to settlement and inadequate compaction problem.

d. Show the corrective plans in regards to the adverse effects of corrosion of the reinforcing bars in the crack areas.

Q11. Because the fill was replaced by other material such as lean concrete in case of the auxilliary building and the feedwater valve pits, the soil properties of the foundation material will be changed. We recommend that the new properties of this new foundation material be thoroughly investigated. The new soil properties (e.g. damping values and shear modulus) should be used in the revised seismic analysis to determine the structural adequacy of the affected structures. Pertinent soil-structure interaction methods should be used in the revised analysis. Structural analysis should be conducted using the revised seismic loading and current NRC criteria so that margins of safety can be determined against current standards. This analysis should include the effects of settlement and revised load combination equations that are appropriate for the structure.

Q12. Since a majority of the containment design was completed by 1973, the load combinations used and presented in the FSAR do not agree with those in the U.S. Atomic Energy Commission Standard Review Plan (SRP) 3.8.1. Also, the applicant has not demonstrated the degree of conservatism used in the midland design, with respect to the load combinations and the related acceptance criteria. Is it equivalent to that which would have resulted if the NRC Standard Review Plan Acceptance criteria had been used?

Q13. Since the design of other Category I and internal concrete structures were completed before 1973, the load combinations presented in the FSAR are not in accordance with the current NRC requirements. Specifically, the staff uses as the Acceptable Reference ACI-349, modified as per Regulatory Guide (RG) 1.142. The applicant has not demonstrated the degree of conservatism used in the midland design, with respect to the load combination and the related acceptance criteria. Is it equivalent to that which would have resulted if the current NRC acceptance criteria had been used?

NAVY

1 REQUESTED BY (NAME CODE EXT.) JOHN P. MATRA JR 6402	2 DATE 6-6-80	3 <input checked="" type="checkbox"/> PROCURE <input type="checkbox"/> TURN-IN	4 PAGE 1 OF 1	5 REQUEST NO.
---	-------------------------	---	-----------------------------	---------------

6 ROUTING	7 AFD/DFEC NO.	8 DATE REQUIRED	9 DATE FUNDS EXPIRE	10 JOB ORDER NO. 0698VAM:1
11 DELIVER TO (NAME CODE BLDG ROOM NO EXT.)	12 ECC	13 (M) PRIORITY NO (M) AUTHORIZING DOCUMENT		

14 SUPPLIER (M) (S) (S) (S) BUTLER ANALYSES 932 BEAVERBANK CIRCLE TOWSON MD 21204	15 REQUEST AUTHORIZED SIGNATURE
---	---------------------------------

16 SCREENING DATE	17 BUYER	18 DATE ORDERED	19 DELIVERY DATE	20 CONTRACT/ORDER/REQUISITION NO.	21 EPA CALL
-------------------	----------	-----------------	------------------	-----------------------------------	-------------

21 (M) APPROPRIATION/SUBHEAD	(M) B C N	(M) SUB-ALLOT	(M) A A A	(M) T T	(M) STORE ROOM	(M) E E	(M) CAT	(M) O B L	(M) ESTIMATED AMOUNT 5,000
------------------------------	-----------	---------------	-----------	---------	----------------	---------	---------	-----------	--------------------------------------

22 ITEM NO. (M)	NATIONAL/LOCAL STOCK NUMBER AND DESCRIPTION OF MATERIALS AND SERVICES (INCLUDE MANUFACTURER'S PART, MODEL AND SERIAL NUMBERS) (M)	QUANTITY (M)	UNIT OF ISSUE (M)	UNIT PRICE ESTIMATE CATALOG (M)	UNIT PRICE (M)	EXTENSION (M)
-----------------	---	--------------	-------------------	---------------------------------	----------------	---------------

1 STATEMENT OF WORK

PREPARE A PRE-PROCESSOR PROGRAM TO CONVERT AN ACCELERATION TIME HISTORY ON A RIGID BASE TO A FORCING TIME HISTORY DISTRIBUTED OVER A CYLINDER, MODELED TWO WAYS; FIRST AS A SHELL, THEN AS A STICK MODEL. DELIVER A SET OF ROTE (USER INSTRUCTIONS) INSTRUCTIONS AND AN EXECUTABLE PROGRAM TESTED ON NSWC COMPUTER. ALL COMPUTING TIME AND COST WILL BE GOVERNMENT FURNISHED. TASK TO BE COMPLETED APPROX 45 DAYS AFTER GO AHEAD.

BUTLER ANALYSES
% TOM BUTLER
932 BEAVERBANK CIRCLE
TOWSON MD 21204
PHONE 301-823-2918

Matra *Sept 4*
1-7-81 *dfb*

23 TURN-IN CONDITION	24 RECEIVED BY	DATE	25 INSPECTED BY	DATE	26 GRAND TOTAL
----------------------	----------------	------	-----------------	------	----------------

27 DO NOT INCLUDE CLASSIFIED MATERIAL ON THIS DOCUMENT

CLASSIFIED INFORMATION ATTACHED UNCLASSIFIED WHEN REMOVED

28 ACCEPTED BY

DATE

From 6402 (Huanh)
TO

(VIA U) 640

SUBJ: NEGOTIATION OF A CONTRACT WITH BUTLER ANALYSES
ON A SOLE SOURCE BASIS; REQUEST FOR

ENCL: (1) REQUISITION/TURN-IN DOCUMENT

1. IT IS REQUESTED THAT A CONTRACT BE NEGOTIATED WITH BUTLER ANALYSES DEVELOP A PRE-PROCESSOR PROGRAM CAPABLE OF CONVERTING ACCELERATION TIME HISTORY ON A RIGID BONE TO A FORCING TIME HISTORY DISTRIBUTED OVER A CYLINDER.
2. BUTLER ANALYSES IS UNIQUELY QUALIFIED TO PERFORM THIS STUDY FOR THE FOLLOWING REASONS.
 - (a) THESE CODE CHANGES ARE TO BE INCORPORATED INTO THE NASTRAN PROGRAM; A CODE WHICH BUTLER ANALYSES IS THOROUGHLY FAMILIAR WITH.
 - (b) THE COST OF MODIFYING THE EXISTING NASTRAN CODE TO ACCEPT THE PRE-PROCESSOR WOULD BE MUCH LESS THAN THE COST TO DEVELOP OR MODIFY A NEW CODE.

(3. NO OTHER COMPANY IN THE UNITED STATES HAS TO THE BEST OF MY KNOWLEDGE, THIS UNIQUE COMBINATION OF TALENTS, PROGRAM AND DATA BASE NECESSARY TO THE PERFORMANCE OF THE CONTRACT

4. I CERTIFY THAT THE FACTS AND REPRESENTATIONS UNDER MY COGNIZANCE WHICH ARE INCLUDED IN THE ABOVE SOLE SOURCE JUSTIFICATION ARE ACCURATE TO THE BEST OF MY KNOWLEDGE AND BELIEF.

P. C. HUANG

J. P. MATRA JR

copy to

640

6402

(6402 (MATRA))

KANE

X 492 - 2162

OUR INTEREST IS WHAT IS THE DESIGN INPUT TO THE STRUCTURE, SINCE THE DESIGN IS BASED ON AN EFFECTIVE DEWATERING SYSTEM AND WITH ASSURANCE THAT THE BULK OF SYSTEM WILL GUARANTEE THE VALIDITY OF THE DESIGN INPUTS, WE WOULD LIKE TO KNOW THE RELIANCE OF THE COMPLETE SYSTEM.

② SEISMIC RE-ANALYSIS OF ALL CATEGORY 2 STRUCTURES DUE TO PLANT FILL CONDITIONS ARE REQUIRED.