

CP&L

Carolina Power & Light Company

84 JUN 2 A7:36

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
June 27, 1984

FILE: B09-13510C
SERIAL: BSEP/84-1541


Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30323

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-84-4)

Dear Mr. O'Reilly:

On May 24, 1984, a fire barrier LCO was initiated to permit the installation of the 1A conventional service water pump. This pump requires the use of the intake crane for pump installation. During the installation of the pump, the crane was rendered inoperable due to broken electrical connections in a section of conduit. This damage caused delay of the pump installation, and the specified seven-day time frame of the subject LCO has been exceeded. Until the completion of the repairs on the crane and subsequent installation of the 1A conventional service water pump, appropriate stationed fire watches will be maintained.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MTA/jo/LETCG2

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8407120181 840627
PDR ADOCK 05000325
S PDR

OFFICIAL COPY
IE 22
1/0