



231 W Michigan, PO Box 2046 Milwaukee, WI 53201

(414) 221-2345

VPNPD-92-091
NRC-92-029

February 27, 1992

U. S. NUCLEAR REGULATORY COMMISSION
Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Gentlemen:

DOCKETS 50-266 AND 50-301
IMPLEMENTATION OF GENERIC LETTER 89-13
SERVICE WATER SYSTEM PROBLEMS AFFECTING
SAFETY-RELATED EQUIPMENT
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

On July 18, 1989, the Nuclear Regulatory Commission issued Generic Letter 89-13, "Service Water System Problems Affecting Safety-Related Equipment." In our response dated January 12, 1990, we stated that we would notify you within 30 days of completing the last action taken to address the concerns in the Generic Letter.

On January 31, 1992, the G01 emergency diesel generator annual maintenance outage was completed with replacement of the diesel's glycol cooler and its service water supply line. Replacement of the glycol cooler was the final activity necessary to address Generic Letter 89-13 concerns. We have now completed all actions planned in response to Generic Letter 89-13 concerns, as contained in our January 12, 1990, letter.

Please contact us if you have any questions concerning the above information.

Sincerely,

A handwritten signature in cursive script, appearing to read 'J. Zach'.

James J. Zach
Vice President
Nuclear Power

Copies to NRC Regional Administrator, Region III
NRC Resident Inspector

9203030300 920227
PDR ADDCK 05000266
P PDR

ADD5
10