



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DEC 14 1982

MEMORANDUM FOR: Thomas Novak, Assistant Director for Licensing
Division of Licensing

FROM: Themis P. Speis, Assistant Director for Reactor Safety
Division of Systems Integration

SUBJECT: SAFETY EVALUATION OF LASALLE COUNTY STATION UNIT 1,
SINGLE LOOP OPERATION

Plant Name: LaSalle County Station, Unit 1
Docket Numbers: 50-373
NSSS Supplier: General Electric
Responsible Branch: LB-2
Project Manager: A. Bournia
Review Status: Complete

Enclosed is the Safety Evaluation Report to permit LaSalle Unit 1 to operate on a single loop with power limited to 50%. This completes our action on TACS 49189.

Themis P. Speis, Assistant Director
for Reactor Safety
Division of Systems Integration

Enclosure: As stated

cc: R. Mattson
L. Phillips
G. Schwenk
D. B. Vassallo
A. Bournia
T. Marsh
J. Rosenthal
N. Lauben
C. Berlinger

CONTACT: Tim Collins, RSB
X29403

54-373

8212220333 KH