

# NORTHEAST UTILITIES



The Connecticut Light And Power Company  
Western Massachusetts Electric Company  
Holyoke Water Power Company  
Northeast Utilities Service Company  
Northeast Nuclear Energy Company

General Offices: Selden Street, Berlin Connecticut

P.O. BOX 270  
HARTFORD, CONNECTICUT 06141-0270  
(203)665-5000

Re: 10CFR50.73(a)(2)(i)  
February 26 1992  
MP-92-221

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Reference: Facility Operating License No. DPR-21  
Docket No. 50-245  
Licensee Event Report 92-001-00

Gentlemen:

This letter forwards Licensee Event Report 92-001-00 required to be submitted within thirty (30) days pursuant to 10CFR50.73(A)(2)(i).

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
Stephen E. Scace  
Director, Millstone Station

SES/SC:dlr

Attachment: LER 92-001-00

cc: T. T. Martin, Region I Administrator  
W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2 and 3  
D. H. Jaffe, NRC Project Manager, Millstone Unit No. 1

9203040150 920226  
PDR ADOCK 05000423  
S PDR

*Cert No*  
*98288713565*  
*IF22*  
*11*

## LICENSEE EVENT REPORT (LER)

Estimated burden per response to comply with this information collection request: 50-0 hrs. Forward comments regarding burden estimate to the Records and Reports Management Branch (3-530), U. S. Nuclear Regulatory Commission, Washington, DC 20555, and to the Paperwork Reduction Project (3150-0104), Office of Management and Budget, Washington, DC 20503.

FACILITY NAME (1)

Millstone Nuclear Power Station Unit 1

DOCKET NUMBER (2)

0 5 0 0 0 2 4 5 1 OF 0 5

PAGE (3)

TITLE (4)

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)								
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES								
0	1	2	7	9	2	0	0	1	0	5	0	0	0	0	0	0	0
0	1	2	7	9	2	0	0	1	0	0	0	2	2	6	9	2	0

OPERATING MODE (9)		THIS REPORT IS BEING SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)											
POWER LEVEL (10)	0	0	0	20.402(b)	20.402(c)	50.73(a)(2)(iv)	73.71(b)						
				20.405(a)(1)(i)	50.36(d)(1)	50.73(a)(2)(v)	73.71(c)						
				20.405(a)(1)(ii)	50.36(d)(2)	50.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text - NRC Form 366A)						
				20.405(a)(1)(iii)	50.73(a)(2)(j)	50.73(a)(2)(vii)(A)							
				20.405(a)(1)(iv)	50.73(a)(2)(k)	50.73(a)(2)(viii)(B)							
			20.405(a)(1)(v)	50.73(a)(2)(l)	50.73(a)(2)(ix)								

LICENSEE CONTACT FOR THIS LER (12)

NAME

Steven Cohen, Assoc. Engineer Ext. 4401

TELEPHONE NUMBER

AREA CODE

2 0 3 4 4 7 - 1 7 9 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)		NO		EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR		
<input checked="" type="checkbox"/>		<input type="checkbox"/>		0	8	0	3	9	2

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 27, 1992, at 1300 hours, with the plant in cold shutdown (136 degrees Fahrenheit, 0 psi) it was discovered that opening a Stand-by Gas Treatment (SBGT) circuit breaker would defeat the isolation signal to two (2) of the four (4) reactor building ventilation isolation dampers thus making them inoperable with regard to providing secondary containment isolation. Defeating the isolation signal to two of the four reactor building ventilation isolation dampers resulted in a violation of Technical Specifications secondary containment requirements. The remaining two dampers were operable and would have isolated the reactor building in the event of a condition requiring secondary containment isolation. The SBGT system procedures have been revised to provide guidance on removing one SBGT circuit from service. No safety consequences resulted from this event.

LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

Estimated burden per response to comply with this information collection request: 50.0 hrs. Forward comments regarding burden estimate to the Records and Reports Management Branch (p-630), U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to the Paperwork Reduction Project (3150-0104), Office of Management and Budget, Washington, DC 20503.

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (3)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Millstone Nuclear Power Station Unit 1	0500024592	92	001	00	02	OF 05

TEXT (if necessary please is required, use additional NRC Form 366A, s) (17)

I. Description of Event

On January 27, 1992, at 1300 hours, with the plant in cold shutdown (136 degrees Fahrenheit, 0 psi) it was discovered that opening a Stand-by Gas Treatment (SBGT) circuit breaker would defeat the isolation signal to two (2) of the four (4) reactor building ventilation isolation dampers thus making them inoperable with regard to providing secondary containment isolation. Defeating the isolation signal to two of the four reactor building ventilation isolation dampers resulted in a violation of Technical Specifications secondary containment requirements. The remaining two dampers were operable and would have isolated the reactor building in the event of a condition requiring secondary containment isolation. The SBGT system procedures have been revised to provide guidance on removing one SBGT circuit from service. No safety consequences resulted from this event.

II. Cause of Event

The cause of this event was determined to be the inadequate design of the original isolation logic for the Reactor Building Ventilation dampers for all SBGT system configurations (i.e. one SBGT breaker opened).

III. Analysis of Event

The isolation of the Reactor Building Ventilation is required to prevent a radioactive release during an accident or high radiation condition. The Reactor Building Ventilation isolates on a Group II isolation (2 psi drywell pressure and low reactor water level (+8)) or Hi-radiation signal (steam tunnel exhaust radiation 50mr/hr or greater, refuel floor radiation 100mr/hr or greater and reactor building ventilation exhaust radiation 1 mr/hr or greater).

During an engineering technical evaluation of the supporting systems required to implement an Emergency Operating Procedure (EOP) the following was discovered: (Reference Figures 1 and 2 attached)

- 1) The relay that provides the isolation signal to the reactor building ventilation dampers also provides the SBGT initiation signal. This relay is energized to isolate/initiate and receives power from the SBGT circuit breaker.
- 2) The pilot solenoids to the air operated isolation dampers are normally energized and de-energize to isolate. These pilot solenoids valves receive power from Instrument AC and 125 VDC and do not fail closed when a SBGT breaker is opened. These pilot solenoids valves receive a close signal when the SBGT initiation relay energizes. When the SBGT circuit breaker is opened, the power to the SBGT initiation relay is removed. This prevents the SBGT initiation relay from energizing and providing the isolation signal to 2 of the 4 Reactor Building Ventilation Isolation dampers (one supply damper and one exhaust damper). These two dampers will remain open until the redundant supply and exhaust damper close, tripping the Reactor Building Supply fans. The redundant supply and exhaust dampers would still receive an isolation signal and isolate the Reactor Building.
- 3) Defeating the isolation signal to 2 of the 4 isolation dampers would reduce the reliability of the Reactor Building Ventilation Isolation. However, during normal plant operation a SBGT circuit breaker is not opened except as required for maintenance or surveillance.

This event is being reported per 10CFR50.73 (a) (2) (i) (B), "Any operation or condition prohibited by Technical Specifications" based on the following:

- 1) The opening of a SBGT circuit breaker defeats the isolation signal to 2 of the 4 isolation dampers. These two dampers will remain open and will not receive an isolation signal until the redundant supply and exhaust damper close, tripping the Reactor Building supply fans.

NRC Form 366A (6-89)		U.S. NUCLEAR REGULATORY COMMISSION		APPROVED OMB NO. 3150-0104 EXPIRES: 4/30/92 Estimated burden per response to comply with this information collection request: 50.0 hrs. Forward comments regarding burden estimate to the Records and Reports Management Branch (p-530), U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to the Paperwork Reduction Project (3150-0104), Office of Management and Budget, Washington, DC 20503.			
<b>LICENSEE EVE REPORT (LER)</b> <b>TEXT CONTINUATION</b>							
FACILITY NAME (1)  Millstone Nuclear Power Station Unit 1		DOCKET NUMBER (2)  <div style="border: 1px solid black; padding: 2px; text-align: center;">             0 6 0 0 0 2 4 5 9 2           </div>		LER NUMBER (6)		PAGE (3)	
				YEAR <div style="border: 1px solid black; padding: 2px; text-align: center;">             9 2           </div>	SEQUENTIAL NUMBER <div style="border: 1px solid black; padding: 2px; text-align: center;">             0 0 1           </div>	REVISION NUMBER <div style="border: 1px solid black; padding: 2px; text-align: center;">             0 0           </div>	<div style="border: 1px solid black; padding: 2px; text-align: center;">             0 3 OF 0 5           </div>

TEXT (if more space is required, use additional NRC Form 366A, s) (17)

2) Technical Specification's definition of Secondary Containment requires "All automatic ventilation system isolation valves be operable or secured in the isolated position".

IV. Corrective Action

The short term corrective action was to revise the SBTG System operating procedure (SP 646.5) to provide guidance on removing one train of SBTG from service when Secondary Containment is required per Technical Specification Requirements. The procedure revision provides guidance for removing one train of SBTG for maintenance or surveillance of the fan and filter assembly or for maintenance of the SBTG control logic. The procedure directs operators to pull the thermal overloads in lieu of opening the circuit breaker. This prevents the isolation signal to 2 of the 4 dampers from being defeated. If the breaker is required to be opened, the operators will be required to isolate the normal reactor building ventilation and run the operable SBTG train. Additionally, Caution 1 bells have been installed on the SBTG breakers referencing the operators to SP 646.6 prior to opening a SBTG circuit breaker.

A design modification to the SBTG initiation and Reactor Building Ventilation isolation logic is being evaluated. If deemed appropriate, this modification will be implemented during the next refueling outage.

V. Additional Information

None

LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

Estimated burden per response to comply with this information collection request: 30-60 hrs. Forward comments regarding burden estimate to the Records and Reports Management Branch (R-530), U.S. Nuclear Regulatory Commission, Washington, DC 20546, and to the Paperwork Reduction Project (3150-0104) Office of Management and Budget, Washington, DC 20503.

FACILITY NAME (1)

DOCKET NUMBER (2)

LER NUMBER (3)


PAGE (3)

Millstone Nuclear Power Station  
Unit 1

0	5	0	0	0	1	2	4	5	9	2	—	0	1	0	1	—	0	1	0	0	4	OF	0	5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	----	---	---

TEXT (if more space is required, use additional NRC Form 360A as (17))

REACTOR BUILDING VENTILATION ISOLATION LOGIC FIGURE 1



LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

Estimated burden per response to comply with this information collection request: 60.0 hrs. Forward comments regarding burden estimate to the Records and Reports Management Branch (p-530), U.S. Nuclear Regulatory Commission, Washington, DC 20585, and to the Paperwork Reduction Project (3150-0104), Office of Management and Budget, Washington, DC 20503.

FACILITY NAME (1)

DOCKET NUMBER (2)

LER NUMBER (6)

PAGE (3)

Millstone Nuclear Power Station  
Unit 1

YEAR	SEQUENTIAL NUMBER	REVISION NUMBER
92	001	00

0500024592--001005 OF 05

TEXT (If more space is required, use additional NRC Form 366A a) (17)

FIGURE 2

REACTOR BUILDING VENTILATION ISOLATION DAMPERS

