

February 27, 1992

Docket Nos. 50-424
and 50-425

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC
ISSUES 48, 'LCOs FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND
49, 'INTERLOCKS AND LCOs FOR CLASS 1E TIE BREAKERS,' PURSUANT
TO 10 CFR 50.54(f)," FOR VOGTLE ELECTRIC GENERATING PLANT
(VEGP), UNITS 1 AND 2 (TACS M82483 AND M82484)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 that provided staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that (1) procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters, or other onsite power sources for VIB, and tie breakers, or (2) if procedures do not exist, a justification demonstrating the reasons why the controls are not needed.

By letter dated December 19, 1991, you responded to the GL. You indicated that VEGP has in place the appropriate procedures and administrative controls to meet the requirements of GL 91-11 at your site.

The NRC staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC Nos. M82483 and M82484.

Sincerely,

/s/

Darl S. Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

NRC FILE CENTER COPY

cc: See next page

DISTRIBUTION:
SEE NEXT PAGE

LA:PDII-3
LBerry *LB*
02/21/92

PM:PDII-3
DHood *DH*
02/26/92

PM:PDII-3
SHoffman
02/26/92

Jan
D:PDII-3
DMatthews
02/27/92

OFFICIAL RECORD COPY
Document Name: A:\GL91.11

DFol
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

February 27, 1992

Docket Nos. 50-424
and 50-425

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUES 48, 'LCOs FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 4C, 'INTERLOCKS AND LCOs FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)," FOR VOGTLE ELECTRIC GENERATING PLANT (VEGP), UNITS 1 AND 2 (TACS M82483 AND M82484)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 that provided staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that (1) procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters, or other onsite power sources for VIB, and tie breakers, or (2) if procedures do not exist, a justification demonstrating the reasons why the controls are not needed.

By letter dated December 19, 1991, you responded to the GL. You indicated that VEGP has in place the appropriate procedures and administrative controls to meet the requirements of GL 91-11 at your site.

The NRC staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC Nos. M82483 and M82484.

Sincerely,

A handwritten signature in black ink that reads "Darl S. Hood".

Darl S. Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects - 1/11
Office of Nuclear Reactor Regulation

cc: See next page

Mr. W. G. Hairston, III
Georgia Power Company

Vogtle Electric Generating Plant

cc:

Mr. J. A. Bailey
Manager - Licensing
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Joe J. Tanner, Commissioner
Department of Natural Resources
205 Butler Street, SE. Suite 1252
Atlanta, Georgia 30334

Mr. W. B. Shipman
General Manager, Vogtle Electric
Generating Plant
P. O. Box 1600
Waynesboro, Georgia 30830

Attorney General
Law Department
132 Judicial Building
Atlanta, Georgia 30334

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW., Suite 2900
Atlanta, Georgia 30323

Mr. Alan R. Herdt
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Office of Planning and Budget
Room 615B
270 Washington Street, SW.
Atlanta, Georgia 30334

Mr. Dan Smith
Program Director of Power
Production
Oglethorpe Power Corporation
2100 East Exchange Place
Tucker, Georgia 30085-1349

Mr. C. K. McCoy
Vice President - Nuclear
Vogtle Project
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
12th Floor
1050 Connecticut Avenue, NW.
Washington, DC 20036

Mr. R. P. McDonald
Executive Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Art Domby, Esquire
Troutman, Sanders, Lockerman
and Ashmore
127 Peachtree Street
Atlanta, Georgia 30303-1810

Office of the County Commissioner
Burke County Commission
Waynesboro, Georgia 30830

February 27, 1992

Distribution

Docket File	D. Matthews
NRC & Local PDRs	L. Berry
PDII-3 R/F	D. Hood
Vogtle R/F	OGC
S. Varga	ACRS (10)
G. Lainas	L. Reyes, RII
S. Hoffman	S. Vias, RII