

LICENSEE EVENT REPORT

CONTROL BLOCK:
1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME														LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	N	Y	N	M	P	1									4	1	1	1	1	0	1									
7	8	9				14	15										25	26				30	31	32						

CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE					REPORT DATE								
01	CONT	M	1	L	L	0	5	0	-	0	2	2	0	0	2	0	7	7	6	0	3	0	3	7	6
7	8		57	58	59	60	61					68	69							74	75				80

EVENT DESCRIPTION

02	During routine surveillance testing RE-04A, high drywell pressure indicator (1 of 4)																								80
03	tripped at 3.35 psig rather than 3.5 + .053 psig.																								80
04																									80
05																									80
06	RO 76-03																								80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION	
07	I	A	E	I	N	S	T	R	U	N	B	0	8	0	N
7	8	9	10	11	12				17	43	44			47	48

CAUSE DESCRIPTION

08	Set point drift. Redundant sensors operable therefore no hazard to general public.																								80
09																									80
10																									80

FACILITY STATUS		% POWER		OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION															
11	E	0	9	0					b																
7	8	9	10	12	13				44	45	46														80

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE																	
12	Z	Z	N/A				N/A																		
7	8	9	10	11				44	45																80

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION																					
13	0	0	0	Z	N/A																				
7	8	9	11	12	13																				80

PERSONNEL INJURIES

NUMBER		DESCRIPTION																							
14	0	0	0	N/A																					
7	8	9	11	12																					80

OFFSITE CONSEQUENCES probable
 NONE

15																									80
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION																							
16	Z	N/A																							
7	8	9	10																						80

PUBLICITY

17	NONE																								80
----	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

ADDITIONAL FACTORS

18	NONE																								80
----	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

19																									80
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

NAME: T. Dente

PHONE: 315-343-2110