

CENSEE EVENT REPORT

CONTROL BLOCK:

1					6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME				LICENSE NUMBER										LICENSE TYPE					EVENT TYPE						
01	N	Y	N	M	P	1												4	1	1	1	1	0	1	
7	8	9				14	15											25	26				30	31	32

CON'T		CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER							EVENT DATE					REPORT DATE							
01		M	I	L	L	0	5	0	-	0	2	2	0	1	1	2	1	7	5	1	2	1	7	7	5
7	8	57	58	59	60	61							68	69					74	75					80

EVENT DESCRIPTION	DATE	TIME	LOCATION	STATUS
...

02	During routine surveillance testing, RE-04D, high drywell pressure sensor (1 of 4)	80
03	was found to trip at 3.4 psi rather than $3.5 \pm .053$ psi. The device is a Barton	80
04	Model #289.	80
05		80
06	AOR 75-33A	80

SYSTEM CODE		CAUSE CODE	COMPONENT CODE					PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION			
0	7	I	A	E	I	N	S	T	R	U	N	B	O	8	0	N
7	8	9	10	11	12					17	43	44				48

CAUSE DESCRIPTION

08	Could find no apparent reason for the .047 psi drift, however, routine surveillance	80
09	is sufficient to locate these drifting problems.	80
10		80

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	H	0	0	0			b			
7	9	10	12	13	44	45	46			80
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE				
1	Z	Z	N/A							
7	9	10	11	44	45		80			

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION	
13	0	0	0	Z	N/A

PERSONNEL INJURIES

NUMBER			DESCRIPTION
14	0	0	N/A

XXXXXX CONSEQUENCES Probable

15 | None - Drift in more conservative direction

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION
15	Z	N/A

PUBLICITY

17	None	
----	------	--

ADDITIONAL FACTORS

18	None	PDR	ADDER	00000	PDR
89		S			

19 89

NAME: T.J. Dente

PHONE: 315 - 343-2110

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

December 17, 1975

Mr. James P. O'Reilly
Directorate of Regulatory Operations
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406




RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Report 75-33A.

This report conforms to the requirements of Regulatory Guide 1.16, Revision 2 and was completed within the intent of the Licensee Event Report instruction book 00E-SS-001, dated October, 1974, revised December 24, 1974. Due to the minimal significance category of the report, no supplemental report is included.

Very truly yours,


R.R. Schneider
Vice President
Electric Operations

TJD/mm

Enc. 3 copies

cc: 30 copies to Mr. K.R. Goller

14351