

DCS
FEB 27 1992

Docket Nos. 50-352
50-353

Mr. D. M. Smith
Senior Vice President -
Nuclear
Philadelphia Electric Company
Nuclear Group Headquarters
Correspondence Control Desk
P. O. Box 195
Wayne, PA 19087-0195

Dear Mr. Smith

Subject: Combined Inspection Report 50-352/92-08 & 50-353/92-07

A routine, unannounced inspection of the radiological controls program was conducted by S. Sherbini at the Limerick Generating Station on February 10-14, 1992. Areas inspected included qualifications and training of the staff, the continuing training program, the survey instrument calibration and control program, and the personnel dosimetry program. Tours of the radiological controls areas and observation of ongoing work activities were also conducted.

All areas inspected were found to be good. The plant was clean and well posted, and observed work activities were conducted in the proper radiological manner. The programs reviewed were also found to be well managed and technically sound. Some areas for improvement were also identified, however. These included some deviations from procedural requirements noted during observation of ongoing work, as well as some deficiencies and omissions in some of the procedures reviewed. The continuing training program for the technical health physics staff was also found to be poorly defined. Details of these findings are presented in the attached inspection report.

Within the scope of this inspection, no violations were identified. No response to this letter is required.

"STANDARD COPY"


IE 06

FEB. 27 1982

Philadelphia Electric Company

Your cooperation with us is appreciated.

Sincerely,



James H. Joyner, Chief
Facilities Radiological Safety
and Safeguards Branch
Division of Radiation Safety
and Safeguards

Enclosure:

Combined Inspection Report 50-352/92-08 & 50-353/92-07

cc w/encl:

R. Charles, Chairman, Nuclear Review Board
G. Leitch, Vice President - Limerick Generating Station
D. Helwig, Vice President of Nuclear Engineering and Services
J. W. Durham, Sr., Senior Vice President and General Counsel
J. Doering, Manager - Limerick Generating Station
G. J. Beck, Manager - Licensing Section
G. Hunger, Project Manager - Limerick Generating Station
J. O'Rourke, Manager - Limerick Quality Division
G. Madsen, Regulatory Engineer - Limerick Generating Station
Secretary, Nuclear Committee of the Board
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
K. Abraham, PAO (2)
NRC Resident Inspector
Commonwealth of Pennsylvania

FEB. 27 1982

3

Philadelphia Electric Company

bcc w/encl:
Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
R. Blough, DRP
R. Clark, NRR
L. Doerflein, DRP
DRS SALP Coordinator
DRSS SALP Coordinator
M. Banerjee, SLO
R. Lobel, OEDO

M. Miller, SLO

SS
S. Sherbini
2/21/92

WP
W. Pasciak
2/26/92

JJ
J. Joyner
2/27/92

"OFFICIAL RECORD COPY"