

Initial Telephone Report Date: November 6, 1975

Date of Occurrence: November 6, 1975

Initial Written Report Date: November 7, 1975

Time of Occurrence: approx. 10:30 AM

**OYSTER CREEK NUCLEAR GENERATING STATION
FORKED RIVER, NEW JERSEY 08733**

**Abnormal Occurrence
Report No. 50-219/75/30**

IDENTIFICATION OF OCCURRENCE: Violation of the Technical Specifications, paragraph 3.1.1.D.3
Low Reactor Pressure Core Spray Valve Permissive Pressure Switches RE 17 A and C was found to trip at pressures less than the minimum required value of 285 psig.

This event is considered to be an abnormal occurrence as defined in the Technical Specifications, paragraph 1.15B.

CONDITIONS PRIOR TO OCCURRENCE:

<input checked="" type="checkbox"/> Steady State Power	<input type="checkbox"/> Routine Shutdown
<input type="checkbox"/> Hot Standby	<input type="checkbox"/> Operation
<input type="checkbox"/> Cold Shutdown	<input type="checkbox"/> Load Changes During
<input type="checkbox"/> Refueling Shutdown	<input type="checkbox"/> Routine Power Operation
<input type="checkbox"/> Routine Startup	<input type="checkbox"/> Other (Specify)
<input type="checkbox"/> Operation	

Power: Core 1565 MW
Electrical 532 MW

Flow: Recirculation 15.2 x 10³ GPM
Feedwater 5.75 x 10³ M³/hr.

Stack Gas 9,000 μ Ci/Sec.

DESCRIPTION OF OCCURRENCE: On Thursday and Friday, November 6 and 7, 1975 while performing the monthly surveillance testing on the four (4) low Reactor Pressure Core Spray Valve Permissive Pressure Switches, it was discovered that Switches RE 17 A and C tripped at 277 psig and 282 psig, respectively. These values are less than the Technical Specifications limit of 285 psig. The Pressure Switches RE 17 A and C were immediately recalibrated. The "as found" and "as left" switch settings were:

	<u>"As Found" Settings</u>	<u>"As Left" Settings</u>
RE 17 A	277 psig	285 psig
RE 17 B	286 psig	286 psig
RE 17 C	282 psig	285 psig
RE 17 D	288 psig	288 psig

8302230110 751107
PDR ADCK 05000219
S PDR

APPARENT CAUSE
OF OCCURRENCE:

Design
 Manufacture
 Installation/
 Construction
 Operator

Procedure
 Unusual Service Condition
 Inc. Environmental
 Component Failure
 Other (Specify)

The cause of this occurrence is switch repeatability.

ANALYSIS OF


OCCURRENCE: The Core Spray System parallel isolation valves open when a low-low reactor water level and/or high drywell pressure condition exists in addition to a low reactor pressure condition (285 psig). The four (4) low reactor pressure core spray valve permissive switches (RE 17A, B, C, and D) the low reactor pressure condition and provide signals to the valve opening logic. Two (2) of these switches (RE 17A and B) are associated with Core Spray System I and the other two (2) switches (RE 17C and D) are associated with Core Spray System II. A trip of one switch in a Core Spray System is required to effect parallel isolation valve opening in that system. A review of the "as found" switch settings indicate that parallel isolation valves in both Core Spray Systems would have opened at a reactor pressure of 285 psig for System I and 288 psig for System II had a reactor low-low water level and/or high drywell pressure condition exist concurrently. The safety significance of this event is considered to be the loss of switch redundancy.

CORRECTIVE

ACTION: Immediate corrective action involved the recalibration of pressure switches RE17A as there are continuing efforts to resolve the incompatibilities between the Technical Specification setpoint limits and the sensor performance limits. It is felt that the conservative design associated with the deprivation of the plant safety limits will permit a change in the Technical Specifications to be made which will take into account the expected sensor performance variability. This will eliminate instances of abnormal occurrence reports caused by the normal variation in sensor setpoint within the design margins of the plant safety limits.

ALLIANCE DATA: Manufacturer: Beckhoff
Type: Pressure Sensing Switch
Range: 50-1200 psig
Switch No.: BPT-AL285 (RE17A)
BPT-AL288 (RE17C)
Abnormal Occurrence 50-219/75/12
Abnormal Occurrence 50-219/75/27

Prepared by:


John L. Sullivan

Date:

November 7, 1975

TO:

James P. O'Sullivan
Directorate of Regulatory Operations
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

FROM:


Jersey Central Power & Light Company
Oyster Creek Nuclear Generating Station Docket #50-21
Forked River, New Jersey 08731

SUBJECT:

Abnormal Occurrence Report No. 50-219/75/ 30

The following is a preliminary report being
submitted in compliance with the Technical
Specifications, paragraph 4.6.2.

Preliminary Approval:


S. F. Desoll, Jr. Date

CC: Mr. A. Giambusso