

MAY 19 1972

D. L. Ziemann, Chief, Operating Reactors Branch 2, L

NIAGARA MOHAWK POWER CORPORATION (NINE MILE POINT)-VIBRATIONS  
INDUCED PARTIAL DISASSEMBLY OF AN AUTOMATIC PRESSURE RELIEF  
VALVE

Enclosed for your information is a copy of an Inquiry Report from our Region I (Newark) Office concerning a vibration induced failure of one of the automatic pressure relief valves at the Nine Mile Point facility.

Based on our review of this problem, we question whether the valve could have operated, if called upon, in its degraded condition. We believe, however, that the action taken by the licensee to correct the problem was appropriate. Recognizing that this potential safety related problem could be generic, we plan to alert other operating BWR facilities of details of this problem. We will keep you informed of significant findings.

Original signed by  
J. G. Keppler

J. G. Keppler, Chief,  
Reactor Testing and Operations  
Branch  
Directorate of Regulatory Operations

8303020168 720526  
PDR ADOCK 05000220  
G PDR

Enclosure:  
RO Inquiry Report  
No. 50-220/72-03

- cc: L. Rogers, RS (3)
- R. S. Boyd, L (2)
- R. C. DeYoung, L (2)
- D. J. Skevhelt, L (3)
- H. R. Denton, L (2)
- P. A. Morris, RO
- H. D. Thornburg, RO
- J. B. Henderson, RO
- J. P. O'Reilly, RO:I
- J. G. Davis, RO:II
- B. H. Grier, RO:III

bcc: F. J. Nolan

*50-220  
Inquiry*

OFFICE ▶	J. W. Flora, RO:IV R. W. Smith, RO:V DR Central Files	7 RO FJNolan JGKeppler 5/19/72		
SURNAME ▶				
DATE ▶				

MAY 19 1972

D. L. Ziemann, Chief, Operating Reactors Branch 2, L

NIAGARA MOHAWK POWER CORPORATION (NINE MILE POINT)-VIBRATION  
INDUCED PARTIAL DISASSEMBLY OF AN AUTOMATIC PRESSURE RELIEF  
VALVE

Enclosed for your information is a copy of an Inquiry Report from  
our Region I (Newark) Office concerning a vibration induced failure  
of one of the automatic pressure relief valves at the Nine Mile  
Point facility.

Based on our review of this problem, we question whether the valve  
could have operated, if called upon, in its degraded condition.  
We believe, however, that the action taken by the licensee to  
correct the problem was appropriate. Recognizing that this potential  
safety related problem could be generic, we plan to alert other operat-  
ing BWR facilities of details of this problem. We will keep you  
informed of significant findings.

Original signed by  
J. G. Keppler

J. G. Keppler, Chief,  
Reactor Testing and Operations  
Branch  
Directorate of Regulatory Operations

8303020168 720526  
PDR ADOCK 05000220  
Q PDR

Enclosure:  
RO Inquiry Report  
No. 50-220/72-03

- cc: L. Rogers, AS (3)
- R. S. Boyd, L (2)
- R. C. DeYoung, L (2)
- D. J. Skovholt, L (3)
- H. R. Denton, L (2)
- P. A. Morris, RO
- H. D. Thornburg, RO
- J. F. Henderson, RO
- J. P. O'Reilly, RO:I
- J. G. Davis, RO:II
- B. H. Grier, RO:III

bcc: F. J. Nolan

*50-220  
inquiry*

OFFICE ▶	J. W. Flora, RO:IV	7 RO		
SURNAME ▶	R. W. Smith, RO:V	FJNolan		
DATE ▶	DR Central Files	JGKeppler		
		5/19/72		