

**ILLINOIS
POWER**

March 4, 1992

Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61827
Tel 217 935-8881

U-601941
142-92(03-04)LP
4F.190

Docket No. 50-461

Mr. A. B. Davis
Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Revised Repair Schedule for Shutdown Service Water System
Temperature Regulating Valves (Reference Illinois Power Letter
U-601615, "Response to the Operational Safety Team Inspection
Report" dated February 28, 1990)

Dear Mr. Davis:


The Illinois Power Company (IP) response to the report of the Operational Safety Team Inspection at the Clinton Power Station (CPS) (Inspection Report 50-461/89030) identified that two shutdown service water system temperature regulating valves required repair. The response further stated that these valves were scheduled for repair during the plant's second refueling outage (RF-2) which was scheduled to begin in September 1990.

The two valves, 1SX019A and 1SX019B (Control Room Cooling Coil Flow Control Valves), were not repaired during RF-2 because parts could not be obtained to support repair during the outage. However, repairs were made to isolation valves so the flow control valves could be replaced during a non-plant outage period.

Because the valve manufacturer has been unable to supply the needed parts in a timely manner, the existing valves will be replaced rather than repaired. The replacement valves were received recently; however, to avoid increasing the scope of the current third refueling outage (RF-3), replacement of the valves has been scheduled for the first Control Room Ventilation system outage following RF-3. The replacement valves are currently scheduled for installation in late June 1992.

The rescheduling of this work has been discussed between P. G. Brochman of your staff and R. F. Phares of my staff.

Sincerely yours,



F. A. Spangenberg, III
Manager, Licensing and Safety

RSF/alh

cc: NRC Clinton Licensing Project Manager
NRC Resident Office
Illinois Department of Nuclear Safety

7203090345 720304
PDR ADDCK 05000461
PDR
G

030053

JE01 1/0